



**Regional Office, Yamuna Nagar Region  
Haryana State Pollution Control Board**

S.C.O. No- 131, Sector -17, HUDA, Jagadhri, Yamuna Nagar

Website - [www.hspcb.gov.in](http://www.hspcb.gov.in) E-Mail - [hspcbroyr@gmail.com](mailto:hspcbroyr@gmail.com) -Contact No. 01732-268137,237840

No. HSPCB / YR / 2019 / 12456  
To

Dated: 01 / 07 / 2019

The Registrar General,  
National Green Tribunal,  
New Delhi. (Email Id - [rg.ngt@nic.in](mailto:rg.ngt@nic.in) & [ngtpb.pg@gmail.com](mailto:ngtpb.pg@gmail.com))

**Sub: - Submission of Action Taken Report - Order dated 03.05.2019 O.A. No. 298 titled as Ramji Dass Vs. State of Haryana and Ors.**

Respected Sir,

In this regard, the action taken report is as under:-

That the field officer inspected the said area on dated 05.05.2019 and found that following plants exists in the nearby village Churni as under:-

1. Milkhi Ram Jindal Brick Kiln, Village Ramba, Churni Road, Karnal, which is having valid consent from Board upto 31.03.2020 and installed zig - zag technology. The said brick kiln is **approx. 1.5 KM** from village Churni. The Brick Kiln was inspected on dated 05.05.2019 and found not using waste tyre as a fuel. **(Copy of Spot inspection report is attached).**

2. Shree Balaji Bhatta Co, Vill. Samora, Churni Road Indri, Karnal, which is having valid consent from Board upto 31.03.2022 and installed zig - zag technology. The said brick kiln is **approx. 1.5 KM** from village Churni. The Brick Kiln was inspected on dated 05.05.2019 and found not using waste tyre as a fuel. **(Copy of Spot inspection report is attached).**

3. M/s Satbir Singh Contractor (HMP), VPO Ramba, Churni Road, Karnal. The said Hot Mix Plant is having CTE/CTO from Board. It is **approx. 1.5 KM** from village Churni. The Hot Mix Plant was inspected on dated 05.05.2019 and no waste tyre burning as a fuel was found. **(Copy of Spot inspection report is attached).**

4. There is a old abandoned Hot Mix Plant, which is not in working position as turned almost in to scrap, it is **approx. 1.7 KM** from village Churni. **(Copy of Spot inspection report is attached).**

5. M/s Acer Builders and Contractors Pvt Ltd., Village Kheri Mann Singh, Near Indri, Karnal is engaged in recovery of pyrolysis oil from waste tyres, which is having valid consent from Board upto 31.03.2028, it is **approx. 4.5 KM** from village Churni & established in **Village Kheri Mann Singh**, Near Indri. The wood and gas is being used as a fuel and analysis reports also shows the parameters within limits. The villagers of village Kheri Mann Singh, Village Amargarh and Village Gorgarh also submitted regarding no complaint from said plant **(Copy attached).**

It is requested that the report be placed on record.

DA: As Above.

Regional Officer  
Yamuna Nagar



①  
1.5 KM - 2 KM from Churni

Regional Office :  
हरियाणा राज्य प्रदूषण नियंत्रण बोर्ड  
Haryana State Pollution Control Board  
SCO No. 131, Sec-17, Jagadhri (Yamuna Nagar)  
E-mail : hspcbroyr@gmail.com

**SPOT INSPECTION REPORT**

- 1. Name & Address of Unit : Milkhi Ram Jindal BKO, Churni Road
- 2. Location : Vill Ramba, Indri, Kaul
- 3. Name of Owner/MD/Partner/Director : Daulhan Khay Mobile No. 9355545102
- 4. Date of Inspection - 5/5/19 : Sanjeev Jindal
- 5. Date of Commissioning of the Unit : old unit
- 6. Product : - Bricks
- 7. Raw Material used : - Mud
- 8. Manufacturing Process in brief : Mixing, kneading, baking
- 9. Source of Water Pollution : Domestic effluent
- 10. Status of ETP/STP with details, if any : Septic tank installed
- (I) Components of ETP/STP :
- 11. Source of Air Pollution : - Brick Kiln
- 12. Status of APCM with detail : lat - 29.80212
- 13. (i) Status of DG Set : long - 77.01366
- (ii) Acoustic Chamber provided or Not :
- 14. Whether Complying HWM Rules or not : -> Zig Zag Provided.
- Whether Board displayed or not :
- (ii) Storage pit provided or not :
- 15. Pollution/Non-Pollution : /
- 16. Sample Collected or not :
- 17. Cess : - CTO upto 31/3/2020
- a) Total No. Tube well :
- b) Discharge of each T/Well :
- c) Running hours of each of Tube well :
- d) Date of Commissioning of Tube well : - No waste type found burning as a fuel
- e) No. of Workers :
- 18. Remarks : Unit has installed Zig-Zag technology at site.

Sign. of Representative of Unit Present at the time of Inspection of Unit

Name Pardeep  
Mobile No. \_\_\_\_\_

Sign. of the Inspection Officers of the Board

Name \_\_\_\_\_  
Designation \_\_\_\_\_



(2)  
1.5 KM from  
Chunni

Regional Office :  
हरियाणा राज्य प्रदूषण नियंत्रण बोर्ड  
Haryana State Pollution Control Board  
SCO No. 131, Sec-17, Jagadhri (Yamuna Nagar)  
E-mail : hspcbroyr@gmail.com

**SPOT INSPECTION REPORT**

1. Name & Address of Unit : Shri Ballyji Bhatta Co Samara, Karnal.

2. Location : 1) Left \_\_\_\_\_  
2) Right \_\_\_\_\_  
3) Opposite \_\_\_\_\_

3. Name of Owner/MD/Partner/Director : Mai Chand Kaurlik Mobile No. (Vikas Gupta)

4. Date of Inspection : 05/5/19

5. Date of Commissioning of the Unit : old unit

6. Product : Brick

7. Raw Material used : Mud.

8. Manufacturing Process in brief : Mixing, Kneady, Baking

9. Source of Water Pollution : Domestic

10. Status of ETP/STP with details, if any : Septic tank

(I) Components of ETP/STP : \_\_\_\_\_

11. Source of Air Pollution : Brick Kiln

12. Status of APCM with detail : Zig Zag provided

13. (i) Status of DG Set : \_\_\_\_\_  
(ii) Acoustic Chamber provided or Not : \_\_\_\_\_

14. Whether Complying HWM Rules or not : \_\_\_\_\_  
(i) Whether Board displayed or not : \_\_\_\_\_  
(ii) Storage pit provided or not : \_\_\_\_\_

15. Pollution/Non-Pollution : BKO converted to Zig Zag technology

16. Sample Collected or not : \_\_\_\_\_

17. Cess : \_\_\_\_\_  
a) Total No. Tube well : \_\_\_\_\_  
b) Discharge of each T/Well : CTO upto 31/3/2022  
c) Running hours of each of Tube well : \_\_\_\_\_  
d) Date of Commissioning of Tube well : \_\_\_\_\_  
e) No. of Workers : No waste tyre found lying at site.

18. Remarks : \_\_\_\_\_

Sign. of Representative of Unit AM  
Present at the time of Inspection of Unit  
Name Amritlal Munch.  
Mobile No. \_\_\_\_\_

[Signature]  
Sign. of the Inspection  
Officers of the Board  
Name \_\_\_\_\_



1.5 = 2 KM from will Churni

3

Regional Office :  
हरियाणा राज्य प्रदूषण नियंत्रण बोर्ड  
Haryana State Pollution Control Board  
SCO No. 131, Sec-17, Jagadhri (Yamuna Nagar)  
E-mail : hspcbroyr@gmail.com

**SPOT INSPECTION REPORT**

- 1. Name & Address of Unit : M/s Sabin Contractor, HMP
- 2. Location : will Ramba, Churni Road, Indri  
1) Left Kand  
2) Right \_\_\_\_\_  
3) Opposite \_\_\_\_\_
- 3. Name of Owner/MD/Partner/Director : Rahul Kna Manager Mobile No. 8059830477
- 4. Date of Inspection : 05/5/19
- 5. Date of Commissioning of the Unit : Installed
- 6. Product : Bitumenous Mix
- 7. Raw Material used : Bitumen, Bagri,
- 8. Manufacturing Process in brief : Heating / Mixing
- 9. Source of Water Pollution : NA
- 10. Status of ETP/STP with details, if any : NA  
(I) Components of ETP/STP : \_\_\_\_\_
- 11. Source of Air Pollution : - Process
- 12. Status of APCM with detail : - M.cyclone with Bag filter installed
- 13. (i) Status of DG Set : DG Set - 125 KVA  
(ii) Acoustic Chamber provided or Not : 320 KVA
- 14. Whether Complying HWM Rules or not : \_\_\_\_\_  
(i) Whether Board displayed or not : \_\_\_\_\_  
(ii) Storage pit provided or not : \_\_\_\_\_
- 15. Pollution/Non-Pollution : The said HMP obtained Noc  
from board & established  
at site. CTO applied
- 16. Sample Collected or not : \_\_\_\_\_
- 17. Cess : \_\_\_\_\_  
a) Total No. Tube well : \_\_\_\_\_  
b) Discharge of each TWell : \_\_\_\_\_  
c) Running hours of each of Tube well : \_\_\_\_\_  
d) Date of Commissioning of Tube well : \_\_\_\_\_  
e) No. of Workers : \_\_\_\_\_
- 18. Remarks : No waste tyre bung found  
at site.

*No one available at site lying closed*

Sign. of Representative of Unit Present at the time of Inspection of Unit

Name \_\_\_\_\_

Mobile No. \_\_\_\_\_

Sign. of the Inspection Officers of the Board

Name \_\_\_\_\_

Designation \_\_\_\_\_



1.7 KM

**SPOT INSPECTION REPORT**

1. Name & Address of Unit : Unnamed HMP - Singla H&M  
 2. Location : near Street Balaji HMP  
 1) Left vill Samong  
 2) Right \_\_\_\_\_  
 3) Opposite \_\_\_\_\_  
 3. Name of Owner/MD/Partner/Director : Not available at site Mobile No. \_\_\_\_\_  
 4. Date of Inspection : 05/5/19 (Single)  
 5. Date of Commissioning of the Unit : \_\_\_\_\_  
 6. Product : \_\_\_\_\_  
 7. Raw Material used : \_\_\_\_\_  
 8. Manufacturing Process in brief : \_\_\_\_\_  
 9. Source of Water Pollution : \_\_\_\_\_  
 10. Status of ETP/STP with details, if any : \_\_\_\_\_  
 (I) Components of ETP/STP : \_\_\_\_\_  
 11. Source of Air Pollution : \_\_\_\_\_  
 12. Status of APCM with detail : Lat - 29.81408  
Long - 77.01224  
 13. (i) Status of DG Set : \_\_\_\_\_  
 (ii) Acoustic Chamber provided or Not : \_\_\_\_\_  
 14. Whether Complying HWM Rules or not : \_\_\_\_\_  
 (i) Whether Board displayed or not : lying almost  
abandoned  
 (ii) Storage pit provided or not : \_\_\_\_\_  
 15. Pollution/Non-Pollution : \_\_\_\_\_  
 16. Sample Collected or not : \_\_\_\_\_  
 17. Cess : \_\_\_\_\_  
 a) Total No. Tube well : \_\_\_\_\_  
 b) Discharge of each T/Well : \_\_\_\_\_  
 c) Running hours of each of Tube well : \_\_\_\_\_  
 d) Date of Commissioning of Tube well : \_\_\_\_\_  
 e) No. of Workers : \_\_\_\_\_  
 18. Remarks : → lying Abandoned since 8 years and  
→ old sealed impression at the machines  
of HMP.

Sign. of Representative of Unit  
 Present at the time of Inspection of Unit  
 Name Sri Chand Chauhan  
 Mobile No. \_\_\_\_\_

Sign. of the Inspection  
 Officers of the Board  
 Name \_\_\_\_\_  
 Designation \_\_\_\_\_



**SPOT INSPECTION REPORT**

1. Name & Address of Unit : Inspection of unit M/s Acer builders, Vill Kheri Mann Singh, Gndhi, Hnd
2. Location : 1) Left \_\_\_\_\_  
2) Right \_\_\_\_\_  
3) Opposite \_\_\_\_\_
3. Name of Owner/MD/Partner/Director : Sh. Neeraj Gupta Mobile No. \_\_\_\_\_
4. Date of Inspection : 14/5/19.
5. Date of Commissioning of the Unit : old unit
6. Product : Carbon, Plyso oil
7. Raw Material used : Waste tyres
8. Manufacturing Process in brief : Heating / Reaction
9. Source of Water Pollution : Wet scrubber effluent
10. Status of ETP/STP with details, if any : ETP → Wet scrubber effluent (2 tanks) → Holding tank  
(i) Components of ETP/STP : Reaction + Settle tank → Treated water tank + Filter  
+ Wet scrubber + SDB - 2 MO
11. Source of Air Pollution : \_\_\_\_\_
12. Status of APCM with detail : \_\_\_\_\_
13. (i) Status of DG Set : ⇒ 60 KVA + 40 KVA -  
(ii) Acoustic Chamber provided or Not : \_\_\_\_\_
14. Whether Complying HWM Rules or not : → Reactor - 2 MO (Ant → Condenser - 5  
(i) Whether Board displayed or not : + wet scrubber } steel  
(ii) Storage pit provided or not : 1. 2nd - Colby coil + wet scrubber }
15. Pollution/Non-Pollution : → Colby system + recirculation system
16. Sample Collected or not : → Carbon collection by screw conveyor  
+ feeder in bag directly
17. Cess : → Separate 50x150" size for storage of tyres  
like storage on pucca platform  
a) Total No. Tube well : → Inside path pucca  
b) Discharge of each T/Well : → Carbon storage shed.  
c) Running hours of each of Tube well : → Oil storage tank - 3 MO / 15000 liter + 18000 x 2 MO  
d) Date of Commissioning of Tube well : \_\_\_\_\_  
e) No. of Workers : \_\_\_\_\_
18. Remarks : → Unit found not running during inspection  
The unit has made adequate arrangements at site

Sign. of Representative of Unit  
Present at the time of Inspection of Unit  
Name owner  
Mobile No. \_\_\_\_\_

Sign. of the Inspection Officers of the Board  
Name Ravish Singh  
Designation \_\_\_\_\_

सेवा में,

क्षेत्रीय अधिकारी  
हरियाणा राज्य प्रदूषण नियंत्रण बोर्ड,  
जगाधरी।

विषय :- Acer Buildings and Constructions Pvt. Ltd. Village  
Kheri Maan Singh, Distt. Karnal के खिलाफ झूठी  
दरखास्त देने बारे।

श्रीमान जी,

निवेदन है कि हम सभी गांव खेड़ी मान सिंह के निवासी हैं।  
उपरोक्त फर्म द्वारा हमारे गांव के काफी बेरोजगार व्यक्तियों को रोजगार दिया  
गया है। इस फर्म द्वारा कोई टायर नहीं जलाए जाते और ना ही इस फर्म द्वारा  
कोई प्रदूषण फैलाया जा रहा है। इस फर्म के किसी भी कार्य से हमारे गांव के  
किसी व्यक्ति, पशु, फसल आदि को किसी प्रकार का कोई नुकसान ना है।  
उक्त फर्म के खिलाफ जो दरखास्त दी गई है वह फर्म के मालिकों को  
नाजायज रूप से तंग करने के लिए दी गई है।

अतः आपसे निवेदन है कि फर्म को दिया गया नोटिस दफतर  
दाखिल किया जाए।

प्राथी समस्त ग्रामवासी

स्थान : करनाल

दिनांक :

गांव खेड़ीमान सिंह तहसील इन्द्री,  
जिला करनाल

जैश राजी पूर्व अध्यक्ष

रोहित शर्मा

राजेश्वर शर्मा

जमील

राजेश

मोहन शर्मा

निखिल

पारस

Shiv Kumar

शैल

शिवान

रामदीव

राजेश

श्री राजा २

पूज्य  
मामी

मीना

शिवसिंह

जयवती  
पुनम

शलीम  
इराना

नरेश सिंह  
श्याम

श्रीश अमर

Salinder Singh

Lahri Singh

Azad Singh.

Rehman Khan

Ramesh Kumar

गुल  
तोता

Janeer

गुला सिंह

Rajiv Kumar

श्री 212

श्री 212

Jai Singh

Balender Singh

Rupam



# ग्राम पंचायत अमरगढ़

(काला माजरा) खण्ड नीलोखेड़ी (करनाल)

80532-64000  
94661-31000



प्रस्ताव नं. \_\_\_\_\_

दिनांक 29-4-19.

लक्ष्मीक विद्या जाता है कि मैं गाँव अमरगढ़ की मौजूदा सरपंच हूँ। यह है कि गाँव खेड़ीमानसिंह में ACEX Builders की फैक्टरी है। जो गाँव खेड़ीमानसिंह से लगभग 1.5 किलोमीटर की दूरी पर है और हमारे गाँव अमरगढ़ से लगभग 1.5 किलोमीटर है। इस फैक्टरी में गाँव के बाकी व्यक्तियों को रोज-गार मिला हुआ है। इस फैक्टरी की वजह से हमारे गाँव या आसपास के किसी भी गाँव में किसी तरह का प्रदूषण / Pollution नहीं है। ना ही किसी कसल पर या व्यक्तियों को कोई प्रदूषण है। ना ही इस फैक्टरी में लम्बर जलाये जाते हैं। और ना ही इस फैक्टरी की वजह से किसी तरह का कोई Pollution है।

रेखा देवी  
Sarpanch  
Gram Panchayat Amargadh  
Block Nilokheri (Karnal)

# पास करदा ग्राम पंचायत गोरगड खण्ड इन्दी, जिला करनाल

विषय:-

राजकीय काम जाला हे फि से गाँव गोखादे से भी भोखा  
 राज्य हे पदे हे फि गाँव खेरी नाम सिद्ध से Ameer Buidas  
 से भी भोखा हे जो फि गाँव खेरी नाम सिद्ध से लोका से  
 फि भोखा से भी पूरी पदे हे और धारे मर्ये गोखादे से भी लोका  
 फि भोखा से भी पूरी पदे हे इस भोखा से गाँव से मर्ये  
 लोका से खेरी नाम सिद्ध हे इस भोखा से लोका से  
 धारे मर्ये गोखादे से फि लोका से भी पदे पदे गरी  
 हे और गरी फि भोखा से फि लोका से भी पदे पदे गरी  
 पदे पदे गरी हे

*N. J. ...*  
 सरपंच  
 ग्राम पंचायत गोरगड  
 खण्ड इन्दी (करनाल)



# HARYANA TEST HOUSE

## & Consultancy Services

### NABL ACCREDITED LABORATORY

50-C, Sector-25 Part-II, HUDA, PANIPAT-132 104 (HR.)

Contact : (M) 86077-70160, (O) 0180-2671112

Web Site : www.haryanatesthouse.net, e-mail : info@haryanatesthouse.net, haryanatesthousecv@gmail.com

Recognition / Accreditation : NABL / MoEF / FSSAI / BIS / PPCB / HSPCB / ISO 9001, 14001, 18001 Certified Lab.

Report No: 190408033

## TEST CERTIFICATE

Date: 13.04.2019

Issued to:

M/S ACER BUILDERS & CONTRACTORS PVT. LTD.,  
Vill- Kheri Maan Singh,  
Near Indri, Karnal (HR)

Party's Ref. No: Nil

Job Order No: HTH/M/190408033, DL: 08.04.2019

### Sample Description: Stack Emission – Process

Type of unit	: Pyrolysis Industry
Name of Plant/ Section	: Process Section
Date of sampling	: 08.04.2019
Source of Emission	: Stack Attached to Reactor (Reactor Section)
Instrument used	: Stack Sampler APM 160 (Sr. No. 88-DTL – 2016)
Instrument Calibration Status	: Calibrated (upto 30-12-2019)
Type of Chimney	: Metal
Stack height (from the ground level)	: 30 meter
Stack diameter (at the sampling point)	: 18 inch
Purpose of sampling	: Monitoring
Location of sampling point	: As per standard norms
Sample collected by	: By our Lab. Representative
Type of APCM installed	: Condenser + Wet Scrubber
Period of testing	: 08.04.2019 to 13.04.2019

### A. Observations:

S. No.	Particulars	Data Observed
1	Stack gas temperature, °C	: 65.0
2	Metering point temperature, °C	: 32.0
3	Avg. stack gas velocity, m/sec	: 7.77
4	Sampling flow rate, Lt./min.	: 30.0
5	Period of sampling, Minutes	: 30.0
6	Volumetric flow rate, Nm <sup>3</sup> / Hr	: 3890.54

### B. Results:

S.No.	Parameters	Results	Standard Limits (CPCB)	Protocol Used
1	Particulate Matter (PM), mg/Nm <sup>3</sup>	83.93	150 max	IS 31256 (P-11) HRB
2	Sulphur Dioxide (SO <sub>2</sub> ), mg/Nm <sup>3</sup>	< 2.62		SOP No. HTH/DEVT/ACC/06/15/2018
3	Oxides of Nitrogen (NO <sub>x</sub> ), mg/Nm <sup>3</sup>	< 1.88		SOP No. HTH/DEVT/ACC/06/15/2018

Mgr (Lab.) / Sr. Chemist



# HARYANA TEST HOUSE

& Consultancy Services

NABL ACCREDITED LABORATORY

50-C, Sector-25 Part-II, HUDA, PANIPAT-132 104 (HR.)  
 Contact : (M) 86077-70160, (C) 0180-2671112  
 Web Site : www.haryanatesthouse.net, e-mail : info@haryanatesthouse.net, haryanatesthousecs@gmail.com

Recognition / Accreditation : NABL / MoEF / FSSAI / BIS / PPCB / HSPCB / ISO 9001, 14001, 18001 Certified Lab.

## TEST CERTIFICATE

Report No: 190408031

Date: 13.04.2019

Issued to:  
**M/S ACER BUILDERS & CONTRACTORS PVT. LTD.,**  
 VIII- Kheri Maan Singh,  
 Near Indri, Karnal (HR)

Party's Ref No: Nil  
 Job Order No: HTH/M/190408031- 032, Dt.: 08.04.2019

Sample Description: Effluent Water Sample (ETP- Inlet & Outlet)

Type of industry : Pyrolysis Industry  
 Sample type : Effluent Water  
 Date of sampling : 08.04.2019  
 Date of receipt of sample : 08.04.2019  
 Sample location : ETP - Inlet & Outlet  
 Sample quantity : 2 litre each  
 Purpose of analysis : Monitoring  
 Sample collected/ supplied by : By our lab. Representative  
 Period of testing : 08.04.2019 to 13.04.2019

### Test Results

Sr. No.	Parameters	ETP - Inlet	ETP - Outlet	Specification Environment Protection Act 1986 (Inland Surface Water)	Protocol Used
1	Appearance	Grey	Colourless	-	Visual
2	Odour	Mild	Odourless	-	Qualitative
3	pH	7.49	7.63	5.5 to 9.0	IS 3025 (P-21) : 1981
4	COD, mg/l	276.0	104.0	250 max.	IS 3025 (P-58) : 2009
5	BOD at 27°C for 3 days, mg/l	121.0	23.0	30 max.	IS 3025 (P-44) : 1993
6	Total Suspended Solids, mg/l	116.0	42.0	100 max.	IS 3025 (P-17) : 1993
7	Oil & Grease, mg/l	24.8	7.6	50 max.	IS 3025 (P-39) : 1996

*Toto*  
 Mgr. (Lab.)/ Sr. Chemist

Authorised Signatory