

**BEFORE THE HON'BLE NATIONAL GREEN TRIBUNAL
SOUTHERN ZONE, CHENNAI
Original Application No.107 of 2023 (SZ)**

Suo Motu based on the news item published in The New Indian Express, dt. 09.08.2023, under the caption "Huge pollution risk in 8 Km around NLC" and in The Times of India, Chennai Edition dt. 09.08.2023 under the caption "Water near NLC full of Mercury".

Vs.

The Managing Director,
NLC India Limited,
Chennai and Ors.

...Respondents

INDEX

S.No	Description	Page No.
1.	REPORT OF THE TAMIL NADU POLLUTION CONTROL BOARD (5TH RESPONDENT) AS PER THE ORDERS OF THE HON'BLE NGT(SZ) DATED 10.08.2023.	1 – 20
2.	ANNEXURE – 1 TO 30	21 – 88



**Filed by
Thiru. S. Sai Sathya Jith,
Advocate, Chennai.**

Report of the TNPCB Committee as per orders of the Hon'ble National Green Tribunal (Southern Zone) in O.A.No. 107 of 2023 (SZ) - Suo Motu based on news item published in The New Indian Express, dt 09.08.2023, under the caption "Huge pollution risk in 8 Km around NLC" and in The Times of India, Chennai Edition dt. 09.08.2023 under the caption "Water near NLC full of Mercury".



TAMIL NADU POLLUTION CONTROL BOARD

AUGUST 2023

INDEX

S.NO	CONTENT	PAGE NO.
1.0	INTRODUCTION	1
1.1	NEWS REPORT	2
2.0	M/S. NLC INDIA LIMITED	2
2.1	M/s. NLC INDIA LIMITED MINE I	2
2.2	M/s. NLC INDIA LIMITED MINE IA	4
2.3	M/s. NLC INDIA LIMITED MINE II	6
2.4	M/s. NEYVELI THERMAL POWER STATION I	8
2.5	M/s. NEYVELI THERMAL POWER STATION II	8
2.6	M/s. NEYVELI THERMAL POWER STATION II EXPANSION	10
2.7	M/s. NLC TPS I EXPANSION	12
2.8	M/s. NEYVELI NEW THERMAL POWER STATION	14
2.9	OVER ALL FLY ASH DISPOSAL BY ALL TPSS IN NLCIL	16
2.10	CONTINUOUS AMBIENT AIR QUALITY MONITORING STATIONS IN NLCIL CAMPUS	16
2.11	TOWNSHIP SEWAGE TREATMENT PLANT	17
3.0	M/S. IL& FS TAMIL NADU POWER COMPANY LIMITED	17

4.0	SAMPLE COLLECTION	20
	ANNEXURES	21 - 77
	PHOTOGRAPHS PLATES	78 - 88

Report of the TNPCB Committee as per orders of the Hon'ble National Green Tribunal (Southern Zone) in O.A.No. 107 of 2023 (SZ) - Suo Motu based on news item published in The New Indian Express, dt 09.08.2023, under the caption "Huge pollution risk in 8 Km around NLC" and in The Times of India, Chennai Edition dt. 09.08.2023 under the caption "Water near NLC full of Mercury".

1.0 INTRODUCTION

The Hon'ble National Green Tribunal (Southern Zone) took a Suo Mote Case O.A.No. 107 of 2023 based on newspaper Article '***Huge Pollution Risk in 8KM around NLC***' referring the study titles '***POWERing Pollution: The Environmental and Pollution Impacts of Thermal Power Stations and mining Operation in Neyveli & Parangipettai – August 2023***'. The Hon'ble NGT in its order dated 10.08.2023 have directed the Tamil Nadu Pollution Control Board (TNPCB) to inspect the area, study the water quality of the water bodies near NLC and also to ascertain whether the news is correct or not.

Based on the directions, the TNPCB has formed an internal committee comprising of the following officers to inspect the area and collect water and soil samples in the areas referred in the study report and submit a detailed report on or before 23.08.2023 so as to file a report the Hon'ble NGT (SZ) on or before 28.08.2023.

- 1 Dr R.Rajamanickam, Additional Chief Environmental Engineer, TNPCB
- 2 Thiru. S.Sankarasubramanian, Assistant Director, Advanced Environmental Laboratory, Chennai
- 3 Dr A.Samuel Rajkumar, Joint Chief Environmental Engineer (Monitoring), Cuddalore
- 4 Dr R.Umayakunjaram, District Environmental Engineer, Cuddalore
- 5 Thiru T.Chitrarasu, Assistant Director, Advanced Environmental Laboratory, Cuddalore

The Committee has inspected the NLC and the surrounding areas on 11.08.2023, 16.08.2023 and 17.08.2023. The committee report is submitted as follows:

1.1 News Report

Poovulagin Nanbargal and Manthan Adhyayan Kendra have published a report in August 2023 titled '*POWERing Pollution: The Environmental and Pollution Impacts of Thermal Power Stations and mining Operation in Neyveli & Parangipettai*'. In the report, it is mentioned that a comprehensive assessment in both Neyveli and Parangipettai regions have been carried out with the involvement of local communities and bring out new issues that may have not been previously highlighted, identify source of pollution and suggest ways in which the issues could be addressed. It is also mentioned that they carried out water and soil sampling, and also questionnaire-based surveys of the local communities in the surrounding of NLC in Neyveli and ITPCL in Parangipettai. In the report, it is mentioned that several surface as well as ground water sources were found to be high levels of turbidity, hardness, total dissolved solids (TDS), total suspended solids (TSS), Oil and Grease, high chemical oxygen demand (COD) and presence of elements like aluminium, boron, fluoride, iron, manganese, magnesium, mercury and selenium in high concentration. The TNPCB committee has gone through the above report and made a detailed study. It is submitted as follows:

2.0 M/S. NLC INDIA LIMITED

M/s. NLC India Limited (NLCIL) is a Government of India Enterprise functioning under the control of Ministry of Coal was incepted in the year 1956, following the finding of lignite deposits in Neyveli, Tamil Nadu. Its core business is lignite mining and thermal power generation. NLCIL currently operates three open cast lignite mines of total capacity of 32.5 Million Tonnes per Annum (MTPA) and four thermal power stations with a total installed capacity of 3390 MW in Neyveli. The total extent of the NLCIL area is 200.sq.km. The details of each unit is given as follows:

2.1 M/s. NLC India Limited Mine I

The unit of M/s. NLC India Limited Mine-I was started on 20.05.1957. The unit got first consent of TNPCB on 07.06.1984 for mining of 6.5 Million Tons per Annum (MTPA). Later in 1989, the Ministry of Environment and Forest (MoEF), Government of India issued Environmental appraisal for Mine - I (Expansion) vide proceeding No. J-11015/11/88-IA, dt on 06.03.1989. In 2015, the unit obtained

environmental clearance for expansion from the MoEF vide proceeding No. J-11015/01/2012-IA-II (M) dated 02.09.2015 for the capacity of 10.5 MTPA with a mine lease area from 3178.4 Ha to 3635.4 Ha. The unit has obtained consent to operate from TNPCB vide proceeding dated 06.12.2021 for mining of lignite 10.5 MTPA. The unit was permitted to discharge 186 kilo litres per day (KLD) of sewage on industries own land for green belt development. The unit was permitted to discharge trade effluent quantity of 65480 KLD (mine seepage water) for irrigation. The unit has provided water sprinklers to control the fugitive emissions from lignite storage yards, transfer points and roads. The unit has obtained CTO renewal vide proceeding dated 14.11.2022 with validity upto 31.03.2027. During Inspection of the committee, the unit is in operation.

Water Management

The unit is drawing 65665.0 KLD of water from the sources such as aquifer, mine seepage and rain water. The unit is consuming 185 KLD of aquifer water for domestic purposes. 25 KLD of Mine seepage and rain water is utilized in mini auto service. The remaining water from aquifer, mine seepage and Rain water is partially sent outside the campus for irrigation and partially to artificially created lake to supply water to M/s TPS-I Expansion, and M/s New Neyveli Thermal Power Plant.

Waste water Management

Sewage: The unit has provided Sewage Treatment Plants to treat the canteen waste water/ toilet waste water and treated effluent is utilized for Green belt development. The ROA of the treated sewage samples collected for the year 2018-2023 (5 years) from the outlet of the STP reveals that the parameters were within the standards prescribed by the Board. (Consolidated ROA - Annexure-1)

Trade Effluent: The trade effluent generated from the following sources: (a) Trade effluent - I (aquifer, seepage and rain water), (b) Trade effluent - II (mini auto service). The ROA of the treated effluent samples collected for the year 2018-2023 (5 years) from the outlet of the ETP reveals that the parameters were within the standards prescribed by the board except the exceedance of pH (8/45). The ROA of the seepage water samples collected for the year 2018-2023 (5 years) from the outlet of the seepage reveals that the parameters were within the standards prescribed by the Board except the exceedance of pH (1/45). (Consolidated ROA- Annexure-2)

Air Pollution Management

The unit has provided water sprinkler systems to control the fugitive emission generated from lignite storage yard, lignite transfer points & lorry movement on road. Consolidated ROA of the Ambient Air Quality Monitoring survey in the year 2018 - 2023 all the parameters all the parameters are within the standards prescribed by the Board except PM₁₀ in the range of 579 µg/m³ (1/10) which is slightly higher than 500 µg/m³. (Consolidated ROA - Annexure-3).

Solid waste Management**Mines Overburden soil**

It is reported that the existing external overburden dump yard area is 478.4 Hectares and about 239.1 MM³ is dumped until 2015 and afterwards there is no external OB dumping. It is also reported that, the overburden excavated during mining operation till inception upto 01.07.2023 is 2208.07 MM³ and the same quantity is back filled into the voids formed due to excavation of Lignite. The area reclaimed since inception 1240.65 Ha.

Hazardous waste

The unit has obtained authorization under Hazardous and Other Wastes (Management and Transboundary Movement) Rules, 2016 vide proceeding dated 12.01.2016 with validity upto 11.01.2021. The unit has submitted application for renewal of authorization and it is under process.

Green Belt Development

The development of Greenbelt carried out in Mine-I is given vide Plate No.-1

2.2 M/s. NLC India Limited Mine IA

The unit M/s. NLC India Limited Mine IA has obtained Consent to Operate for mining of 3MTPA of lignite vide proceeding dated 28.03.2003 and further renewal upto 31.03.2020. Later, the unit has obtained environmental clearance from the MoEF, GoI vide J-11015/02/2012-IA.II (M) dated 02.09.2015 for expansion from 3 MTPA to 7 MTPA in a total project area of 2005.8 hectares. The unit has obtained CTE for expansion vide proceeding dated 03.07.2019 with a validity upto

01.09.2022. Later the unit has obtained CTO expansion from 3 MTPA to 7 MTPA vide proceeding dated 19.02.2020. The unit is permitted to discharge 4 KLD of sewage and 1,05,777.3 KLD of trade effluent (mine seepage water and rain water) for irrigation, supply to Chennai Metro Water, mine spraying and their power plants. Consent is renewed upto 31.03.2026. During Inspection of the committee, the unit is in operation.

Water Management

Around 6.2 KLD is utilized for domestic purposes. The aquifer water of 59975.0 KLD is utilized in M/s TPS-I Expansion and M/s New Neyveli Thermal Power Plant. Further, 13090.0 KLD of mine seepage and rain water is supplied to Chennai Metro Water during summer. 25 KLD of mine seepage is utilized in Mini Auto service. The remaining 32551.6 KLD of water from mine seepage and rain water is sent to outside for irrigation,

Waste Water Management

Sewage: The unit has provided with septic tank and soaks pit arrangements to treat the sewage generated from its activity

Trade Effluent: The trade effluent generated from the following sources: (a) Trade effluent - I (aquifer, seepage and rain water), (b) Trade effluent - II (mini auto service). The ROA of the seepage water and outlet of ETP collected for the year 2018-2023 (5 years) from the ETP ad outlet of the seepage reveals that the parameters were within the standards prescribed by the Board. (Consolidated ROA- Annexure - 4)

Air Pollution Management

The unit has provided water sprinkler system to control the fugitive emission generated from lignite storage yard, lignite transfer points and lignite transport by trucks. Consolidated ROA of the AAQ survey in the year 2018-2023 (5 years) reveals that all the parameters are within the standards prescribed by the Board. (Consolidated ROA - Annexures - 5).

Solid waste Management

Mine Overburden Soil

It is reported that the overburden excavated during mining operation till inception upto 01.07.2023 is 557.12 MM³ and the same quantity is back filled into the

voids formed due to excavation of lignite. The area reclaimed since inception is 360.69 Ha.

Hazardous waste

The unit has obtained the authorization under Hazardous and Other Wastes (Management and Transboundary Movement) Rules, 2016 vide proceeding dated 12.01.2016 with validity up to 11.01.2021. The unit has applied for renewal of authorization. The application is under process.

Green Belt Development

The development of Greenbelt carried out in Mine-IA is given vide Plate No.-2

2.3 M/s. NLC India Limited Mine II

The unit M/s. Mine-II NLC India Limited has obtained Environmental Clearance from the Ministry of Environment and Forest vide No. J 11015/30/2001-IA.II (M) dated 24.02.2002 for setting up an Open cast lignite mining of 15.0 MTPA. Based on that, the unit has obtained CTO from TNPCB under Water and Air Acts for 15 MTPA vide Board Proc. dated 31.10.2022 with a validity upto 31.03.2027. The unit is permitted to discharge to discharge 100 KLD of sewage, trade effluent 78475 KLD of trade effluent (Seepage and rain water). During Inspection of the committee, the unit is in operation.

Water Management

Around 120 KLD of water is utilized for domestic purposes. 33.69 MCM per annum seepage/rain water collected is utilized in M/s TPS-II and M/s TPS-II Expansion. 25 KLD of mine seepage is utilized in Mini Auto service. The remaining 78475 KLD of water from mine seepage and rain water is sent to outside for irrigation,

Waste Water Management

Sewage: The unit has provided sewage treatment plant to treat the sewage from canteen and toilet. The ROA of the treated sewage samples collected for the year 2018-2023 from the outlet of the STP reveals that the parameters were generally within the standards prescribed by the Board except the exceedance of TSS (2/52), BOD (15/52), COD (10/52). (Consolidated ROA - Annexure-6)

Trade Effluent: The trade effluent generated from the following sources:
(a) Trade effluent - I (aquifer, seepage and rain water), (b) Trade effluent - II (mini

auto service). Treated trade effluent from mini auto service unit is discharged into eastern garland canal which is used for irrigation purposes. ROA of the treated trade effluent samples collected from the ETP outlet and seepage water reveals that, mostly the parameters were within the standards prescribed by the Board except the exceedance of pH (4/50). (Consolidated ROA - Annexure-7).

Air Pollution Management

The unit has provided water sprinklers at lignite storage yard, lignite transfer points, and haul roads. Consolidated ROA of the AAQ survey in the year 2020-2021, 2021-2022 and 2022-2023 reveals that all the parameters are within the standards prescribed by the Board.

Solid waste Management

Mine Overburden Soil

It is reported that the mine overburden soil excavated during mining operation till inception upto 01.07.2023 is 2206.62 MM³ and the same is back filled into the voids formed due to excavation of Lignite. The area reclaimed since inception is 1171.90 Hectares.

Hazardous waste

The unit has obtained authorization under Hazardous and Other Wastes (Management and Transboundary Movement) Rules, 2016 valid upto 23.05.2023. The unit has applied for renewal and it is under process.

Green Belt Development

The development of Greenbelt carried out in Mine-II is given vide Plate No.-3

2.4 M/s. Neyveli Thermal Power Station I

The unit of M/s. Neyveli Thermal Power Station I was commissioned in the year 1960. The unit has obtained CTO vide proceeding dated T1/TNPCB/3652/82-2 DATED 23.11.1984 and subsequently renewed upto 31.3.2020. The unit has operated 6 x 50 MW and 3 x 100 MW plants. After service of six decades and considering the conditions of plant and machineries, the unit has decommissioned the plant in the year 2020.

2.5 M/s. Neyveli Thermal Power Station II

The unit M/s. Neyveli Lignite Corporation Limited Thermal Power station II has obtained environment clearance from the MoEF vide letter No.14/13/82-Env.2 dated 05.01.1983 for the capacity 7 x 210 MW. The unit has obtained CTO under the Water and Air Acts vide dated 22.03.1991 with validity upto 31.03.1991 and subsequently renewed upto 31.03.2019. Further, the unit has obtained for CTO vide dated: 10.08.2021 with a validity upto 31.03.2022 and obtained renewal upto 31.03.2027 for the operation of 7 x 210 MW. The unit was consented to discharge 142 KLD of sewage for green belt development and 89040 KLD of trade effluent discharged outside the unit for irrigation after treatment. The unit is consented to discharge emissions from three boilers through stack of 170 metre each and four boilers with stack of 220 m each. During Inspection of the committee, the unit is in operation.

Water & Waste Water Management

The main water source of the plant is from Mine-II discharge water and it is collected in the artificial lake, situated within the NLC campus.

Sewage: The unit has provided sewage treatment plant and the treated sewage is utilized for green belt development within the industry's premises. ROA of the treated sewage reveals that, most of the parameters are within the standards prescribed by the Board except the exceedance of - TSS 1/27, BOD (4/27), COD (2/27) ammonical nitrogen (1/27). (Consolidated ROA - Annexure-8)

Trade effluent: The unit has provided Effluent Treatment Plant and the treated trade effluent is discharged into nearby channel for irrigation purposes. The unit has provided the Online Effluent Quality Monitoring system (online sensor) for pH, Temperature, TSS in the treated trade effluent disposal line and is connected with Water Quality Watch, TNPCB, Chennai. ROA of the treated trade effluent samples collected for the year 2018-2023 (5years) reveals that, most of the parameters are within the standards prescribed by the Board except the exceedance of TSS (2/53), TDS 3/53, BOD (2/53). (Consolidated ROA - Annexure-9)

Air Pollution Management

The unit has provided common stack along with electrostatic precipitator (ESP) for the boilers. The unit has provided 1 No of dust extraction system in the lignite conveying system and also the unit has provided automatic medium velocity water sprinklers in the lignite handling system in order to suppress the dust emanating during the operation. The unit has provided bag filter for the fly ash silo. Consolidated ROA of the Stack emission survey in the year 2018-2023 reveals that PM(4 /10) NO_x (4/10) and SO_x (10/10) (Consolidated ROA - Annexure-10)

The unit has provided continuous online stack monitoring system for parameters SPM, SO₂ and NO_x for each unit and connected the same to CAC, TNPCB, Chennai

Consolidated ROA of the AAQ survey in the year 2018-2023 reveals that all the parameters are within the standards prescribed by the Board except the exceedance of PM₁₀ (6/10) PM_{2.5} (5/10) Sox (4/10) and NO_x (4/10) (Consolidated ROA - Annexure-11)

Solid waste Management**Fly ash Management**

The unit is disposing the fly ash to cement industries and brick manufactures. The bottom ash is being sent to Mine-I of M/s NLC India Ltd for back filling in the mined area.

Hazardous Waste Management

The unit has obtained the authorization under Hazardous and Other Wastes (Management and Transboundary Movement) Rules, 2016 vide Bd's Proc. dated 09/02/2016 and valid upto 08.02.2021 for handling of used oil/spent oil, spent ion exchange resins. The unit has yet to apply for renewal of authorization.

Greenbelt Development

The development of Greenbelt carried out in TPS-II is given vide Plate No.-4

2.6 M/s. Neyveli Thermal Power Station II Expansion

The unit M/s. Neyveli Lignite Corporation Limited Thermal Power Station II has obtained Environment Clearance from the MoEF for vide letter No.J13011/8/2002-IA.11(T) dated 9.01.2003. Based on that, the unit has obtained CTE under Water and Air Acts vide dated 07.07.2005 and the unit has obtained CTO under Water and Air Acts vide dated 04.01.2011 with valid upto 31.03.2011 to produce electric power 2 x 250 MW and it was further renewed upto 31.03.2027. The unit was consented to discharge 150 KLD of sewage and 21440 KLD of trade effluent. The unit is consented to discharge emission from two boilers 850TPH through a stack of 220 m. During Inspection of the committee, the unit is in operation.

Water & Waste Water Management

The main water source of the plant is from Mine-II discharge water and it is collected in the artificial lake, situated within the NLC campus.

Sewage: The unit has provided sewage treatment plant and the treated sewage is utilized for green belt development within the industry's premises. ROA of the treated sewage samples collected for the year 2018-2023 from the outlet of the STP reveals that most of the parameters are within the standards prescribed by the Board except the exceedance of pH 1/48 and BOD (3/48). (Consolidated ROA - Annexure-12)

Trade effluent: The unit has provided ETP and the treated trade effluent is being recycled with in the process. The unit has provided the Online Effluent Quality Monitoring system for pH, Temperature, TSS in the treated trade effluent disposal line and is connected with Water Quality Watch, TNPCB, Chennai. ROA of the treated trade effluent samples collected for the year 2018-2023 (5 years) from the outlet of ETP reveals that, most of the parameters are within the standards prescribed by the Board except the exceedance of - TDS (4/43), (Consolidated ROA - Annexure-13)

Air Pollution Management

The unit has provided common stack along with Electrostatic Precipitator (ESP) for the boilers. The unit has provided Circulating Fluidized Bed Combustion

(CFBC) Boilers with limestone feeders to control SO₂ emission. The unit has provided continuous online stack monitoring system for parameters SPM, SO₂ and NO_x, for each unit and connected the same to CAC, TNPCB, Chennai. The unit has provided bag filter for the fly ash silo. The unit has provided 3Nos of dust extraction system in the lignite conveying system and also provided automatic medium velocity water sprinklers in the lignite handling system in order to suppress the dust emanating during the operation.

ROA of the Stack emission survey in the year 2018-2023 (5 years) reveals that all the parameters are within the limit prescribed standard except SO_x (1/10). (Consolidated ROA - Annexure-14). Consolidated ROA of the AAQ survey in the year 2018-2023 (5years) reveals that PM₁₀,(3/10) PM_{2.5} (2/10) Sox(1/10) and NO_x(1/10). (Consolidated ROA - Annexure-15)

Solid waste Management

Fly Ash Management

The unit is disposing the fly ash to cement industries and brick manufactures. The bottom ash is being sent to Mine-II of M/s NLC India Ltd for back filling in the mined area.

Hazardous Waste Management

The unit has obtained the authorization under Hazardous and Other Wastes (Management and Transboundary Movement) Rules, 2016 vide Bd's Proc. Dated 09.02.2016 and valid upto 08.02.2021 for handling of used oil/spent oil, spent ion exchange resins. The unit has to apply for renewal of authorization.

Greenbelt Development

The development of Greenbelt carried out in TPS-II Expansion is given vide Plate No.-5

2.7 M/s. NLC TPS I Expansion

The unit M/s. Neyveli Lignite Corporation Limited has obtained Environment Clearance from the MoEF for Expansion of Unit-I vide letter No.J13011/31/87-IA II dt 29.06.1990 for a capacity 2 x 210 MW. Based on that, the unit has obtained CTE under Water and Air Acts vide proceeding dated 22.02.2001 with a validity upto

21.02.2003. Later the unit has obtained CTO under Water and Air Acts vide dated 21.07.2006 with valid upto 31.03.2007 and further renewed upto 31.03.2023 to produce 2 x 210 MW. The unit is consented to discharge 385 KLD of sewage and 9000 KLD of trade effluent. The unit is consented to discharge emission from two nos. of 690TPH boilers through a 220 m stack. During Inspection of the committee, the unit is in operation.

Water & Waste Water Management

The main water source of the plant is from Mine-I/1A discharge water and it is collected in the artificial lake, situated within the NLC campus. In addition, the unit is also drawing GW at the rate of 500 KLD for the boiler make up to produce steam and also for domestic consumption

Sewage: The unit has provided sewage treatment plant for the treatment of the sewage and canteen wastewater and the treated sewage is utilised for greenbelt development within the industry's premises. ROA of the treated sewage samples collected for the year 2018-2023 from the outlet of the STP and it reveals that most of the parameters are within the standards prescribed by the Board except the exceedance of - pH (1/55), BOD (6/55) and COD (1/55).(Consolidated ROA - Annexure-16)

Trade effluent: The unit has provided Effluent Treatment Plant and the treated trade effluent is discharged into nearby channel for irrigation purposes. ROA of the treated trade effluent samples collected for the 2018-2023 reveals that, most of the parameters are within the standards prescribed by the Board except the exceedance of - except the exceedance of pH (1/55), TDS (1/55). (Consolidated ROA - Annexure-17). The unit has provided the Online Effluent Quality Monitoring system (online sensor) for pH, Temperature, TSS in the treated trade effluent disposal line and is connected with Water Quality Watch, TNPCB, Chennai.

Air Pollution Management

The unit has provided common stack along with ESP for the boilers. The unit has provided continuous online stack monitoring system for parameters SPM, SO₂ and NO_x, for each unit and connected the same to CAC, TNPCB, Chennai. The unit has provided bag filter for the lignite crusher house. The unit has provided 4 Nos of

dust extraction system in the lignite conveying system and automatic water sprinklers in the lignite handling system to suppress the dust.

ROA of the Stack emission survey in the year 2018-2023 reveals that PM(2/10), NO_x(1/10) 618 mg/Nm³ and SO_x 3 (7/10). (Consolidated ROA - Annexure-18). To meet the SO_x norms in the stack emission, the unit has proposed to install flue gas de-sulfurization (FGD) system and it is planned to complete as per the timeline given by MoEF& CC (i.e) 31.12.2026.

Consolidated ROA of the Ambient Air Quality Monitoring survey in the year 2018-2023 (5 years) all the parameters are within the standards prescribed by the Board except the exceedance of - PM 10 (4/10) PM 2.5 (6/10) SO_x (2/10) and NO_x (2/10) (Consolidated ROA - Annexure-19).

Solid waste Management

Fly Ash Management

The unit is disposing the fly ash to cement industries and brick manufactures. The bottom ash is being sent to Mine-I of M/s NLC India Ltd for back filling in the mined area.

Hazardous Waste Management

The unit has obtained the authorization under Hazardous and Other Wastes (Management and Transboundary Movement) Rules, 2016 vide Bd's Proc. dated 09.02.2016 and valid upto 08.02.2021 for handling of used oil/spent oil, spent ion exchange resins. The unit has to apply for renewal of authorization

Greenbelt Development

The development of Greenbelt carried out in TPS-I Expansion is given vide Plate No.- 6

2.8 M/s. Neyveli New Thermal Power Station

The unit M/s. Neyveli New Thermal Power Station has obtained Environment Clearance was obtained from the MoEF for the capacity 2x500 MW vide MoeEFLetter J-13012/250/2007-IA.II (T) dated 21.10.2010. Based on that the unit has obtained CTE from TNPCB under Water and Air Acts vide proceeding dated 12.01.2012 with validity upto 31.03.2014. Later the unit has obtained CTO vide

proceeding dated 26.04.2019 with validity upto 31.03.2021 to produce electric power 2 x 500 MW. The unit has applied for renewal of consent. The application is returned for want of additional details.

The unit is consented to discharge 35 KLD of sewage and 15600 KLD of trade effluent. The unit has two boilers of 1600 TPH and consented to discharge emission through a 275 m stack. During inspection of the committee, the unit is in operation.

Water & waste water management

The main water source of the plant is from Mine-I/1A discharge water and it is collected in the artificial lake, situated within the NLC campus

Sewage: The unit has provided sewage treatment plant for the treatment of the sewage and canteen wastewater generated and the treated sewage is disposed on land for green belt development within the industry's premises. ROA of the treated sewage samples collected for the year December 2020-2021, 2021-2022 and 2022 -2023 from the outlet of the STP reveals that most of the parameters are within the standards prescribed by the Board except the exceedance of - pH (1/31) and BOD (1/31). (Consolidated ROA - Annexure-20).

Trade effluent: The unit has provided effluent treatment plant and the treated trade effluent is discharged into nearby channel for irrigation purposes. The unit has provided the Online Effluent Quality Monitoring system for pH, Temperature, TSS in the treated trade effluent disposal line and is connected with Water Quality Watch, TNPCB, Chennai. ROA of the treated trade effluent samples collected for the year September 2020-2021, 2021-2022 and 2022 -2023 from the outlet of ETP reveals that most of the parameters are within the standards prescribed by the Board except the exceedance of - pH (6/32), TDS 8/32 chloride (1/32). (Consolidated ROA - Annexure-21).

Air Pollution Control measures

The unit has provided common stack along with ESP for the boilers. The unit has provided continuous online stack monitoring system for parameters SPM, SO₂ and NO_x for each unit and connected the same to CAC, TNPCB, Chennai. The unit has started the construction activity on 31.01.2022 for FGD system and planned to complete before January 2025. The unit has provided bag filter for the lignite crusher house. The unit has provided 4 Nos of dust extraction system in the lignite conveying

system and automatic water sprinklers in the lignite handling system to suppress dust.

ROA of the Stack emission survey in the year 2020-2023 reveals that the following parameters are exceeded the standards PM (5/6), SO_x (6/6) and NO_x (6/6) (Consolidated ROA - Annexure-22). ROA of the AAQ survey in the year 2020-2021, 2021 - 2022 and 2022-2023 reveals that all the parameters are within the standards prescribed by the Board except the exceedance of - PM₁₀ (2/6). (Consolidated ROA - Annexure-23).

Fly Ash Management

The unit is disposing the fly ash to cement industries and brick manufactures. The bottom ash is being sent to Mine-I of M/s NLC India Ltd for back filling in the mined area.

Hazardous Waste Management

The unit has made agreement is made with M/s. Dalmia cements for disposing the spent resin and oil soaked cotton waste. Spent resin is stored in the MS drums in the hazardous waste storage shed. Spent oil is stored in the closed shed. Agreement is made with M/s. MSTC for disposing the spent oil. The unit has applied for hazardous waste authorization to the Board. The application is returned for want of additional particulars.

Greenbelt Development

The development of Greenbelt carried out in Neyveli New Thermal Power Station is given vide Plate No.- 7

2.9 Over all Fly Ash Disposal by all TPSs in NLCIL

M/s. NLCIL reported that all the power plants (viz., TPS I Exp, TPS II, TPS II Exp & NNTPS) are achieving 100% ash utilization since 2013 by supplying the generated ash to brick manufacturing companies, cement manufacturing companies, filling of mine voids, low lying areas etc., complying with the guidelines of MoEF&CC fly ash notifications. The details of fly ash generation and utilization during FY 2022-2023 are given below:

		TPS I Exp	TPS II	TPS II Exp	NNTPS
Generation	Total Ash (Dry Fly Ash + Bottom Ash) in Tons	2,25,737.8	7,74,991.2	1,42,172	4,53,890
	Total Dry Fly Ash in Tons	1,65,956.2	3,36,742.3	1,12,150	4,07,195
	Total Bottom Ash in Tons	59,781.6	4,38,248.9	30,022	46,695
Utilization	Total Dry Fly Ash in Tons	1,65,956.2	3,36,742.3	1,12,150	4,07,195
	Total Bottom Ash in Tons	59,781.6	4,38,248.9	30,022	46,695
	% of Total Ash Utilization	100%	100%	100%	100%

2.10 Continuous Ambient Air Quality Monitoring Stations in NLCIL campus

TNPCB has directed the NLCIL to install Continuous Ambient Air Quality Monitoring System (CAAQMS). Based on that NLCIL have installed seven CAAQMS in and around the units of NLCIL and connected to TNPCB's Care Air Centre. Installation of two additional CAAQMS is in progress.

The details of the locations of the CAAQMS are as below:

Sl.No	Station	Location	Status
1	Mine-I	Block 8	Installed
2	Mine-IA	Vadakuthu	Under progress
3	Mine-II	Administrative Office	Installed
4	TPS-I Exp/Mine-I	Block 6	Installed
5	TPS-II	Inside TPS-II premises	Installed
6	TPS-II Exp	Inside TPS-II Expn premises	Installed
7	Mine-II	Substation near Muthanai	Under progress
8	NNTPS	Inside NNTPS premises	Installed
9	CARD	Inside CARD	Installed

M/s. NCLIL has provided LED display boards at prominent places and entrances of the units and displaying the environmental monitoring data to the public.

2.11 Township Sewage Treatment Plant

The unit of M/s. NLC India Limited has established a Sewage Treatment Plant and obtained CTO from Board under Water and Air Acts vide Board Proceedings No. DEE/TNPCB/CUD/OL/A&W/2004 dated 23.12.2004 and subsequently renewed with validity up to 30.03.2025. The unit has installed 30 MLD capacity of STP to treat the sewage from NLC Township. Treated sewage is discharged into Kanniakoil Odai which is used for irrigation in the downstream. ROA of the treated sewage samples collected for the year 2018- 2023 (5 years) from the outlet of the STP reveals that, most of the parameters are within the standards prescribed by the Board. (Consolidated ROA - Annexure-24).

3.0 M/S. IL& FS TAMIL NADU POWER COMPANY LIMITED

The unit of M/s. IL& FS Tamil Nadu Power Company Limited has obtained environmental clearance from Ministry of Environment and Forest vide J 13012/34/2008-IA.II (T) dated 31.05.2010 for setting up a thermal power plant of 2X 600MW and 3X 800 MW and also 30 MLD desalination plant. The unit has obtained environmental and CRZ clearance for captive port of capacity 15MTPA and 30 MLD desalination plant from MoEF vide F.No. 11-43/2010 –IA-III dated 29.10.2010. Based on that the unit has obtained CTE from Board under Water and Air Acts to manufacture 2x 600 MW Power and 12 MLD desalination plant vide Board Proc. Dated 14.06.2011.

The unit has obtained CTO from the Board vide dated: 15.04.2016 with a validity upto 31.03.2017 and further renewed upto 31.03.2028 for the operation of 2 x 600 MW units and 10MLD desalination plant. The unit is consented to discharge 840 KLD of sewage, 205705 KLD of trade effluent. The unit is consented to discharge emission from boiler through a stack of 275 metre height. During inspection of the committee, 1 x 600 MW plant is in operation and another plant is under maintenance. The imported coal is used as fuel. Ash and sulphur content of coal is 6% and 0.8% respectively.

Water Management

The unit is drawing water from the Bay of Bengal located in the Eastern side of the plant. The unit has provided desalination plant of 10 MLD. Desalination plant

contains two stages (a) Sea Water Reverse Osmosis Plant (b) Brackish Water Reverse Osmosis. Product of BWRO is used for domestic purpose and for demineralised plant. The demineralised water is used for make up in boiler, electro chlorination plant and condensate polishing unit regeneration. Reject from Brackish Water Reverse Osmosis and cooling tower blow down are collected in central monitoring basin from there, it is discharged into sea (Bay of Bengal) through pipe line.

Waste Water Management

Sewage: The unit has provided Sewage Treatment Plant to treat the sewage generated and the treated sewage is used for on land for green belt development. The ROA of the treated sewage samples collected for the year 2018-2023 (5 years) from the outlet of the STP reveals that, most of the parameters are within the standards prescribed by the Board except the exceedance of - BOD (6/52) COD (4/52) Nitrogen (1/52). (Consolidated ROA - Annexure-25).

Trade Effluent: The trade effluent generated from cooling tower blow down and seawater reverse osmosis reject are collected in guard pond and discharged into the sea. Trade effluent from oil wastewater treatment plant, coal wastewater treatment plant, DM plant regeneration, boiler blow down and condensate polishing unit regeneration are treated in the ETP and used for dust suppression, coal handling plant and plant wash. Consolidated ROA of the treated trade effluent samples collected from the ETP outlet reveals that most of the parameters are within the standards prescribed by the Board except the exceedance of - BOD (1/52) , sulphide (4/52) and chloride (5/52) (Consolidated ROA - Annexure-26).

Air Pollution Management

The unit has provided common stack of 275m height and FGD systems along with separate ESPs for the Boiler I and Boiler II. The unit has provided online continuous stack emission monitoring systems for the parameters PM, SO₂ and NO_x and connected the same to CAC, TNPCB, Chennai. The unit has provided 6 Nos of CAAQM stations for PM₁₀, PM_{2.5}, SO₂, NO_x and CO and connected to CAC, TNPCB, Chennai. The unit has provided water sprinklers in coal handling area, coal stockyard and bag filters at coal transfer points as APC measures. In coal stockyard,

the unit has provided wind barriers of 15 m height all around to prevent fugitive emission.

Consolidated ROA of the stack emission survey in the year 2018-2023 (5 years) all the parameters are within the standards prescribed by the Board except the exceedance of - PM 10 (9/21). (Consolidated ROA - Annexure-27). Consolidated ROA of the AAQ monitoring survey in the year 2018-2023 (5 years) reveals that all the parameters are within the standards prescribed by the Board except the exceedance of - PM₁₀ (4/10) range of 108-116 µg/m³, PM_{2.5} (5/10) range of 62-82 µg/m³. (Consolidated ROA - Annexure-28). The unit has obtained authorization under Hazardous and Other Wastes (Management and Transboundary Movement) Rules, 2016 vide Bd's proc. dated 30.11.2021 with validity upto 31.03.2026.

Fly Ash Management

The fly Ash, bottom ash and gypsum are disposed to cement factories. The pond ash accumulated is being disposed to road project (Vikravandi to Nagapattinam- NH 45) carried out by M/s. Oriental Structural Engineers Limited as when required.

Green Belt Development

The unit has developed around 3,30,219 Nos of trees till December 2022 in 262.30 acres. The unit authorities informed that during the year 2022-2023 around 46055 trees were planted in 8.5 acres.

4.0 SAMPLE COLLECTION


In the '*POWERing Pollution*' report, it is noted that there are 26 samples collected in Feb 2023 and 11 samples in April 2023 in both NLCIL, Neyveli and ITPCL, Parangipettai surrounding areas covering surface water groundwater and soil. In order to know the correctness of the report, the committee has taken the samples in the same areas. Totally 41 samples (surface water-27, ground Water-8, soil-6) were collected on 11.08.2023 and 16.08.2023. The sample collection detail is given Annexure-29. Photographs are given in Plate No.- 8. The collected samples are given to IITM CUBE, Chennai laboratory for analysis. Once the report of analysis received, a detailed report will be submitted.

Further, in order to know changes in the quality of ground water over a period of time, it is proposed to collect additional samples in the 10KM surrounding area of NLCIL with reference to the earlier EIA study reports. (i.e) Samples will be collected in the same villages where samples were collected while carrying out EIA study for their expansion/new mining and thermal plants. The details of proposed sampling are given in Annexure- 30. This sampling will be done in the first week of September 2023.


Enclosure: Annexures




T. Chitrarasu
AD, AEL, Cuddalore




Dr R. Umayakunjaram
DEE, Cuddalore



Dr A. Samuel Rajkumar
JCEE(M), Cuddalore



S. Sankarasubramanian
AD, AEL, Chennai



Dr R. Rajamanickam
ACEE, TNPCB

ANNEXURE 1**CONSOLIDATED ROA OF TREATED SEWAGE FROM M/S. NLC INDIA LTD,
MINE I FOR THE YEAR 2018-2023**

Mine - I Outlet of Sewage Treatment Plant						
S.No.	Month	pH	TSS	BOD	COD	Ammonical Nitrogen (NH₃-N)
1	Apr-18	7.7	8	12	52	12.89
2	May-18	6.92	8	10	88	<MDL
3	Jun-18	7.59	10	8	64	<MDL
4	Jul-18	8.98	6	26	160	12.89
5	Aug-18	6.96	16	20	80	<MDL
6	Sep-18	7.16	8	4	16	–
7	Oct-18	7.93	12	16	32	–
8	Nov-18	7.41	12	26	100	16.25
9	Dec-18	7.85	10	10	40	7.84
10	Jan-19	8.01	6	4	16	6.16
11	Feb-19	7.8	10	16	64	10.09
12	Mar-19	6.84	6	8	32	8.4
13	Jan-20	6.49	10	20	80	8.4
14	Feb-20	6.96	12	28	120	–
15	Mar-20	7.92	8	20	88	10.09
16	May-20	7.45	8	14	64	–
17	Jun-20	6.46	12	18	72	–
18	Jul-20	7.61	14	18	72	8.96
19	Sep-20	7.73	10	16	48	6.72
20	Oct-20	8.54	8	18	48	4.48
21	Nov-20	6.28	10	16	44	3.36
22	Dec-20	7.4	14	20	52	5.04
23	Jan-21	7.6	10	16	44	–
24	Feb-21	7.05	10	16	44	3.92
25	Apr-21	6.74	10	14	44	–
26	Jun-21	6.52	14	16	44	<MDL
27	Jul-21	7.36	10	16	44	<MDL
28	Aug-21	7.97	12	18	44	–
29	Sep-21	8	12	16	44	<MDL
30	Oct-21	6.59	14	16	44	<MDL
31	Nov-21	6.48	12	16	44	<MDL
32	Dec-21	6.61	12	16	44	<MDL
33	Jan-22	7.16	16	18	44	<MDL
34	Feb-22	8.12	12	16	44	<MDL
35	Mar-22	7.02	14	16	44	<MDL
36	May-22	6.19	16	20	64	<MDL
37	Jun-22	5.91	10	8	32	4.48

38	Aug-22	7.44	10	10	32	3.36
39	Sep-22	6.57	10	14	64	5.04
40	Oct-22	6.66	12	5.8	24	<MDL
41	Nov-22	7.96	12	12	32	4.48
42	Dec-22	7.07	12	8	32	6.72
43	Jan-23	9.12	18	36	144	6.72
44	Feb-23	6.94	18	16.4	56	9.52
45	Mar-23	9.1	6	6	80	6.2
Standards for STP		5.5-9.0	30	20	100	-

Inference:The ROA of the treated sewage samples collected for the year 2018 – 2019, 2019-2020, 2020-2021, 2021-2022 and 2022 -2023 from the outlet of the STP reveals that the parameters were within the standards prescribed by the Board in most of the months.

ANNEXURE 2**CONSOLIDATED ROA OF TREATED EFFLUENT**
FROM M/S. NLC INDIA LTD., MINE I FOR THE YEAR 2018-2023

Mine - I Outlet of Effluent Treatment Plant					
S.No.	Month	pH	TSS	BOD	COD
1	Apr-18	8.99	12	28	112
2	May-18	6.58	22	18	116
3	Jun-18	5.19	10	10	96
4	Jul-18	7.04	8	28	180
5	Aug-18	6.95	12	16	64
6	Sep-18	6.87	8	30	144
7	Oct-18	7.76	28	16	64
8	Nov-18	5.28	10	22	88
9	Dec-18	5.37	12	6	32
10	Jan-19	8.01	8	14	56
11	Feb-19	7.57	8	16	64
12	Mar-19	4.28	8	8	32
13	Dec-19	8.92	14	18	76
14	Jan-20	3.83	12	20	80
15	Feb-20	6.02	22	22	108
16	Mar-20	7.67	12	22	96
17	May-20	4.1	12	20	80
18	Jun-20	5.77	12	10	40
19	Sep-20	5.89	12	18	72
20	Oct-20	4.72	24	18	80
21	Nov-20	5.7	14	18	76
22	Jan-21	4.8	12	20	64
23	Feb-21	4.83	14	20	80
24	Apr-21	6.52	10	16	44
25	Jun-21	6.48	14	18	64
26	Jul-21	7.36	14	20	80
27	Aug-21	6.04	18	20	80
28	Sep-21	7.98	14	20	80
29	Oct-21	5.48	14	20	80
30	Nov-21	6.06	18	20	88
31	Dec-21	5.78	16	20	80
32	Jan-22	7.28	16	20	88
33	Feb-22	7.6	16	20	88
34	Mar-22	4.31	18	20	88
35	May-22	6.16	12	16	44
36	Jun-22	6.91	12	8	16
37	Jul-22	8.23	21	2	8
38	Aug-22	7.75	18	8	32

39	Sep-22	6.23	22	16	72
40	Oct-22	7.91	12	6.1	24
41	Nov-22	6.62	8	18	64
42	Dec-22	7.18	18	28	144
43	Jan-23	6.33	12	18	64
44	Feb-23	7.98	14	9.8	48
45	Mar-23	4.02	10	5	64
Standards for ETP		5.5-9.0	200	100	-

Inference: The ROA of the treated effluent samples collected for the year 2018 – 2019, 2019-2020, 2020-2021, 2021-2022 and 2022 -2023 from the outlet of the ETP reveals that the parameters were within the standards prescribed by the board except the exceedance of pH (8/45).

ANNEXURE 2**CONSOLIDATED ROA OF SEEPAGEWATER FROM
M/S. NLC INDIA LTD., MINE I FOR THE YEAR 2018-2023**

Mine - I Outlet of Seepage water					
S.No.	Month	pH	TSS	BOD	COD
1	Apr-18	8.83	18	38	152
2	May-18	7.2	16	12	108
3	Jun-18	6.84	16	14	108
4	Jul-18	7.3	12	20	136
5	Aug-18	7.04	10	20	80
6	Sep-18	6.47	6	12	64
7	Oct-18	7.71	12	10	32
8	Nov-18	6.79	14	25	100
9	Dec-18	7.26	10	16	64
10	Jan-19	8.1	16	26	104
11	Feb-19	7.52	14	13	52
12	Mar-19	7.42	6	4	16
13	Dec-19	8.7	12	16	68
14	Jan-20	6.65	14	22	88
15	Feb-20	6.99	18	24	136
16	Mar-20	7.62	8	10	64
17	May-20	6.99	20	22	88
18	Jun-20	6.66	18	14	64
19	Sep-20	7.34	14	20	80
20	Oct-20	7.15	14	16	64
21	Nov-20	5.08	16	20	80
22	Dec-20	4.91	14	20	80
23	Jan-21	7.69	10	18	56
24	Feb-21	7.03	12	18	72
25	Apr-21	6.92	12	20	52
26	Jun-21	7.98	16	20	72
27	Jul-21	7.09	16	22	88
28	Aug-21	8.14	20	22	92
29	Sep-21	7.7	16	22	84
30	Oct-21	6.58	12	18	72
31	Nov-21	7.75	20	22	92
32	Dec-21	6.28	14	18	64
33	Jan-22	7.43	20	22	96
34	Feb-22	7.58	18	22	92
35	Mar-22	7.73	16	22	92
36	May-22	6.84	14	18	64
37	Jun-22	7.22	10	6	24

38	Jul-22	8.44	14	10	56
39	Aug-22	7.02	12	12	40
40	Sep-22	7.36	18	12	64
41	Oct-22	6.29	12	1.8	8
42	Nov-22	6.43	12	8	32
43	Jan-23	6.4	14	2	8
44	Feb-23	4.87	12	8	40
45	Mar-23	7.04	10	4	40
Standards		5.5-9.0	200	100	-

Inference: *The ROA of the seepage water samples collected for the year 2018 – 2019, 2019-2020, 2020-2021, 2021-2022 and 2022 -2023 from the outlet of the seepage reveals that the parameters were within the standards prescribed by the board except the exceedance of pH (1/45).*

ANNEXURE 3**CONSOLIDATED ROA OF THE AMBIENT AIR QUALITY MONITORING SURVEY
CONDUCTED AT M/S. NLC INDIA LTD., MINE I FOR THE YEAR 2018-23**

Parameters		PM10		PM2.5		SO2		NOx	
Standards		500		250		120		120	
Year		Min.	Max.	Min.	Max.	Min.	Max.	Min.	Max.
2018-19	1 st Half year	150	344	26	70	10	18	12	20
	2 nd Half year	320	158	34	68	11	20	14	22
2019-20	1 st Half year	310	340	58	94	15	18	17	20
	2 nd Half year	256	316	54	102	8	13	10	16
2020-21	1 st Half year	285	292	56	58	14	16	17	19
	2 nd Half year	286	296	59	60	9	10	11	12
2021-22	1 st Half year	168	579	69	78	13	16	18	21
	2 nd Half year	129	133	45	51	14	17	16	23
2022-23	1 st Half year	222	260	38	46	12	22	13	23
	2 nd Half year	230	250	32	56	14	16	15	20

Inference: Ambient Air Quality Survey was conducted at six locations inside and outside of the Mine I. The minimum and maximum value at particular location is given above. As per the survey report of the year 2018 – 2023, all the parameters are within the standards prescribed by the Board except PM10 in the range of 579 $\mu\text{g}/\text{m}^3$ (1/10) which is slightly higher than 500 $\mu\text{g}/\text{m}^3$.

ANNEXURE 4**CONSOLIDATED ROA OF TREATED EFFLUENT
FROM M/S. NLC INDIA LTD., MINE IA FOR THE YEAR 2018-2023**

Mine - IAOutlet of Effluent Treatment Plant					
S.No.	Month	pH	TSS	BOD	COD
1	Apr-18	6.73	8	8	32
2	May-18	6.65	8	12	48
3	Jun-18	6.64	14	13	80
4	Jul-18	7.49	6	8	32
5	Sep-18	5.95	8	8	32
6	Oct-18	6.05	10	4	16
7	Nov-18	7.21	12	8	32
8	Dec-18	7.76	14	16	64
9	Jan-19	7.12	8	8	32
10	Feb-19	7.74	2	8	32
11	Mar-19	7.34	6	4	16
12	Apr-19	6.81	6	12	64
13	May-19	5.86	8	4	16
14	Jun-19	6.92	4	4	16
15	Jul-19	7.13	6	8	32
16	Aug-19	6.41	6	8	32
17	Sep-19	7.35	8	18	64
18	Oct-19	7.81	12	16	64
19	Nov-19	6.26	16	26	108
20	Dec-19	8.5	14	24	96
21	Jan-20	4.38	10	20	76
22	Feb-20	6.32	12	18	72
23	Mar-20	7.69	10	14	64
24	Sep-20	4.53	14	20	88
25	Oct-20	4.69	14	18	76
26	Dec-20	4.94	14	20	72
27	Apr-21	3.32	16	20	72
28	Jun-21	7.21	20	22	96
29	Jul-21	6.75	20	22	96
30	Aug-21	7.4	20	22	116
31	Sep-21	7.73	16	20	76
32	Oct-21	7.07	14	22	88
33	Nov-21	6.13	16	20	76
34	Dec-21	6.06	14	20	72
35	Apr-22	6.84	18	22	88
36	May-22	7.44	16	18	60
37	Jun-22	8.19	10	8	32
38	Jul-22	8.38	10	10	32

39	Aug-22	7.01	8	12	64
40	Sep-22	6.84	16	12	48
41	Oct-22	7.03	12	8	40
42	Dec-22	7.51	8	8	32
43	Jan-23	5.8	18	12	32
44	Feb-23	7.08	16	8.2	40
45	Mar-23	5.83	8	3.2	24
Standards for ETP		5.5-9.0	200	100	-

Inference:The ROA of the treated effluent samples collected for the year 2018 – 2019, 2019-2020, 2020-2021, 2021-2022 and 2022 -2023 from the outlet of the ETP reveals that the parameters were within the standards prescribed by the Board.

ANNEXURE 4**CONSOLIDATED ROA OF SEEPAGE WATER
FROM M/S. NLC INDIA LTD., MINE IA FOR THE YEAR 2018-2023**

Mine - IAOutlet of Seepage water					
S.No.	Month	pH	TSS	BOD	COD
1	Apr-18	8.24	6	4	16
2	May-18	7.91	6	12	48
3	Jun-18	7.3	22	18	96
4	Jul-18	7.61	8	16	64
5	Sep-18	6.09	12	18	64
6	Oct-18	6.27	12	12	32
7	Nov-18	7.29	18	20	80
8	Dec-18	7.85	12	8	32
9	Jan-19	6.96	12	16	64
10	Feb-19	7.68	4	14	64
11	Mar-19	7.18	12	8	32
12	Apr-19	6.49	8	8	32
13	May-19	6.97	12	8	32
14	Jun-19	6.64	8	8	32
15	Jul-19	7.27	8	12	64
16	Aug-19	6.7	8	16	64
17	Sep-19	6.45	12	26	104
18	Oct-19	8.08	18	22	88
19	Nov-19	8.36	18	28	112
20	Dec-19	8.5	14	24	96
21	Jan-20	5.68	12	22	80
22	Feb-20	6.36	20	26	136
23	Mar-20	7.8	14	18	72
24	Sep-20	3.63	20	26	112
25	Oct-20	4.8	18	20	80
26	Nov-20	4.25	18	24	116
27	Dec-20	3.86	20	24	88
28	Apr-21	4.13	16	18	64
29	Jun-21	8.48	16	20	92
30	Jul-21	4.16	18	20	88
31	Aug-21	5.41	16	24	104
32	Sep-21	7.75	18	22	80
33	Oct-21	6.36	18	20	80
34	Nov-21	3.08	20	22	104
35	Dec-21	5.34	18	20	88
36	Feb-22	8.2	18	24	104
37	Mar-22	7.87	20	22	96
38	Apr-22	7.16	16	24	96

39	May-22	7.96	14	16	48
40	Jun-22	7.78	10	16	64
41	Jul-22	8.2	18	12	40
42	Aug-22	7.04	2	20	88
43	Sep-22	7.32	20	16	88
44	Oct-22	7.3	18	4.2	16
45	Dec-22	7.76	12	16	64
46	Jan-23	7.28	12	7.4	32
47	Feb-23	7.16	12	7.8	32
48	Mar-23	7.14	14	5.4	40
Standards for Seepage					

Inference:The ROA of the seepage water samples collected for the year 2018 – 2019, 2019-2020, 2020-2021, 2021-2022 and 2022 -2023 from the outlet of the seepage reveals that the parameters were within the standards prescribed by the Board.

ANNEXURE 5**CONSOLIDATED ROA OF THE AMBIENT AIR QUALITY MONITORING SURVEY
CONDUCTED AT M/S. NLC INDIA LTD., MINE IA FOR THE YEAR 2018-2023**

Parameters		PM10		PM2.5		SO2		NOx	
Standards		500		250		120		120	
Year		Min.	Max.	Min.	Max.	Min.	Max.	Min.	Max.
2018-19	1 st Half year	158	320	34	68	20	11	22	14
	2 nd Half year	270	290	55	56	8	15	12	18
2019-20	1 st Half year	340	268	98	55	22	17	25	20
	2 nd Half year	268	360	58	105	12	22	15	26
2020-21	1 st Half year	290	286	56	55	12	15	15	18
	2 nd Half year	287	297	58	54	10	12	4	7
2021-22	1 st Half year	104	340	72	86	15	13	25	18
	2 nd Half year	110	109	46	64	14	15	16	18
2022-23	1 st Half year	248	262	32	40	10	18	13	20
	2 nd Half year	232	252	34	58	14	18	15	22

Inference: Consolidated ROA of the AAQ survey in the year 2018-2019, 2019-2020, 2020-2021, 2021-2022 and 2022-2023 reveals that all the parameters are within the standards prescribed by the Board.

ANNEXURE 6**CONSOLIDATED ROA OF TREATED SEWAGE FROM M/S. NLC, MINE II FOR THE YEAR 2018-2023**

Mine - II Outlet of Sewage Treatment Plant						
S. No.	Month	pH	TSS	BOD	COD	Ammonical Nitrogen (NH₃-N)
1	Apr-18	7.22	8	16	64	—
2	May-18	7.2	6	8	80	—
3	Jun-18	7.58	10	12	96	—
4	Jul-18	8.02	12	10	96	—
5	Aug-18	7.06	8	30	148	—
6	Sep-18	7.09	8	36	144	—
7	Oct-18	7.52	38	72	288	—
8	Nov-18	7.48	12	26	104	—
9	Dec-18	7.75	8	12	64	—
10	Jan-19	7.17	28	34	136	—
11	Feb-19	7.58	12	26	104	—
12	Mar-19	7.78	12	8	32	—
13	Apr-19	6.92	8	36	144	—
14	May-19	6.17	12	18	64	—
15	Jun-19	6.98	8	26	104	—
16	Jul-19	6.81	8	18	64	—
17	Aug-19	6.69	12	8	32	—
18	Sep-19	7.26	18	18	72	—
19	Oct-19	7.45	10	20	80	—
20	Nov-19	7.9	12	20	80	—
21	Apr-20	8.1	14	18	96	—
22	May-20	8.1	14	18	96	—
23	Jun-20	7.2	14	14	64	—
24	Jul-20	7.09	12	16	76	—
25	Aug-20	7.27	12	14	72	—
26	Sep-20	8.01	14	20	80	—
27	Oct-20	8.92	14	20	88	—
28	Nov-20	7.15	14	20	80	—
29	Jan-21	7.43	12	20	80	—
30	Feb-21	7.81	18	22	96	—
31	Mar-21	7.87	10	18	48	—
32	Apr-21	7.08	14	20	72	—
33	Jun-21	7.26	18	20	80	—
34	Jul-21	7.22	14	20	80	—
35	Aug-21	8.12	18	24	108	—
36	Sep-21	8.31	16	18	72	—
37	Oct-21	6.64	18	22	88	—
38	Nov-21	7.02	16	20	96	—
39	Dec-21	7.4	20	22	96	—

40	Feb-22	8.07	14	22	96	–
41	Mar-22	7.73	14	16	48	–
42	Apr-22	6.82	10	16	40	<MDL
43	May-22	7.41	18	18	64	<MDL
44	Jun-22	6.7	18	20	96	5.04
45	Jul-22	8.24	16	26	80	–
46	Aug-22	6.96	8	20	80	8.4
47	Sep-22	7.54	20	32	112	10.64
48	Oct-22	7.7	16	5.4	24	<MDL
49	Dec-22	6.79	12	16	64	3.36
50	Jan-23	6.71	133	9.2	24	3.36
51	Feb-23	7.28	16	12	32	3.36
52	Mar-23	6.54	18	6.4	40	5.6
Standards for STP		5.5-9.0	30	20	100	–

Inference:The ROA of the treated sewage samples collected for the year 2018-2023 from the outlet of the STP reveals that the parameters were generally within the standards prescribed by the Board except the exceedance of TSS (2/52), BOD (15/52), COD(10/52).

ANNEXURE 7**CONSOLIDATED ROA OF TREATED EFFLUENT
FROM M/S. NLC INDIA LTD., MINE II FOR THE YEAR 2018-23**

Mine - II Outlet of Effluent Treatment Plant					
S.No.	Month	pH	TSS	BOD	COD
1	Apr-18	7.84	6	12	66
2	May-18	7.99	8	4	48
3	Jun-18	7.72	12	8	64
4	Jul-18	7.61	10	8	48
5	Aug-18	7.19	10	20	80
6	Sep-18	7.21	6	26	104
7	Oct-18	7.65	14	12	32
8	Nov-18	7.83	8	8	64
9	Dec-18	7.92	10	18	72
10	Jan-19	7.53	8	12	32
11	Feb-19	7.57	10	8	32
12	Mar-19	7.99	6	18	64
13	Apr-19	6.87	6	8	64
14	May-19	6.73	8	4	16
15	Jun-19	7.28	6	18	64
16	Jul-19	6.74	6	20	84
17	Aug-19	6.51	8	4	16
18	Sep-19	6.68	8	8	32
19	Oct-19	4.86	14	26	104
20	Nov-19	4.53	14	22	84
21	Apr-20	8.18	12	16	88
22	May-20	8.18	12	16	88
23	Jun-20	4.54	18	18	88
24	Jul-20	6.25	14	18	80
25	Aug-20	5.43	14	18	80
26	Sep-20	7.79	12	18	72
27	Oct-20	8.84	10	18	72
28	Nov-20	7.68	16	18	84
29	Jan-21	7.68	18	22	96
30	Feb-21	6.15	16	20	80
31	Mar-21	7.6	14	20	80
32	Apr-21	7.75	18	22	80
33	Jun-21	7.01	18	20	80
34	Jul-21	7.08	20	22	92
35	Aug-21	8.17	20	26	112
36	Sep-21	8.51	18	22	80
37	Oct-21	7.72	16	20	80
38	Nov-21	7.18	14	18	92

39	Dec-21	6.93	18	20	92
40	Apr-22	6.84	18	22	88
41	May-22	7.44	16	18	60
42	Jun-22	8.19	10	8	32
43	Jul-22	8.38	10	10	32
44	Aug-22	7.01	8	12	64
45	Sep-22	6.84	16	12	48
46	Oct-22	7.03	12	8	40
47	Dec-22	7.51	12	8	32
48	Jan-23	7.59	18	8	32
49	Feb-23	8.1	12	10	32
50	Mar-23	6.6	130	6	56
Standards for ETP		5.5-9.0	200	100	-

Inference: Consolidated ROA of the treated trade effluent samples collected from the ETP outlet reveals that, mostly the parameters were within the standards prescribed by the Board except the exceedance of pH (4/50).

ANNEXURE 7**CONSOLIDATED ROA OF SEEPAGE WATER
FROM M/S. NLC INDIA LTD., MINE II FOR THE YEAR 2018-23**

Mine - II Outlet of Seepage water					
S.No.	Month	pH	TSS	BOD	COD
1	Apr-18	7.68	10	16	64
2	May-18	7.67	12	10	72
3	Jun-18	7.55	18	6	72
4	Jul-18	8.25	12	10	104
5	Aug-18	7.54	12	8	32
6	Sep-18	6.3	10	8	32
7	Oct-18	7.9	12	14	52
8	Nov-18	7.92	18	10	66
9	Dec-18	8.12	6	12	48
10	Jan-19	6.89	12	4	16
11	Feb-19	7.26	18	4	16
12	Mar-19	7.85	8	12	60
13	Apr-19	6.65	12	4	16
14	May-19	6.75	10	18	72
15	Jun-19	7.42	8	8	32
16	Jul-19	6.81	8	22	88
17	Aug-19	6.52	12	18	80
18	Sep-19	7.65	12	16	64
19	Oct-19	8.63	18	18	72
20	Nov-19	7.91	16	24	96
21	Apr-20	8.15	10	14	84
22	May-20	8.15	10	14	84
23	Jun-20	7.25	20	22	104
24	Jul-20	6.8	16	20	88
25	Aug-20	7.37	16	20	88
26	Sep-20	7.6	18	22	96
27	Oct-20	8.68	16	22	104
28	Nov-20	7.12	18	22	96
29	Dec-20	4.01	16	22	96
30	Jan-21	7.93	14	20	88
31	Feb-21	7.14	16	104	10
32	Mar-21	7.93	20	22	96
33	Apr-21	7.72	14	22	104
34	Jun-21	8.06	14	20	88
35	Jul-21	7.99	16	18	72
36	Aug-21	8.35	16	22	108
37	Sep-21	8.39	14	20	80
38	Oct-21	8.18	14	18	72

39	Nov-21	6.68	16	20	80
40	Dec-21	6.77	20	22	96
41	Feb-22	8.07	14	22	96
42	Mar-22	7.87	20	22	96
43	Apr-22	7.16	16	24	96
44	May-22	7.96	14	16	48
45	Jun-22	7.78	10	16	64
46	Jul-22	8.2	18	12	40
47	Aug-22	7.04	2	20	88
48	Sep-22	7.32	20	16	88
49	Oct-22	7.3	18	4.2	16
50	Dec-22	7.76	12	16	64
51	Jan-23	7.6	26	12	32
52	Feb-23	7.56	18	7.2	24
53	Mar-23	6.91	12	4.8	64
54	Dec-22	7.76	12	16	64
Standards		5.5-9.0	200	100	-

Inference: Consolidated ROA of the water samples collected from the Seepage outlet reveals that, all the parameters were within the standards prescribed by the Board.

ANNEXURE 8**CONSOLIDATED ROA OF TREATED SEWAGE FROM M/S. NEYVELI THERMAL
POWER STATION II FOR THE YEAR 2020-23**

NLC Limited Thermal Power Station II Outlet of Sewage Treatment Plant						
S. No.	Month	pH	TSS	BOD	COD	Ammonical Nitrogen (NH₃-N)
1	Oct-20	7.98	8	10	44	4.48
2	Nov-20	7.25	8	10	40	2.8
3	Dec-20	8.41	10	16	48	3.92
4	Jan-21	8.2	14	20	56	8.4
5	Feb-21	6.94	10	16	44	4.48
6	Apr-21	6.31	10	16	44	<MDL
7	Jun-21	6.78	12	18	44	<MDL
8	Jul-21	6.22	10	16	44	<MDL
9	Aug-21	6.45	16	18	44	
10	Sep-21	7.76	10	16	44	<MDL
11	Oct-21	6.48	10	16	44	<MDL
12	Nov-21	7.49	10	16	40	<MDL
13	Jan-22	7.26	14	16	44	<MDL
14	Feb-22	7.83	12	18	56	4.48
15	Mar-22	7.45	14	18	44	<MDL
16	Apr-22	7.17	12	18	48	<MDL
17	May-22	7.54	16	18	40	<MDL
18	Jun-22	7.65	12	16	64	8.4
19	Jul-22	8.44	12	20	80	5.3
20	Aug-22	7.43	68	64	256	15.12
21	Sep-22	8.08	24	18	48	5.04
22	Oct-22	6.52	8	34	112	<MDL
23	Nov-22	7.74	16	12	32	10.65
24	Dec-22	7.75	18	60	80	6.72
25	Jan-23	6.33	23	6.4	40	4.48
26	Feb-23	6.56	12	24	80	8.96
27	Mar-23	6.34	14	4.6	40	<2
Standards for STP		5.5-9.0	30	20	100	15

Inference: ROA of the treated sewage reveals that, most of the parameters are within the standards prescribed by the Board except the exceedance of – TSS 1/27, BOD (4/27), COD (2/27) ammonical nitrogen (1/27).

ANNEXURE 9**CONSOLIDATED ROA OF TREATED EFFLUENT FROM M/S. NEYVELI
THERMAL POWER STATION II FOR THE YEAR 2018-2023**

NLC Limited Thermal Power Station II – Outlet of Effluent Treatment Plant										
S.No.	Month	pH	TSS	TDS	Chlorides	Sulphates	Oil&Grease	BOD	COD	% Sodium
1	Apr-18	8.18	8	620	230	132	2	16	64	13.16
2	May-18	8.08	6	1016	140	96	–	8	64	31.63
3	Jun-18	8.29	8	714	318	126	–	8	64	47.67
4	Jul-18	8.32	8	608	105	31	<1.0	8	28	10.02
5	Aug-18	8.24	8	698	160	92	2	18	72	12.37
6	Sep-18	8.02	6	764	255	150	2	8	32	8.14
7	Oct-18	8.02	12	886	245	112	2	12	44	10.1
8	Nov-18	7.97	8	986	215	62	2	18	64	10.1
9	Dec-18	8.16	8	936	310	260	2	18	64	10.1
10	Jan-19	7.81	8	698	315	168	2	10	44	6.82
11	Feb-19	7.73	8	472	215	110	2	18	64	8.95
12	Mar-19	7.9	8	800	355	120	2	8	32	8.14
13	Apr-19	7.85	6	1176	305	152	2	18	64	8.14
14	May-19	8.19	10	754	210	68	2	18	64	10.1
15	Jun-19	7.08	8	850	220	102	2	8	32	6.78
16	Jul-19	7.52	6	326	105	60	2	12	32	8.14
17	Sep-19	7.87	12	768	255	82	2	20	72	6.78
18	Oct-19	8.78	12	2458	805	400	2	18	72	10.1
19	Nov-19	8.19	12	958	255	112	2	22	92	10.1
20	Dec-19	7.46	18	902	255	102	<MDL	24	92	8.14
21	Jan-20	7.87	18	586	220	102	–	22	88	10.1
22	Feb-20	8.03	14	954	210	102	–	26	124	12.37
23	Mar-20	8.34	20	820	255	112	2	22	104	10.1
24	May-20	8.22	18	1116	355	152	<MDL	24	108	10.1
25	Jun-20	8.39	14	1308	455	252	<MDL	18	80	8.14
26	Jul-20	8.2	14	1018	210	102	<MDL	18	72	8.99
27	Aug-20	6.39	86	810	280	122	2	24	108	10.1
28	Sep-20	7.28	104	932	185	187	<2	21	176	
29	Oct-20	8.22	18	802	225	122	2	22	96	10.1
30	Nov-20	7.72	20	830	210	102	<MDL	22	92	8.99
31	Dec-20	8.3	12	810	255	112	<MDL	22	104	11.64
32	Jan-21	8.12	18	1670	625	302	<MDL	22	96	10.02
33	Feb-21	8.08	20	852	225	132	<MDL	20	80	9.61
34	Apr-21	7.92	20	1152	405	204	–	22	96	7.75
35	Jun-21	7.23	16	1016	255	126	–	22	88	7.75
36	Jul-21	7.1	18	1012	230	120	–	22	92	6.16
37	Aug-21	7.5	18	862	260	134	–	24	108	8.99
38	Oct-21	7.85	18	896	305	126	–	22	96	25.36
39	Dec-21	8.12	14	934	325	196	–	22	80	8.99

40	Jan-22	7.9	18	534	210	122	–	20	80	7.04
41	Feb-22	8.03	16	1098	310	172	–	22	96	7.75
42	Mar-22	8.19	18	1034	305	165	–	22	96	6.34
43	Apr-22	8.29	18	1182	455	212	–	20	92	6.16
44	May-22	7.07	14	316	110	58	–	20	64	
45	Jun-22	7.79	12	488	220	152	–	12	32	17.35
46	Jul-22	7.44	20	82	25	14	–	10	24	1.47
47	Aug-22	8.32	18	284	145	62	–	12	72	3.52
48	Oct-22	7.49	12	360	142	48	–	36	128	8.14
49	Nov-22	7.94	14	2810	725	428	–	16	64	16.03
50	Dec-22	6.12	20	198	115	53	–	6	32	40.59
51	Jan-23	7.21	4	738	218	78	–	16	32	4.27
52	Feb-23	6.38	165	288	145	35	–	62	240	6.23
53	Mar-23	6.9	100	330	115	25	–	12	40	5.66
Standards for ETP		5.5-9.0	100	2100	1000	1000	10	30	250	-

Inference:ROA of the treated trade effluent samples collected for the year 2018 - 2023 reveals that, most of the parameters are within the standards prescribed by the Board except the exceedance of TSS (2/53), TDS (3/53),BOD (2/53).

ANNEXURE 10**CONSOLIDATED ROA OF STACK EMISSION SURVEY CONDUCTED
AT M/S. NEYVELI THERMAL POWER STATION II FOR YEAR 2018-2023**

Parameters		PM		SO ₂		NO _x	
Standards		100		600		600	
Year		Min.	Max.	Min.	Max.	Min.	Max.
2018-19	1 st Half year	62	138	3728	3737	120	650
	2 nd Half year	102	132	3518	3759	610	652
2019-20	1 st Half year	52	56	3210	3799	133	134
	2 nd Half year	108	138	3539	3790	614	640
2020-21	1 st Half year	52	80	2380	2851	191	260
	2 nd Half year	48	56	1641	2714	163	714
2021-22	1 st Half year	46	56	2253	3078	265	310
	2 nd Half year	20	65	645	1442	90	215
2022-23	1 st Half year	104	120	2512	2528	464	478
	2 nd Half year	55	58	1442	1448	476	478

Inference: Consolidated ROA of the Stack emission survey in the year 2018-2023 reveals that PM 4 /10 NO_x 4/10 and SO_x (10/10).

ANNEXURE 11**CONSOLIDATED ROA OF THE AMBIENT AIR QUALITY MONITORING SURVEY
CONDUCTED AT M/S. NEYVELI THERMAL POWER STATION II FOR
YEAR 2018-2023**

Parameters		PM10		PM2.5		SO2		NOx	
Standards		100		60		80		80	
Year		Min.	Max.	Min.	Max.	Min.	Max.	Min.	Max.
2018-19	1 st Half year	56	108	20	64	52	86	56	90
	2 nd Half year	54	112	56	62	46	84	52	88
2019-20	1 st Half year	95	124	44	78	68	89	72	95
	2 nd Half year	85	112	45	80	56	86	60	90
2020-21	1 st Half year	88	95	52	56	20	26	16	21
	2 nd Half year	89	97	55	59	23	29	18	24
2021-22	1 st Half year	82	129	49	57	18	23	21	28
	2 nd Half year	68	124	51	62	17	29	18	31
2022-23	1 st Half year	50	88	32	48	40	68	44	68
	2 nd Half year	44	80	32	48	40	68	42	70

Inference: Ambient Air Quality Survey was conducted at six locations inside and outside of the thermal power station. The minimum and maximum value at particular location is given above. Consolidated ROA of the AAQ survey in the year 2018-2023 reveals that all the parameters are within the standards prescribed by the Board except the exceedance of PM₁₀ (6/10) PM_{2.5} (5/10) Sox (4/10) and NOx (4/10)

ANNEXURE 12**CONSOLIDATED ROA OF TREATED SEWAGE FROM M/S. NEYVELI THERMAL
POWER STATION II EXPANSION FOR THE YEAR 2018-23**

NLC Limited Thermal Power Station II						
Outlet of Sewage Treatment Plant						
S.No.	Month	pH	TSS	BOD	COD	Ammonical Nitrogen (NH₃-N)
1	Apr-18	7.87	8	8	32	10.65
2	May-18	7.86	6	8	45	<MDL
3	Jun-18	8.32	8	4	16	<MDL
4	Jul-18	8.36	10	6	16	7.28
5	Aug-18	7.98	10	16	64	12.59
6	Sep-18	7.96	8	18	32	10.09
7	Oct-18	7.64	12	8	28	10.09
8	Nov-18	8.02	8	12	32	10.09
9	Dec-18	8.01	12	12	64	12.33
10	Jan-19	7.74	8	16	32	6.72
11	Feb-19	7.79	8	6	16	8.4
12	Mar-19	7.89	6	8	32	6.72
13	Apr-19	7.59	6	12	32	10.09
14	May-19	7.23	8	12	32	8.4
15	Jun-19	7.69	6	4	16	6.72
16	Jul-19	7.7	8	18	64	12.33
17	Aug-19	7.26	8	12	32	8.4
18	Sep-19	7.45	8	8	32	8.4
19	Oct-19	8.78	18	20	80	10.09
20	Nov-19	8.85	12	18	72	8.96
21	May-20	7.99	12	18	48	8.48
22	Jun-20	7.55	12	14	64	8.4
23	Jul-20	7.63	14	18	72	8.4
24	Aug-20	7.07	14	16	64	6.72
25	Oct-20	8.36	16	20	52	8.4
26	Nov-20	7.71	14	18	52	4.48
27	Apr-21	7.22	10	16	48	<MDL
28	Jun-21	7.08	14	18	48	<MDL
29	Jul-21	6.22	10	16	44	<MDL
30	Aug-21	7.28	10	16	44	<MDL
31	Sep-21	8.1	12	14	44	<MDL
32	Oct-21	7.27	10	16	40	<MDL
33	Nov-21	7.16	10	16	44	<MDL
34	Jan-22	6.86	18	20	56	<MDL

35	Feb-22	7.5	18	22	80	6.72
36	Mar-22	7.62	14	18	48	<MDL
37	Apr-22	7.73	10	16	44	<MDL
38	May-22	7.12	16	18	48	<MDL
39	Jun-22	4.29	8	4	8	6.72
40	Jul-22	8.4	18	24	88	7.84
41	Aug-22	7.68	12	12	64	7.24
42	Sep-22	8.18	16	48	64	4.48
43	Oct-22	6.99	24	3.8	16	<MDL
44	Nov-22	6.7	18	8	32	3.92
45	Dec-22	7.63	8	8	32	4.48
46	Jan-23	7.84	8	12	64	3.92
47	Feb-23	8.45	18	16	40	3.92
48	Mar-23	8.6	6	4	72	5.6
Standards for STP		5.5-9.0	30	20	100	15

Inference: *The consolidated ROA of the treated sewage samples collected for the year 2018-2023 from the outlet of the STP reveals that most of the parameters are within the standards prescribed by the Board except the exceedance of pH 1/48 and BOD (3/48).*

ANNEXURE 13
CONSOLIDATED ROA OF EFFLUENT TREATMENT PLANT OF
M/S. NLC INDIA LTD – TPS II EXP FOR THE YEAR 2019 – 2023

Sl. No	MONTH	pH	TSS	TDS	Chlorides	Sulphates	Oil & Grease	BOD	COD	% Sodium
1.	FEB-19	7.63	8	1524	610	252	2	8	32	12.37
2.	MAR-19	7.88	8	2230	655	252	2	12	64	8.95
3.	APR-19	7.73	8	1964	415	218	2	18	64	8.14
4.	MAY-19	6.78	8	518	145	68	2	8	32	9.11
5.	JUN-19	7.8	8	2022	610	220	2	18	40	8.14
6.	JUL-19	6.83	8	534	155	62	2	12	32	8.14
7.	AUG-19	6.63	8	1892	620	240	2	18	64	8.14
8.	SEP-19	7.84	8	776	205	102	2	8	32	8.14
9.	OCT-19	8.61	8	1942	505	252	<MDL	16	64	8.14
10.	NOV-19	8.41	10	1982	695	302	<MDL	18	80	6.16
11.	MAY-20	7.95	14	1982	610	312	2	24	112	13.16
12.	JUN-20	7.63	14	1950	555	284	<MDL	22	108	10.62
13.	AUG-20	6.34	18	2982	610	422	<MDL	22	104	10.1
14.	SEP-20	8.68	20	1814	460	252	<MDL	26	104	8.14
15.	OCT-20	8.64	20	1860	510	252	2	24	108	11.64
16.	NOV-20	7.85	20	1930	705	302	<MDL	26	116	9.61
17.	JAN-21	7.85	10	2160	705	362	-	28	164	6.34
18.	FEB-21	8.12	18	1670	455	252	-	24	104	10.43
19.	APR-21	8.23	18	2768	825	402	-	28	108	9.5
20.	JUN-21	6.98	18	1938	610	328	-	28	124	10.43
21.	JUL-21	7.38	22	2098	635	318	-	28	124	10.43
22.	SEP-21	8.25	16	1942	450	204	-	26	112	10.02
23.	OCT-21	7.69	22	1528	505	202	-	26	108	20.02
24.	NOV-21	7.91	22	1942	555	250	-	26	116	10.02
25.	APR-22	7.83	18	1004	350	190	-	20	92	10.02
26.	MAY-22	8.25	14	236	80	44	-	18	48	
27.	JUN-22	8.01	4	1075	723.1	152	-	16	64	11.78
28.	JUL-22	8.12	10	648	230	109	-	10	40	3.61
29.	AUG-22	8.27	8	76	40	8	-	8	32	2.45
30.	SEP-22	8.16	26	838	744	16	-	28	96	1.2
31.	OCT-22	7.06	28	620	244	92	-	12	40	9.59
32.	NOV-22	8.3	8	6.72	10.09	-	-	8	32	
33.	DEC-22	7.9	8	1568	870	112	-	26	114	16.03
TNPCB NORMS		5.5-9.0	100	2100	1000	1000	10	30	250	

Inference: ROA of the treated trade effluent samples collected for the year 2019-2023 collected from the outlet of ETP and it reveals that, most of the parameters are within the standards prescribed by the Board except the exceedance of - TDS (4/33).

ANNEXURE14

CONSOLIDATED ROA OF STACK EMISSION SURVEY CONDUCTED
M/S. NEYVELI THERMAL POWER STATION II EXP FOR YEAR 2018-2023

Parameters		PM		SO2		NOx	
Standards		50		600		450	
Year		Min.	Max.	Min.	Max.	Min.	Max.
2018-19	1 st Half year	42	-	544	-	101	-
	2 nd Half year	41	-	537	-	102	-
2019-20	1 st Half year	35	36	520	531	94	94
	2 nd Half year	38	-	528	-	122	-
2020-21	1 st Half year	34	36	513	522	85	90
	2 nd Half year	36	38	518	531	188	192
2021-22	1 st Half year	39	40	2338	2719	154	175
	2 nd Half year	30	32	348	359	194	197
2022-23	1 st Half year	37	-	741	-	110	-

Inference: ROA of the Stack emission survey in the year 2018-2023 reveals that all the parameters are within the limit prescribed standard except Sox (1/10).

ANNEXURE – 15**CONSOLIDATED ROA OF THE AMBIENT AIR QUALITY MONITORING SURVEY
CONDUCTED AT M/S. NLC INDIA LTD, TPS II EXPANSION FOR THE YEAR
2018 – 2023**

Parameters		PM10		PM2.5		SO2		NOx	
Standards		100		60		80		80	
Year		Min.	Max.	Min.	Max.	Min.	Max.	Min.	Max.
2018-19	1 st Half year	52	80	24	58	48	70	54	78
2019-20	1 st Half year	76	112	43	68	57	86	64	91
	2 nd Half year	70	98	40	58	56	76	60	78
2020-21	1 st Half year	88	94	57	59	46	58	21	33
	2 nd Half year	91	98	52	56	12	26	11	19
2021-22	1 st Half year	72	148	36	42	17	31	19	26
	2 nd Half year	68	124	51	62	17	29	18	31
2022-23	1 st Half year	48	74	32	46	12	19	15	22
	2 nd Half year	45	72	38	48	24	40	26	42

Inference :Ambient Air Quality was conducted at six locations inside and outside of the unit TPS II EXP. The minimum and Maximum value at particular locations are given above. ROA of the AAQ survey in the year 2018-2023 reveals that PM₁₀,(3/10) PM_{2.5} (2/10) Sox(1/10) and Nox(1/10).

ANNEXURE – 16**CONSOLIDATED ROA OF TREATED SEWAGE FROM M/S. NLC INDIA LTD.
TPS – 1 EXPANSION FOR THE YEAR 2018 – 2023**

NLC LIMITED TPS- 1 EXPANSION – OUTLET OF SEWAGE TREATMENT PLANT						
S.No	MONTH	pH	TSS	BOD	COD	Ammonical Nitrogen
1.	Apr-18	7.04	4	4	16	5.04
2.	May-18	7.26	6	4	16	<MDL
3.	June-18	7.64	8	6	64	<MDL
4.	July-18	7.78	6	6	32	12.89
5.	Aug-18	7.14	6	8	32	<MDL
6.	Sep-18	7.78	4	4	16	6.72
7.	Oct-18	7.91	10	8	32	4.48
8.	Nov-18	6.83	6	8	32	6.72
9.	Dec-18	7.81	8	8	32	6.72
10.	Jan-19	7.46	4	4	16	5.04
11.	Feb-19	7.97	4	4	16	4.48
12.	Mar-19	7.29	6	8	32	5.04
13.	Apr-19	7.42	4	2	8	4.48
14.	May-19	7.19	6	4	16	6.72
15.	Jun-19	7.76	4	6	16	5.04
16.	Jul-19	7.23	6	8	32	6.72
17.	Aug-19	7.06	6	4	16	6.72
18.	Sep-19	7.65	8	4	32	8.4
19.	Oct-19	8.82	8	8	32	6.72
20.	Nov-19	7.36	22	24	100	8.4
21.	Dec-19	8.49	20	16	64	6.16
22.	Jan-20	7.82	14	22	88	8.4
23.	Feb-20	6.29	12	24	104	12.33
24.	Apr-20	7.86	14	18	80	8.4
25.	May-20	6.38	10	6	32	5.04
26.	Jun-20	7.48	12	18	60	8.4
27.	Jul-20	8.37	12	14	32	6.72
28.	Aug-20	8.11	12	18	48	8.96
29.	Oct-20	8.5	10	8	32	3.98
30.	Nov-20	8.98	12	18	56	6.16
31.	Dec-20	8.38	12	18	44	4.48
32.	Jan-21	7.14	14	18	52	5.04
33.	Feb-21	7.86	10	18	48	4.48
34.	Apr-21	7.22	10	16	48	<MDL
35.	Jun-21	7.08	14	18	48	<MDL
36.	July-21	6.22	10	16	44	<MDL
37.	Aug-21	7.28	10	16	44	<MDL

38.	Sep-21	8.1	12	14	44	<MDL
39.	Oct-21	7.27	10	16	40	<MDL
40.	Nov-21	7.16	10	16	44	<MDL
41.	Jan-22	6.86	18	20	56	<MDL
42.	Feb-22	7.5	18	22	80	6.72
43.	Mar-22	7.62	14	18	48	<MDL
44.	Apr-22	7.73	10	16	44	<MDL
45.	May-22	7.12	16	18	48	<MDL
46.	Jun-22	4.29	8	4	8	6.72
47.	July-22	8.4	18	24	88	7.84
48.	Aug-22	7.68	12	12	64	7.24
49.	Sep-22	8.18	16	48	64	4.48
50.	Oct-22	6.99	24	3.8	16	<MDL
51.	Nov-22	6.7	18	8	32	3.92
52.	Dec-22	7.63	8	8	32	4.48
53.	Jan-23	7.84	8	12	64	3.92
54.	Feb-23	8.45	18	16	40	3.92
55.	Mar-23	8.6	6	4	72	5.6
	standards	5.5-9.0	30	20	100	15

Inference : ROA of the treated sewage samples collected for the year 2018-2023 from the outlet of the STP and it reveals that most of the parameters are within the standards prescribed by the Board except the exceedance of - pH (1/55), BOD (6/55) and COD (1/55).

ANNEXURE 17**CONSOLIDATED ROA OF TREATED EFFLUENT FROM M/S. NEYVELI
THERMAL POWER STATION - I EXPANSION FROM THE YEAR 2018-23****NLC Thermal Power Station I Expansion – Outlet of Effluent Treatment Plant**

S.No	MONTH	pH	TSS	TDS	Chlorides	Sulphates	Oil&Grease	BOD	COD	% Sodium
1	Apr-18	7.73	12	352	105	58	2	16	64	9.59
2	May-18	7.35	8	296	120	86	<MDL	4	16	16.03
3	Jun-18	7.81	36	1818	718	360	4	26	148	62.98
4	Jul-18	7.82	12	266	33	47	<1	6	28	–
5	Aug-18	7.76	12	788	215	320	2	26	144	10.1
6	Sep-18	7.52	8	890	335	152	2	6	32	8.14
7	Oct-18	7.84	14	280	110	32	2	8	32	6.69
8	Nov-18	7.83	8	830	305	112	2	14	56	4.68
9	Dec-18	7.82	10	230	115	60	2	8	32	10.62
10	Jan-19	7.53	8	618	255	128	2	12	32	8.95
11	Feb-19	7.92	6	620	265	132	2	16	60	8.14
12	Mar-19	7.65	6	992	355	68	2	8	32	6.78
13	Apr-19	7.61	8	930	250	116	2	8	32	10.1
14	May-19	7.88	8	540	145	68	2	16	32	8.14
15	Jun-19	8.03	8	398	105	52	2	16	32	6.16
16	Jul-19	7.6	8	622	245	120	2	8	32	6.78
17	Aug-19	7.86	8	90	12	8	2	8	16	10.1
18	Sep-19	7.49	8	1142	390	128	2	16	64	8.14
19	Oct-19	8.47	14	516	135	52	2	16	64	8.14
20	Nov-19	7.56	8	3602	995	602	<MDL	20	80	6.34
21	Dec-19	7.5	12	1246	505	172	<MDL	18	72	8.99

22	Jan-20	8.03	12	522	155	62	<MDL	20	84	8.14
23	Feb-20	6.19	16	176	55	22	<MDL	8	40	6.78
24	May-20	7.84	12	106	40	22	<MDL	8	32	6.78
25	Jun-20	6.07	10	82	35	22	<MDL	8	32	6.78
26	Jul-20	6.35	10	130	40	22	<MDL	8	32	4.12
27	Aug-20	8.38	10	438	155	92	<MDL	14	72	6.78
28	Sep-20	8.72	14	556	205	102	<MDL	18	72	6.78
29	Oct-20	8.21	18	2758	685	362	<MDL	20	88	8.99
30	Nov-20	9.24	14	226	85	48	<MDL	16	52	5.61
31	Dec-20	7.04	10	168	65	42	<MDL	18	64	4.12
32	Jan-21	7.81	16	542	195	122	<MDL	20	80	6.34
33	Feb-21	7.4	12	676	225	128	<MDL	22	96	6.16
34	Apr-21	6.16	14	726	245	122	–	20	88	8.99
35	Jun-21	7.29	18	794	265	110	–	22	96	8.99
36	Jul-21	6.34	14	698	205	102	–	22	88	8.99
37	Aug-21	7.35	18	716	200	102	–	22	88	7.75
38	Sep-21	7.98	18	658	210	102	–	24	104	8.99
39	Oct-21	6.93	16	812	255	116	–	20	88	26.16
40	Nov-21	6.66	18	680	205	102	–	20	80	5.34
41	Jan-22	7.17	12	–	–	–	–	18	44	–
42	Feb-22	7.79	16	–	–	–	–	20	64	5.04
43	Mar-22	7.97	20	1146	365	204	–	20	104	6.16
44	Apr-22	7.56	14	1018	305	204	–	24	108	8.99
45	May-22	7.18	14	256	90	52	–	16	44	–
46	Jun-22	4.51	12	206	70.9	18	–	10	40	5.17
47	Jul-22	8.84	10	220	80	39	–	10	24	2.68

48	Aug-22	7.78	24	148	65	12	–	8	32	5.47
49	Sep-22	7.57	12	188	75	18	–	24	88	0.13
50	Oct-22	8.18	16	318	126	48	–	6.8	24	10.2
51	Nov-22	7.93	12	112	75	28	–	8	16	4.68
52	Dec-22	6.58	32	496	160	68	–	8	32	4.68
53	Jan-23	6.85	18	442	250	68	–	20	80	12.37
54	Feb-23	7.69	10	520	260	62	–	10.6	40	6.69
55	Mar-23	7.1	8	380	195	60	–	5.6	56	9.08
Standards for ETP		5.5-9.0	100	2100	1000	1000	10	30	250	-

Inference:ROA of the treated trade effluent samples collected for the year 2018 - 2023 reveals that, most of the parameters are within the standards prescribed by the Board except the exceedance of pH (1/55), TDS (1/55).

ANNEXURE 18**CONSOLIDATED ROA OF STACK EMISSION SURVEY CONDUCTED
AT M/S. NEYVELI THERMAL POWER STATION I EXPANSION FOR
YEAR 2018-2023**

Parameters		PM		SO2		NOx	
Standards		100		600		600	
Year		Min.	Max.	Min.	Max.	Min.	Max.
2018-19	1 st Half year	102	–	2866	–	540	–
	2 nd Half year	104	–	3803	–	544	–
2019-20	1 st Half year	84	–	2842	–	484	–
	2 nd Half year	106	–	2945	–	618	–
2020-21	1 st Half year	60	66	1704	2104	291	356
	2 nd Half year	52	54	516	536	264	267
2021-22	1 st Half year	64	66	2102	2115	293	297
	2 nd Half year	28	70	2442	2844	70	131
2022-23	1 st Half year	97	98	2500	2512	408	472
	2 nd Half year	52	–	1433	–	400	–

Inference: ROA of the Stack emission survey in the year 2018-2023 reveals that PM(2/10) , NOx (1/10) 618 mg/Nm³ and SOx 3 (7/10)

ANNEXURE 19**CONSOLIDATED ROA OF THE AMBIENT AIR QUALITY MONITORING SURVEY
CONDUCTED AT M/S. NLC INDIA LTD., TPS I EXPANSION****FOR THE YEAR 2018-23**

Parameters		PM10		PM2.5		SO2		NOx	
Standards		100		60		80		80	
Year		Min.	Max.	Min.	Max.	Min.	Max.	Min.	Max.
2018-19	1 st Half year	54	110	38	80	40	60	46	64
	2 nd Half year	72	118	58	66	42	64	48	68
2019-20	1 st Half year	72	122	42	84	54	88	57	92
	2 nd Half year	74	118	40	82	58	85	62	90
2020-21	1 st Half year	94	98	55	58	22	28	18	22
	2 nd Half year	92	98	58	59	23	29	18	25
2021-22	1 st Half year	91	126	58	78	13	23	15	28
	2 nd Half year	81	148	56	122	14	25	16	27
2022-23	1 st Half year	58	70	32	52	14	20	16	22
	2 nd Half year	48	79	46	53	28	38	30	40

Inference: Ambient Air Quality Survey was conducted at six locations inside and outside of the unit TPS I expansion. The minimum and maximum value at particular location is given above. Consolidated ROA of the Ambient Air Quality Monitoring survey in the year 2018-2023 all the parameters are within the standards prescribed by the Board except the exceedance of – PM 10 (4/10) PM 2.5 (6/10) SOx (2/10) and NOx (2/10)

ANNEXURE 20**CONSOLIDATED ROA OF TREATED SEWAGE FROM M/S. NEYVELI NEW
THERMAL POWER STATION FOR THE YEAR DEC 2020-MAR 2023**

NEYVELI NEW THERMAL POWER STATION Outlet of Sewage Treatment Plant						
S.No.	Month	pH	TSS	BOD	COD	Ammonical Nitrogen (NH₃-N)
1	Dec-20	8.82	10	16	52	3.92
2	Nov-20	7.09	14	18	48	5.6
3	Jan-21	6.94	12	18	48	4.48
4	Feb-21	8.12	12	18	48	5.54
5	Mar-21	7.91	10	16	44	<MDL
6	Mar-21	7.08	16	18	48	5.04
7	Apr-21	7.57	12	18	48	<MDL
8	Jun-21	7.59	14	18	44	<MDL
9	Jul-21	6.4	12	18	44	<MDL
10	Aug-21	7.35	12	18	48	<MDL
11	Sep-21	8.14	12	18	48	<MDL
12	Oct-21	7.57	12	18	44	4.48
13	Nov-21	7.43	12	18	44	<MDL
14	Dec-21	7.32	14	16	40	<MDL
15	Jan-22	7.5	16	18	48	<MDL
16	Mar-22	7.87	12	18	44	<MDL
17	Apr-22	7.86	12	16	44	<MDL
18	May-22	7.9	10	18	44	<MDL
19	Jun-22	4.63	8	2	8	5.04
20	Jul-22	8.36	12	26	80	7.28
21	Aug-22	8.19	12	8	32	2.8
22	Sep-22	8	14	20	48	<MDL
23	Oct-22	7.53	10	21	72	<MDL
24	Nov'22	8.06	12	8	32	4.48
25	Dec-22	7.5	12	12	32	12.89
26	Jan-23	7.32	12	14	64	6.72
27	Feb-23	7.76	10	10.6	32	3.92
28	Mar-23	7.39	6	4.2	24	<2
Standards for STP		5.5-9.0	30	20	100	15

Inference:ROA of the treated sewage samples collected for the year December 2020-2021, 2021-2022 and 2022 -2023 from the outlet of the STP reveals that most of the parameters are within the standards prescribed by the Board except the exceedance of - pH (1/31) and BOD (1/31).

ANNEXURE 21

CONSOLIDATED ROA OF TREATED EFFLUENT
FROM M/S. NEYVELI NEW THERMAL POWER STATION FROM THE YEAR
SEP 2020- MARCH 2023

NEYVELI NEW THERMAL POWER STATION– Outlet of Effluent Treatment Plant									
S.No.	Month	pH	TSS	TDS	Chlorides	Sulphates	BOD	COD	% Sodium
1	Sep'20	8.3	18	1368	495	222	22	88	-
2	Oct'20	9.28	18	1678	450	262	24	104	10.62
3	Nov'20	8.39	24	2770	655	316	24	112	10.43
4	Dec'20	8.58	18	2384	610	318	26	116	10.43
5	Jan'21	8.58	20	2872	805	402	24	96	7.75
6	Feb'21	9.44	22	2580	625	326	26	116	10.43
7	Mar'21	8.4	18	2308	855	532	24	108	8.99
8	April'21	7.62	20	2334	725	328	28	116	10.02
9	June'21	6.24	22	2120	725	326	28	116	9.61
10	Jul'21	8.16	20	2034	625	322	26	116	9.61
11	Aug'21	3.26	22	4908	1050	602	28	136	10.02
12	Sep'21	8.33	22	1860	605	302	28	124	11.64
13	Oct'21	7.65	20	1436	455	242	24	116	29.5
14	Nov'21	7.07	22	1456	525	210	26	124	10.1
15	Dec-21	3.2	18	1324	455	220	24	112	7.75
16	Jan-22	3.82	18	1066	325	182	24	108	8.99
17	Mar-22	7.51	16	842	325	122	20	80	6.34
18	Apr-22	8	18	1580	495	252	24	112	10.1
19	May-22	8.42	12	362	105	68	20	64	-
20	Jun-22	5.04	8	521	326	110	12	48	18.97
21	Jul-22	8.74	12	104	35	19.4	6	24	5.69
22	Aug-22	7.83	18	712	510	218	28	8	6.26

23	Sep-22	8.37	18	570	320	136	16	48	1.2
24	Oct-22	8.13	14	416	168	56	23	80	11.64
25	Nov'22	7.22	18	424	120	80	18	72	15.45
26	Dec-22	6.99	18	980	465	118	28	176	16.03
27	Jan-23	7.13	12	1332	675	230	18	80	9.59
28	Feb-23	8.29	12	612	305	85	8	32	14.09
29	Mar-23	8.6	12	510	245	65	5.2	56	12.19
Standards for ETP		5.5-9.0	100	2100	1000	1000	30	250	-

Inference:ROA of the treated trade effluent samples collected for the year September 2020-2021, 2021-2022 and 2022 -2023 collected from the outlet of ETP reveals that most of the parameters are within the standards prescribed by the Board except the exceedance of - pH (6/32), TDS 8/32 chloride (1/32).

ANNEXURE 22**CONSOLIDATED ROA OF STACK EMISSION SURVEY CONDUCTED****M/S. NEYVELI NEW THERMAL POWER STATION FOR THE YEAR 2020-2023**

Parameters		PM		SO2		NOx	
Standards		30		100		100	
Year		Min.	Max.	Min.	Max.	Min.	Max.
2020-21	1 st Half year	28	-	673	-	255	-
	2 nd Half year	39	46	592	681	258	283
2021-22	1 st Half year	39	48	1497	1499	142	146
	2 nd Half year	42	49	1507	1518	233	239
2022-23	1 st Half year	56	-	1480	-	432	-
	2 nd Half year	52	-	1348	-	488	-

Inference:ROA of the Stack emission survey in the year 2020-2023 reveals that the following parameters are exceedance the standards PM (5/6) , SOX (6/6) and NOx (6/6)

ANNEXURE 23

CONSOLIDATED ROA OF THE AMBIENT AIR QUALITY MONITORING SURVEY
CONDUCTED AT M/S. NEYVELI NEW THERMAL POWER STATION
FOR THE YEAR 2020-23

Parameters		PM10		PM2.5		SO2		NOx	
Standards		100		60		80		80	
Year		Min.	Max.	Min.	Max.	Min.	Max.	Min.	Max.
2020-21	1 st Half year	85	96	54	57	19	30	16	25
	2 nd Half year	74	96	42	49	12	26	12	38
2021-22	1 st Half year	87	129	32	46	12	22	15	26
	2 nd Half year	46	144	50	118	12	20	15	24
2022-23	1 st Half year	42	68	26	32	08	42	12	48
	2 nd Half year	52	74	40	48	30	38	34	40

Inference:ROA of the AAQ survey in the year 2020-2021, 2021 - 2022 and 2022-2023 reveals that all the parameters are within the standards prescribed by the Board except the exceedance of - PM₁₀ (2/6)

ANNEXURE 24**CONSOLIDATED ROA OF TREATED SEWAGE FROM M/S. NLC INDIA LTD
MODERN SEWAGE TREATMENT PLANT FOR THE YEAR 2018-2023**

Outlet of Sewage Treatment Plant					
S.No.	Month	pH	TSS	BOD	COD
1	May-18	6.67	36	18	96
2	Jun-18	7.4	8	4	16
3	Jul-18	7.45	12	8	32
4	Aug-18	7.34	12	18	72
5	Sep-18	8.08	8	22	84
6	Oct-18	6.65	12	16	64
7	Nov-18	7.71	18	40	184
8	Dec-18	7.8	12	26	104
9	Jan-19	7.32	8	16	32
10	Feb-19	7.72	8	16	64
11	Mar-19	7.85	4	4	12
12	Apr-19	7.39	6	4	16
13	May-19	6.33	8	12	32
14	June-19	7.29	8	12	32
15	July-19	7.34	8	28	112
16	Aug-19	7.64	8	30	104
17	Sep-19	8.17	12	26	104
18	Oct-19	8.79	12	10	40
19	Nov-19	8.23	14	26	104
20	Dec-19	8.14	20	42	172
21	Jan-20	7.72	12	24	96
22	Feb-20	6.75	20	24	116
23	Mar-20	6.98	18	20	80

Outlet of Sewage Treatment Plant					
S.No.	Month	pH	TSS	BOD	COD
24	May-20	7.49	12	14	64
25	Jun-20	6.78	12	10	48
26	July-20	7.12	12	14	64
27	Aug-20	6.86	14	18	48
28	Sep-20	7.75	14	20	72
29	Oct-20	8.28	10	18	48
31	Dec-20	7.47	12	18	44
33	Jan-21	7.76	18	20	52
34	Feb-21	7.6	8	16	44
35	Apr-21	7.24	12.00	18.00	44.00
36	Jun-21	8.01	12.00	16.00	44.00
37	Jul-21	6.14	8.00	16.00	40.00
38	Aug-21	7.59	12.00	18.00	44.00
39	Sep-21	8.39	10.00	16.00	44.00
40	Oct-21	7.19	12.00	18.00	44.00
41	Nov-21	6.95	8.00	10.00	44.00
42	Dec-21	7	12	18	44
43	Jan-22	8	12	16	44
44	Feb-22	8	12	18	44
45	Mar-22	8	12	16	44
46	Apr-22	7.83	14.00	18.00	44.00
47	Jun-22	7.97	10.00	8.00	16.00
48	Jul-22	7.92	12.00	28.00	72.00
49	Aug-22	6.91	10.00	14.00	64.00
50	Sep-22	7.09	16.00	8.00	16.00
51	Oct-22	7.07	10.00	1.60	8.00

Outlet of Sewage Treatment Plant					
S.No.	Month	pH	TSS	BOD	COD
52	Nov-22	7.09	12.00	18.00	64.00
53	Dec-22	6.70	12.00	16.00	64.00
54	Jan-23	7.23	18.00	12.00	64.00
55	Feb-23	7.27	26.00	12.00	64.00
56	Mar-23	6.80	16.00	3.30	40.00
57	Apr-23	6.50	18.00	5.40	24.00
58	May-23	7.30	16.00	8.00	32.00
59	June-23	6.76	10.00	6.00	48.00
Standards for ETP		5.5-9.0	200	100	-

Inference: The ROA of the treated effluent samples collected for the year 2018 – 2019, 2019-2020, 2020-2021, 2021-2022 and 2022 -2023 from the outlet of the ETP reveals that the parameters were within the standards prescribed by the board.

ANNEXURE 25**CONSOLIDATED ROA OF TREATED SEWAGE FROM M/S. IL & FS TAMILNADU
POWER COMPANY LIMITED FOR THE YEAR 2018-23**

Outlet of Sewage Treatment Plant						
S.No.	Month	pH	TSS	BOD	COD	Ammonical Nitrogen (NH ₃ -N)
1.	June-2018	8.13	10	6	32	-
2.	July-2018	8.19	8	8	32	-
3.	Sep-2018	8.58	8	8	16	-
4.	Oct-2018	7.82	8	6	32	8.96
5.	Nov-2018	7.76	12	16	40	-
6.	Dec-2018	8.02	8	12	64	-
7.	Jan-2019	7.93	8	8	32	10.65
8.	Feb-2019	8.01	8	6	16	8.4
9.	Mar-2019	8.04	6	8	32	5.6
10.	Apr-2019	6.52	8	12	32	8.4
11.	May-2019	7.41	8	6	32	6.72
12.	June-2019	7.81	8	8	32	6.72
13.	July-2019	8.32	8	18	32	6.72
14.	Aug-2019	7.39	8	6	32	6.72
15.	Sep-2019	8.6	12	18	72	8.4
16.	Oct-2019	8.12	18	26	104	8.4
17.	Nov-2019	8.45	12	18	76	6.72
18.	Jan-2020	8.06	18	26	104	8.96
19.	Feb-2020	7.52	18	26	112	15.13
20.	Mar-2020	8.25	18	24	104	10.09
21.	May-2020	7.39	20	14	80	8.4
22.	June-2020	7.86	18	20	96	10.09
23.	July-2020	7.71	14	26	96	8.4
24.	Aug-2020	7.96	12	18	72	8.4
25.	Sep-2020	8.11	14	20	64	8.96
26.	Oct-2020	8.89	14	18	48	4.48
27.	Nov-2020	7.42	10	16	48	5.04
28.	Dec-2020	8.39	12	18	48	4.48
29.	Jan-2021	8.28	10	16	44	<MDL
30.	Feb-2021	7.43	10	18	48	4.48
31.	Mar-2021	8.34	12	18	44	<MDL
32.	June-2021	7.21	14	18	48	<MDL
33.	July-2021	7.54	14	20	52	4.48
34.	Sep-2021	6.8	14	20	56	4.48
35.	Oct-2021	7.59	14	18	48	<MDL
36.	Nov-2021	8.1	14	18	48	<MDL
37.	Dec-2021	8.24	14	20	56	5.04
38.	Jan-2022	7.42	14	18	48	<MDL

39.	Feb-2022	8.24	10	16	48	<MDL
40.	Mar-2022	6.84	14	18	48	<MDL
41.	Apr-2022	7.96	14	18	48	<MDL
42.	May-2022	8.3	20	20	96	-
43.	June-2022	8.4	14	6	32	<MDL
44.	July-2022	7.79	8	18	72	6.72
45.	Aug-2022	7.15	12	16	64	5.04
46.	Sep-2022	7.82	8	20	88	5.6
47.	Oct-2022	7.74	14	11	40	<MDL
48.	Nov-2022	7.68	8	16	64	<MDL
49.	Dec-2022	7.85	10	8	24	3.92
50.	Jan-2023	7.74	11	8.2	32	4.48
51.	Feb-2023	8.25	10	16.4	32	3.92
52.	Mar-2023	7.75	8	34	72	4.48
Standards for STP		5.5-9.0	30	20	100	15

Inference: The ROA of the treated sewage samples collected for the year 2018-2023 from the outlet of the STP outlet reveals that, mostly the parameters were within the standards prescribed by the Board except the exceedance of – BOD (6/52) COD (4/52) Nitrogen (1/52).

ANNEXURE 26**CONSOLIDATED ROA OF TREATED EFFLUENT FROM M/S. IL&FS TAMILNADU****POWER COMPANY LTD., FOR THE YEAR June-2018-2023**

M/S. IL & FS TAMIL NADU POWER COMPANY LTD.- Outlet of Effluent Treatment Plant										
S.No.	Month	pH	TSS	TDS	Chlorides	Sulphates	Oil&Grease	BOD	COD	Sulfide
1	Jun-2018	8.24	12	1112	418	160	<MDL	8	64	<MDL
2	Jul-2018	8.07	6	978	337	111	2	16	64	<MDL
3	Sep-2018	8.36	6	1574	630	210	<MDL	4	16	<MDL
4	Oct-2018	7.65	8	1728	415	130	<MDL	12	32	<MDL
5	Nov-2018	7.7	14	1210	520	172	<MDL	18	68	<MDL
6	Dec-2018	7.76	10	1078	415	216	2	8	32	<MDL
7	Jan-2019	8.21	10	898	350	128	2	10	40	<MDL
8	Feb-2019	8.26	6	1246	550	148	<MDL	8	28	<MDL
9	Mar-2019	7.83	12	1220	510	320	4	16	40	<MDL
10	Apr-2019	7.72	6	1240	350	12	<MDL	8	28	<MDL
11	May-2019	7.93	6	1248	610	220	<MDL	8	32	<MDL
12	Jun-2019	8.22	8	984	325	148	<MDL	14	52	<MDL
13	Jul-2019	7.01	10	1090	465	210	2	18	64	<MDL
14	Aug-2019	7.99	6	1606	960	552	<MDL	8	32	<MDL
15	Sep-2019	6.56	6	1056	405	102	<MDL	14	36	<MDL
16	Oct-2019	8.57	12	3400	980	602	<MDL	18	72	<MDL
17	Nov-2019	8.74	12	658	265	92	<MDL	22	92	<MDL
18	Jan-2020	8.18	16	748	255	112	<MDL	24	104	<MDL
19	Feb-2020	6.54	12	916	355	122	<MDL	24	108	<MDL
20	Mar-2020	8.16	14	1176	355	126	<MDL	22	84	<MDL
21	May-2020	7.74	14	938	280	118	<MDL	22	96	<MDL
22	Jun-2020	6.73	12	1318	405	202	<MDL	22	96	<MDL
23	Jul-2020	7.44	12	748	210	102	<MDL	16	72	<MDL
24	Aug-2020	3.19	12	1684	555	252	<MDL	20	96	<MDL
25	Sep-2020	7.76	14	766	305	122	<MDL	18	96	<MDL
26	Oct-2020	8.05	18	2034	795	312	<MDL	26	108	<MDL
27	Nov-2020	7.74	16	988	190	102	<MDL	22	84	<MDL
28	Dec-2020	6.9	18	1222	375	168	<MDL	22	96	<MDL
29	Jan-2021	7.26	12	470	210	126	-	20	80	-
30	Feb-2021	7.07	14	1178	355	218	-	20	72	<MDL
31	Mar-2021	7.96	20	1332	450	204	-	22	96	-
32	Jun-2021	6.59	16	886	255	136	-	20	80	-
33	Jul-2021	6.89	14	692	205	102	-	50	96	<MDL
34	Sep-2021	7.97	18	1030	220	124	-	20	80	-
35	Oct-2021	8.31	20	1128	400	202	-	20	80	<MDL
36	Nov-2021	7.62	16	952	325	120	-	20	80	<MDL
37	Dec-2021	8.21	20	1250	405	210	-	24	104	<MDL
38	Jan-2022	7.47	20	464	200	102	-	22	96	<MDL
39	Feb-2022	7.39	18	1008	315	162	-	20	80	<MDL

40	Mar-2022	6.59	16	902	305	142	-	20	88	<MDL
41	Apr-2022	7.71	14	348	150	102	-	22	96	<MDL
42	May-2022	7.67	18	488	165	102	-	20	92	<MDL
43	Jun-2022	7.01	12	726	205	102	-	6	16	<MDL
44	Jul-2022	5.06	10	382	115	55.9	-	20	96	3
45	Aug-2022	6.77	12	402	145	90	-	20	88	<MDL
46	Sep-2022	7.43	10	320	205	82	-	28	136	4.8
47	Oct-2022	7.73	22	182	70	24	-	18	64	5.12
48	Nov-2022	7.25	12	275	120	60	-	4	16	<MDL
49	Dec-2022	6.48	8	846	435	210	-	4	32	4.06
50	Jan-2023	7.36	12	574	255	116	2	18	64	<MDL
51	Feb-2023	6.87	12	98	50	12	-	14	40	<MDL
52	Mar-2023	6.51	14	280	150	52	-	14	40	<1
Standards for ETP		5.5-9.0	200	2100	600	1000	10	100	-	2

Inference:

Consolidated ROA of the treated trade effluent samples collected from the ETP outlet reveals that mostly the parameters were within the standards prescribed by the Board except the exceedance of – pH (2/52), TDS (1/52), Chloride (5/52), and sulfide (4/52).

ANNEXURE 27**CONSOLIDATED ROA OF STACK EMISSION SURVEY CONDUCTED AT M/S.
IL&FS TAMIL NADU POWER COMPANY LIMITED FOR THE YEAR 2018-2023**

Parameters		PM		SO2		NOx	
Standards		50		200		450	
Year		Min.	Max.	Min.	Max.	Min.	Max.
2018-19	1 st Half year	64	-	302	-	350	-
	2 nd Half year	60	62	224	230	352	354
2019-20	1 st Half year	56	62	232	243	257	268
	2 nd Half year	58	60	236	247	262	265
2020-21	1 st Half year	57	-	243	-	260	-
	2 nd Half year	40	42	164	185	265	271
2021-22	1 st Half year	52	-	182	-	375	-
	2 nd Half year	12	-	126	-	162	-
2022-23	1 st Half year	18	-	32	-	260	-
	2 nd Half year	14	-	36	-	212	-

Inference: Consolidated ROA of the Stack emission survey in the year 2018-2023 reveals that exceedance of – PM 10 (6/10)

ANNEXURE 28**CONSOLIDATED ROA OF THE AMBIENT AIR QUALITY MONITORING SURVEY
CONDUCTED AT M/S. IL&FS TAMILNADU POWER COMPANY FOR
YEAR 2018-2023**

Parameters		PM10		PM2.5		SO2		NOx	
Standards		100		60		80		80	
Year		Min.	Max.	Min.	Max.	Min.	Max.	Min.	Max.
2018-19	1 st Half year	64	114	34	82	36	98	40	102
	2 nd Half year	68	112	59	62	12	20	14	22
2019-20	1 st Half year	72	116	57	64	20	32	26	38
	2 nd Half year	78	114	46	68	22	34	26	38
2020-21	1 st Half year	75	108	43	66	18	30	22	35
	2 nd Half year	78	89	45	58	23	38	19	32
2021-22	1 st Half year	68	79	-	-	15	23	18	25
	2 nd Half year	17	24	10	12	12	18	14	21
2022-23	1 st Half year	40	72	38	56	14	28	16	30
	2 nd Half year	42	76	32	56	8	26	12	20

Inference: Ambient Air Quality Survey was conducted at six locations inside and outside of the Thermal power station. The minimum and maximum value at particular location is given above. Consolidated ROA of the Ambient Air Quality Monitoring survey in the year 2018-2023 reveals that all the parameters are within the standards prescribed by the Board except the exceedance of - PM₁₀ (4/10) range from 108-116 µg/m³, PM_{2.5} (5/10). In the range of 62-82 µg/m³.

Annexure - 29
DETAILS OF SAMPLES COLLECTED BY TNPCB IN NLC
ON 11.08.2023 AND 16.08.2023

Sample code No	Date and Time	Place, Latitude & Longitude	Type of Sample
1	11.08.2023 at 12.30 pm	Neyveli PCS Store Discharge – Surface water Lat : 11.596363 Lon: 79.465716	Surface water
2	11.08.2023 at 12.45 pm	Discharge from NNTPS - Surface water Lat : 11.579525 Lon: 79.461002	Surface water
3	11.08.2023 at 12.55 pm	Discharge from Neyveli TPS II - Surface water Lat : 11.561055 Lon: 79.452025	Surface water
4	11.08.2023 at 01.20 pm	Artificial Lake located at North side of TS-II, South side of NNTPS, west side of abandoned ash pond Lat : 11.56802 Lon: 79.44848	Surface water
5	11.08.2023 at 02.00 pm	Bore well water Located near OHT, Thandapani Koil Street, Kaikalarkuppam Lat : 11.595008 Lon: 79.446353	Ground Water
6	11.08.2023 at 4.40 pm	Opposite to Main Gate of Mine II – Kootu Kudineer Thittam near Valayamadevi – surface water Lat : 11.561003 Lon: 79.451945	surface water
7	11.08.2023 at 04.13 pm	Paravanar River Carrying NLC Mine-II Discharge – Surface water Lat : 11.572065 Lon: 79.517808	surface water
8	11.08.2023 at 05.22 pm	Walaja Lake Lat : 11.514743 Lon: 79.562468	surface water
9	11.08.2023 at 04.30 pm	NLC Supplied Water at U. Mangalam Tank Lat : 11.536934 Lon: 79.43294	surface water
10	11.08.2023 at 06.53 pm	Coal Mine Discharge from Mine –I – Surface water Lat : 11.58316 Lon: 79.467776	surface water
11	11.08.2023 at 03.58 pm	Direct Discharge from TPS-I – Surface water Lat : 11.590535 Lon: 79.478162	surface water
12	11.08.2023	Paddy field near NNTPS Stack	Soil Sample

	at 03.43 pm	Lat : 11.589198 Lon: 79.446201	
13	11.08.2023 at 05.36 pm	Romapuri,Mandarakupam – Vadakkuvellur – Surface water Lat : 11.538715 Lon: 79.458366	surface water
14	11.08.2023 at 04.50 pm	Vadakkuvellur Pond near Sivan Koil Lat : 11.549235 Lon: 79.459217	surface water
15	11.08.2023 at 04.58 pm	Vadakkuvellur Sugar cane field Lat : 11.547582 Lon: 79.457119	Soil Sample
16	11.08.2023 at 06.23 pm	Bore well Located at Vanadhirayapuram Village Lat : 11.51474 Lon: 79.56248	Ground water
17	11.08.2023 at 06.40 pm	Bore well water at Mariyamman Temple, Ayikuppam Village Lat : 11.617468 Lon: 79.664808	Ground water
18	11.08.2023 at 06.15 pm	Kanjamanadanpettai pond water Lat : 11.573015 Lon: 79.611106	Surface Water
19	11.08.2023 at 05.15 pm	Bore Well water at Block-22 Pump House(Jawahar College) Lat : 11.611015 Lon: 79.465224	Ground water
20	11.08.2023 at 05.45 pm	Mine –I Outlet at Veenangeni –Surface water Lat : 11.550328 Lon: 79.532898	Surface water
21	16.08.2023 at 1.48 PM	Agriculture land near Iyyan Lake Lat :11.554339° Long : 79.562573°	Soil Sample
22	16.08.2023 at 1.38 PM	Iyyan Lake Lat :11.557013° Long : 79.562686°	Surface water
23	16.08.2023 at 12.49 PM	Pallitheru, Vadakku Vellore Lat :11.5479011° Long : 79.464587°	Soil Sample
24	16.08.2023 at 12.41 PM	Tholkappiem Nagar Lat :11.5479011° Long : 79.4645875°	Surface Water
25	16.08.2023 at 12.26 PM	Muppaneri Lat :11.552566° Long : 79.459706°	Surface Water
26	16.08.2023	Vadakku Vellore By-pass	Soil Sample


	at 1.08 PM	Lat : 11.5464224° Long : 79.462478°	
27	16.08.2023 at 3.00 PM	TPS I expansion - Effluent outlet at the boundary of the plant Lat : 11.589242° Long : 79.469104°	Surface Water
28	16.08.2023 at 3.16 PM	Strom water drain (opp to TPS I exp RCC bunker) Lat : 11.589435° Long : 79.471444°	Surface Water
29	16.08.2023 at 3.30 PM	Discharge from TPS I exp at karuvetti village Lat : 11.573758° Long : 79.457836°	Surface Water
30	16.08.2023 at 3.50 PM	TPS II expansion - Strom water drain near STP & junction tower 5 Lat : 11.546642° Long : 79.450058°	Surface Water
31	16.08.2023 at 4.30 PM	MSTP Outflow & MINE I Seepage confluence point (to kanniyakoilodai) Lat : 11.601228° Long : 79.520014°	Surface Water
32	16.08.2023 at 05.00 PM	Mine I A Seepage discharge point to sengulam&anbarasankulam lake Lat: 11 deg 32'45.209 N Long : 79 deg 31' 4. 6084 E	Surface Water
33	16.08.2023 at 5.12 PM	Mine I A Seepage Discharge point into Ayan lake Lat : 11.516503° Long : 79.745177°	Surface Water
34	16.08.2023 at 5.45 PM	Mine I Seepage lake Lat : 11 deg 34' 59.7399 N Long : 79 deg 28' 46. 7760 E	Surface Water

M/S IL& FS TAMIL NADU POWER COMPANY LIMITED

Sample code No	Date and Time	Place, Latitude & Longitude	Type of Sample
1.	16.08.2023 at 9.53 AM	Karikuppam Village Lat: 11.515833° Long: 79.742616°	Groundwater
2.	16.08.2023 at 10.00 AM	Karikuppam Village Fish Pond Lat: 11.516401° Long: 79.74471°	Surface water
3.	16.08.2023 at 10.12 AM	Pudukuppam Village (Owner Mr. Vedhavan) Lat: 11.523577° Long: 79.762972°	Groundwater

4.	16.08.2023 at 10.16 AM	Pudukuppam Village- Pipe Water Lat: 11.525248° Long: 79.762342°	Piped water
5.	16.08.2023 at 10.43 AM	Canal near the Thermal Power Plant (Water Discharge from the plant time to time) Lat: 11.51545° Long: 79.740301°	Surface water
6.	16.08.2023 at 10.51 AM	Karikuppam village agricultural land near Thermal Power Plant Lat: 11.51955° Long: 79.743695°	Soil
7.	16.08.2023 at 11.00 AM	Karikuppam Panchayat union middle school Lat: 11.516482° Long: 79.745192°	Ground Water

PLAN SHOWING THE LOCATIONS OF WATER & SOIL SAMPLES COLLECTED BY TNPCB



Sources: Esri, HERE, Garmin, Intermap, increment P Corp., GEBCO, USGS, FAO, NPS, NRCAN, GeoBase, IGN, Kadaster NL, Ordnance Survey, Esri Japan, METI, Esri China (Hong Kong), © OpenStreetMap contributors, and the GIS User Community

Legend:

- TNPCB Samples Locations
- Mines & Thermal

Scale: 0 0.5 1 2 3 4 Kilometers

Annexure -30

Additional Sampling Locations proposed surrounding the NLCIL based on earlier EIA Study reports

Tube wells				
SI no	Well ID	Well Location	Latitude	Longitude
1	SAL-12	Rajakuppam	11.5415583	79.5776250
2	SAL-22	Madhanagopalapuram	11.6475900	79.6042017
3	MI/31A	TS-II Out side	11.5547069	79.4384814
4	X0/34	Block-3	11.6259700	79.5113717
5	CST-4	Block-15	11.6161033	79.4564633
6	Block-24	Block-24 (Near 8 road)	11.599025	79.502952
7	RO/13A	Block-7	11.6205517	79.4749533
8	MIII-48	Erumboor	11.460055	79.525113
9	HS-III/1	Kammapuram	11.4779217	79.4217417
10	HS-III/2A	Chinnakottumulai	11.4498667	79.4496683
11	HS-II/1	Arasakuzhi	11.5279850	79.3909467
12	NRO/13	Karunkuzhi	11.52255833	79.538765
Total No. of Tube Well samplings				12

Dug wells				
SI no	Well ID	Well Location	Latitude	Longitude
1	D-5	Block-28 Mariyamman koil	11.5961900	79.4735011
2	D-6	Block-9 Ragavendra koil	11.6131833	79.5077133
3	D-7	Vadakuthu	11.5999433	79.5510556
4	D-11	Vadalur Sabai	11.5482117	79.5460567
5	D-13	Karunkuzhi temple	11.5221667	79.5442500
6	D-16 A	Veppankurichi	11.5327283	79.4790017

7	D-18 A	Kunamkurichi Field	11.5484383	79.4354783
8	D-28	Pudukoorapettai	11.5228133	79.3586433
9	D-29	Veerasingakuppam	11.6553433	79.4701583
10	D-33	Arasakuzhi church	11.5237350	79.3923217
11	D-130	Kaikalaikuppam (Thandapani koil)	11.5950800	79.4489600
12	D-42	Melakuppam (chettiyar st)	11.5704558	79.4417133
Total No. of Dug Well samplings				12

**STATUS OF AFFORESTATION IN RECLAIMED AREA OF MINE I, M/S. NLC INDIA LTD.,
(as on Aug 2023) – PLATE – 1**

Mine Project area (Hectares)	Area mined out since inception till 2023 (Hectares)	Area Reclaimed since inception till 2023 (Hectares)	Total afforestation developed in Hectares	No. of Trees in approx.
3635.4	2484.6	1240.6	1100.15	1200000




Inference:

The afforestation in the reclaimed area of Mine I, NLC INDIA LIMITED has been well established, with the plants growing as a dense forest. The remaining accessible land could be used for further plantations.

**STATUS OF AFFORESTATION IN RECLAIMED AREA OF MINE IA, M/S. NLC INDIA LTD.,
(As on Aug 2023) – PLATE – 2**

Mine Project area (Hectares)	Area mined out since inception till 2023 (Hectares)	Area Reclaimed since inception till 2023 (Hectares)	Total afforestation developed in Hectares	No. of Trees in approx.
2005.8	778.1	360.69	298.78	135000



Inference:

Out of the 370 ha of total reclaimed area, 298 ha were planted with trees as part of the afforestation project. So, until sufficient development is achieved, plantations need to be improved along with adequate care. The unit may enhance and expand the green belt area for the benefit of the environment because there are surplus water and topsoil sources accessible for greater green belt development.

**STATUS OF AFFORESTATION IN RECLAIMED AREA OF MINE - II, M/S. NLC INDIA LTD.,
(As on Aug 2023) – PLATE – 3**

Mine Project area (Hectares)	Area mined out since inception till 2023 (Hectares)	Area Reclaimed since inception till 2023 (Hectares)	Total Greenbelt Developed in Hectares	No. of Trees in approx.
7193.975	2544.71	1171.9	896.7	1200000




Inference:

Out of the 1171 ha of total reclaimed area, 896 ha were planted with trees as part of the afforestation project. So, until sufficient development is achieved, plantations need to be improved along with adequate care. It is observed that an invasive plant species named *Acacia Auriculiformis* has spread over one third of reclaimed area of Mine II, NLC IL. It is an invasive species, native of Australia. This plant is harmful for the soil health through reduction of soil moisture, soil fertility, atmospheric moisture and undergrowth. It forms as monoculture eventually affects the Native Biodiversity of the area. This fast growing invasive plant displaces native vegetation and can shade out rare plants. Hence, the Mine II unit may take initiative to eradicate this invasive vegetation including *Acacia nilotica* and replanting with natural wild & fruit bearing species can be proceeded at the earliest so it can help to attract more birds.

**STATUS OF GREEN BELT DEVELOPMENT OF TPS - II, M/S. NLC INDIA LTD.,
(As on Aug 2023) – PLATE – 4**

As per EC Area Allotted (Hectares)	Actual Area acquired (Hectares)	Greenbelt Developed inside the unit
210	210	70,000




Inference:

Out of the 210 ha of total acquired area, approximately 140 ha area is utilized for power generation process, buildings and road transport etc. So, 70 ha of huge land area is available for green belt development. In which, green belt developmental progress has been done with approximately 70,000 trees and plants. This unit may enhance and expand the green belt because there are plenty of water, topsoil sources and land area available for green belt coverage.

**STATUS OF GREEN BELT DEVELOPMENT OF TPS – II EXPANSION, M/S. NLC INDIA LTD.,
(As on Aug 2023) – PLATE – 5**

As per EC Area Allotted (Hectares)	Actual Area acquired (Hectares)	Green belt Developed inside the unit
147	147	40,000




Inference:

Out of the 147 ha of total acquired area, approximately 117 ha area is utilized for power generation process, Lake, buildings and road transport etc. So, nearly 30 ha of actual land is available for green belt development. In which, green belt developmental progress has been done with approximately 40,000 trees and plants. In this location, more plantation cover need to be improved along with adequate care until sufficient plant growth is achieved for better green mass covering .

**STATUS OF GREEN BELT DEVELOPMENT OF TPS – I EXPANSION, M/S. NLC INDIA LTD.,
(As on Aug 2023) – PLATE – 6**

As per EC Area Allotted (Hectares)	Actual Area acquired (Hectares)	Green belt Developed inside the unit
40	40	2000




Inference:

Out of the 40 ha of total acquired area, approximately 35 ha area is utilized for power generation process, buildings and road transport etc. So, only 5 ha of actual land is available for green belt development. In which, greenbelt developmental progress has been done with approximately 2,000 plants. In this location, plantations need to be improved along with adequate care until sufficient development is achieved for better green mass.

STATUS OF GREEN BELT DEVELOPMENT OF NNTPS, M/S. NLC INDIA LTD.,
(As on Aug 2023) – PLATE – 7

As per EC Area Allotted (Hectares)	Actual Area acquired (Hectares)	Green belt Developed inside the unit
210	160	35,000



Inference:

Out of the 160 ha of total acquired area, approximately 100 ha area is utilized for power generation process, buildings and road transport etc. So, approximately 60 ha of actual land is available for green belt development. In which, greenbelt developmental progress has been done with approximately 35,000 trees and plants. The unit may improve and expand the green belt area for the benefit of the environment because there are surplus water, topsoil sources and land area available for green belt development.

Samples Collected by the TNPCB's Committee visit Plate - 8



Ground water Sample collected on 16.08.2023 @ Tholkappier Nagar nearer to M/s. NLC Limited



Surface water Sample collected on 16.08.2023 @ Iyyan Lake nearer to M/s. NLC Limited



Surface water Sample collected on 11.08.2023 @ River Paravanar nearer to M/s. NLC Limited.



Surface water Sample collected on 16.08.2023 @ River Paravanar nearer to M/s. NLC Limited Mine IA.



Soil sample collected on 11.08.2023 @ vadakkuvellur bypass nearer to M/s. NLC India Limited.



Soil sample collected on 11.08.2023 @ agricultural land nearer to Iyaan lake nearer to M/s. NLC India Limited.



Water sample collected on 16.08.2023 @ Karrikuppam Village Fish pond nearer to M/s. IL& FS Tamilnadu Power Company Limited.



Soil sample collected on 16.08.2023 @ Karrikuppam nearer to M/s. IL& FS Tamilnadu Power Company Limited.

**BEFORE THE HON'BLE NATIONAL
GREEN TRIBUNAL
SOUTHERN ZONE, CHENNAI**

Original Application No.107 of 2023 (SZ)

Suo Motu based on the news item published in The New Indian Express, dt. 09.08.2023, under the caption "Huge pollution risk in 8 Km around NLC" and in The Times of India, Chennai Edition dt. 09.08.2023 under the caption "Water near NLC full of Mercury".

Vs.

The Managing Director NLC India Limited,
Chennai and Ors.

...Respondents

**REPORT OF THE TAMIL NADU
POLLUTION CONTROL BOARD (5TH
RESPONDENT) AS PER THE ORDERS
OF THE HON'BLE NGT(SZ) DATED
10.08.2023.**

**Advocate for Respondent: TNPCB
Thiru.Sai Sathya Jith,
Advocate, Chennai.**

Date:25.08.2023.

Date of hearing on:28.08.2023.