

IN THE HON'BLE NATIONAL GREEN TRIBUNAL, NEW DELHI

O.A. No. 627 of 2022

IN THE MATTER OF:

Prakash Yadav

...Petitioner

Vs

State of Haryana and Others


...Respondents

INDEX

Sr. No.	Particulars	Page No.
1	ADDITIONAL REPLY ON BEHALF OF RESPONDENT NO.7 i.e. HARYANA SHEHRI VIKAS PRADHIKARAN	1-2
2	Annexure - A-I - The sample test report dated 11.08.2025 and 23.09.2025.	3-4
3	Annexure - A-II - The sample test report dated 13.10.2025.	5

Dated: 29.10.2025

Through



Rahul Khurana, Advocate
A-174 A, 2nd Floor, Defence Colony
New Delhi, 09811894060
rkhuranalegal@gmail.com

IN THE HON'BLE NATIONAL GREEN TRIBUNAL, NEW DELHI

IN THE MATTER OF:

O.A. No. 627 of 2022

Prakash Yadav

...Petitioner

Vs

State of Haryana and Others

...Respondents

ADDITIONAL REPLY ON BEHALF OF RESPONDENT NO.7 i.e.
HARYANA SHEHRI VIKAS PRADHIKARAN

MOST RESPECTFULLY SHOWETH:

1. That the present additional reply is being filed by Sh. Amit Rathee, Executive Engineer, Haryana Shehri Vikas Pradhikaran, Division Rewari for HSVP area in Dharuhera Town.
2. The disposal of HSVP, STP at Dharuhera, District Rewari is as per the norms. The testing of samples from STP under the jurisdiction of HSVP has conducted time to time. The sample test result reports from the Lab Universal Analytical Lab PVT. LTD. for the month of August and September 2025 are complying with the CPCB/HSPCB norms (the sample test report dated 11.08.2025 and 23.09.2025 are enclosed as **annexure - A-I**. The sample test result report from the Haryana State Pollution Control Board Laboratory for the month of September and October 2025 is complying with the CPCB/HSPCB norms (the sample test report dated 13.10.2025 is enclosed as **annexure - A-II**).

3. The existing HSVP STP capacity is 5.0 MLD. The detailed project report for upgradation of STP has been got prepared by the consultant. Now the same has been forwarded to higher authority for approval. The tender will be invited for the said work after the approval is received from higher authority.

In view of the submissions made herein above, it is humbly prayed that present additional reply may kindly be taken on record.

Place: Rewari
Dated:29.10.2025



Executive Engineer,
HSVP Division, Rewari



918 UNIVERSAL ANALYTICAL LAB PVT. LTD.

AN ISO 9001 CERTIFIED & GOVERNMENT APPROVED LABORATORY

Works : Plot.No. -77-77A, Khevat No. 222, Opposite HUDA Sector- 4A, Nagarpalika, Dharuhera-123106, Distt. Rewari (Haryana)
E-mail : universalanalyticallab@gmail.com, info@universallab.in, Web : www.universallab.in
Mob.: +91 9992929181, +91 9729948882, +91 8569966516



Report No: UAL/DH/-372/08/25

Date: 11/08/2025

Issued to:
5.0 MLD S.T.P.
Sector-6
Dharuhera Haryana

Customer's Ref No: Verbal
Dated: 04/08/2025
Lab Job Order No: 452/08/25
Period of Testing: 06/08/2025 to 11/08/2025

TEST REPORT

A. SAMPLE PARTICULARS:

- | | | |
|----------------------------------|---|-----------------------------|
| 1. Name of the Unit | : | 5.0 MLD S.T.P. |
| 2. Type of the Sample | : | Treated Sewage Water Sample |
| 3. Date of Sampling | : | 06/08/2025 |
| 4. Point of Sample Collection | : | From STP Outlet |
| 5. Purpose of Analysis | : | Monitoring |
| 6. Sample Collected/ Supplied by | : | Lab Representative |
| 7. Sampling Procedure | : | As Per IS 17614 (P-1) |
| 8. Sampling Plan | : | 5.7 F-01 (B) |

B. TEST RESULTS:

Sr. No.	Parameters	Result	Std. Limits (as per HSPCB)	Test Method
1	Colour	Colourless	-	IS-3025 (P-4)
2	Odour	Odourless	-	IS-3025 (P-5)
3	pH	7.87	5.5-9.0	IS-3025 (P-11)
4	COD, mg/l	40.0	50	APHA 24 th Ed.5220-B
5	BOD (at 27°C for 3 days), mg/l	8.0	10	IS-3025 (P-44)
6	Total Suspended Solids, mg/l	13	20	IS-3025 (P-17)
7	Oil & Grease, mg/l	<3	-	IS-3025 (P-39)
8	Conductivity μ mhos/cm	1610	-	IS-3025(P-14)
9	Ammonical Nitrogen (as N), mg/l	19.4	-	IS-3025(P-34)
10	Faecal Coliform, MPN/100 ml	70	<100	IS-1622
11	Total Coliform, MPN/100 ml	180	-	IS-1622
12	Faecal Streptococci, MPN/100 ml	50	-	IS-1622

Mgr. / Sr. Analyst
Akshay



Authorized Signatory
Ajeet Singh
Technical Manager

Note :

1. This report is not to be reproduced wholly or in part and cannot be used as an evidence in the court of law.
2. This report should not be used in any advertising media without our special permission in writing.
3. Sample will be destroyed after retention time unless otherwise specified.
4. The results are related to the test items only.

Page 1 of 1

Date: 23/09/2025

Report No: UAL/DH/-1050/09/25

Issued to:
5.0 MLD S.T.P.
 Sector-6
 Dharuhera Haryana

Customer's Ref No: Verbal

Dated: 17/09/2025

Lab Job Order No: 1243/09/25

Period of Testing: 19/09/2025 to 23/09/2025

TEST REPORT

A. SAMPLE PARTICULARS:


- | | | |
|----------------------------------|---|-----------------------------|
| 1. Name of the Unit | : | 5.0 MLD S.T.P. |
| 2. Type of the Sample | : | Treated Sewage Water Sample |
| 3. Date of Sampling | : | 19/09/2025 |
| 4. Point of Sample Collection | : | From STP Outlet |
| 5. Purpose of Analysis | : | Monitoring |
| 6. Sample Collected/ Supplied by | : | By Customer |

B. TEST RESULTS:

Sr. No.	Parameters	Result	Std. Limits (as per HSPCB)	Test Method
1	Colour	Lt. Yellowish	-	IS-3025 (P-4)
2	Odour	Odourless	-	IS-3025 (P-5)
3	pH	8.25	5.5-9.0	IS-3025 (P-11)
4	COD, mg/l	36	50	APHA 24 th Ed.5220-B
5	BOD (at 27°C for 3 days), mg/l	7.1	10	IS-3025 (P-44)
6	Total Suspended Solids, mg/l	8	20	IS-3025 (P-17)
7	Oil & Grease, mg/l	<3	-	IS-3025 (P-39)
8	Conductivity µmhos/cm	1786	-	IS-3025(P-14)
9	Ammonical Nitrogen (as N), mg/l	36.1	-	IS-3025(P-34)
10	Faecal Coliform, MPN/100 ml	50	<100	IS-1622
11	Total Coliform, MPN/100 ml	120	-	IS-1622
12	Faecal Streptococci, MPN/100 ml	30	-	IS-1622


 Mgr. / Sr. Analyst
 Akshay
 Microbiologist




 Authorized Signatory
 Ajeet Singh
 Technical Manager

Note :

1. This report is not to be reproduced wholly or in part and cannot be used as an evidence in the court of law.
2. This report should not be used in any advertising media without our special permission in writing.
3. Sample will be destroyed after retention time unless otherwise specified.
4. The results are related to the test items only.



**PREVENT
POLLUTION**

920

Annexure - A-II , Page No.5

FORM J
(See Rule 36)

Report No.:-1310

Dated - October 13, 2025

I, hereby, certify that I Neeraj Bala as Board Analyst, duly appointed under sub section (3) of section 53 of Water (Prevention and control of Pollution) Act, 1974(6 of 1974) received on the 30th day of September, 2025 from Sh. Ajay Yadav, AEE, a sample of liquid domestic effluent of M/s 5 MLD STP HSVP, Dharuhera, Rewari, collected on 29.09.2025 from the Inlet & Outlet of STP for analysis. The Sample was in a condition fit for analysis reported below:-
I further certify that I have analyzed the afore-mentioned sample on 30/09/2025 to 13/10/2025 and declare the result of analysis to be as follow:-

Sr. No.	Parameter	Inlet of STP	Outlet of STP	Prescribed Limits	Test Method
1.	Sample Code	HSPCB-FBD/WW/2025/09/55	HSPCB-FBD/WW/2025/09/56	----	----
2.	Colour	Yellowish	Colorless	-----	----
3.	Odour	Bad	Odourless	-----	----
4.	pH Value at 25°C	6.42	7.68	5.5-9.0	APHA 4500 H ⁺ B (24 th Edition 2023)
5.	Conductivity µS/cm at 25°C	14500	1820	----	IS 3025 (Part 14) 2023
6.	Total Suspended Solids mg/l	245	17	20	IS 3025 (Part 17) 2023
7.	B.O.D.(3 Days at 27 ^o C) mg/l	85	7.5	10	IS 3025 (Part 44) 2023
8.	Chemical Oxygen Demand mg/l	322.7	43.2	50	IS 3025 (Part 58) 2023
9.	Oil & Grease mg/l	6.8	BDL* (DL**=4)	10	IS 3025 (Part 39) 2023
10.	Fecal Coliform MPN/100 ml	27000	93	<100	APHA 9221-E (24 th Edition 2023)

BDL* = Below Detection Limit

DL** = Detection Limit

*** As information given by field officer, Flow meter is not working at Inlet & Outlet of STP

The condition of the seals, fastening and container on receipt was as follow:

Container had its seals found intact in order; slip on the container had the signature of the representative of the industry and the board representative.

Signed this on **13th day of October, 2025**

Haryana State Pollution Control Board Laboratory,
Sector-16 A, Faridabad

Neeraj Bala
Board Analyst

To

The Member Secretary, HSPCB, Panchkula/ Regional Office, HSPCB, Dharuhera / M/s 5 MLD STP HSVP, Dharuhera, Rewari

Endst. No. HSPCB/LAB/F/2025/ 6402

Dated: 13-10-25

This test report relate only to the particular sample submitted for testing