



TANISHKA EARTH CARE SERVICES (OPC) PRIVATE LIMITED

AN ISO/IEC 17025 NABL ACCREDITED ENVIRONMENT TESTING LABORATORY

GPCB Recognized Environmental Auditor (Schedule -II)

PLOT NO.111. HIRA PARK, OPP- VISHAL HOTEL, JAMNAGAR - 361006

+91 78749 15777 | +91 98794 06097 | tanishkaearthcare@gmail.com

TEST REPORT

Company Name	M/s. Krishna Construction Company	Sample ID	WQ/25/12/29
Address	1st Floor,H-110, Shreedhar Flora, Amar JavanCircle, Nikol Gam Road, Ahmedabad.382350	Condition of sample	Satisfactory
		Sample Done By	Customer
		Quantity of Sample	1000 ml
		Sampling Method	APHA
Date of Sampling	05.02.2026	Date of Sample Received	05.02.2026
Analysis Starts Date	05.02.2026	Analysis Completion Date	10.02.2026
Sample Description	OUTLET AT BABRA 4.0 MLD STP	Temperature/ Humidity during testing	Temp.- 25-29 deg C / Humidity <50 %
Report Number:	LAB/WQ/25/12/29	Report Date:	10.02.2026

S.No.	PARAMETERS	UNIT	RESULTS	LIMIT	Testing Method/ Standard
PHYSICAL CHEMICAL AND MICRO PARAMETERS					
1	pH @ 27 deg.	--	7.10	6.5-9	APHA 24 th Edition 4500 B: 2023
2	Total Suspended Solids	mg/l	7.90	<10	APHA 24 th Edition 2540 D: 2023
3	Total Phosphorus	mg/l	0.70	<1	APHA 24 th Edition 4500P D: 2023
4	Chemical Oxygen Demand	mg/l	22.40	<50	IS 3025 (Part 58) 2006
5	Biochemical Oxygen Demand	mg/l	7.10	<10	IS 3025 (Part 44) 1993
6	Ammonical Nitrogen	mg/l	3.00	<5	APHA 24 th Edition 4500 NH3 C : 2023
7	Total Nitrogen	mg/l	3.80	<10	APHA 24 th Edition 4500 N113C / Norg B/ NO3 B/NO2 B; 2023
8	Faecal Coliform	MPN/100 ml	60.00	<100	IS 1622
12	Total Coliform	MPN/100 ml	70.00	<100	IS 1622

Checked By :	Parth Bandhiya	Authorized Signatory :	Mufaddal Nathani
Signature :		Signature :	
Designation :	Chemist	Designation :	Technical Manager

- Notes:**
- The report shall not be reproduced except in full without approval of the laboratory can provide assurance that parts of a report are not taken out of context.
 - This certificate is based on the sample submitted for testing.
 - Additions to, deviations, or exclusions from the method- NA
 - Results which were outsourced to external providers are marked with ** and results which are performed and not in NABL accreditation scope are marked with * in parameter column
 - Disclaimer: When the information is supplied by the customer and can affect the validity of results
 - Disclaimer: The report that the results apply to the sample as received in case of the sample has been supplied by customer
 - Disclaimer: The laboratory shall be responsible for all the information provided in the report, except when information is provided by the customer
 - Regulatory limit reference if any:- NA
 - Opinion, Interpretation & Statement of Conformity if provided can be referred in the remarks section as "Permissible" "Below acceptable" or whatever is applicable as per the limit
 - BDL : Below Detection Limit

● End of the Test Report ●

TANISHKA EARTH CARE SERVICES (OPC) PRIVATE LIMITED



TANISHKA EARTH CARE SERVICES (OPC) PRIVATE LIMITED

AN ISO/IEC 17025 NABL ACCREDITED ENVIRONMENT TESTING LABORATORY

GPCB Recognized Environmental Auditor (Schedule -II)

PLOT NO.111. HIRA PARK, OPP- VISHAL HOTEL, JAMNAGAR - 361006

+91 78749 15777 | +91 98794 06097 | tanishkaearthcare@gmail.com

TEST REPORT

Company Name	M/s. Krishna Construction Company	Sample ID	WQ/25/12/29
Address	1st Floor,H-110, Shreedhar Flora, Amar JavanCircle, Nikol Gam Road, Ahmedabad.382350	Condition of sample	Satisfactory
		Sample Done By	Customer
		Quantity of Sample	1000 ml
		Sampling Method	APHA
Date of Sampling	05.02.2026	Date of Sample Received	05.02.2026
Analysis Starts Date	05.02.2026	Analysis Completion Date	10.02.2026
Sample Description	INTLET AT BABRA 4.0 MLD STP	Temperature/ Humidity during testing	Temp.- 25-29 deg C / Humidity <50 %
Report Number:	LAB/WQ/25/12/29	Report Date:	10.02.2026

S.No.	PARAMETERS	UNIT	RESULTS	LIMIT	Testing Method/ Standard
PHYSICAL CHEMICAL AND MICRO PARAMETERS					
1	pH @ 27 deg.	--	7.50		APHA 24 th Edition 4500 B: 2023
2	Total Suspended Solids	mg/l	321.90		APHA 24 th Edition 2540 D: 2023
3	Total Phosphorus	mg/l	3.10		APHA 24 th Edition 4500P D: 2023
4	Chemical Oxygen Demand	mg/l	639.40		IS 3025 (Part 58) 2006
5	Biochemical Oxygen Demand	mg/l	214.20		IS 3025 (Part 44) 1993
6	Ammonical Nitrogen	mg/l	32.65		APHA 24 th Edition 4500 NH3 C : 2023
7	Total Kjeldhal Nitrogen	mg/l	46.60		APHA 24 th Edition 4500 NH3 C/Norg B:2017
8	Nitrate	mg/l	24.20		APHA 24 th Edition 4500 NO3 B: 2023
9	Nitrite	mg/l	0.95		APHA 24 th Edition 4500 NO2 B: 2023
10	Total Nitrogen	mg/l	71.75		APHA 24 th Edition 4500 N113C / Norg B/ NO3 B/NO2 B: 2023
11	Faecal Coliform	MPN/100 ml	900.00		IS 1622
12	Total Coliform	MPN/100 ml	1600.00		IS 1622

Checked By :	Parth Bandhiya	Authorized Signatory :	Mufadda Nathani
Signature :		Signature :	
Designation :	Chemist	Designation :	Technical Manager



- Notes:**
- The report shall not be reproduced except in full without approval of the laboratory can provide assurance that parts of a report are not taken out of context.
 - This certificate is based on the sample submitted for testing.
 - Additions to, deviations, or exclusions from the method- NA
 - Results which were outsourced to external providers are marked with ** and results which are performed and not in NABL accreditation scope are marked with * in parameter column
 - Disclaimer: When the information is supplied by the customer and can affect the validity of results
 - Disclaimer: The report that the results apply to the sample as received in case of the sample has been supplied by customer
 - Disclaimer: The laboratory shall be responsible for all the information provided in the report, except when information is provided by the customer
 - Regulatory limit reference if any:- NA
 - Opinion, Interpretation & Statement of Conformity if provided can be referred in the remarks section as "Permissible" "Below acceptable" or whatever is applicable as per the limit
 - BDL: Below Detection Limit

● End of the Test Report ●

TANISHKA EARTH CARE SERVICES (OPC) PRIVATE LIMITED



AN ISO/IEC 17025 NABL ACCREDITED ENVIRONMENT TESTING LABORATORY

GPCB Recognized Environmental Auditor (Schedule -II)

PLOT NO.111. HIRA PARK, OPP- VISHAL HOTEL, JAMNAGAR - 361006

+91 78749 15777 | +91 98794 06097 | tanishkaearthcare@gmail.com

Testing solution for a better tomorrow

TEST REPORT

Company Name	M/s. Krishna Construction Company	Sample ID	WQ/26/02/45
Address	1st Floor,H-110, Shreedhar Flora, Amar JavanCircle, Nikol Gam Road, Ahmedabad.382350	Condition of sample	Satisfactory
		Sample Done By	Customer
		Quantity of Sample	1000 ml
		Sampling Method	APHA
Date of Sampling	11.02.2026	Date of Sample Received	11.02.2026
Analysis Starts Date	11.02.2026	Analysis Completion Date	15.02.2026
Sample Description	OUTLET AT BABRA 4.0 MLD STP	Temperature/ Humidity during testing	Temp.- 25-29 deg C / Humidity <50 %
Report Number:	LAB/WQ/26/02/46	Report Date:	15.02.2026

S.No.	PARAMETERS	UNIT	RESULTS	LIMIT	Testing Method/ Standard
PHYSICAL CHEMICAL AND MICRO PARAMETERS					
1	pH @ 27 deg.	--	7.12	6.5-9	APHA 24 th Edition 4500 B: 2023
2	Total Suspended Solids	mg/l	8.00	<10	APHA 24 th Edition 2540 D: 2023
3	Total Phosphorus	mg/l	0.66	<1	APHA 24 th Edition 4500P D: 2023
4	Chemical Oxygen Demand	mg/l	24.62	<50	IS 3025 (Part 58) 2006
5	Biochemical Oxygen Demand	mg/l	7.54	<10	IS 3025 (Part 44) 1993
6	Ammonical Nitrogen	mg/l	2.78	<5	APHA 24 th Edition 4500 NH3 C : 2023
7	Total Nitrogen	mg/l	5.62	<10	APHA 24 th Edition 4500 N113C / Norg B/ NO3 B/NO2 B; 2023
8	Faecal Coliform	MPN/100 ml	60.00	<100	IS 1622
12	Total Coliform	MPN/100 ml	70.00	<100	IS 1622

Checked By :	Parth Bandhiya	Authorized Signatory :	Mukund Nathan
Signature :		Signature :	
Designation :	Chemist	Designation :	Technical Manager



- Notes:**
- The report shall not be reproduced except in full without approval of the laboratory can provide assurance that parts of a report are not taken out of context.
 - This certificate is based on the sample submitted for testing.
 - Additions to, deviations, or exclusions from the method- NA
 - Results which were outsourced to external providers are marked with ** and results which are performed and not in NABL accreditation scope are marked with * in parameter column
 - Disclaimer: When the information is supplied by the customer and can affect the validity of results
 - Disclaimer: The report that the results apply to the sample as received in case of the sample has been supplied by customer
 - Disclaimer: The laboratory shall be responsible for all the information provided in the report, except when information is provided by the customer
 - Regulatory limit reference if any:- NA
 - Opinion, Interpretation & Statement of Conformity if provided can be referred in the remarks section as "Permissible" "Below acceptable" or whatever is applicable as per the limit
 - BDL : Below Detection Limit
- End of the Test Report ●

TANISHKA EARTH CARE SERVICES (OPC) PRIVATE LIMITED



TANISHKA EARTH CARE SERVICES (OPC) PRIVATE LIMITED

AN ISO/IEC 17025 NABL ACCREDITED ENVIRONMENT TESTING LABORATORY

GPCB Recognized Environmental Auditor (Schedule -II)

📍 PLOT NO.111. HIRA PARK, OPP- VISHAL HOTEL, JAMNAGAR - 361006

☎ +91 78749 15777 | +91 98794 06097 ✉ tanishkaearthcare@gmail.com

TEST REPORT

Company Name	M/s. Krishna Construction Company	Sample ID	WQ/26/02/45
Address	1st Floor,H-110, Shreedhar Flora, Amar JavanCircle, Nikol Gam Road, Ahmedabad.382350	Condition of sample	Satisfactory
		Sample Done By	Customer
		Quantity of Sample	1000 ml
		Sampling Method	APHA
Date of Sampling	11.02.2026	Date of Sample Received	11.02.2026
Analysis Starts Date	11.02.2026	Analysis Completion Date	15.02.2026
Sample Description	INLET AT BABRA 4.0 MLD STP	Temperature/ Humidity during testing	Temp.- 25-29 deg C / Humidity <50 %
Report Number:	LAB/WQ/26/02/45	Report Date:	15.02.2026

S.No.	PARAMETERS	UNIT	RESULTS	LIMIT	Testing Method/ Standard
PHYSICAL CHEMICAL AND MICRO PARAMETERS					
1	pH @ 27 deg.	--	7.46		APHA 24 th Edition 4500 B: 2023
2	Total Suspended Solids	mg/l	320.60		APHA 24 th Edition 2540 D: 2023
3	Total Phosphorus	mg/l	2.68		APHA 24 th Edition 4500P D: 2023
4	Chemical Oxygen Demand	mg/l	640.52		IS 3025 (Part 58) 2006
5	Biochemical Oxygen Demand	mg/l	218.49		IS 3025 (Part 44) 1993
6	Ammonical Nitrogen	mg/l	34.10		APHA 24 th Edition 4500 NH3 C : 2023
7	Total Kjeldhal Nitrogen	mg/l	44.61		APHA 24 th Edition 4500 NH3 C/Norg B:2017
8	Nitrate	mg/l	26.80		APHA 24 th Edition 4500 NO3 B: 2023
9	Nitrite	mg/l	0.80		APHA 24 th Edition 4500 NO2 B: 2023
10	Total Nitrogen	mg/l	72.21		APHA 24 th Edition 4500 N113C / Norg B/ NO3 B/NO2 B; 2023
11	Faecal Coliform	MPN/100 ml	900.00		IS 1622
12	Total Coliform	MPN/100 ml	1600.00		IS 1622

Checked By:	Parth Bandhiya	Authorized Signatory:	Muraddal Nathani
Signature:		Signature:	
Designation:	Chemist	Designation:	Technical Manager

Notes:

- The report shall not be reproduced except in full without approval of the laboratory can provide assurance that parts of a report are not taken out of context.
- This certificate is based on the sample submitted for testing.
- Additions to, deviations, or exclusions from the method- NA
- Results which were outsourced to external providers are marked with ** and results which are performed and not in NABL accreditation scope are marked with * in parameter column
- Disclaimer: When the information is supplied by the customer and can affect the validity of results
- Disclaimer: The report that the results apply to the sample as received in case of the sample has been supplied by customer
- Disclaimer: The laboratory shall be responsible for all the information provided in the report, except when information is provided by the customer
- Regulatory limit reference if any:- NA
- Opinion, Interpretation & Statement of Conformity if provided can be referred in the remarks section as "Permissible" "Below acceptable" or whatever is applicable as per the limit
- BDL: Below Detection Limit

● End of the Test Report ●

TANISHKA EARTH CARE SERVICES (OPC) PRIVATE LIMITED


TEST REPORT OF WASTEWATER

Report No.:	TEL/LAB/012026/430			Date: 19/01/2026
Client Name	M/s. Maruti – Tolani JV			
Client Address	3.8 MLD Lathi STP			
Sample Description	Wastewater	Date of Sampling	-	
Point of Sample Collection	STP Inlet	Sample Received Date	10/01/2026	
Sample Quantity	2 L + 1 L	Date of Analysis Start on	12/01/2026	
Sampling Method	Grab	Date of Analysis Completed	17/01/2026	
Sample Code	TEL/LAB/STP/0126/128	Sampling Done by	Sample by Party	
Environmental Condition During Testing	Temp. 27 ± 2 °C & Humidity. 65 ± 5 % RH			

TEST REPORT

Sr. No.	Parameters	Unit	Results	Test Method
1.	pH Value	--	6.58	IS 3025 (Part-11)
2.	Total Suspended Solids (TSS)	mg/L	642	APHA 24 th Edition: 2540 D
3.	Chemical Oxygen Demand (COD)	mg/L	418	APHA 24 th Edition: 5220 B
4.	Biochemical Oxygen Demand (BOD)	mg/L	266	IS 3025 (Part-44)
5.	Ammonical Nitrogen	mg/L	26	IS 3025 (Part-34)
6.	Total Nitrogen	mg/L	28	APHA 24 th Edition: 4500-N
7.	Phosphorus	mg/L	2.0	APHA 24 th Edition: 4500-P
8.	Fecal Coliforms	MPN/100 mL	280	APHA 24th Edition: 9221 - E
9.	Total Coliform	MPN/100 mL	120	APHA 24th Edition: 9221 - E

Notes:

1. The results relate only to the samples tested.
2. The report shall not be reproduced except in full, without the written approval of the laboratory.
3. Report cannot be used as evidence anywhere without prior permission of laboratory.
4. The test samples will be disposed off after two weeks from the date of issue of test report, unless specified by the customer.


 Analysed By:




 Authorized Signatory

-----End of Report-----


TEST REPORT OF WASTEWATER

Report No.:	TEL/LAB/012026/431			Date: 19/01/2026
Client Name	M/s. Maruti – Tolani JV			
Client Address	3.8 MLD Lathi STP			
Sample Description	Wastewater	Date of Sampling	-	
Point of Sample Collection	STP Outlet	Sample Received Date	10/01/2026	
Sample Quantity	2 L + 1 L	Date of Analysis Start on	12/01/2026	
Sampling Method	Grab	Date of Analysis Completed	17/01/2026	
Sample Code	TEL/LAB/STP/0126/129	Sampling Done by	Sample by Party	
Environmental Condition During Testing	Temp. 27 ± 2 °C & Humidity. 65 ± 5 % RH			
TEST REPORT				
Sr. No.	Parameters	Unit	Results	Test Method
1.	pH Value	--	7.72	IS 3025 (Part-11)
2.	Total Suspended Solids (TSS)	mg/L	8.0	APHA 24 th Edition: 2540 D
3.	Chemical Oxygen Demand (COD)	mg/L	36	APHA 24 th Edition: 5220 B
4.	Biochemical Oxygen Demand (BOD)	mg/L	8.5	IS 3025 (Part-44)
5.	Ammonical Nitrogen	mg/L	3.0	IS 3025 (Part-34)
6.	Total Nitrogen	mg/L	8.2	APHA 24 th Edition: 4500-N
7.	Phosphorus	mg/L	0.2	APHA 24 th Edition: 4500-P
8.	Fecal Coliforms	MPN/100 mL	92	APHA 24 th Edition: 9221 - E
9.	Total Coliform	MPN/100 mL	88	APHA 24 th Edition: 9221 - E

Notes:

1. The results relate only to the samples tested.
2. The report shall not be reproduced except in full, without the written approval of the laboratory.
3. Report cannot be used as evidence anywhere without prior permission of laboratory.
4. The test samples will be disposed off after two weeks from the date of issue of test report, unless specified by the customer.


Analysed By:




Authorized Signatory

-----End of Report-----


TEST REPORT OF WASTEWATER

Report No.:	TEL/LAB/012026/451			Date: 04/02/2026
Client Name	M/s. Maruti – Tolani JV			
Client Address	3.8 MLD Lathi STP			
Sample Description	Wastewater	Date of Sampling	-	
Point of Sample Collection	STP Inlet	Sample Received Date	26/01/2026	
Sample Quantity	2 L + 1 L	Date of Analysis Start on	27/01/2026	
Sampling Method	Grab	Date of Analysis Completed	03/02/2026	
Sample Code	TEL/LAB/STP/0126/132	Sampling Done by	Sample by Party	
Environmental Condition During Testing		Temp. 27 ± 2 °C & Humidity. 65 ± 5 % RH		
TEST REPORT				
Sr. No.	Parameters	Unit	Results	Test Method
1.	pH Value	--	6.28	IS 3025 (Part-11)
2.	Total Suspended Solids (TSS)	mg/L	814	APHA 24 th Edition: 2540 D
3.	Chemical Oxygen Demand (COD)	mg/L	396	APHA 24 th Edition: 5220 B
4.	Biochemical Oxygen Demand (BOD)	mg/L	252	IS 3025 (Part-44)
5.	Ammonical Nitrogen	mg/L	22	IS 3025 (Part-34)
6.	Total Nitrogen	mg/L	48	APHA 24 th Edition: 4500-N
7.	Phosphorus	mg/L	3.0	APHA 24 th Edition: 4500-P
8.	Fecal Coliforms	MPN/100 mL	280	APHA 24 th Edition: 9221 - E
9.	Total Coliform	MPN/100 mL	125	APHA 24 th Edition: 9221 - E

Notes:

1. The results relate only to the samples tested.
2. The report shall not be reproduced except in full, without the written approval of the laboratory.
3. Report cannot be used as evidence anywhere without prior permission of laboratory.
4. The test samples will be disposed off after two weeks from the date of issue of test report, unless specified by the customer.


 Analysed By:




 Authorized Signatory

-----End of Report-----


TEST REPORT OF WASTEWATER

Report No.:	TEL/LAB/012026/452			Date: 04/02/2026
Client Name	M/s. Maruti – Tolani JV			
Client Address	3.8 MLD Lathi STP			
Sample Description	Wastewater	Date of Sampling	-	
Point of Sample Collection	STP Outlet	Sample Received Date	26/01/2026	
Sample Quantity	2 L + 1 L	Date of Analysis Start on	27/01/2026	
Sampling Method	Grab	Date of Analysis Completed	03/02/2026	
Sample Code	TEL/LAB/STP/0126/133	Sampling Done by	Sample by Party	
Environmental Condition During Testing		Temp. 27 ± 2 °C & Humidity. 65 ± 5 % RH		
TEST REPORT				
Sr. No.	Parameters	Unit	Results	Test Method
1.	pH Value	--	7.16	IS 3025 (Part-11)
2.	Total Suspended Solids (TSS)	mg/L	5.2	APHA 24 th Edition: 2540 D
3.	Chemical Oxygen Demand (COD)	mg/L	32	APHA 24 th Edition: 5220 B
4.	Biochemical Oxygen Demand (BOD)	mg/L	6.0	IS 3025 (Part-44)
5.	Ammonical Nitrogen	mg/L	3.5	IS 3025 (Part-34)
6.	Total Nitrogen	mg/L	7.6	APHA 24 th Edition: 4500-N
7.	Phosphorus	mg/L	0.5	APHA 24 th Edition: 4500-P
8.	Fecal Coliforms	MPN/100 mL	140	APHA 24th Edition: 9221 - E
9.	Total Coliform	MPN/100 mL	92	APHA 24th Edition: 9221 - E

Notes:

1. The results relate only to the samples tested.
2. The report shall not be reproduced except in full, without the written approval of the laboratory.
3. Report cannot be used as evidence anywhere without prior permission of laboratory.
4. The test samples will be disposed off after two weeks from the date of issue of test report, unless specified by the customer.

Analysed By:

Authorized Signatory

-----End of Report-----




TEST REPORT OF WASTEWATER

Report No.:	TEL/LAB/022026/379			Date: 19/02/2026
Client Name	M/s. Maruti – Tolani JV			
Client Address	3.8 MLD Lathi STP			
Sample Description	Wastewater	Date of Sampling	-	
Point of Sample Collection	STP Inlet	Sample Received Date	11/02/2026	
Sample Quantity	2 L + 1 L	Date of Analysis Start on	12/02/2026	
Sampling Method	Grab	Date of Analysis Completed	18/02/2026	
Sample Code	TEL/LAB/STP/1225/101	Sampling Done by	Sample by Party	
Environmental Condition During Testing	Temp. 27 ± 2 °C & Humidity. 65 ± 5 % RH			

TEST REPORT

Sr. No.	Parameters	Unit	Results	Test Method
1.	pH Value	--	6.73	IS 3025 (Part-11)
2.	Total Suspended Solids (TSS)	mg/L	246	APHA 24 th Edition: 2540 D
3.	Chemical Oxygen Demand (COD)	mg/L	358	APHA 24 th Edition: 5220 B
4.	Biochemical Oxygen Demand (BOD)	mg/L	256	IS 3025 (Part-44)
5.	Ammonical Nitrogen	mg/L	32.4	IS 3025 (Part-34)
6.	Total Nitrogen	mg/L	38	APHA 24 th Edition: 4500-N
7.	Phosphorus	mg/L	4.6	APHA 24 th Edition: 4500-P
8.	Fecal Coliforms	MPN/100 mL	286	APHA 24th Edition: 9221 - E
9.	Total Coliform	MPN/100 mL	130	APHA 24th Edition: 9221 - E

Notes:

1. The results relate only to the samples tested.
2. The report shall not be reproduced except in full, without the written approval of the laboratory.
3. Report cannot be used as evidence anywhere without prior permission of laboratory.
4. The test samples will be disposed off after two weeks from the date of issue of test report, unless specified by the customer.


 Analysed By:




 Authorized Signatory

-----End of Report-----


TEST REPORT OF WASTEWATER

Report No.:	TEL/LAB/022026/380			Date: 19/02/2026
Client Name	M/s. Maruti – Tolani JV			
Client Address	3.8 MLD Lathi STP			
Sample Description	Wastewater	Date of Sampling	-	
Point of Sample Collection	STP Outlet	Sample Received Date	11/02/2026	
Sample Quantity	2 L + 1 L	Date of Analysis Start on	12/02/2026	
Sampling Method	Grab	Date of Analysis Completed	18/02/2026	
Sample Code	TEL/LAB/STP/0226/102	Sampling Done by	Sample by Party	
Environmental Condition During Testing	Temp. 27 ± 2 °C & Humidity. 65 ± 5 % RH			

TEST REPORT

Sr. No.	Parameters	Unit	Results	Test Method
1.	pH Value	--	8.26	IS 3025 (Part-11)
2.	Total Suspended Solids (TSS)	mg/L	5.0	APHA 24 th Edition: 2540 D
3.	Chemical Oxygen Demand (COD)	mg/L	36	APHA 24 th Edition: 5220 B
4.	Biochemical Oxygen Demand (BOD)	mg/L	6.2	IS 3025 (Part-44)
5.	Ammonical Nitrogen	mg/L	3.5	IS 3025 (Part-34)
6.	Total Nitrogen	mg/L	7.0	APHA 24 th Edition: 4500-N
7.	Phosphorus	mg/L	0.2	APHA 24 th Edition: 4500-P
8.	Fecal Coliforms	MPN/100 mL	110	APHA 24th Edition: 9221 - E
9.	Total Coliform	MPN/100 mL	86	APHA 24th Edition: 9221 - E

Notes:

1. The results relate only to the samples tested.
2. The report shall not be reproduced except in full, without the written approval of the laboratory.
3. Report cannot be used as evidence anywhere without prior permission of laboratory.
4. The test samples will be disposed off after two weeks from the date of issue of test report, unless specified by the customer.

Analysed By:

Authorized Signatory

-----End of Report-----


TEST REPORT OF WASTEWATER

Report No.:	TEL/LAB/022026/382			Date: 03/03/2026
Client Name	M/s. Maruti – Tolani JV			
Client Address	3.8 MLD Lathi STP			
Sample Description	Wastewater	Date of Sampling	-	
Point of Sample Collection	STP Inlet	Sample Received Date	26/02/2026	
Sample Quantity	2 L + 1 L	Date of Analysis Start on	27/02/2026	
Sampling Method	Grab	Date of Analysis Completed	02/03/2026	
Sample Code	TEL/LAB/STP/0226/105	Sampling Done by	Sample by Party	
Environmental Condition During Testing	Temp. 27 ± 2 °C & Humidity. 65 ± 5 % RH			

TEST REPORT

Sr. No.	Parameters	Unit	Results	Test Method
1.	pH Value	--	6.98	IS 3025 (Part-11)
2.	Total Suspended Solids (TSS)	mg/L	566	APHA 24 th Edition: 2540 D
3.	Chemical Oxygen Demand (COD)	mg/L	484	APHA 24 th Edition: 5220 B
4.	Biochemical Oxygen Demand (BOD)	mg/L	218	IS 3025 (Part-44)
5.	Ammonical Nitrogen	mg/L	38.5	IS 3025 (Part-34)
6.	Total Nitrogen	mg/L	26.2	APHA 24 th Edition: 4500-N
7.	Phosphorus	mg/L	0.2	APHA 24 th Edition: 4500-P
8.	Fecal Coliforms	MPN/100 mL	160	APHA 24th Edition: 9221 - E
9.	Total Coliform	MPN/100 mL	140	APHA 24th Edition: 9221 - E

Notes:

1. The results relate only to the samples tested.
2. The report shall not be reproduced except in full, without the written approval of the laboratory.
3. Report cannot be used as evidence anywhere without prior permission of laboratory.
4. The test samples will be disposed off after two weeks from the date of issue of test report, unless specified by the customer.

Analysed By:

Authorized Signatory

-----End of Report-----




TEST REPORT OF WASTEWATER

Report No.:	TEL/LAB/022026/383			Date: 03/03/2026
Client Name	M/s. Maruti – Tolani JV			
Client Address	3.8 MLD Lathi STP			
Sample Description	Wastewater	Date of Sampling	-	
Point of Sample Collection	STP Outlet	Sample Received Date	26/02/2026	
Sample Quantity	2 L + 1 L	Date of Analysis Start on	27/02/2026	
Sampling Method	Grab	Date of Analysis Completed	02/03/2026	
Sample Code	TEL/LAB/STP/0226/106	Sampling Done by	Sample by Party	
Environmental Condition During Testing		Temp. 27 ± 2 °C & Humidity. 65 ± 5 % RH		
TEST REPORT				
Sr. No.	Parameters	Unit	Results	Test Method
1.	pH Value	--	7.41	IS 3025 (Part-11)
2.	Total Suspended Solids (TSS)	mg/L	6.2	APHA 24 th Edition: 2540 D
3.	Chemical Oxygen Demand (COD)	mg/L	26.5	APHA 24 th Edition: 5220 B
4.	Biochemical Oxygen Demand (BOD)	mg/L	5.0	IS 3025 (Part-44)
5.	Ammonical Nitrogen	mg/L	3.0	IS 3025 (Part-34)
6.	Total Nitrogen	mg/L	7.4	APHA 24 th Edition: 4500-N
7.	Phosphorus	mg/L	0.6	APHA 24 th Edition: 4500-P
8.	Fecal Coliforms	MPN/100 mL	92	APHA 24th Edition: 9221 - E
9.	Total Coliform	MPN/100 mL	80	APHA 24th Edition: 9221 - E

Notes:

1. The results relate only to the samples tested.
2. The report shall not be reproduced except in full, without the written approval of the laboratory.
3. Report cannot be used as evidence anywhere without prior permission of laboratory.
4. The test samples will be disposed off after two weeks from the date of issue of test report, unless specified by the customer.

Analysed By:

Authorized Signatory

-----End of Report-----



AN ISO/IEC 17025 NABL ACCREDITED ENVIRONMENT TESTING LABORATORY

GPCB Recognized Environmental Auditor (Schedule -II)

PLOT NO.111. HIRA PARK, OPP- VISHAL HOTEL, JAMNAGAR - 361006

+91 78749 15777 | +91 98794 06097 tanishkaearthcare@gmail.com

TEST REPORT

Company Name	M/s. Krishna Construction Company	Sample ID	WQ/26/03/24
Address	1st Floor,H-110, Shreedhar Flora, Amar JavanCircle, Nikol Gam Road, Ahmedabad.382350	Condition of sample	Satisfactory
		Sample Done By	Customer
		Quantity of Sample	1000 ml
		Sampling Method	APHA
Date of Sampling	06.03.2026	Date of Sample Received	06.03.2026
Analysis Starts Date	06.03.2026	Analysis Completion Date	12.03.2026
Sample Description	OUTLET AT GARIYADHAR 7.10 MLD STP	Temperature/ Humidity during testing	Temp.- 25-29 deg C / Humidity <50 %
Report Number:	LAB/WQ/26/03/24	Report Date:	12.03.2026

S.No.	PARAMETERS	UNIT	RESULTS	LIMIT	Testing Method/ Standard
PHYSICAL CHEMICAL AND MICRO PARAMETERS					
1	pH @ 27 deg.	--	6.92	6.5-9	APHA 24 th Edition 4500 B: 2023
2	Total Suspended Solids	mg/l	6.00	<10	APHA 24 th Edition 2540 D: 2023
3	Total Phosphorus	mg/l	0.45	<1	APHA 24 th Edition 4500P D: 2023
4	Chemical Oxygen Demand	mg/l	26.52	<50	IS 3025 (Part 5B) 2006
5	Biochemical Oxygen Demand	mg/l	7.80	<10	IS 3025 (Part 4A) 1993
6	Ammonical Nitrogen	mg/l	3.15	<5	APHA 24 th Edition 4500 NH3 C : 2023
7	Total Nitrogen	mg/l	5.66	<10	APHA 24 th Edition 4500 N113C / Norg B/ NO3 B/NO2 B; 2023
8	Faecal Coliform	MPN/100 ml	40.00	<100	IS 1622
9	Total Coliform	MPN/100 ml	60.00	<100	IS 1622

Checked By :	Hardev Singh	Authorized Signatory :	Munaddal Natham
Signature :		Signature :	
Designation :	Chemist	Designation :	Technical Manager



- Notes:**
1. The report shall not be reproduced except in full without approval of the laboratory can provide assurance that parts of a report are not taken out of context.
 2. This certificate is based on the sample submitted for testing.
 3. Additions to, deviations, or exclusions from the method- NA
 4. Results which were outsourced to external providers are marked with ** and results which are performed and not in NABL accreditation scope are marked with * in parameter column
 5. Disclaimer: When the information is supplied by the customer and can affect the validity of results
 6. Disclaimer: The report that the results apply to the sample as received in case of the sample has been supplied by customer
 7. Disclaimer: The laboratory shall be responsible for all the information provided in the report, except when information is provided by the customer
 8. Regulatory limit reference if any:- NA
 9. Opinion, Interpretation & Statement of Conformity if provided can be referred in the remarks section as "Permissible" "Below acceptable" or whatever is applicable as per the limit
 10. BDL : Below Detection Limit

● End of the Test Report ●



TANISHKA EARTH CARE SERVICES (OPC) PRIVATE LIMITED

AN ISO/IEC 17025 NABL ACCREDITED ENVIRONMENT TESTING LABORATORY

GPCB Recognized Environmental Auditor (Schedule -II)

PLOT NO.111. HIRA PARK, OPP- VISHAL HOTEL, JAMNAGAR - 361006

+91 78749 15777 | +91 98794 06097 | tanishkaearthcare@gmail.com

TEST REPORT

Company Name	M/s. Krishna Construction Company	Sample ID	WQ/26/03/23
Address	1st Floor,H-110, Shreedhar Flora, Amar JavanCircle, Nikol Gam Road, Ahmedabad.382350	Condition of sample	Satisfactory
		Sample Done By	Customer
		Quantity of Sample	1000 ml
		Sampling Method	APHA
Date of Sampling	06.03.2026	Date of Sample Received	06.03.2026
Analysis Starts Date	06.03.2026	Analysis Completion Date	12.03.2026
Sample Description	INLET AT GARIYADHAR 7.10 MLD STP	Temperature/ Humidity during testing	Temp.- 25-29 deg C / Humidity <50 %
Report Number:	LAB/WQ/26/03/23	Report Date:	12.03.2026

S.No.	PARAMETERS	UNIT	RESULTS	LIMIT	Testing Method/ Standard
PHYSICAL CHEMICAL AND MICRO PARAMETERS					
1	pH @ 27 deg.	--	7.05		APHA 24 th Edition 4500 B: 2023
2	Total Suspended Solids	mg/l	340.00		APHA 24 th Edition 2540 D: 2023
3	Total Phosphorus	mg/l	1.12		APHA 24 th Edition 4500P D: 2023
4	Chemical Oxygen Demand	mg/l	444.78		IS 3025 (Part 58) 2006
5	Biochemical Oxygen Demand	mg/l	158.80		IS 3025 (Part 44) 1993
6	Ammonical Nitrogen	mg/l	28.68		APHA 24 th Edition 4500 NH3 C : 2023
7	Total Kjeldhal Nitrogen	mg/l	60.24		APHA 24 th Edition 4500 NH3 C/Norg B:2017
8	Nitrate	mg/l	32.40		APHA 24 th Edition 4500 NO3 B: 2023
9	Nitrite	mg/l	0.88		APHA 24 th Edition 4500 NO2 B: 2023
10	Total Nitrogen	mg/l	93.52		APHA 24 th Edition 4500 N113C / Norg B/ NO3 B/NO2 B: 2023
11	Faecal Coliform	MPN/100 ml	900.00		IS 1622
12	Total Coliform	MPN/100 ml	1600.00		IS 1622

Checked By :	Hardev Sinh	Authorized Signatory :	Mufaddal Nathani
Signature :		Signature :	
Designation :	Chemist	Designation :	Technical Manager



Notes:

- The report shall not be reproduced except in full without approval of the laboratory can provide assurance that parts of a report are not taken out of context.
- This certificate is based on the sample submitted for testing.
- Additions to, deviations, or exclusions from the method- NA
- Results which were outsourced to external providers are marked with ** and results which are performed and not in NABL accreditation scope are marked with * in parameter column
- Disclaimer: When the information is supplied by the customer and can affect the validity of results
- Disclaimer: The report that the results apply to the sample as received in case of the sample has been supplied by customer
- Disclaimer: The laboratory shall be responsible for all the information provided in the report, except when information is provided by the customer
- Regulatory limit reference if any:- NA
- Opinion, Interpretation & Statement of Conformity if provided can be referred in the remarks section as "Permissible" "Below acceptable" or whatever is applicable as per the limit
- BDL : Below Detection Limit

● End of the Test Report ●

TANISHKA EARTH CARE SERVICES (OPC) PRIVATE LIMITED



AN ISO/IEC 17025 NABL ACCREDITED ENVIRONMENT TESTING LABORATORY

GPCB Recognized Environmental Auditor (Schedule -II)

PLOT NO.111. HIRA PARK, OPP- VISHAL HOTEL, JAMNAGAR - 361006

+91 78749 15777 | +91 98794 06097 | tanishkaearthcare@gmail.com

TEST REPORT

Company Name	M/s. Krishna Construction Company	Sample ID	WQ/26/02/05
Address	1st Floor,H-110, Shreedhar Flora, Amar JavanCircle, Nikol Gam Road, Ahmedabad.382350	Condition of sample	Satisfactory
		Sample Done By	Customer
		Quantity of Sample	1000 ml
		Sampling Method	APHA
Date of Sampling	01.02.2026	Date of Sample Received	02.02.2026
Analysis Starts Date	02.02.2026	Analysis Completion Date	09.02.2026
Sample Description	OUTLET AT GARIYADHAR 7.10 MLD STP	Temperature/ Humidity during testing	Temp.- 25-29 deg C / Humidity <50 %
Report Number:	LAB/WQ/26/02/05	Report Date:	09.02.2026

S.No.	PARAMETERS	UNIT	RESULTS	LIMIT	Testing Method/ Standard
PHYSICAL CHEMICAL AND MICRO PARAMETERS					
1	pH @ 27 deg.	--	6.90	6.5-9	APHA 24 th Edition 4500 B: 2023
2	Total Suspended Solids	mg/l	6.20	<10	APHA 24 th Edition 2540 D: 2023
3	Total Phosphorus	mg/l	0.40	<1	APHA 24 th Edition 4500P D: 2023
4	Chemical Oxygen Demand	mg/l	25.20	<50	IS 3025 (Part 5B) 2006
5	Biochemical Oxygen Demand	mg/l	6.50	<10	IS 3025 (Part 4A) 1993
6	Ammonical Nitrogen	mg/l	3.80	<5	APHA 24 th Edition 4500 NH3 C : 2023
7	Total Nitrogen	mg/l	5.60	<10	APHA 24 th Edition 4500 N113C / Norg B/ NO3 B/NO2 B: 2023
8	Faecal Coliform	MPN/100 ml	50.00	<100	IS 1622
9	Total Coliform	MPN/100 ml	70.00	<100	IS 1622

Checked By :	Hardev Sinh	Authorized Signatory :	Mufaddal Nathani
Signature :		Signature :	
Designation :	Chemist	Designation :	Technical Manager



Notes:

1. The report shall not be reproduced except in full without approval of the laboratory can provide assurance that parts of a report are not taken out of context.
2. This certificate is based on the sample submitted for testing.
3. Additions to, deviations, or exclusions from the method- NA
4. Results which were outsourced to external providers are marked with ** and results which are performed and not in NABL accreditation scope are marked with * in parameter column
5. Disclaimer: When the information is supplied by the customer and can affect the validity of results
6. Disclaimer: The report that the results apply to the sample as received in case of the sample has been supplied by customer
7. Disclaimer: The laboratory shall be responsible for all the information provided in the report, except when information is provided by the customer
8. Regulatory limit reference if any:- NA
9. Opinion, Interpretation & Statement of Conformity if provided can be referred in the remarks section as "Permissible" "Below acceptable" or whatever is applicable as per the limit
10. BDL : Below Detection Limit

● End of the Test Report ●



TEST REPORT

Company Name	M/s. Krishna Construction Company	Sample ID	WQ/26/02/04
Address	1st Floor,H-110, Shreedhar Flora, Amar JavanCircle, Nikol Gam Road, Ahmedabad.382350	Condition of sample	Satisfactory
		Sample Done By	Customer
		Quantity of Sample	1000 ml
		Sampling Method	APHA
Date of Sampling	01.02.2026	Date of Sample Received	02.02.2026
Analysis Starts Date	02.02.2026	Analysis Completion Date	09.02.2026
Sample Description	INLET AT GARIYADHAR 7.10 MLD STP	Temperature/ Humidity during testing	Temp.- 25-29 deg C / Humidity <50 %
Report Number:	LAB/WQ/26/02/04	Report Date:	09.02.2026

S.No.	PARAMETERS	UNIT	RESULTS	LIMIT	Testing Method/ Standard
PHYSICAL CHEMICAL AND MICRO PARAMETERS					
1	pH @ 27 deg.	--	6.98		APHA 24 th Edition 4500 B: 2023
2	Total Suspended Solids	mg/l	330.00		APHA 24 th Edition 2540 D: 2023
3	Total Phosphorus	mg/l	1.28		APHA 24 th Edition 4500P D: 2023
4	Chemical Oxygen Demand	mg/l	435.00		IS 3025 (Part 58) 2006
5	Biochemical Oxygen Demand	mg/l	165.20		IS 3025 (Part 44) 1993
6	Ammonical Nitrogen	mg/l	28.00		APHA 24 th Edition 4500 NH3 C : 2023
7	Total Kjeldhal Nitrogen	mg/l	62.55		APHA 24 th Edition 4500 NH3 C/Norg B:2017
8	Nitrate	mg/l	32.40		APHA 24 th Edition 4500 NO3 B: 2023
9	Nitrite	mg/l	0.90		APHA 24 th Edition 4500 NO2 B: 2023
10	Total Nitrogen	mg/l	95.85		APHA 24 th Edition 4500 N113C / Norg B/ NO3 B/NO2 B; 2023
11	Faecal Coliform	MPN/100 ml	500.00		IS 1622
12	Total Coliform	MPN/100 ml	900.00		IS 1622

Checked By :	Hardev Sinh	Authorized Signatory :	Mufaddal Nathan
Signature :		Signature :	
Designation :	Chemist	Designation :	Technical Manager



Notes:

- The report shall not be reproduced except in full without approval of the laboratory can provide assurance that parts of a report are not taken out of context.
- This certificate is based on the sample submitted for testing.
- Additions to, deviations, or exclusions from the method- NA
- Results which were outsourced to external providers are marked with ** and results which are performed and not in NABL accreditation scope are marked with * in parameter column
- Disclaimer: When the information is supplied by the customer and can affect the validity of results
- Disclaimer: The report that the results apply to the sample as received in case of the sample has been supplied by customer
- Disclaimer: The laboratory shall be responsible for all the information provided in the report, except when information is provided by the customer
- Regulatory limit reference if any:- NA
- Opinion, Interpretation & Statement of Conformity if provided can be referred in the remarks section as "Permissible" "Below acceptable" or whatever is applicable as per the limit
- BDL : Below Detection Limit

● End of the Test Report ●

TANISHKA EARTH CARE SERVICES (OPC) PRIVATE LIMITED



ISO 9001:2015 and ISO 17025:2017 NABL certified

No.4, Versetile Industrial Estate, Nr. Kotak Bank, Gate No.5, Kathwada Gidc, Ahmedabad - 382430.

+91 8469130040, +91 6357351655 naturemicrovision@gmail.com GSTIN : 24AAWFN4704G1Z4

Test Report

Report ID: NML/WW/25-26/1113

Date: 13/01/2026

Customer Name		Rajkamal Builders Infrastructure Private Limited		
Customer Address		5.80 MLD STP Talaja		
Date & Time of Sampling	08/01/2026	Sampling Plan & Method	IS 3025(Part-1) RA 2019	
Date of Receipt of Sample	09/01/2026			
Sample Collected by	Client	Sample Condition	SATISFACTORY	
Analysis Starting Date	09/01/2026	Packing / Seal	SEALED	
Analysis Completion Date	12/01/2026	Quantity / No. of Samples	Approx. 1 LIT. * 1NO.	
Environmental Condition	Temperature: 25 °C ± 2	Relative Humidity (%)	Humidity ≤ 50 %	
Sample No.	Sample ID	Sample Type	Location	Description
1.	25-26/1122	Waste Water	Inlet	Untreated Water

Analysis Results

Sr. No.	Parameters	Reference Method	Results	Unit
1.	pH	IS 3025 (Part 11): 2022	7.23	--
2.	BIOLOGICAL OXYGEN DEMAND (3 days at 27°C)	IS 3025 (Part 44): 2023	264	mg/L
3.	CHEMICAL OXYGEN DEMAND	IS 3025 (Part 58) : 2023	448	mg/L
4.	TOTAL SUSPENDED SOLIDS	IS 3025 (Part 17): 1988 (RA 2022)	327	mg/L
5.	TOTAL NITROGEN	IS 3025 (Part 34/sec- 1):2023	41	mg/L
6.	TOTAL PHOSPHORUS	IS 3025 (Part 31) :Sec 1 : 2022	2.5	mg/L
7.	TOTAL COLIFORM	APHA 24 th Edition 2023 9221 B	6.7× 10 ⁵	(MPN)/100
8.	FECAL COLIFORM	APHA 24 th Edition 2023 9221 E	1.8× 10 ²	(MPN)/100

Checked by Senior Chemist



Authorised by Lab Manager/CEO

End of Test Report

Remarks:

- BDL: Below Detectable Limit.
- The report pertains only to the sample tested and does not apply to the bulk quantity.
- The test report may not be reproduced, wholly or partially, nor used for promotional or publicity purposes without written consent from the laboratory department.
- Samples will be retained for 15 days after the completion of analysis. A longer retention period can be arranged upon customer request.



ISO 9001:2015 and ISO 17025:2017 NABL certified

No.4, Versetile Industrial Estate, Nr. Kotak Bank, Gate No.5, Kathwada Gidc, Ahmedabad - 382430.

+91 8469130040, +91 6357351655 naturemicrovision@gmail.com GSTIN : 24AAWFN4704G1Z4

Test Report

Report ID: NML/WW/25-26/1114


Date: 13/01/2026

Customer Name		Rajkamal Builders Infrastructure Private Limited		
Customer Address		5.80 MLD STP Talaja		
Date & Time of Sampling	08/01/2026	Sampling Plan & Method	IS 3025(Part-1) RA 2019	
Date of Receipt of Sample	09/01/2026			
Sample Collected by	Client	Sample Condition	SATISFACTORY	
Analysis Starting Date	09/01/2026	Packing / Seal	SEALED	
Analysis Completion Date	12/01/2026	Quantity / No. of Samples	Approx. 1 LIT. * 1NO.	
Environmental Condition	Temperature: 25 °C ± 2	Relative Humidity (%)	Humidity ≤ 50 %	
Sample No.	Sample ID	Sample Type	Location	Description
1.	25-26/1123	Waste Water	Outlet	Treated Water

Analysis Results

Sr. No.	Parameters	Reference Method	Results	Regulatory Limit	Unit
1.	pH	IS 3025 (Part 11): 2022	7.47	6.5-9.0	--
2.	BIOLOGICAL OXYGEN DEMAND (3 days at 27°C)	IS 3025 (Part 44): 2023	8.2	<10	mg/L
3.	CHEMICAL OXYGEN DEMAND	IS 3025 (Part 58) : 2023	43	<50	mg/L
4.	TOTAL SUSPENDED SOLIDS	IS 3025 (Part 17): 1988 (RA 2022)	6.67	<10	mg/L
5.	AMMONICAL NITROGEN	IS 3025 (Part 34/sec-1):2023	1.8	<5	mg/L
6.	TOTAL NITROGEN	IS 3025 (Part 34/sec-1):2023	6.5	<10	mg/L
7.	TOTAL PHOSPHORUS	IS 3025 (Part 31) :Sec 1 : 2022	0.76	<2	mg/L
8.	FECAL COLIFORM	APHA 24 th Edition 2023 9221 E	124	<230	(MPN)/100
9.	RESIDUAL CHLORINE	IS 3025 (Part 31) : Sec 1 : 2022	0.85	0.5-1.0	mg/L
10.	TOTAL COLIFORM	APHA 24 th Edition 2023 9221 B	179	<230	(MPN)/100

Checked by
Senior Chemist



Authorised by
Lab Manager/CEO

Remarks:

- BDL: Below Detectable Limit.
- The report pertains only to the sample tested and does not apply to the bulk quantity.
- The test report may not be reproduced, wholly or partially, nor used for promotional or publicity purposes without written consent from the laboratory department.
- Samples will be retained for 15 days after the completion of analysis. A longer retention period can be arranged upon customer request.



ISO 9001:2015 and ISO 17025:2017 NABL certified

No.4, Versatile Industrial Estate, Nr. Kotak Bank, Gate No.5,
Kathwada Gidc, Ahmedabad - 382430.

+91 8469130040, +91 6357351655 naturemicrovision@gmail.com GSTIN : 24AAWFN4704G1Z4

Test Report

Report ID: NML/WW/25-26/1205

Date: 07/02/2026

Customer Name		Rajkamal Builders Infrastructure Private Limited		
Customer Address		5.80 MLD STP Talaja		
Date & Time of Sampling	02/02/2026	Sampling Plan & Method	IS 3025(Part-1) RA 2019	
Date of Receipt of Sample	03/02/2026			
Sample Collected by	Client	Sample Condition	SATISFACTORY	
Analysis Starting Date	03/02/2026	Packing / Seal	SEALED	
Analysis Completion Date	06/02/2026	Quantity / No. of Samples	Approx. 1 LIT. * 1NO.	
Environmental Condition	Temperature: 25 °C ± 2	Relative Humidity (%)	Humidity ≤ 50 %	
Sample No.	Sample ID	Sample Type	Location	Description
1.	25-26/1214	Waste Water	Inlet	Untreated Water

Analysis Results

Sr. No.	Parameters	Reference Method	Results	Unit
1.	pH	IS 3025 (Part 11): 2022	7.36	--
2.	BIOLOGICAL OXYGEN DEMAND (3 days at 27°C)	IS 3025 (Part 44): 2023	232.2	mg/L
3.	CHEMICAL OXYGEN DEMAND	IS 3025 (Part 58) : 2023	441	mg/L
4.	TOTAL SUSPENDED SOLIDS	IS 3025 (Part 17): 1988 (RA 2022)	346.4	mg/L
5.	TOTAL NITROGEN	IS 3025 (Part 34/sec- 1):2023	33	mg/L
6.	TOTAL PHOSPHORUS	IS 3025 (Part 31) :Sec 1 : 2022	6.9	mg/L
7.	TOTAL COLIFORM	APHA 24 th Edition 2023 9221 B	8.2 × 10 ⁶	(MPN)/100
8.	FECAL COLIFORM	APHA 24 th Edition 2023 9221 E	3.6 × 10 ²	(MPN)/100



Checked by
Senior Chemist

Authorised by
Lab Manager/CEO

End of Test Report

Remarks:

- BDL: Below Detectable Limit.
- The report pertains only to the sample tested and does not apply to the bulk quantity.
- The test report may not be reproduced, wholly or partially, nor used for promotional or publicity purposes without written consent from the laboratory department.
- Samples will be retained for 15 days after the completion of analysis. A longer retention period can be arranged upon customer request.



ISO 9001:2015 and ISO 17025:2017 NABL certified

No.4, Versetile Industrial Estate, Nr. Kotak Bank, Gate No.5,
Kathwada Gidc, Ahmedabad - 382430.

+91 8469130040, +91 6357351655 naturemicrovision@gmail.com GSTIN : 24AAWFN4704G1Z4

Test Report

Report ID: NML/WW/25-26/1206


Date:07/02/2026

Customer Name		Rajkamal Builders Infrastructure Private Limited		
Customer Address		5.80 MLD STP Talaja		
Date & Time of Sampling	02/02/2026	Sampling Plan & Method	IS 3025(Part-1) RA 2019	
Date of Receipt of Sample	03/02/2026			
Sample Collected by	Client	Sample Condition	SATISFACTORY	
Analysis Starting Date	03/02/2026	Packing / Seal	SEALED	
Analysis Completion Date	06/02/2026	Quantity / No. of Samples	Approx. 1 LIT. * 1NO.	
Environmental Condition	Temperature: 25 °C ± 2	Relative Humidity (%)	Humidity ≤ 50 %	
Sample No.	Sample ID	Sample Type	Location	Description
1.	25-26/1215	Waste Water	Outlet	Treated Water

Analysis Results

Sr. No.	Parameters	Reference Method	Results	Regulatory Limit	Unit
1.	pH	IS 3025 (Part 11): 2022	7.41	6.5-9.0	--
2.	BIOLOGICAL OXYGEN DEMAND (3 days at 27°C)	IS 3025 (Part 44): 2023	7.8	<10	mg/L
3.	CHEMICAL OXYGEN DEMAND	IS 3025 (Part 58) : 2023	42	<50	mg/L
4.	TOTAL SUSPENDED SOLIDS	IS 3025 (Part 17): 1988 (RA 2022)	8.27	<10	mg/L
5.	AMMONICAL NITROGEN	IS 3025 (Part 34/sec-1):2023	2.3	<5	mg/L
6.	TOTAL NITROGEN	IS 3025 (Part 34/sec- 1):2023	7.5	<10	mg/L
7.	TOTAL PHOSPHORUS	IS 3025 (Part 31) :Sec 1 : 2022	0.60	<2	mg/L
8.	FECAL COLIFORM	APHA 24 th Edition 2023 9221 E	133	<230	(MPN)/100
9.	RESIDUAL CHLORINE	IS 3025 (Part 31) : Sec 1 : 2022	0.55	0.5-1.0	mg/L
10.	TOTAL COLIFORM	APHA 24 th Edition 2023 9221 B	290	<230	(MPN)/100

Checked by
Senior Chemist



Authorised by
Lab Manager/CEO

Remarks:

- BDL: Below Detectable Limit.
- The report pertains only to the sample tested and does not apply to the bulk quantity.
- The test report may not be reproduced, wholly or partially, nor used for promotional or publicity purposes without written consent from the laboratory department.
- Samples will be retained for 15 days after the completion of analysis. A longer retention period can be arranged upon customer request.



ISO 9001:2015 and ISO 17025:2017 NABL certified

No.4, Versetile Industrial Estate, Nr. Kotak Bank, Gate No.5, Kathwada Gidc, Ahmedabad - 382430.

+91 8469130040, +91 6357351655 naturemicrovision@gmail.com GSTIN : 24AAWFN4704G1Z4

Test Report

Report ID: NML/WW/25-26/1290

Date: 24/02/2026

Customer Name	Rajkamal Builders Infrastructure Private Limited		
Customer Address	5.80 MLD STP Talaja		
Date & Time of Sampling	20/02/2026	Sampling Plan & Method	IS 3025(Part-1) RA 2019
Date of Receipt of Sample	21/02/2026		
Sample Collected by	Client	Sample Condition	SATISFACTORY
Analysis Starting Date	21/02/2026	Packing / Seal	SEALED
Analysis Completion Date	24/02/2026	Quantity / No. of Samples	Approx. 1 LIT. * 1NO.
Environmental Condition	Temperature: 25 °C ± 2	Relative Humidity (%)	Humidity ≤ 50 %

Sample No.	Sample ID	Sample Type	Location	Description
1.	25-26/1299	Waste Water	Inlet	Untreated Water

Analysis Results

Sr. No.	Parameters	Reference Method	Results	Unit
1.	pH	IS 3025 (Part 11): 2022	7.18	--
2.	BIOLOGICAL OXYGEN DEMAND (3 days at 27°C)	IS 3025 (Part 44): 2023	209.6	mg/L
3.	CHEMICAL OXYGEN DEMAND	IS 3025 (Part 58) : 2023	419	mg/L
4.	TOTAL SUSPENDED SOLIDS	IS 3025 (Part 17): 1988 (RA 2022)	296.65	mg/L
5.	TOTAL NITROGEN	IS 3025 (Part 34/sec- 1):2023	30	mg/L
6.	TOTAL PHOSPHORUS	IS 3025 (Part 31) :Sec 1 : 2022	3.9	mg/L
7.	TOTAL COLIFORM	APHA 24 th Edition 2023 9221 B	5.5 × 10 ⁵	(MPN)/100
8.	FECAL COLIFORM	APHA 24 th Edition 2023 9221 E	2.3 × 10 ³	(MPN)/100

Checked by Senior Chemist



Authorised by Lab Manager/CEO

Remarks:

- BDL: Below Detectable Limit.
- The report pertains only to the sample tested and does not apply to the bulk quantity.
- The test report may not be reproduced, wholly or partially, nor used for promotional or publicity purposes without written consent from the laboratory department.
- Samples will be retained for 15 days after the completion of analysis. A longer retention period can be arranged upon customer request.



ISO 9001:2015 and ISO 17025:2017 NABL certified

No.4, Versatile Industrial Estate, Nr. Kotak Bank, Gate No.5,
Kathwada Gidc, Ahmedabad - 382430.

+91 8469130040, +91 6357351655 naturemicrovision@gmail.com GSTIN : 24AAWFN4704G1Z4

Test Report

Report ID: NML/WW/25-26/1291

Date:24/02/2026

Customer Name	Rajkamal Builders Infrastructure Private Limited			
Customer Address	5.80 MLD STP Talaja			
Date & Time of Sampling	20/02/2026	Sampling Plan & Method	IS 3025(Part-1) RA 2019	
Date of Receipt of Sample	21/02/2026			
Sample Collected by	Client	Sample Condition	SATISFACTORY	
Analysis Starting Date	21/02/2026	Packing / Seal	SEALED	
Analysis Completion Date	24/02/2026	Quantity / No. of Samples	Approx. 1 LIT. * 1NO.	
Environmental Condition	Temperature: 25 °C ± 2	Relative Humidity (%)	Humidity ≤ 50 %	
Sample No.	Sample ID	Sample Type	Location	Description
1.	25-26/1300	Waste Water	Outlet	Treated Water

Analysis Results

Sr. No.	Parameters	Reference Method	Results	Regulatory Limit	Unit
1.	pH	IS 3025 (Part 11): 2022	7.48	6.5-9.0	--
2.	BIOLOGICAL OXYGEN DEMAND (3 days at 27°C)	IS 3025 (Part 44): 2023	7.4	<10	mg/L
3.	CHEMICAL OXYGEN DEMAND	IS 3025 (Part 58) : 2023	38	<50	mg/L
4.	TOTAL SUSPENDED SOLIDS	IS 3025 (Part 17): 1988 (RA 2022)	7.75	<10	mg/L
5.	AMMONICAL NITROGEN	IS 3025 (Part 34/sec-1):2023	2.1	<5	mg/L
6.	TOTAL NITROGEN	IS 3025 (Part 34/sec- 1):2023	5.8	<10	mg/L
7.	TOTAL PHOSPHORUS	IS 3025 (Part 31) :Sec 1 : 2022	0.58	<2	mg/L
8.	FECAL COLIFORM	APHA 24 th Edition 2023 9221 E	122	<230	(MPN)/100
9.	RESIDUAL CHLORINE	IS 3025 (Part 31) : Sec 1 : 2022	0.59	0.5-1.0	mg/L
10.	TOTAL COLIFORM	APHA 24 th Edition 2023 9221 B	190	<230	(MPN)/100


Checked by
Senior Chemist




Authorised by
Lab Manager/CEO

Remarks:

- BDL: Below Detectable Limit.
- The report pertains only to the sample tested and does not apply to the bulk quantity.
- The test report may not be reproduced, wholly or partially, nor used for promotional or publicity purposes without written consent from the laboratory department.
- Samples will be retained for 15 days after the completion of analysis. A longer retention period can be arranged upon customer request.



ISO 9001:2015 and ISO 17025:2017 NABL certified

No.4, Versetile Industrial Estate, Nr. Kotak Bank, Gate No.5,
Kathwada Gidc, Ahmedabad - 382430.

+91 8469130040, +91 6357351655 naturemicrovision@gmail.com GSTIN : 24AAWFN4704G1Z4

Test Report

Report ID: NML/WW/25-26/1356

Date: 09/03/2026

Customer Name	Rajkamal Builders Infrastructure Private Limited		
Customer Address	5.80 MLD STP Talaja		
Date & Time of Sampling	04/03/2026	Sampling Plan & Method	IS 3025(Part-1) RA 2019
Date of Receipt of Sample	05/03/2026		
Sample Collected by	Client	Sample Condition	SATISFACTORY
Analysis Starting Date	05/03/2026	Packing / Seal	SEALED
Analysis Completion Date	09/03/2026	Quantity / No. of Samples	Approx. 1 LIT. * 1NO.
Environmental Condition	Temperature: 25 °C ± 2	Relative Humidity (%)	Humidity ≤ 50 %

Sample No.	Sample ID	Sample Type	Location	Description
1.	25-26/1365	Waste Water	Inlet	Untreated Water

Analysis Results

Sr. No.	Parameters	Reference Method	Results	Unit
1.	pH	IS 3025 (Part 11): 2022	8.10	--
2.	BIOLOGICAL OXYGEN DEMAND (3 days at 27°C)	IS 3025 (Part 44): 2023	226	mg/L
3.	CHEMICAL OXYGEN DEMAND	IS 3025 (Part 58) : 2023	435.5	mg/L
4.	TOTAL SUSPENDED SOLIDS	IS 3025 (Part 17): 1988 (RA 2022)	380.67	mg/L
5.	TOTAL NITROGEN	IS 3025 (Part 34/sec- 1):2023	38	mg/L
6.	TOTAL PHOSPHORUS	IS 3025 (Part 31) :Sec 1 : 2022	3.2	mg/L
7.	TOTAL COLIFORM	APHA 24 th Edition 2023 9221 B	6.1 × 10 ⁶	(MPN)/100
8.	FECAL COLIFORM	APHA 24 th Edition 2023 9221 E	1.1 × 10 ²	(MPN)/100

Checked by
Senior Chemist



Authorised by
Lab Manager/CEO

End of Test Report

Remarks:

- BDL: Below Detectable Limit.
- The report pertains only to the sample tested and does not apply to the bulk quantity.
- The test report may not be reproduced, wholly or partially, nor used for promotional or publicity purposes without written consent from the laboratory department.
- Samples will be retained for 15 days after the completion of analysis. A longer retention period can be arranged upon customer request.



ISO 9001:2015 and ISO 17025:2017 NABL certified

No.4, Versetile Industrial Estate, Nr. Kotak Bank, Gate No.5,
Kathwada Gidc, Ahmedabad - 382430.

+91 8469130040, +91 6357351655 naturemicrovision@gmail.com GSTIN : 24AAWFN4704G1Z4

Test Report

Report ID: NML/WW/25-26/1357


Date: 09/03/2026

Customer Name		Rajkamal Builders Infrastructure Private Limited		
Customer Address		5.80 MLD STP Talaja		
Date & Time of Sampling	04/03/2026	Sampling Plan & Method	IS 3025(Part-1) RA 2019	
Date of Receipt of Sample	05/03/2026			
Sample Collected by	Client	Sample Condition	SATISFACTORY	
Analysis Starting Date	05/03/2026	Packing / Seal	SEALED	
Analysis Completion Date	09/03/2026	Quantity / No. of Samples	Approx. 1 LIT. * 1NO.	
Environmental Condition	Temperature: 25 °C ± 2	Relative Humidity (%)	Humidity ≤ 50 %	
Sample No.	Sample ID	Sample Type	Location	Description
1.	25-26/1366	Waste Water	Outlet	Treated Water

Analysis Results

Sr. No.	Parameters	Reference Method	Results	Regulatory Limit	Unit
1.	pH	IS 3025 (Part 11): 2022	7.75	6.5-9.0	--
2.	BIOLOGICAL OXYGEN DEMAND (3 days at 27°C)	IS 3025 (Part 44): 2023	7.9	<10	mg/L
3.	CHEMICAL OXYGEN DEMAND	IS 3025 (Part 58) : 2023	41	<50	mg/L
4.	TOTAL SUSPENDED SOLIDS	IS 3025 (Part 17): 1988 (RA 2022)	7.6	<10	mg/L
5.	AMMONICAL NITROGEN	IS 3025 (Part 34/sec-1):2023	2.3	<5	mg/L
6.	TOTAL NITROGEN	IS 3025 (Part 34/sec-1):2023	5.4	<10	mg/L
7.	TOTAL PHOSPHORUS	IS 3025 (Part 31) :Sec 1 : 2022	0.71	<2	mg/L
8.	FECAL COLIFORM	APHA 24 th Edition 2023 9221 E	140	<230	(MPN)/100
9.	RESIDUAL CHLORINE	IS 3025 (Part 31) : Sec 1 : 2022	0.70	0.5-1.0	mg/L
10.	TOTAL COLIFORM	APHA 24 th Edition 2023 9221 B	225	<230	(MPN)/100

Checked by
Senior Chemist



Authorised by
Lab Manager/CEO

Remarks:

- BDL: Below Detectable Limit.
- The report pertains only to the sample tested and does not apply to the bulk quantity.
- The test report may not be reproduced, wholly or partially, nor used for promotional or publicity purposes without written consent from the laboratory department.
- Samples will be retained for 15 days after the completion of analysis. A longer retention period can be arranged upon customer request.



Green
Enviro Chem LLP
Formerly known as Green Envirocare



9427697145 / 7201000816
greenenvirocarejtp@gmail.com
1st Floor, Gopijan Complex,
Amarnagar Road, Jetpur.

TEST REPORT

Report No.: GE/WW/062025/47	Date of Reporting	:	23-06-2025		
Name & Address of Customer: M/s. Ankita Construction 103, Maruti Titanium, Nr. Galaxy Business Park, Opp. Torrent Power Sub Station, S. P. Ring Road, Nikol, Ahmedabad, Gujarat - 382346	Format No.	:	7.8 F-02		
	Sample Description	:	Waste Water		
	Sampling Type	:	Not Applicable		
	Reference Method for Sampling	:	Not Applicable		
Collection of Sample Date	:	Not Applicable	Sample Collected/Submitted by	:	Sent by Party
Receipt of Sample Date	:	16-06-2025	Sample ID	:	WW/062025/47
Sampling Location	:	STP Inlet (Sutrapada 4 MLD)	Environment condition during the test	:	25 ± 3 °C
Quantity / No. of Sample	:	5 Liter/1 Nos.	Details of Packing/Label/Seal	:	Satisfactory
Analysis Start Date	:	16-06-2025	Analysis Completion Date	:	23-06-2025

Wastewater Analysis Results

Sr. No.	Parameters	Results	Unit	Reference Method
1.	Ammonical Nitrogen as NH ₃ -N	BDL	mg/L	APHA, 24 th Edition 2023/Preliminary Distillation Step & Titrimetric Method 4500- NH ₃ B & C
2.	Chemical Oxygen Demand	244	mg/L	IS 3025 (Part 58):2006/Reaffirmed 2023
3.	Bio Chemical Oxygen Demand @ 27 °C for 3 Days	84.2	mg/L	IS 3025 (Part 44):1993/Reaffirmed 2019
4.	pH at 25 °C	7.43	--	APHA, 24 th Edition 2023/Electrometric Method 4500-H+ B
5.	Total Suspended solids	221.6	mg/L	APHA, 24 th Edition 2023/ Total Suspended Solids Dried at 103-105°C 2540-D

*BDL - Below Detection Limit

Verified By
Sr. Analyst/Analyst



Authorized Signatory
Mr. Hardik Korat
Quality Manager

This Report is issued under the following terms & Condition:

- The report is referring only to the tested sample and for applicable parameter.
- This Test report shall not to be reproduced, except in full unless written permission for the publication of an approved abstract has been obtained from the management of Green Envirocare (Environment Testing Laboratory)
- The sample is retained for a period of 15 Days unless otherwise specified specially.



Green
Enviro Chem LLP
Formerly known as Green Envirocare

9427697145 / 7201000816
greenenvirocarejtp@gmail.com
1st Floor, Gopijan Complex,
Amarnagar Road, Jetpur.

TEST REPORT

Report No.: GE/WW/062025/38		Date of Reporting	: 23-06-2025
Name & Address of Customer: M/s. Ankita Construction 103, Maruti Titanium, Nr. Galaxy Business Park, Opp. Torrent Power Sub Station, S. P. Ring Road, Nikol, Ahmedabad, Gujarat - 382346		Format No.	: 7.8 F-02
		Sample Description	: Waste Water
		Sampling Type	: Not Applicable
		Reference Method for Sampling	: Not Applicable
Collection of Sample Date	: Not Applicable	Sample Collected/Submitted by	: Sent by Party
Receipt of Sample Date	: 16-06-2025	Sample ID	: WW/062025/38
Sampling Location	: STP Inlet (Sutrapada 4 MLD)	Environment condition during the test	: 25 ± 3 °C
Quantity / No. of Sample	: 5 Liter/1 Nos.	Details of Packing/Label/Seal	: Satisfactory
Analysis Start Date	: 16-06-2025	Analysis Completion Date	: 23-06-2025

Wastewater Analysis Results

Sr. No.	Parameters	Results	Unit	Reference Method
1.	TKN	7.28	mg/L	IS 3025 (Part 34)
2.	Total Phosphate	5.16	mg/L	APHA, 24 th Edition 2023

*BDL – Below Detection Limit

Verified By
Sr. Analyst/Analyst



Authorized Signatory
Mr. Hardik Korat
Quality Manager

This Report is issued under the following terms & Condition:

1. The report is referring only to the tested sample and for applicable parameter.
2. This Test report shall not to be reproduced, except in full unless written permission for the publication of an approved abstract has been obtained from the management of Green Envirocare (Environment Testing Laboratory)
3. The sample is retained for a period of 15 Days unless otherwise specified specially.



Green
Enviro Chem LLP
Formerly known as Green Envirocare



9427697145 / 7201000816
greenenvirocarejtp@gmail.com
1st Floor, Gopijan Complex,
Amarnagar Road, Jetpur.

TEST REPORT

Report No.: GE/WW/062025/48	Date of Reporting	:	23-06-2025		
Name & Address of Customer: M/s. Ankita Construction 103, Maruti Titanium, Nr. Galaxy Business Park, Opp. Torrent Power Sub Station, S. P. Ring Road, Nikol, Ahmedabad, Gujarat - 382346	Format No.	:	7.8 F-02		
	Sample Description	:	Waste Water		
	Sampling Type	:	Not Applicable		
	Reference Method for Sampling	:	Not Applicable		
Collection of Sample Date	:	Not Applicable	Sample Collected/Submitted by	:	Sent by Party
Receipt of Sample Date	:	16-06-2025	Sample ID	:	WW/062025/48
Sampling Location	:	STP Outlet (Sutrapada 4 MLD)	Environment condition during the test	:	25 ± 3 ° C
Quantity / No. of Sample	:	5 Liter/1 Nos.	Details of Packing/Label/Seal	:	Satisfactory
Analysis Start Date	:	16-06-2025	Analysis Completion Date	:	23-06-2025

Wastewater Analysis Results

Sr. No.	Parameters	Results	Unit	Reference Method
1.	Ammonical Nitrogen as NH ₃ -N	BDL	mg/L	APHA, 24 th Edition 2023/Preliminary Distillation Step & Titrimetric Method 4500- NH ₃ B & C
2.	Chemical Oxygen Demand	42.5	mg/L	IS 3025 (Part 58):2006/Reaffirmed 2023
3.	Bio Chemical Oxygen Demand @ 27 °C for 3 Days	12.9	mg/L	IS 3025 (Part 44):1993/Reaffirmed 2019
4.	pH at 25 °C	7.12	--	APHA, 24 th Edition 2023/Electrometric Method 4500-H+ B
5.	Total Suspended solids	68	mg/L	APHA, 24 th Edition 2023/ Total Suspended Solids Dried at 103-105°C 2540-D

*BDL - Below Detection Limit

Verified By
Sr. Analyst/Analyst



Authorized Signatory
Mr. Hardik Korat
Quality Manager

This Report is issued under the following terms & Condition:

- The report is referring only to the tested sample and for applicable parameter.
- This Test report shall not to be reproduced, except in full unless written permission for the publication of an approved abstract has been obtained from the management of Green Envirocare (Environment Testing Laboratory)
- The sample is retained for a period of 15 Days unless otherwise specified specially.



Green

Enviro Chem LLP

Formerly known as Green Envirocare

9427697145 / 7201000816
 greenenvirocarejtp@gmail.com
 1st Floor, Gopijan Complex,
 Amarnagar Road, Jetpur.

TEST REPORT

Report No.: GE/WW/062025/39	Date of Reporting	:	23-06-2025		
Name & Address of Customer: M/s. Ankita Construction 103, Maruti Titanium, Nr. Galaxy Business Park, Opp. Torrent Power Sub Station, S. P. Ring Road, Nikol, Ahmedabad, Gujarat - 382346	Format No.	:	7.8 F-02		
	Sample Description	:	Waste Water		
	Sampling Type	:	Not Applicable		
	Reference Method for Sampling	:	Not Applicable		
Collection of Sample Date	:	Not Applicable	Sample Collected/Submitted by	:	Sent by Party
Receipt of Sample Date	:	16-06-2025	Sample ID	:	WW/062025/39
Sampling Location	:	STP Outlet (Sutrapada 4 MLD)	Environment condition during the test	:	25 ± 3 °C
Quantity / No. of Sample	:	5 Liter/1 Nos.	Details of Packing/Label/Seal	:	Satisfactory
Analysis Start Date	:	16-06-2025	Analysis Completion Date	:	23-06-2025

Wastewater Analysis Results

Sr. No.	Parameters	Results	Unit	Reference Method
1.	TKN	4.21	mg/L	IS 3025 (Part 34)
2.	Total Phosphate	3.64	mg/L	APHA, 24 th Edition 2023

*BDL – Below Detection Limit

Verified By
Sr. Analyst/Analyst



Authorized Signatory
Mr. Hardik Korat
Quality Manager

This Report is issued under the following terms & Condition:

- The report is referring only to the tested sample and for applicable parameter.
- This Test report shall not to be reproduced, except in full unless written permission for the publication of an approved abstract has been obtained from the management of Green Envirocare (Environment Testing Laboratory)
- The sample is retained for a period of 15 Days unless otherwise specified specially.

Test Report
Water Sample Analysis Report

Client's Name & Address: GWSSB, veraval, Shivam builders, ahmedabad, talala 3.8 MLD STP	Report No: GLEPL/230259/1397 Issue Date: 26/02/2026
--	--


Lab ID Code	: GLEPL/230222/WL ₁
Sample Description	: Waste Water (STP Inlet) Purpose : As per Client requirement
Date of Sampling	: Submitted by Client Sample Collected/Submitted by : Submitted by Client
Date of Sample Received	: 23/02/2026 Test Parameters : As per Client requirement
Date of starting Analysis	: 24/02/2026 Quantity/No. of sample : 2 Lit./01
Date of completion Analysis	: 26/02/2026 Packed/Seal : Sealed

Result Table

Sr. No.	Test Parameters	Test Method	Unit	Results
1	pH @30 °C	IS 3025 (P-11) 1983 (Reaffirmed 2017)	pH Unit	7.61
2	Total Suspended Solids	IS 3025 (P-17) 1984 (Reaffirmed 2017)	mg/L	372.22
3	Chemical Oxygen Demand	IS 3025 (P-58) 2006 (Reaffirmed 2017)	mg/L	187.10
4	BOD (5 days at 20°C)	IS 3025 (P-44) 1993 (Reaffirmed 2019)	mg/L	82.32
5	Ammonical Nitrogen	IS 3025 (P-34) 1988 (Reaffirmed 2019)	mg/L	16.02
6	Total Phosphorus	IS 3025 (P-31) 1988 (Reaffirmed 2019)	mg/L	BDL
7	Total Kjeldahl Nitrogen	IS 3025 (P-34) 1988 (Reaffirmed 2019)	mg/L	12.22
8	Residual Chlorine	IS 3025 (P-26) 1986 (Reaffirmed 2019)	mg/L	ND
9	Fecal Coliform	APHA & AWWA 23 rd Ed. 9221 E (9-77)	MPN/100MI	450.00
10	Total Coliform	APHA & AWWA 23 rd Ed. 9221 E (9-77)	MPN/100MI	750.00

Note: BDL: Below Detection Limit, ND: Not Detected.

WL₁: STP Inlet Water



Chemist



Authorized Signatory
Rekha Dare

Notes: (1) The results pertain to tested items only.

(2) This report shall not be reproduced, except in full, without written approval of the laboratory.

(3) Authenticity of this Report could be validated with office copy at Greenleaf Evirotech Pvt. Ltd.

(4) Perishable samples will be destroyed after testing, others after 7 days from the date of issue of the report, unless otherwise agreed with the customer or as required by the applicable regulations.

Test Report
Water Sample Analysis Report

Client's Name & Address: GWSSB, veraval, Shivam builders, ahmedabad, talala 3.8 MLD STP	Report No: GLEPL/230259/1397 Issue Date: 26/02/2026
--	--


Lab ID Code	:	GLEPL/230222/WL ₁		
Sample Description	:	Waste Water (STP outlet)	Purpose	: As per Client requirement
Date of Sampling	:	Submitted by Client	Sample Collected/Submitted by	: Submitted by Client
Date of Sample Received	:	23/02/2026	Test Parameters	: As per Client requirement
Date of starting Analysis	:	24/02/2026	Quantity/No. of sample	: 2 Lit./01
Date of completion Analysis	:	26/02/2026	Packed/Seal	: Sealed

Result Table

Sr. No.	Test Parameters	Test Method	Unit	Results	Permissible Limit
1	pH @30 °C	IS 3025 (P-11) 1983 (Reaffirmed 2017)	pH Unit	7.58	6.5-9.0
2	Total Suspended Solids	IS 3025 (P-17) 1984 (Reaffirmed 2017)	mg/L	6.10	<10
3	Chemical Oxygen Demand	IS 3025 (P-58) 2006 (Reaffirmed 2017)	mg/L	22.13	<50
4	BOD (5 days at 20°C)	IS 3025 (P-44) 1993 (Reaffirmed 2019)	mg/L	5.04	<10
5	Ammonical Nitrogen	IS 3025 (P-34) 1988 (Reaffirmed 2019)	mg/L	2.48	<5.0
6	Total Phosphorus	IS 3025 (P-31) 1988 (Reaffirmed 2019)	mg/L	BDL	<1.0
7	Total Nitrogen	IS 3025 (P-34) 1988 (Reaffirmed 2019)	mg/L	5.06	<10.0
8	Residual Chlorines	IS 3025 (P-26) 1986 (Reaffirmed 2019)	mg/L	0.71	0.5-1.0
9	Faecal Coliform	APHA & AWWA 23 rd Ed. 9221 E (9-77)	MPN/100mL	96	<230
10	Total Coliform	APHA & AWWA 23 rd Ed. 9221 E (9-77)	MPN/10 OMI	130	<230

Note: BDL: Below Detection Limit.

WL₁: STP Outlet Water



Chemist



Authorized Signatory
Rekha Dare

Notes: (1) The results pertain to tested items only.

(2) This report shall not be reproduced, except in full, without written approval of the laboratory.

(3) Authenticity of this Report could be validated with office copy at Greenleaf Evirotech Pvt. Ltd.

(4) Perishable samples will be destroyed after testing, others after 7 days from the date of issue of the report, unless otherwise agreed with the customer or as required by the applicable regulations.

Recognized by MoEF, Govt. of India, EP Act 1986; NABL accredited; GPCB Schedule II Environment Auditor; OHSAS – 18001:2017 Certified Laboratory.



CCS
Enviro Control LLP

4558

ACCREDITED LAB :
17-18, Block-B,
2nd Floor, Amrapali Complex,
Bopal Cross Roads, SPRR,
Ahmedabad - 380 058
Email: amd@cometconserve.com
Tele: (+91) 2717 489859

609

(Formerly known as Comet Consultancy Services)

Schedule II Environmental Auditor (GPCB)
NABL Accreditation - ISO / IEC 17025 : 2017

RefNo. :AMD/W/19/03/2025-2026

Date:17/03/2026

TEST REPORT OF PHYSICO-CHEMICAL ANALYSIS

F/OPN/07
IssueNo:02
Page1of1

Name of Company: Kunal Structure (India) Pvt Ltd.

Address Mondeal Heights, B-Wing, 15th Floor, Opp. Karnavati Club, S.G. Highway, Ahmedabad - 380015, Gujarat India.

Name of Site: 4.9 MLD STP Manavadar (Junagadh District)

Discipline	: Chemical	Group	: Pollution and Environment
Description of Sample	: STP Inlet	Quantity/No. Of Samples	: 02Liters
Date of Sampling	: 09/03/2026	Sampling Procedure	: Not Specified
Sampling By	: Party	Purpose	: --
Sample Receipt Date	: 10/03/2026	Lab ID	: W-14
Packing/Seal	: Sealed	Test Parameters & Method	: APHA23 rd Edition/IS3025
Analysis Started on	: 11/03/2026	Analysis Concluded on	: 16/03/2026
Environment condition during testing	: 25±2°C	Location of test performance	: At Laboratory

TESTRESULTS

Sr. No.	Parameters	Unit	Permissible Limits	Test Results	TestMethod
1.	pH@25°C	pH Unit	--	7.25	APHA-23 rd Edition4500H ⁺ B
2.	Total Suspended Solids(TSS)	mg/L	--	225	APHA-23 rd Edition2540D
3.	Chemical Oxygen Demand(COD)	mg/L	--	425	APHA-23 rd Edition5220B
4.	Biochemical OxygenDemand(BOD) @27°Cfor3days	mg/L	--	215	IS3025(Part44):1993
5.	Total Nitrogen	mg/L	--	22	APHA-23 rd Edition4500NC
6.	Total Phosphorus	mg/L	--	4.00	APHA-23 rd Edition4500PD
7.	Total Coli form	MPN/100ml	--	10 ⁸	APHA-23 rd Edition9221-B&E
8.	Fecal Coli form	MPN/100ml	--	10 ⁵	APHA-23 rd Edition9221-B&E

Tested By: Jay Fadadu
Designation : Chemist



Reviewed & Approved By: Kalpesh Shah
Designation : Technical Manager

Rajkot - Registered Office:
E-mail ; rjt@cometconserve.com
Tele: (+91) 281 2225675 / 2226399

Ankleshwar - Branch Office:
E-mail : ccs.ankleshwar@gmail.com
Tele: (+91) 2646 245263





CCS
Enviro Control LLP

4559

ACCREDITED LAB :
17-18, Block-B,
2nd Floor, Amrapali Complex,
Bopal Cross Roads, SPRR,
Ahmedabad - 380 058
Email: amd@cometconserve.com
Tele: (+91) 2717 489859

610

(Formerly known as Comet Consultancy Services)

Schedule II Environmental Auditor (GPCB)
NABL Accreditation - ISO / IEC 17025 : 2017

RefNo.:AMD/W/20/03/2025-2026

Date:17/03/2026

TESTREPORTOFPHYSICO-CHEMICALANALYSIS

F/OPN/07
IssueNo:02
Page1of1

Name of Company: Kunal Structure (India) Pvt Ltd.
Address Mondeal Heights, B-Wing, 15th Floor, Opp. Karnavati Club, S.G. Highway, Ahmedabad - 380015, Gujarat India.

Name of Site: 4.9 MLD STP Manavadar (Junagadh District)

Discipline	: Chemical	Group	: Pollution and Environment
Description of Sample	: STP Outlet	Quantity/No. Of Samples	: 02Liters
Date of Sampling	: 09/03/2026	Sampling Procedure	: Not Specified
Sampling By	: Party	Purpose	: --
Sample Receipt Date	: 10/03/2026	Lab ID	: W-15
Packing/Seal	: Sealed	Test Parameters & Method	: APHA23 rd Edition/IS3025
Analysis Started on	: 11/03/2026	Analysis Concluded on	: 16/03/2026
Environment condition during testing	: 25±2°C	Location of test performance	: At Laboratory

TESTRESULTS

Sr. No.	Parameters	Unit	Permissible Limits	Test Results	TestMethod
1.	pH@25°C	pHUnit	6.5-9.0	7.22	APHA-23 rd Edition4500H ⁺ B
2.	Total Suspended Solids(TSS)	mg/L	<10	6.5	APHA-23 rd Edition2540D
3.	Chemical Oxygen Demand(COD)	mg/L	<50	19	APHA-23 rd Edition5220 B
4.	Biochemical Oxygen Demand(BOD) @27°Cfor3days	mg/L	<10	4	IS3025(Part44):1993
5.	Free Residual Chlorine	mg/L	0.5-1.0	0.68	APHA-23 rd Edition4500CIB
6.	Total Nitrogen	mg/L	<10	5.3	APHA-23 rd Edition4500NC
7.	Total Phosphorus	mg/L	<1	0.3	APHA-23 rd Edition4500PD
8.	Total Coli form	MPN/100ml	<230	38	APHA-23 rd Edition9221-B&E
9.	Fecal Coli form	MPN/100ml	<230	35	APHA-23 rd Edition9221-B&E



Jay Fadadu

Tested By: Jay Fadadu
Designation : Chemist

Kalpesh Shah

Reviewed & Approved By: Kalpesh Shah
Designation : Technical Manager

Rajkot - Registered Office:
E-mail ; rjt@cometconserve.com
Tele: (+91) 281 2225675 / 2226399

Ankleshwar - Branch Office:
E-mail ; ccs.ankleshwar@gmail.com
Tele: (+91) 2646 245253





TANISHKA EARTH CARE SERVICES (OPC) PRIVATE LIMITED

AN ISO/IEC 17025 NABL ACCREDITED ENVIRONMENT TESTING LABORATORY

GPCB Recognized Environmental Auditor (Schedule -II)

PLOT NO.111. HIRA PARK, OPP- VISHAL HOTEL, JAMNAGAR - 361006

+91 78749 15777 | +91 98794 06097 | tanishkaearthcare@gmail.com

TEST REPORT

Company Name	M/s. Krishna Construction Company	Sample ID	WQ/26/01/49
Address	1st Floor,H-110, Shreedhar Flora, Amar JavanCircle, Nikol Gam Road, Ahmedabad.382350	Condition of sample	Satisfactory
		Sample Done By	Customer
		Quantity of Sample	1000 ml
		Sampling Method	APHA
Date of Sampling	19.01.2026	Date of Sample Received	19.01.2026
Analysis Starts Date	19.01.2026	Analysis Completion Date	23.01.2026
Sample Description	OUTLET AT CHORVAD 3.70 MLD STP	Temperature/ Humidity during testing	Temp.- 25-29 deg C / Humidity <50 %
Report Number:	LAB/WQ/26/01/49	Report Date:	23.01.2026

S.No.	PARAMETERS	UNIT	RESULTS	LIMIT	Testing Method/ Standard
PHYSICAL CHEMICAL AND MICRO PARAMETERS					
1	pH @ 27 deg.	--	7.80	6.5-9	APHA 24 th Edition 4500 B; 2023
2	Total Suspended Solids	mg/l	7.00	<10	APHA 24 th Edition 2540 D; 2023
3	Total Phosphorus	mg/l	0.58	<1	APHA 24 th Edition 4500P D; 2023
4	Chemical Oxygen Demand	mg/l	26.72	<50	IS 3025 (Part 58) 2006
5	Biochemical Oxygen Demand	mg/l	7.92	<10	IS 3025 (Part 44) 1993
6	Ammonical Nitrogen	mg/l	3.54	<5	APHA 24 th Edition 4500 NH3 C; 2023
7	Total Nitrogen	mg/l	7.90	<10	APHA 24 th Edition 4500 N113C / Norg B/ NO3 B/NO2 B; 2023
8	Faecal Coliform	MPN/100 ml	50.00	<100	IS 1622
9	Total Coliform	MPN/100 ml	70.00	<100	IS 1622

Checked By :	Parth Bandhiya	Authorized Signatory :	Mufaddal Nathani
Signature :		Signature :	
Designation :	Chemist	Designation :	Technical Manager

Notes:

- The report shall not be reproduced except in full without approval of the laboratory can provide assurance that parts of a report are not taken out of context.
- This certificate is based on the sample submitted for testing.
- Additions to, deviations, or exclusions from the method- NA
- Results which were outsourced to external providers are marked with ** and results which are performed and not in NABL accreditation scope are marked with * in parameter column
- Disclaimer: When the information is supplied by the customer and can affect the validity of results
- Disclaimer: The report that the results apply to the sample as received in case of the sample has been supplied by customer
- Disclaimer: The laboratory shall be responsible for all the information provided in the report, except when information is provided by the customer
- Regulatory limit reference if any:- NA
- Opinion, Interpretation & Statement of Conformity if provided can be referred in the remarks section as "Permissible" "Below acceptable" or whatever is applicable as per the limit
- BDL : Below Detection Limit

● End of the Test Report ●



TANISHKA EARTH CARE SERVICES (OPC) PRIVATE LIMITED

AN ISO/IEC 17025 NABL ACCREDITED ENVIRONMENT TESTING LABORATORY

GPCB Recognized Environmental Auditor (Schedule -II)

PLOT NO.111. HIRA PARK, OPP- VISHAL HOTEL, JAMNAGAR - 361006

+91 78749 15777 | +91 98794 06097 | tanishkaearthcare@gmail.com

TEST REPORT

Company Name	M/s. Krishna Construction Company	Sample ID	WQ/26/01/48
Address	1st Floor,H-110, Shreedhar Flora, Amar JavanCircle, Nikol Gam Road, Ahmedabad.382350	Condition of sample	Satisfactory
		Sample Done By	Customer
		Quantity of Sample	1000 ml
		Sampling Method	APHA
Date of Sampling	19.01.2026	Date of Sample Received	19.01.2026
Analysis Starts Date	19.01.2026	Analysis Completion Date	23.01.2026
Sample Description	INLET AT CHORVAD 3.70 MLD STP	Temperature/ Humidity during testing	Temp.- 25-29 deg C / Humidity <50 %
Report Number:	LAB/WQ/26/01/48	Report Date:	23.01.2026

S.No.	PARAMETERS	UNIT	RESULTS	LIMIT	Testing Method/ Standard
PHYSICAL CHEMICAL AND MICRO PARAMETERS					
1	pH @ 27 deg.	--	7.38		APHA 24 th Edition 4500 B: 2023
2	Total Suspended Solids	mg/l	320.00		APHA 24 th Edition 2540 D: 2023
3	Total Phosphorus	mg/l	1.99		APHA 24 th Edition 4500P D: 2023
4	Chemical Oxygen Demand	mg/l	632.86		IS 3025 (Part 58) 2006
5	Biochemical Oxygen Demand	mg/l	224.78		IS 3025 (Part 44) 1993
6	Ammonical Nitrogen	mg/l	22.80		APHA 24 th Edition 4500 NH3 C : 2023
7	Total Kjeldhal Nitrogen	mg/l	42.66		APHA 24 th Edition 4500 NH3 C/Norg B:2017
8	Nitrate	mg/l	20.98		APHA 24 th Edition 4500 NO3 B: 2023
9	Nitrite	mg/l	0.06		APHA 24 th Edition 4500 NO2 B: 2023
10	Total Nitrogen	mg/l	63.70		APHA 24 th Edition 4500 N113C / Norg B/ NO3 B/NO2 B; 2023
11	Faecal Coliform	MPN/100 ml	500.00		IS 1622
12	Total Coliform	MPN/100 ml	900.00		IS 1622

Checked By :	Parth Bandhiya	Authorized Signatory :	Mufaddal Nathani
Signature :		Signature :	
Designation :	Chemist	Designation :	Technical Manager



- Notes:**
- The report shall not be reproduced except in full without approval of the laboratory can provide assurance that parts of a report are not taken out of context.
 - This certificate is based on the sample submitted for testing.
 - Additions to, deviations, or exclusions from the method- NA
 - Results which were outsourced to external providers are marked with ** and results which are performed and not in NABL accreditation scope are marked with * in parameter column
 - Disclaimer: When the information is supplied by the customer and can affect the validity of results
 - Disclaimer: The report that the results apply to the sample as received in case of the sample has been supplied by customer
 - Disclaimer: The laboratory shall be responsible for all the information provided in the report, except when information is provided by the customer
 - Regulatory limit reference if any:- NA
 - Opinion, Interpretation & Statement of Conformity if provided can be referred in the remarks section as "Permissible" "Below acceptable" or whatever is applicable as per the limit
 - BDL : Below Detection Limit

● End of the Test Report ●

TANISHKA EARTH CARE SERVICES (OPC) PRIVATE LIMITED



TANISHKA EARTH CARE SERVICES (OPC) PRIVATE LIMITED

AN ISO/IEC 17025 NABL ACCREDITED ENVIRONMENT TESTING LABORATORY

GPCB Recognized Environmental Auditor (Schedule -II)

PLOT NO.111. HIRA PARK, OPP- VISHAL HOTEL, JAMNAGAR - 361006

+ 91 78749 15777 | + 91 98794 06097 | tanishkaearthcare@gmail.com

TEST REPORT

Company Name	M/s. Krishna Construction Company	Sample ID	WQ/26/01/45
Address	1st Floor,H-110, Shreedhar Flora, Amar JavanCircle, Nikol Gam Road, Ahmedabad.382350	Condition of sample	Satisfactory
		Sample Done By	Customer
		Quantity of Sample	1000 ml
		Sampling Method	APHA
Date of Sampling	12.01.2026	Date of Sample Received	12.01.2026
Analysis Starts Date	12.01.2026	Analysis Completion Date	19.01.2026
Sample Description	OUTLET AT CHORVAD 3.70 MLD STP	Temperature/ Humidity during testing	Temp.- 25-29 deg C / Humidity <50 %
Report Number:	LAB/WQ/26/01/45	Report Date:	19.01.2026

S.No.	PARAMETERS	UNIT	RESULTS	LIMIT	Testing Method/ Standard
PHYSICAL CHEMICAL AND MICRO PARAMETERS					
1	pH @ 27 deg.	--	7.82	6.5-9	APHA 24 th Edition 4500 B: 2023
2	Total Suspended Solids	mg/l	7.00	<10	APHA 24 th Edition 2540 D: 2023
3	Total Phosphorus	mg/l	0.62	<1	APHA 24 th Edition 4500P D: 2023
4	Chemical Oxygen Demand	mg/l	28.58	<50	IS 3025 (Part 58) 2006
5	Biochemical Oxygen Demand	mg/l	8.22	<10	IS 3025 (Part 44) 1993
6	Ammonical Nitrogen	mg/l	3.86	<5	APHA 24 th Edition 4500 NH3 C: 2023
7	Total Nitrogen	mg/l	8.24	<10	APHA 24 th Edition 4500 N113C / Norg B/ NO3 B/NO2 B: 2023
8	Faecal Coliform	MPN/100 ml	70.00	<100	IS 1622
9	Total Coliform	MPN/100 ml	80.00	<100	IS 1622

Checked By :	Parth Bandhiya	Authorized Signatory :	Mufaddal Nathani
Signature :		Signature :	
Designation :	Chemist	Designation :	Technical Manager

Notes:

- The report shall not be reproduced except in full without approval of the laboratory can provide assurance that parts of a report are not taken out of context.
- This certificate is based on the sample submitted for testing.
- Additions to, deviations, or exclusions from the method- NA
- Results which were outsourced to external providers are marked with ** and results which are performed and not in NABL accreditation scope are marked with * in parameter column
- Disclaimer: When the information is supplied by the customer and can affect the validity of results
- Disclaimer: The report that the results apply to the sample as received in case of the sample has been supplied by customer
- Disclaimer: The laboratory shall be responsible for all the information provided in the report, except when information is provided by the customer
- Regulatory limit reference if any:- NA
- Opinion, Interpretation & Statement of Conformity if provided can be referred in the remarks section as "Permissible" "Below acceptable" or whatever is applicable as per the limit
- BDL : Below Detection Limit

● End of the Test Report ●



TANISHKA EARTH CARE SERVICES (OPC) PRIVATE LIMITED

AN ISO/IEC 17025 NABL ACCREDITED ENVIRONMENT TESTING LABORATORY

GPCB Recognized Environmental Auditor (Schedule -II)

PLOT NO.111. HIRA PARK, OPP- VISHAL HOTEL, JAMNAGAR - 361006

+91 78749 15777 | +91 98794 06097 | tanishkaearthcare@gmail.com

TEST REPORT

Company Name	M/s. Krishna Construction Company	Sample ID	WQ/26/01/44
Address	1st Floor,H-110, Shreedhar Flora, Amar JavanCircle, Nikol Gam Road, Ahmedabad.382350	Condition of sample	Satisfactory
		Sample Done By	Customer
		Quantity of Sample	1000 ml
		Sampling Method	APHA
Date of Sampling	12.01.2026	Date of Sample Received	12.01.2026
Analysis Starts Date	12.01.2026	Analysis Completion Date	19.01.2026
Sample Description	INLET AT CHORVAD 3.70 MLD STP	Temperature/ Humidity during testing	Temp.- 25-29 deg C / Humidity <50 %
Report Number:	LAB/WQ/26/01/44	Report Date:	19.01.2026

S.No.	PARAMETERS	UNIT	RESULTS	LIMIT	Testing Method/ Standard
PHYSICAL CHEMICAL AND MICRO PARAMETERS					
1	pH @ 27 deg.	--	7.44		APHA 24 th Edition 4500 B: 2023
2	Total Suspended Solids	mg/l	315.00		APHA 24 th Edition 2540 D: 2023
3	Total Phosphorus	mg/l	2.10		APHA 24 th Edition 4500P D: 2023
4	Chemical Oxygen Demand	mg/l	634.62		IS 3025 (Part 58) 2006
5	Biochemical Oxygen Demand	mg/l	226.80		IS 3025 (Part 44) 1993
6	Ammonical Nitrogen	mg/l	24.92		APHA 24 th Edition 4500 NH3 C : 2023
7	Total Kjeldhal Nitrogen	mg/l	40.58		APHA 24 th Edition 4500 NH3 C/Norg B:2017
8	Nitrate	mg/l	21.84		APHA 24 th Edition 4500 NO3 B: 2023
9	Nitrite	mg/l	0.05		APHA 24 th Edition 4500 NO2 B: 2023
10	Total Nitrogen	mg/l	62.47		APHA 24 th Edition 4500 N113C / Norg B/ NO3 B/NO2 B: 2023
11	Faecal Coliform	MPN/100 ml	500.00		IS 1622
12	Total Coliform	MPN/100 ml	900.00		IS 1622

Checked By :	Parth Bandhiya	Authorized Signatory :	Mufaddal Nathani
Signature :		Signature :	
Designation :	Chemist	Designation :	Technical Manager

Notes:

- The report shall not be reproduced except in full without approval of the laboratory can provide assurance that parts of a report are not taken out of context.
- This certificate is based on the sample submitted for testing.
- Additions to, deviations, or exclusions from the method- NA
- Results which were outsourced to external providers are marked with ** and results which are performed and not in NABL accreditation scope are marked with * in parameter column
- Disclaimer: When the information is supplied by the customer and can affect the validity of results
- Disclaimer: The report that the results apply to the sample as received in case of the sample has been supplied by customer
- Disclaimer: The laboratory shall be responsible for all the information provided in the report, except when information is provided by the customer
- Regulatory limit reference if any:- NA
- Opinion, Interpretation & Statement of Conformity if provided can be referred in the remarks section as "Permissible" "Below acceptable" or whatever is applicable as per the limit
- BDL : Below Detection Limit

● End of the Test Report ●





TANISHKA EARTH CARE SERVICES (OPC) PRIVATE LIMITED

AN ISO/IEC 17025 NABL ACCREDITED ENVIRONMENT TESTING LABORATORY

GPCB Recognized Environmental Auditor (Schedule -II)

PLOT NO.111. HIRA PARK, OPP- VISHAL HOTEL, JAMNAGAR - 361006

+91 78749 15777 | +91 98794 06097 | tanishkaearthcare@gmail.com

TEST REPORT

Company Name	M/s. Krishna Construction Company	Sample ID	WQ/26/02/44
Address	1st Floor,H-110, Shreedhar Flora, Amar JavanCircle, Nikol Gam Road, Ahmedabad.382350	Condition of sample	Satisfactory
		Sample Done By	Customer
		Quantity of Sample	1000 ml
		Sampling Method	APHA
Date of Sampling	24.02.2026	Date of Sample Received	24.02.2026
Analysis Starts Date	24.02.2026	Analysis Completion Date	28.02.2026
Sample Description	OUTLET AT CHORVAD 3.70 MLD STP	Temperature/ Humidity during testing	Temp.- 25-29 deg C / Humidity <50 %
Report Number:	LAB/WQ/26/02/44	Report Date:	28.02.2026

S.No.	PARAMETERS	UNIT	RESULTS	LIMIT	Testing Method/ Standard
PHYSICAL CHEMICAL AND MICRO PARAMETERS					
1	pH @ 27 deg.	--	7.80	6.5-9	APHA 24 th Edition 4500 B: 2023
2	Total Suspended Solids	mg/l	8.00	<10	APHA 24 th Edition 2540 D: 2023
3	Total Phosphorus	mg/l	0.54	<1	APHA 24 th Edition 4500P D: 2023
4	Chemical Oxygen Demand	mg/l	26.84	<50	IS 3025 (Part 58) 2006
5	Biochemical Oxygen Demand	mg/l	7.53	<10	IS 3025 (Part 44) 1993
6	Ammonical Nitrogen	mg/l	2.50	<5	APHA 24 th Edition 4500 NH3 C : 2023
7	Total Nitrogen	mg/l	6.28	<10	APHA 24 th Edition 4500 N113C / Norg B/ NO3 B/NO2 B; 2023
8	Faecal Coliform	MPN/100 ml	50.00	<100	IS 1622
9	Total Coliform	MPN/100 ml	70.00	<100	IS 1622

Checked By :	Parth Bandhiya	Authorized Signatory :	Mufaddal Nathani
Signature :		Signature :	
Designation :	Chemist	Designation :	Technical Manager

Notes:

- The report shall not be reproduced except in full without approval of the laboratory can provide assurance that parts of a report are not taken out of context.
- This certificate is based on the sample submitted for testing.
- Additions to, deviations, or exclusions from the method- NA
- Results which were outsourced to external providers are marked with ** and results which are performed and not in NABL accreditation scope are marked with * in parameter column
- Disclaimer: When the information is supplied by the customer and can affect the validity of results
- Disclaimer: The report that the results apply to the sample as received in case of the sample has been supplied by customer
- Disclaimer: The laboratory shall be responsible for all the information provided in the report, except when information is provided by the customer
- Regulatory limit reference if any:- NA
- Opinion, Interpretation & Statement of Conformity if provided can be referred in the remarks section as "Permissible" "Below acceptable" or whatever is applicable as per the limit
- BDL : Below Detection Limit

● End of the Test Report ●



TANISHKA EARTH CARE SERVICES (OPC) PRIVATE LIMITED

AN ISO/IEC 17025 NABL ACCREDITED ENVIRONMENT TESTING LABORATORY

GPCB Recognized Environmental Auditor (Schedule -II)

PLOT NO.111. HIRA PARK, OPP- VISHAL HOTEL, JAMNAGAR - 361006

+91 78749 15777 | +91 98794 06097 | tanishkaearthcare@gmail.com

TEST REPORT

Company Name	M/s. Krishna Construction Company	Sample ID	WQ/26/02/43
Address	1st Floor,H-110, Shreedhar Flora, Amar JavanCircle, Nikol Gam Road, Ahmedabad.382350	Condition of sample	Satisfactory
		Sample Done By	Customer
		Quantity of Sample	1000 ml
		Sampling Method	APHA
Date of Sampling	24.02.2026	Date of Sample Received	24.02.2026
Analysis Starts Date	24.02.2026	Analysis Completion Date	28.02.2026
Sample Description	INLET AT CHORVAD 3.70 MLD STP	Temperature/ Humidity during testing	Temp.- 25-29 deg C / Humidity <50 %
Report Number:	LAB/WQ/26/02/43	Report Date:	28.02.2026

S.No.	PARAMETERS	UNIT	RESULTS	LIMIT	Testing Method/ Standard
PHYSICAL CHEMICAL AND MICRO PARAMETERS					
1	pH @ 27 deg.	--	7.52		APHA 24 th Edition 4500 B: 2023
2	Total Suspended Solids	mg/l	310.00		APHA 24 th Edition 2540 D: 2023
3	Total Phosphorus	mg/l	2.10		APHA 24 th Edition 4500P D: 2023
4	Chemical Oxygen Demand	mg/l	640.56		IS 3025 (Part 58) 2006
5	Biochemical Oxygen Demand	mg/l	230.50		IS 3025 (Part 44) 1993
6	Ammonical Nitrogen	mg/l	30.44		APHA 24 th Edition 4500 NH3 C: 2023
7	Total Kjeldhal Nitrogen	mg/l	42.98		APHA 24 th Edition 4500 NH3 C/Norg B:2017
8	Nitrate	mg/l	18.54		APHA 24 th Edition 4500 NO3 B: 2023
9	Nitrite	mg/l	0.10		APHA 24 th Edition 4500 NO2 B: 2023
10	Total Nitrogen	mg/l	61.62		APHA 24 th Edition 4500 N113C / Norg B/ NO3 B/NO2 B: 2023
11	Faecal Coliform	MPN/100 ml	900.00		IS 1622
12	Total Coliform	MPN/100 ml	1600.00		IS 1622

Checked By :	Parth Bandhiya	Authorized Signatory :	Mufaddal Nathani
Signature :		Signature :	
Designation :	Chemist	Designation :	Technical Manager

- Notes:**
- The report shall not be reproduced except in full without approval of the laboratory can provide assurance that parts of a report are not taken out of context.
 - This certificate is based on the sample submitted for testing.
 - Additions to, deviations, or exclusions from the method- NA
 - Results which were outsourced to external providers are marked with ** and results which are performed and not in NABL accreditation scope are marked with * in parameter column
 - Disclaimer: When the information is supplied by the customer and can affect the validity of results
 - Disclaimer: The report that the results apply to the sample as received in case of the sample has been supplied by customer
 - Disclaimer: The laboratory shall be responsible for all the information provided in the report, except when information is provided by the customer
 - Regulatory limit reference if any:- NA
 - Opinion, Interpretation & Statement of Conformity if provided can be referred in the remarks section as "Permissible" "Below acceptable" or whatever is applicable as per the limit
 - BDL : Below Detection Limit

● End of the Test Report ●

TANISHKA EARTH CARE SERVICES (OPC) PRIVATE LIMITED



TANISHKA EARTH CARE SERVICES (OPC) PRIVATE LIMITED

AN ISO/IEC 17025 NABL ACCREDITED ENVIRONMENT TESTING LABORATORY

GPCB Recognized Environmental Auditor (Schedule -II)

PLOT NO.111. HIRA PARK, OPP- VISHAL HOTEL, JAMNAGAR - 361006

+91 78749 15777 | +91 98794 06097 | tanishkaearthcare@gmail.com

TEST REPORT

Company Name	M/s. Krishna Construction Company	Sample ID	WQ/26/02/40
Address	1st Floor,H-110, Shreedhar Flora, Amar JavanCircle, Nikol Gam Road, Ahmedabad.382350	Condition of sample	Satisfactory
		Sample Done By	Customer
		Quantity of Sample	1000 ml
		Sampling Method	APHA
Date of Sampling	10.02.2026	Date of Sample Received	10.02.2026
Analysis Starts Date	10.02.2026	Analysis Completion Date	15.02.2026
Sample Description	OUTLET AT CHORVAD 3.70 MLD STP	Temperature/ Humidity during testing	Temp.- 25-29 deg C / Humidity <50 %
Report Number:	LAB/WQ/26/02/40	Report Date:	15.02.2026

S.No.	PARAMETERS	UNIT	RESULTS	LIMIT	Testing Method/ Standard
PHYSICAL CHEMICAL AND MICRO PARAMETERS					
1	pH @ 27 deg.	--	7.82	6.5-9	APHA 24 th Edition 4500 B: 2023
2	Total Suspended Solids	mg/l	8.00	<10	APHA 24 th Edition 2540 D: 2023
3	Total Phosphorus	mg/l	0.58	<1	APHA 24 th Edition 4500P D: 2023
4	Chemical Oxygen Demand	mg/l	28.62	<50	IS 3025 (Part 58) 2006
5	Biochemical Oxygen Demand	mg/l	7.86	<10	IS 3025 (Part 44) 1993
6	Ammonical Nitrogen	mg/l	2.44	<5	APHA 24 th Edition 4500 NH3 C : 2023
7	Total Nitrogen	mg/l	6.78	<10	APHA 24 th Edition 4500 N113C / Norg B/ NO3 B/NO2 B; 2023
8	Faecal Coliform	MPN/100 ml	70.00	<100	IS 1622
11	Total Coliform	MPN/100 ml	80.00	<100	IS 1622

Checked By :	Parth Bandhiya	Authorized Signatory :	Mufaddal Nathani
Signature :		Signature :	
Designation :	Chemist	Designation :	Technical Manager

Notes:

- The report shall not be reproduced except in full without approval of the laboratory can provide assurance that parts of a report are not taken out of context.
- This certificate is based on the sample submitted for testing.
- Additions to, deviations, or exclusions from the method- NA
- Results which were outsourced to external providers are marked with ** and results which are performed and not in NABL accreditation scope are marked with * in parameter column
- Disclaimer: When the information is supplied by the customer and can affect the validity of results
- Disclaimer: The report that the results apply to the sample as received in case of the sample has been supplied by customer
- Disclaimer: The laboratory shall be responsible for all the information provided in the report, except when information is provided by the customer
- Regulatory limit reference if any:- NA
- Opinion, Interpretation & Statement of Conformity if provided can be referred in the remarks section as "Permissible" "Below acceptable" or whatever is applicable as per the limit
- BDL : Below Detection Limit

● End of the Test Report ●





TANISHKA EARTH CARE SERVICES (OPC) PRIVATE LIMITED

AN ISO/IEC 17025 NABL ACCREDITED ENVIRONMENT TESTING LABORATORY

GPCB Recognized Environmental Auditor (Schedule -II)

PLOT NO.111. HIRA PARK, OPP- VISHAL HOTEL, JAMNAGAR - 361006

+91 78749 15777 | +91 98794 06097 | tanishkaearthcare@gmail.com

TEST REPORT

Company Name	M/s. Krishna Construction Company	Sample ID	WQ/26/02/39
Address	1st Floor,H-110, Shreedhar Flora, Amar JavanCircle, Nikol Gam Road, Ahmedabad.382350	Condition of sample	Satisfactory
		Sample Done By	Customer
		Quantity of Sample	1000 ml
		Sampling Method	APHA
Date of Sampling	10.02.2026	Date of Sample Received	10.02.2026
Analysis Starts Date	10.02.2026	Analysis Completion Date	15.02.2026
Sample Description	INLET AT CHORVAD 3.70 MLD STP	Temperature/ Humidity during testing	Temp.- 25-29 deg C / Humidity <50 %
Report Number:	LAB/WQ/26/02/39	Report Date:	15.02.2026

S.No.	PARAMETERS	UNIT	RESULTS	LIMIT	Testing Method/ Standard
PHYSICAL CHEMICAL AND MICRO PARAMETERS					
1	pH @ 27 deg.	--	7.54		APHA 24 th Edition 4500 B: 2023
2	Total Suspended Solids	mg/l	330.00		APHA 24 th Edition 2540 D: 2023
3	Total Phosphorus	mg/l	2.15		APHA 24 th Edition 4500P D: 2023
4	Chemical Oxygen Demand	mg/l	638.90		IS 3025 (Part 58) 2006
5	Biochemical Oxygen Demand	mg/l	228.34		IS 3025 (Part 44) 1993
6	Ammonical Nitrogen	mg/l	28.42		APHA 24 th Edition 4500 NH3 C: 2023
7	Total Kjeldhal Nitrogen	mg/l	40.68		APHA 24 th Edition 4500 NH3 C/Norg B:2017
8	Nitrate	mg/l	16.66		APHA 24 th Edition 4500 NO3 B: 2023
9	Nitrite	mg/l	0.13		APHA 24 th Edition 4500 NO2 B: 2023
10	Total Nitrogen	mg/l	57.47		APHA 24 th Edition 4500 N113C / Norg B/ NO3 B/NO2 B: 2023
11	Faecal Coliform	MPN/100 ml	900.00		IS 1622
12	Total Coliform	MPN/100 ml	1600.00		IS 1622

Checked By :	Parth Bandhiya	Authorized Signatory :	Mufaddal Nathani
Signature :		Signature :	
Designation :	Chemist	Designation :	Technical Manager



Notes:

- The report shall not be reproduced except in full without approval of the laboratory can provide assurance that parts of a report are not taken out of context.
- This certificate is based on the sample submitted for testing.
- Additions to, deviations, or exclusions from the method- NA
- Results which were outsourced to external providers are marked with ** and results which are performed and not in NABL accreditation scope are marked with * in parameter column
- Disclaimer: When the information is supplied by the customer and can affect the validity of results
- Disclaimer: The report that the results apply to the sample as received in case of the sample has been supplied by customer
- Disclaimer: The laboratory shall be responsible for all the information provided in the report, except when information is provided by the customer
- Regulatory limit reference if any:- NA
- Opinion, Interpretation & Statement of Conformity if provided can be referred in the remarks section as "Permissible" "Below acceptable" or whatever is applicable as per the limit
- BDL : Below Detection Limit

● End of the Test Report ●

TANISHKA EARTH CARE SERVICES (OPC) PRIVATE LIMITED



TANISHKA EARTH CARE SERVICES (OPC) PRIVATE LIMITED

AN ISO/IEC 17025 NABL ACCREDITED ENVIRONMENT TESTING LABORATORY

GPCB Recognized Environmental Auditor (Schedule -II)

📍 PLOT NO.111. HIRA PARK, OPP- VISHAL HOTEL, JAMNAGAR - 361006

☎ +91 78749 15777 | +91 98794 06097 ✉ tanishkaearthcare@gmail.com

Testing solution for a better tomorrow

TEST REPORT

Company Name	M/s. Krishna Construction Company	Sample ID	WQ/26/01/53
Address	1st Floor,H-110, Shreedhar Flora, Amar JavanCircle, Nikol Gam Road, Ahmedabad.382350	Condition of sample	Satisfactory
		Sample Done By	Customer
		Quantity of Sample	1000 ml
		Sampling Method	APHA
Date of Sampling	06.01.2026	Date of Sample Received	06.01.2026
Analysis Starts Date	06.01.2026	Analysis Completion Date	10.01.2026
Sample Description	OUTLET AT VISAVADAR 3.40 MLD STP	Temperature/ Humidity during testing	Temp.- 25-29 deg C / Humidity <50 %
Report Number:	LAB/WQ/26/01/53	Report Date:	10.01.2026

S.No.	PARAMETERS	UNIT	RESULTS	LIMIT	Testing Method/ Standard
PHYSICAL CHEMICAL AND MICRO PARAMETERS					
1	pH @ 27 deg.	--	7.50	6.5-9	APHA 24 th Edition 4500 B: 2023
2	Total Suspended Solids	mg/l	7.00	<10	APHA 24 th Edition 2540 D: 2023
3	Total Phosphorus	mg/l	0.32	<1	APHA 24 th Edition 4500P D: 2023
4	Chemical Oxygen Demand	mg/l	34.56	<50	IS 3025 (Part 58) 2006
5	Biochemical Oxygen Demand	mg/l	7.98	<10	IS 3025 (Part 44) 1993
6	Ammonical Nitrogen	mg/l	3.54	<5	APHA 24 th Edition 4500 NH3 C : 2023
7	Total Nitrogen	mg/l	6.88	<10	APHA 24 th Edition 4500 N113C / Norg B/ NO3 B/NO2 B; 2023
8	Faecal Coliform	MPN/100 ml	40.00	<100	IS 1622
9	Total Coliform	MPN/100 ml	60.00	<100	IS 1622

Checked By :	Hadevsinh	Authorized Signatory :	Muladhar Nathani
Signature :		Signature :	
Designation :	Chemist	Designation :	Technical Manager

- Notes:**
- The report shall not be reproduced except in full without approval of the laboratory can provide assurance that parts of a report are not taken out of context.
 - This certificate is based on the sample submitted for testing.
 - Additions to, deviations, or exclusions from the method- NA
 - Results which were outsourced to external providers are marked with ** and results which are performed and not in NABL accreditation scope are marked with * in parameter column
 - Disclaimer: When the information is supplied by the customer and can affect the validity of results
 - Disclaimer: The report that the results apply to the sample as received in case of the sample has been supplied by customer
 - Disclaimer: The laboratory shall be responsible for all the information provided in the report, except when information is provided by the customer
 - Regulatory limit reference if any:- NA
 - Opinion, Interpretation & Statement of Conformity if provided can be referred in the remarks section as "Permissible" "Below acceptable" or whatever is applicable as per the limit
 - BDL : Below Detection Limit

● End of the Test Report ●

TANISHKA EARTH CARE SERVICES (OPC) PRIVATE LIMITED



TEST REPORT

Company Name	M/s. Krishna Construction Company	Sample ID	WQ/26/01/52
Address	1st Floor,H-110, Shreedhar Flora, Amar JavanCircle, Nikol Gam Road, Ahmedabad.382350	Condition of sample	Satisfactory
		Sample Done By	Customer
		Quantity of Sample	1000 ml
		Sampling Method	APHA
Date of Sampling	06.01.2026	Date of Sample Received	06.01.2026
Analysis Starts Date	06.01.2026	Analysis Completion Date	10.01.2026
Sample Description	INLET AT VISAVADAR 3.40 MLD STP	Temperature/ Humidity during testing	Temp.- 25-29 deg C / Humidity <50 %
Report Number:	LAB/WQ/26/01/52	Report Date:	10.01.2026

S.No.	PARAMETERS	UNIT	RESULTS	LIMIT	Testing Method/ Standard
PHYSICAL CHEMICAL AND MICRO PARAMETERS					
1	pH @ 27 deg.	--	8.30		APHA 24 th Edition 4500 B: 2023
2	Total Suspended Solids	mg/l	330.00		APHA 24 th Edition 2540 D: 2023
3	Total Phosphorus	mg/l	1.20		APHA 24 th Edition 4500P D: 2023
4	Chemical Oxygen Demand	mg/l	622.56		IS 3025 (Part 58) 2006
5	Biochemical Oxygen Demand	mg/l	220.72		IS 3025 (Part 44) 1993
6	Ammonical Nitrogen	mg/l	28.90		APHA 24 th Edition 4500 NH3 C : 2023
7	Total Kjeldhal Nitrogen	mg/l	48.38		APHA 24 th Edition 4500 NH3 C/Norg B:2017
8	Nitrate	mg/l	32.62		APHA 24 th Edition 4500 NO3 B: 2023
9	Nitrite	mg/l	0.10		APHA 24 th Edition 4500 NO2 B: 2023
10	Total Nitrogen	mg/l	81.10		APHA 24 th Edition 4500 N113C / Norg B/ NO3 B/NO2 B: 2023
8	Faecal Coliform	MPN/100 ml	900.00		IS 1622
9	Total Coliform	MPN/100 ml	1600.00		IS 1622

Checked By :	Hadevsinh	Authorized Signatory :	Mufaddal Nathani
Signature :		Signature :	
Designation :	Chemist	Designation :	Technical Manager

- Notes:**
- The report shall not be reproduced except in full without approval of the laboratory can provide assurance that parts of a report are not taken out of context.
 - This certificate is based on the sample submitted for testing.
 - Additions to, deviations, or exclusions from the method- NA
 - Results which were outsourced to external providers are marked with ** and results which are performed and not in NABL accreditation scope are marked with * in parameter column
 - Disclaimer: When the information is supplied by the customer and can affect the validity of results
 - Disclaimer: The report that the results apply to the sample as received in case of the sample has been supplied by customer
 - Disclaimer: The laboratory shall be responsible for all the information provided in the report, except when information is provided by the customer
 - Regulatory limit reference if any:- NA
 - Opinion, Interpretation & Statement of Conformity if provided can be referred in the remarks section as "Permissible" "Below acceptable" or whatever is applicable as per the limit
 - BDL : Below Detection Limit

● End of the Test Report ●

TANISHKA EARTH CARE SERVICES (OPC) PRIVATE LIMITED





AN ISO/IEC 17025 NABL ACCREDITED ENVIRONMENT TESTING LABORATORY

GPCB Recognized Environmental Auditor (Schedule -II)

PLOT NO.111. HIRA PARK, OPP- VISHAL HOTEL, JAMNAGAR - 361006

+91 78749 15777 | +91 98794 06097 | tanishkaearthcare@gmail.com

Testing solution for a better tomorrow

TEST REPORT

Company Name	M/s. Krishna Construction Company	Sample ID	WQ/26/01/57
Address	1st Floor,H-110, Shreedhar Flora, Amar JavanCircle, Nikol Gam Road, Ahmedabad.382350	Condition of sample	Satisfactory
		Sample Done By	Customer
		Quantity of Sample	1000 ml
		Sampling Method	APHA
Date of Sampling	19.01.2026	Date of Sample Received	19.01.2026
Analysis Starts Date	19.01.2026	Analysis Completion Date	22.01.2026
Sample Description	OUTLET AT VISAVADAR 3.40 MLD STP	Temperature/ Humidity during testing	Temp.- 25-29 deg C / Humidity <50 %
Report Number:	LAB/WQ/26/01/57	Report Date:	22.01.2026

S.No.	PARAMETERS	UNIT	RESULTS	LIMIT	Testing Method/ Standard
PHYSICAL CHEMICAL AND MICRO PARAMETERS					
1	pH @ 27 deg.	--	7.30	6.5-9	APHA 24 th Edition 4500 B: 2023
2	Total Suspended Solids	mg/l	7.00	<10	APHA 24 th Edition 2540 D: 2023
3	Total Phosphorus	mg/l	0.34	<1	APHA 24 th Edition 4500P D: 2023
4	Chemical Oxygen Demand	mg/l	32.74	<50	IS 3025 (Part 58) 2006
5	Biochemical Oxygen Demand	mg/l	7.05	<10	IS 3025 (Part 44) 1993
6	Ammonical Nitrogen	mg/l	2.90	<5	APHA 24 th Edition 4500 NH3 C : 2023
7	Total Nitrogen	mg/l	7.69	<10	APHA 24 th Edition 4500 N113C / Norg B/ NO3 B/NO2 B; 2023
8	Faecal Coliform	MPN/100 ml	70.00	<100	IS 1622
9	Total Coliform	MPN/100 ml	90.00	<100	IS 1622

Checked By :	Hadevsinh	Authorized Signatory :	Mufaddal Naman
Signature :		Signature :	
Designation :	Chemist	Designation :	Technical Manager

- Notes:**
1. The report shall not be reproduced except in full without approval of the laboratory can provide assurance that parts of a report are not taken out of context.
 2. This certificate is based on the sample submitted for testing.
 3. Additions to, deviations, or exclusions from the method- NA
 4. Results which were outsourced to external providers are marked with ** and results which are performed and not in NABL accreditation scope are marked with * in parameter column
 5. Disclaimer: When the information is supplied by the customer and can affect the validity of results
 6. Disclaimer: The report that the results apply to the sample as received in case of the sample has been supplied by customer
 7. Disclaimer: The laboratory shall be responsible for all the information provided in the report, except when information is provided by the customer
 8. Regulatory limit reference if any:- NA
 9. Opinion, Interpretation & Statement of Conformity if provided can be referred in the remarks section as "Permissible" "Below acceptable" or whatever is applicable as per the limit
 10. BDL : Below Detection Limit

● End of the Test Report ●



TANISHKA EARTH CARE SERVICES (OPC) PRIVATE LIMITED

AN ISO/IEC 17025 NABL ACCREDITED ENVIRONMENT TESTING LABORATORY

GPCB Recognized Environmental Auditor (Schedule -II)

PLOT NO.111. HIRA PARK, OPP- VISHAL HOTEL, JAMNAGAR - 361006

+91 78749 15777 | +91 98794 06097 | tanishkaearthcare@gmail.com

Testing solution for a better tomorrow

TEST REPORT

Company Name	M/s. Krishna Construction Company	Sample ID	WQ/26/01/56
Address	1st Floor,H-110, Shreedhar Flora, Amar JavanCircle, Nikol Gam Road, Ahmedabad.382350	Condition of sample	Satisfactory
		Sample Done By	Customer
		Quantity of Sample	1000 ml
		Sampling Method	APHA
Date of Sampling	19.01.2026	Date of Sample Received	19.01.2026
Analysis Starts Date	19.01.2026	Analysis Completion Date	22.01.2026
Sample Description	INLET AT VISAVADAR 3.40 MLD STP	Temperature/ Humidity during testing	Temp.- 25-29 deg C / Humidity <50 %
Report Number:	LAB/WQ/26/01/56	Report Date:	22.01.2026

S.No.	PARAMETERS	UNIT	RESULTS	LIMIT	Testing Method/ Standard
PHYSICAL CHEMICAL AND MICRO PARAMETERS					
1	pH @ 27 deg.	--	8.56		APHA 24 th Edition 4500 B: 2023
2	Total Suspended Solids	mg/l	335.00		APHA 24 th Edition 2540 D: 2023
3	Total Phosphorus	mg/l	1.17		APHA 24 th Edition 4500P D: 2023
4	Chemical Oxygen Demand	mg/l	635.98		IS 3025 (Part 58) 2006
5	Biochemical Oxygen Demand	mg/l	226.84		IS 3025 (Part 44) 1993
6	Ammonical Nitrogen	mg/l	30.28		APHA 24 th Edition 4500 NH3 C: 2023
7	Total Kjeldhal Nitrogen	mg/l	50.66		APHA 24 th Edition 4500 NH3 C/Norg B:2017
8	Nitrate	mg/l	36.82		APHA 24 th Edition 4500 NO3 B: 2023
9	Nitrite	mg/l	0.12		APHA 24 th Edition 4500 NO2 B: 2023
10	Total Nitrogen	mg/l	87.60		APHA 24 th Edition 4500 N113C / Norg B/ NO3 B/NO2 B: 2023
11	Faecal Coliform	MPN/100 ml	900.00		IS 1622
12	Total Coliform	MPN/100 ml	1600.00		IS 1622

Checked By :	Hadevsinh	Authorized Signatory :	Muladhar Nathani
Signature :		Signature :	
Designation :	Chemist	Designation :	Technical Manager

- Notes:**
- The report shall not be reproduced except in full without approval of the laboratory can provide assurance that parts of a report are not taken out of context.
 - This certificate is based on the sample submitted for testing.
 - Additions to, deviations, or exclusions from the method- NA
 - Results which were outsourced to external providers are marked with ** and results which are performed and not in NABL accreditation scope are marked with * in parameter column
 - Disclaimer: When the information is supplied by the customer and can affect the validity of results
 - Disclaimer: The report that the results apply to the sample as received in case of the sample has been supplied by customer
 - Disclaimer: The laboratory shall be responsible for all the information provided in the report, except when information is provided by the customer
 - Regulatory limit reference if any:- NA
 - Opinion, Interpretation & Statement of Conformity if provided can be referred in the remarks section as "Permissible" "Below acceptable" or whatever is applicable as per the limit
 - BDL : Below Detection Limit
- End of the Test Report ●

TANISHKA EARTH CARE SERVICES (OPC) PRIVATE LIMITED



TANISHKA EARTH CARE SERVICES (OPC) PRIVATE LIMITED

AN ISO/IEC 17025 NABL ACCREDITED ENVIRONMENT TESTING LABORATORY

GPCB Recognized Environmental Auditor (Schedule -II)

PLOT NO.111. HIRA PARK, OPP- VISHAL HOTEL, JAMNAGAR - 361006

+91 78749 15777 | +91 98794 06097 | tanishkaearthcare@gmail.com

Testing solution for a better tomorrow

TEST REPORT

Company Name	M/s. Krishna Construction Company	Sample ID	WQ/26/02/51
Address	1st Floor,H-110, Shreedhar Flora, Amar JavanCircle, Nikol Gam Road, Ahmedabad.382350	Condition of sample	Satisfactory
		Sample Done By	Customer
		Quantity of Sample	1000 ml
		Sampling Method	APHA
Date of Sampling	24.02.2026	Date of Sample Received	24.02.2026
Analysis Starts Date	24.02.2026	Analysis Completion Date	28.02.2026
Sample Description	INLET AT VISAVADAR 3.40 MLD STP	Temperature/ Humidity during testing	Temp.- 25-29 deg C / Humidity <50 %
Report Number:	LAB/WQ/26/02/51	Report Date:	28.02.2026

S.No.	PARAMETERS	UNIT	RESULTS	LIMIT	Testing Method/ Standard
PHYSICAL CHEMICAL AND MICRO PARAMETERS					
1	pH @ 27 deg.	--	8.52		APHA 24 th Edition 4500 B: 2023
2	Total Suspended Solids	mg/l	330.00		APHA 24 th Edition 2540 D: 2023
3	Total Phosphorus	mg/l	1.17		APHA 24 th Edition 4500P D: 2023
4	Chemical Oxygen Demand	mg/l	622.68		IS 3025 (Part 58) 2006
5	Biochemical Oxygen Demand	mg/l	226.84		IS 3025 (Part 44) 1993
6	Ammonical Nitrogen	mg/l	24.52		APHA 24 th Edition 4500 NH3 C : 2023
7	Total Kjeldhal Nitrogen	mg/l	54.78		APHA 24 th Edition 4500 NH3 C/Norg B:2017
8	Nitrate	mg/l	40.66		APHA 24 th Edition 4500 NO3 B: 2023
9	Nitrite	mg/l	0.14		APHA 24 th Edition 4500 NO2 B: 2023
10	Total Nitrogen	mg/l	95.58		APHA 24 th Edition 4500 N113C / Norg B/ NO3 B/NO2 B: 2023
11	Faecal Coliform	MPN/100 ml	900.00		IS 1622
12	Total Coliform	MPN/100 ml	1600.00		IS 1622

Checked By :	Hadevsinh	Authorized Signatory :	Mufanda Nathani
Signature :		Signature :	
Designation :	Chemist	Designation :	Technical Manager

- Notes:**
- The report shall not be reproduced except in full without approval of the laboratory can provide assurance that parts of a report are not taken out of context.
 - This certificate is based on the sample submitted for testing.
 - Additions to, deviations, or exclusions from the method- NA
 - Results which were outsourced to external providers are marked with ** and results which are performed and not in NABL accreditation scope are marked with * in parameter column
 - Disclaimer: When the information is supplied by the customer and can affect the validity of results
 - Disclaimer: The report that the results apply to the sample as received in case of the sample has been supplied by customer
 - Disclaimer: The laboratory shall be responsible for all the information provided in the report, except when information is provided by the customer
 - Regulatory limit reference if any:- NA
 - Opinion, Interpretation & Statement of Conformity if provided can be referred in the remarks section as "Permissible" "Below acceptable" or whatever is applicable as per the limit
 - BDL : Below Detection Limit

● End of the Test Report ●

TANISHKA EARTH CARE SERVICES (OPC) PRIVATE LIMITED





TEST REPORT

Company Name	M/s. Krishna Construction Company	Sample ID	WQ/26/02/52
Address	1st Floor,H-110, Shreedhar Flora, Amar JavanCircle, Nikol Gam Road, Ahmedabad.382350	Condition of sample	Satisfactory
		Sample Done By	Customer
		Quantity of Sample	1000 ml
		Sampling Method	APHA
Date of Sampling	24.02.2026	Date of Sample Received	24.02.2026
Analysis Starts Date	24.02.2026	Analysis Completion Date	28.02.2026
Sample Description	OUTLET AT VISAVADAR 3.40 MLD STP	Temperature/ Humidity during testing	Temp.- 25-29 deg C / Humidity <50 %
Report Number:	LAB/WQ/26/02/52	Report Date:	28.02.2026

S.No.	PARAMETERS	UNIT	RESULTS	LIMIT	Testing Method/ Standard
PHYSICAL CHEMICAL AND MICRO PARAMETERS					
1	pH @ 27 deg.	--	8.36	6.5-9	APHA 24 th Edition 4500 B: 2023
2	Total Suspended Solids	mg/l	7.00	<10	APHA 24 th Edition 2540 D: 2023
3	Total Phosphorus	mg/l	0.40	<1	APHA 24 th Edition 4500P D: 2023
4	Chemical Oxygen Demand	mg/l	36.22	<50	IS 3025 (Part 58) 2006
5	Biochemical Oxygen Demand	mg/l	7.86	<10	IS 3025 (Part 44) 1993
6	Ammonical Nitrogen	mg/l	3.10	<5	APHA 24 th Edition 4500 NH3 C : 2023
7	Total Nitrogen	mg/l	5.44	<10	APHA 24 th Edition 4500 N113C / Norg B/ NO3 B/NO2 B; 2023
8	Faecal Coliform	MPN/100 ml	60.00	<100	IS 1622
9	Total Coliform	MPN/100 ml	80.00	<100	IS 1622

Checked By :	Hadevsinh	Authorized Signatory :	Mufaddal Nathani
Signature :		Signature :	
Designation :	Chemist	Designation :	Technical Manager

- Notes:**
1. The report shall not be reproduced except in full without approval of the laboratory can provide assurance that parts of a report are not taken out of context.
 2. This certificate is based on the sample submitted for testing.
 3. Additions to, deviations, or exclusions from the method- NA
 4. Results which were outsourced to external providers are marked with ** and results which are performed and not in NABL accreditation scope are marked with * in parameter column
 5. Disclaimer: When the information is supplied by the customer and can affect the validity of results
 6. Disclaimer: The report that the results apply to the sample as received in case of the sample has been supplied by customer
 7. Disclaimer: The laboratory shall be responsible for all the information provided in the report, except when information is provided by the customer
 8. Regulatory limit reference if any:- NA
 9. Opinion, Interpretation & Statement of Conformity if provided can be referred in the remarks section as "Permissible" "Below acceptable" or whatever is applicable as per the limit
 10. BDL : Below Detection Limit

● End of the Test Report ●

TANISHKA EARTH CARE SERVICES (OPC) PRIVATE LIMITED



AN ISO/IEC 17025 NABL ACCREDITED ENVIRONMENT TESTING LABORATORY

GPCB Recognized Environmental Auditor (Schedule -II)

PLOT NO.111. HIRA PARK, OPP- VISHAL HOTEL, JAMNAGAR - 361006

+91 78749 15777 | +91 98794 06097 | tanishkaearthcare@gmail.com

Testing solution for a better tomorrow

TEST REPORT

Company Name	M/s. Krishna Construction Company	Sample ID	WQ/26/02/50
Address	1st Floor,H-110, Shreedhar Flora, Amar JavanCircle, Nikol Gam Road, Ahmedabad.382350	Condition of sample	Satisfactory
		Sample Done By	Customer
		Quantity of Sample	1000 ml
		Sampling Method	APHA
Date of Sampling	09.02.2026	Date of Sample Received	09.02.2026
Analysis Starts Date	09.02.2026	Analysis Completion Date	15.02.2026
Sample Description	OUTLET AT VISAVADAR 3.40 MLD STP	Temperature/ Humidity during testing	Temp.- 25-29 deg C / Humidity <50 %
Report Number:	LAB/WQ/26/02/50	Report Date:	15.02.2026

S.No.	PARAMETERS	UNIT	RESULTS	LIMIT	Testing Method/ Standard
PHYSICAL CHEMICAL AND MICRO PARAMETERS					
1	pH @ 27 deg.	--	8.40	6.5-9	APHA 24 th Edition 4500 B: 2023
2	Total Suspended Solids	mg/l	7.00	<10	APHA 24 th Edition 2540 D: 2023
3	Total Phosphorus	mg/l	0.42	<1	APHA 24 th Edition 4500P D: 2023
4	Chemical Oxygen Demand	mg/l	36.22	<50	IS 3025 (Part 58) 2006
5	Biochemical Oxygen Demand	mg/l	8.02	<10	IS 3025 (Part 44) 1993
6	Ammonical Nitrogen	mg/l	3.24	<5	APHA 24 th Edition 4500 NH3 C : 2023
7	Total Nitrogen	mg/l	6.40	<10	APHA 24 th Edition 4500 N113C / Norg B/ NO3 B/NO2 B; 2023
8	Faecal Coliform	MPN/100 ml	60.00	<100	IS 1622
11	Total Coliform	MPN/100 ml	80.00	<100	IS 1622

Checked By :	Hadevsinh	Authorized Signatory :	Mufaddal Nathan
Signature :		Signature :	
Designation :	Chemist	Designation :	Technical Manager



- Notes:**
1. The report shall not be reproduced except in full without approval of the laboratory can provide assurance that parts of a report are not taken out of context.
 2. This certificate is based on the sample submitted for testing.
 3. Additions to, deviations, or exclusions from the method- NA
 4. Results which were outsourced to external providers are marked with ** and results which are performed and not in NABL accreditation scope are marked with * in parameter column
 5. Disclaimer: When the information is supplied by the customer and can affect the validity of results
 6. Disclaimer: The report that the results apply to the sample as received in case of the sample has been supplied by customer
 7. Disclaimer: The laboratory shall be responsible for all the information provided in the report, except when information is provided by the customer
 8. Regulatory limit reference if any:- NA
 9. Opinion, Interpretation & Statement of Conformity if provided can be referred in the remarks section as "Permissible" "Below acceptable" or whatever is applicable as per the limit
 10. BDL : Below Detection Limit

● End of the Test Report ●

TANISHKA EARTH CARE SERVICES (OPC) PRIVATE LIMITED



TANISHKA EARTH CARE SERVICES (OPC) PRIVATE LIMITED

AN ISO/IEC 17025 NABL ACCREDITED ENVIRONMENT TESTING LABORATORY

GPCB Recognized Environmental Auditor (Schedule -II)

PLOT NO.111. HIRA PARK, OPP- VISHAL HOTEL, JAMNAGAR - 361006

+91 78749 15777 | +91 98794 06097 | tanishkaearthcare@gmail.com

Testing solution for a better tomorrow

TEST REPORT

Company Name	M/s. Krishna Construction Company	Sample ID	WQ/26/02/49
Address	1st Floor,H-110, Shreedhar Flora, Amar JavanCircle, Nikol Gam Road, Ahmedabad.382350	Condition of sample	Satisfactory
		Sample Done By	Customer
		Quantity of Sample	1000 ml
		Sampling Method	APHA
Date of Sampling	09.02.2026	Date of Sample Received	09.02.2026
Analysis Starts Date	09.02.2026	Analysis Completion Date	15.02.2026
Sample Description	INLET AT VISAVADAR 3.40 MLD STP	Temperature/ Humidity during testing	Temp.- 25-29 deg C / Humidity <50 %
Report Number:	LAB/WQ/26/02/49	Report Date:	15.02.2026

S.No.	PARAMETERS	UNIT	RESULTS	LIMIT	Testing Method/ Standard
PHYSICAL CHEMICAL AND MICRO PARAMETERS					
1	pH @ 27 deg.	--	8.58		APHA 24 th Edition 4500 B: 2023
2	Total Suspended Solids	mg/l	335.00		APHA 24 th Edition 2540 D: 2023
3	Total Phosphorus	mg/l	1.12		APHA 24 th Edition 4500P D: 2023
4	Chemical Oxygen Demand	mg/l	620.54		IS 3025 (Part 58) 2006
5	Biochemical Oxygen Demand	mg/l	224.74		IS 3025 (Part 44) 1993
6	Ammonical Nitrogen	mg/l	26.40		APHA 24 th Edition 4500 NH3 C: 2023
7	Total Kjeldhal Nitrogen	mg/l	52.54		APHA 24 th Edition 4500 NH3 C/Norg B:2017
8	Nitrate	mg/l	38.62		APHA 24 th Edition 4500 NO3 B: 2023
9	Nitrite	mg/l	0.12		APHA 24 th Edition 4500 NO2 B: 2023
10	Total Nitrogen	mg/l	91.28		APHA 24 th Edition 4500 N113C / Norg B/ NO3 B/NO2 B: 2023
11	Faecal Coliform	MPN/100 ml	500.00		IS 1622
12	Total Coliform	MPN/100 ml	900.00		IS 1622

Checked By :	Hadevsinh	Authorized Signatory :	Mufaddal Nathani
Signature :		Signature :	
Designation :	Chemist	Designation :	Technical Manager

- Notes:**
- The report shall not be reproduced except in full without approval of the laboratory can provide assurance that parts of a report are not taken out of context.
 - This certificate is based on the sample submitted for testing.
 - Additions to, deviations, or exclusions from the method- NA
 - Results which were outsourced to external providers are marked with ** and results which are performed and not in NABL accreditation scope are marked with * in parameter column
 - Disclaimer: When the information is supplied by the customer and can affect the validity of results
 - Disclaimer: The report that the results apply to the sample as received in case of the sample has been supplied by customer
 - Disclaimer: The laboratory shall be responsible for all the information provided in the report, except when information is provided by the customer
 - Regulatory limit reference if any:- NA
 - Opinion, Interpretation & Statement of Conformity if provided can be referred in the remarks section as "Permissible" "Below acceptable" or whatever is applicable as per the limit
 - BDL : Below Detection Limit

● End of the Test Report ●

TANISHKA EARTH CARE SERVICES (OPC) PRIVATE LIMITED




TEST REPORT OF WASTEWATER

Report No.:	TEL/LAB/032026/177			Date: 14/03/2026
Client Name	M/s. Chief Officer Chalala Nagarpalika			
Client Address	Chalala Nagarpalika STP			
Sample Description	Wastewater	Date of Sampling	-	
Point of Sample Collection	STP Inlet	Sample Received Date	06/03/2026	
Sample Quantity	2 L + 1 L	Date of Analysis Start on	07/03/2026	
Sampling Method	Grab	Date of Analysis Completed	13/03/2026	
Sample Code	TEL/LAB/STP/0326/038	Sampling Done by	Sample by Party	
Environmental Condition During Testing	Temp. 27 ± 2 °C & Humidity. 65 ± 5 % RH			

TEST REPORT

Sr. No.	Parameters	Unit	Results	Test Method
1.	pH Value	--	6.29	IS 3025 (Part-11)
2.	Total Suspended Solids (TSS)	mg/L	574	APHA 24 th Edition: 2540 D
3.	Chemical Oxygen Demand (COD)	mg/L	433	APHA 24 th Edition: 5220 B
4.	Biochemical Oxygen Demand (BOD)	mg/L	316	IS 3025 (Part-44)
5.	Ammonical Nitrogen	mg/L	32	IS 3025 (Part-34)
6.	Total Nitrogen	mg/L	30	APHA 24 th Edition: 4500-N
7.	Phosphorus	mg/L	2.6	APHA 24 th Edition: 4500-P
8.	Fecal Coliforms	MPN/100 mL	292	APHA 24 th Edition: 9221 - E
9.	Total Coliform	MPN/100 mL	125	APHA 24 th Edition: 9221 - E

Notes:

1. The results relate only to the samples tested.
2. The report shall not be reproduced except in full, without the written approval of the laboratory.
3. Report cannot be used as evidence anywhere without prior permission of laboratory.
4. The test samples will be disposed off after two weeks from the date of issue of test report, unless specified by the customer.

Analysed By:

Authorized Signatory

-----End of Report-----



TEST REPORT OF WASTEWATER

Report No.:	TEL/LAB/032026/178			Date: 14/03/2026
Client Name	M/s. Chief Officer Chalala Nagarpalika			
Client Address	Chalala Nagarpalika STP			
Sample Description	Wastewater	Date of Sampling	-	
Point of Sample Collection	STP Outlet	Sample Received Date	06/03/2026	
Sample Quantity	2 L + 1 L	Date of Analysis Start on	07/03/2026	
Sampling Method	Grab	Date of Analysis Completed	13/03/2026	
Sample Code	TEL/LAB/STP/0326/039	Sampling Done by	Sample by Party	
Environmental Condition During Testing	Temp. 27 ± 2 °C & Humidity. 65 ± 5 % RH			

TEST REPORT

Sr. No.	Parameters	Unit	Results	Test Method
1.	pH Value	--	7.65	IS 3025 (Part-11)
2.	Total Suspended Solids (TSS)	mg/L	7.4	APHA 24 th Edition: 2540 D
3.	Chemical Oxygen Demand (COD)	mg/L	34.5	APHA 24 th Edition: 5220 B
4.	Biochemical Oxygen Demand (BOD)	mg/L	8.2	IS 3025 (Part-44)
5.	Ammonical Nitrogen	mg/L	2.8	IS 3025 (Part-34)
6.	Total Nitrogen	mg/L	7.6	APHA 24 th Edition: 4500-N
7.	Phosphorus	mg/L	0.4	APHA 24 th Edition: 4500-P
8.	Fecal Coliforms	MPN/100 mL	96	APHA 24 th Edition: 9221 – E
9.	Total Coliform	MPN/100 mL	84	APHA 24 th Edition: 9221 – E

Notes:

1. The results relate only to the samples tested.
2. The report shall not be reproduced except in full, without the written approval of the laboratory.
3. Report cannot be used as evidence anywhere without prior permission of laboratory.
4. The test samples will be disposed off after two weeks from the date of issue of test report, unless specified by the customer.

Analysed By:



Authorized Signatory

-----End of Report-----




TEST REPORT OF WASTEWATER

Report No.:	TEL/LAB/012026/432			Date: 20/01/2026
Client Name	M/s. Maruti – Tolani JV			
Client Address	2.8 MLD Damnagar STP			
Sample Description	Wastewater	Date of Sampling	-	
Point of Sample Collection	STP Inlet	Sample Received Date	12/01/2026	
Sample Quantity	2 L + 1 L	Date of Analysis Start on	13/01/2026	
Sampling Method	Grab	Date of Analysis Completed	19/01/2026	
Sample Code	TEL/LAB/STP/0126/130	Sampling Done by	Sample by Party	
Environmental Condition During Testing	Temp. 27 ± 2 °C & Humidity. 65 ± 5 % RH			

TEST REPORT

Sr. No.	Parameters	Unit	Results	Test Method
1.	pH Value	--	6.42	IS 3025 (Part-11)
2.	Total Suspended Solids (TSS)	mg/L	836	APHA 24 th Edition: 2540 D
3.	Chemical Oxygen Demand (COD)	mg/L	428	APHA 24 th Edition: 5220 B
4.	Biochemical Oxygen Demand (BOD)	mg/L	215	IS 3025 (Part-44)
5.	Ammonical Nitrogen	mg/L	48	IS 3025 (Part-34)
6.	Total Nitrogen	mg/L	40	APHA 24 th Edition: 4500-N
7.	Phosphorus	mg/L	2.6	APHA 24 th Edition: 4500-P
8.	Fecal Coliforms	MPN/100 mL	250	APHA 24 th Edition: 9221 - E
9.	Total Coliform	MPN/100 mL	182	APHA 24 th Edition: 9221 - E

Notes:

1. The results relate only to the samples tested.
2. The report shall not be reproduced except in full, without the written approval of the laboratory.
3. Report cannot be used as evidence anywhere without prior permission of laboratory.
4. The test samples will be disposed off after two weeks from the date of issue of test report, unless specified by the customer.


Analysed By:




Authorized Signatory

-----End of Report-----


TEST REPORT OF WASTEWATER

Report No.:	TEL/LAB/012026/433			Date: 20/01/2026
Client Name	M/s. Maruti – Tolani JV			
Client Address	2.8 MLD Damnagar STP			
Sample Description	Wastewater	Date of Sampling	-	
Point of Sample Collection	STP Outlet	Sample Received Date	12/01/2026	
Sample Quantity	2 L + 1 L	Date of Analysis Start on	13/01/2026	
Sampling Method	Grab	Date of Analysis Completed	19/01/2026	
Sample Code	TEL/LAB/STP/0126/131	Sampling Done by	Sample by Party	
Environmental Condition During Testing	Temp. 27 ± 2 °C & Humidity. 65 ± 5 % RH			
TEST REPORT				
Sr. No.	Parameters	Unit	Results	Test Method
1.	pH Value	--	7.32	IS 3025 (Part-11)
2.	Total Suspended Solids (TSS)	mg/L	8.0	APHA 24 th Edition: 2540 D
3.	Chemical Oxygen Demand (COD)	mg/L	40	APHA 24 th Edition: 5220 B
4.	Biochemical Oxygen Demand (BOD)	mg/L	7.0	IS 3025 (Part-44)
5.	Ammonical Nitrogen	mg/L	6.2	IS 3025 (Part-34)
6.	Total Nitrogen	mg/L	5.8	APHA 24 th Edition: 4500-N
7.	Phosphorus	mg/L	0.4	APHA 24 th Edition: 4500-P
8.	Fecal Coliforms	MPN/100 mL	75	APHA 24 th Edition: 9221 - E
9.	Total Coliform	MPN/100 mL	60	APHA 24 th Edition: 9221 - E

Notes:

1. The results relate only to the samples tested.
2. The report shall not be reproduced except in full, without the written approval of the laboratory.
3. Report cannot be used as evidence anywhere without prior permission of laboratory.
4. The test samples will be disposed off after two weeks from the date of issue of test report, unless specified by the customer.

Analysed By:

Authorized Signatory

-----End of Report-----


TEST REPORT OF WASTEWATER

Report No.:	TEL/LAB/012026/453			Date: 05/02/2026
Client Name	M/s. Maruti – Tolani JV			
Client Address	2.8 MLD Damnagar STP			
Sample Description	Wastewater	Date of Sampling	-	
Point of Sample Collection	STP Inlet	Sample Received Date	29/01/2026	
Sample Quantity	2 L + 1 L	Date of Analysis Start on	30/01/2026	
Sampling Method	Grab	Date of Analysis Completed	04/02/2026	
Sample Code	TEL/LAB/STP/0126/134	Sampling Done by	Sample by Party	
Environmental Condition During Testing	Temp. 27 ± 2 °C & Humidity. 65 ± 5 % RH			

TEST REPORT

Sr. No.	Parameters	Unit	Results	Test Method
1.	pH Value	--	6.28	IS 3025 (Part-11)
2.	Total Suspended Solids (TSS)	mg/L	712	APHA 24 th Edition: 2540 D
3.	Chemical Oxygen Demand (COD)	mg/L	485	APHA 24 th Edition: 5220 B
4.	Biochemical Oxygen Demand (BOD)	mg/L	232	IS 3025 (Part-44)
5.	Ammonical Nitrogen	mg/L	36	IS 3025 (Part-34)
6.	Total Nitrogen	mg/L	30	APHA 24 th Edition: 4500-N
7.	Phosphorus	mg/L	1.6	APHA 24 th Edition: 4500-P
8.	Fecal Coliforms	MPN/100 mL	240	APHA 24 th Edition: 9221 - E
9.	Total Coliform	MPN/100 mL	126	APHA 24 th Edition: 9221 - E

Notes:

1. The results relate only to the samples tested.
2. The report shall not be reproduced except in full, without the written approval of the laboratory.
3. Report cannot be used as evidence anywhere without prior permission of laboratory.
4. The test samples will be disposed off after two weeks from the date of issue of test report, unless specified by the customer.

Analysed By:

Authorized Signatory

-----End of Report-----




TEST REPORT OF WASTEWATER

Report No.:	TEL/LAB/012026/454			Date: 05/02/2026
Client Name	M/s. Maruti – Tolani JV			
Client Address	2.8 MLD Damnagar STP			
Sample Description	Wastewater	Date of Sampling	-	
Point of Sample Collection	STP Outlet	Sample Received Date	29/01/2026	
Sample Quantity	2 L + 1 L	Date of Analysis Start on	30/01/2026	
Sampling Method	Grab	Date of Analysis Completed	04/02/2026	
Sample Code	TEL/LAB/STP/0126/135	Sampling Done by	Sample by Party	
Environmental Condition During Testing	Temp. 27 ± 2 °C & Humidity. 65 ± 5 % RH			

TEST REPORT

Sr. No.	Parameters	Unit	Results	Test Method
1.	pH Value	--	6.92	IS 3025 (Part-11)
2.	Total Suspended Solids (TSS)	mg/L	7.0	APHA 24 th Edition: 2540 D
3.	Chemical Oxygen Demand (COD)	mg/L	36.5	APHA 24 th Edition: 5220 B
4.	Biochemical Oxygen Demand (BOD)	mg/L	7.0	IS 3025 (Part-44)
5.	Ammonical Nitrogen	mg/L	3.8	IS 3025 (Part-34)
6.	Total Nitrogen	mg/L	4.2	APHA 24 th Edition: 4500-N
7.	Phosphorus	mg/L	0.4	APHA 24 th Edition: 4500-P
8.	Fecal Coliforms	MPN/100 mL	71	APHA 24 th Edition: 9221 - E
9.	Total Coliform	MPN/100 mL	82	APHA 24 th Edition: 9221 - E

Notes:

1. The results relate only to the samples tested.
2. The report shall not be reproduced except in full, without the written approval of the laboratory.
3. Report cannot be used as evidence anywhere without prior permission of laboratory.
4. The test samples will be disposed off after two weeks from the date of issue of test report, unless specified by the customer.


Analysed By:




Authorized Signatory

-----End of Report-----


TEST REPORT OF WASTEWATER

Report No.:	TEL/LAB/022026/381			Date: 23/02/2026
Client Name	M/s. Maruti – Tolani JV			
Client Address	2.8 MLD Damnagar STP			
Sample Description	Wastewater	Date of Sampling	-	
Point of Sample Collection	STP Inlet	Sample Received Date	14/02/2026	
Sample Quantity	2 L + 1 L	Date of Analysis Start on	16/02/2026	
Sampling Method	Grab	Date of Analysis Completed	21/02/2026	
Sample Code	TEL/LAB/STP/1225/103	Sampling Done by	Sample by Party	
Environmental Condition During Testing	Temp. 27 ± 2 °C & Humidity. 65 ± 5 % RH			

TEST REPORT

Sr. No.	Parameters	Unit	Results	Test Method
1.	pH Value	--	6.53	IS 3025 (Part-11)
2.	Total Suspended Solids (TSS)	mg/L	812	APHA 24 th Edition: 2540 D
3.	Chemical Oxygen Demand (COD)	mg/L	296	APHA 24 th Edition: 5220 B
4.	Biochemical Oxygen Demand (BOD)	mg/L	205	IS 3025 (Part-44)
5.	Ammonical Nitrogen	mg/L	30	IS 3025 (Part-34)
6.	Total Nitrogen	mg/L	36	APHA 24 th Edition: 4500-N
7.	Phosphorus	mg/L	1.2	APHA 24 th Edition: 4500-P
8.	Fecal Coliforms	MPN/100 mL	230	APHA 24 th Edition: 9221 - E
9.	Total Coliform	MPN/100 mL	132	APHA 24 th Edition: 9221 - E

Notes:

1. The results relate only to the samples tested.
2. The report shall not be reproduced except in full, without the written approval of the laboratory.
3. Report cannot be used as evidence anywhere without prior permission of laboratory.
4. The test samples will be disposed off after two weeks from the date of issue of test report, unless specified by the customer.


Analysed By:


Authorized Signatory

-----End of Report-----


TEST REPORT OF WASTEWATER

Report No.:	TEL/LAB/022026/382			Date: 23/02/2026
Client Name	M/s. Maruti – Tolani JV			
Client Address	2.8 MLD Damnagar STP			
Sample Description	Wastewater	Date of Sampling	-	
Point of Sample Collection	STP Outlet	Sample Received Date	14/02/2026	
Sample Quantity	2 L + 1 L	Date of Analysis Start on	16/02/2026	
Sampling Method	Grab	Date of Analysis Completed	21/02/2026	
Sample Code	TEL/LAB/STP/0226/104	Sampling Done by	Sample by Party	
Environmental Condition During Testing	Temp. 27 ± 2 °C & Humidity. 65 ± 5 % RH			
TEST REPORT				
Sr. No.	Parameters	Unit	Results	Test Method
1.	pH Value	--	7.63	IS 3025 (Part-11)
2.	Total Suspended Solids (TSS)	mg/L	6.8	APHA 24 th Edition: 2540 D
3.	Chemical Oxygen Demand (COD)	mg/L	32	APHA 24 th Edition: 5220 B
4.	Biochemical Oxygen Demand (BOD)	mg/L	8.0	IS 3025 (Part-44)
5.	Ammonical Nitrogen	mg/L	4.6	IS 3025 (Part-34)
6.	Total Nitrogen	mg/L	6.5	APHA 24 th Edition: 4500-N
7.	Phosphorus	mg/L	0.3	APHA 24 th Edition: 4500-P
8.	Fecal Coliforms	MPN/100 mL	75	APHA 24 th Edition: 9221 - E
9.	Total Coliform	MPN/100 mL	72	APHA 24 th Edition: 9221 - E

Notes:

1. The results relate only to the samples tested.
2. The report shall not be reproduced except in full, without the written approval of the laboratory.
3. Report cannot be used as evidence anywhere without prior permission of laboratory.
4. The test samples will be disposed off after two weeks from the date of issue of test report, unless specified by the customer.


Analysed By:




Authorized Signatory

-----End of Report-----


TEST REPORT OF WASTEWATER

Report No.:	TEL/LAB/022026/384			Date: 09/03/2026
Client Name	M/s. Maruti – Tolani JV			
Client Address	2.8 MLD Damnagar STP			
Sample Description	Wastewater	Date of Sampling	-	
Point of Sample Collection	STP Inlet	Sample Received Date	28/02/2026	
Sample Quantity	2 L + 1 L	Date of Analysis Start on	02/03/2026	
Sampling Method	Grab	Date of Analysis Completed	07/03/2026	
Sample Code	TEL/LAB/STP/0226/107	Sampling Done by	Sample by Party	
Environmental Condition During Testing	Temp. 27 ± 2 °C & Humidity. 65 ± 5 % RH			
TEST REPORT				
Sr. No.	Parameters	Unit	Results	Test Method
1.	pH Value	--	6.56	IS 3025 (Part-11)
2.	Total Suspended Solids (TSS)	mg/L	596	APHA 24 th Edition: 2540 D
3.	Chemical Oxygen Demand (COD)	mg/L	420	APHA 24 th Edition: 5220 B
4.	Biochemical Oxygen Demand (BOD)	mg/L	216	IS 3025 (Part-44)
5.	Ammonical Nitrogen	mg/L	36	IS 3025 (Part-34)
6.	Total Nitrogen	mg/L	30	APHA 24 th Edition: 4500-N
7.	Phosphorus	mg/L	1.8	APHA 24 th Edition: 4500-P
8.	Fecal Coliforms	MPN/100 mL	250	APHA 24 th Edition: 9221 - E
9.	Total Coliform	MPN/100 mL	122	APHA 24 th Edition: 9221 - E

Notes:

1. The results relate only to the samples tested.
2. The report shall not be reproduced except in full, without the written approval of the laboratory.
3. Report cannot be used as evidence anywhere without prior permission of laboratory.
4. The test samples will be disposed off after two weeks from the date of issue of test report, unless specified by the customer.


Analysed By:




Authorized Signatory

-----End of Report-----


TEST REPORT OF WASTEWATER

Report No.:	TEL/LAB/022026/385		Date: 08/02/2026
Client Name	M/s. Maruti – Tolani JV		
Client Address	2.8 MLD Damnagar STP		
Sample Description	Wastewater	Date of Sampling	-
Point of Sample Collection	STP Outlet	Sample Received Date	28/02/2026
Sample Quantity	2 L + 1 L	Date of Analysis Start on	02/03/2026
Sampling Method	Grab	Date of Analysis Completed	07/03/2026
Sample Code	TEL/LAB/STP/0226/108	Sampling Done by	Sample by Party
Environmental Condition During Testing	Temp. 27 ± 2 °C & Humidity. 65 ± 5 % RH		

TEST REPORT

Sr. No.	Parameters	Unit	Results	Test Method
1.	pH Value	--	7.76	IS 3025 (Part-11)
2.	Total Suspended Solids (TSS)	mg/L	6.0	APHA 24 th Edition: 2540 D
3.	Chemical Oxygen Demand (COD)	mg/L	28	APHA 24 th Edition: 5220 B
4.	Biochemical Oxygen Demand (BOD)	mg/L	6.0	IS 3025 (Part-44)
5.	Ammonical Nitrogen	mg/L	3.8	IS 3025 (Part-34)
6.	Total Nitrogen	mg/L	7.2	APHA 24 th Edition: 4500-N
7.	Phosphorus	mg/L	0.5	APHA 24 th Edition: 4500-P
8.	Fecal Coliforms	MPN/100 mL	75	APHA 24 th Edition: 9221 - E
9.	Total Coliform	MPN/100 mL	86	APHA 24 th Edition: 9221 - E

Notes:

1. The results relate only to the samples tested.
2. The report shall not be reproduced except in full, without the written approval of the laboratory.
3. Report cannot be used as evidence anywhere without prior permission of laboratory.
4. The test samples will be disposed off after two weeks from the date of issue of test report, unless specified by the customer.

Analysed By:

Authorized Signatory

-----End of Report-----



☎ +91 9662054950 / +91 9265433161 ✉ swarnimenv@gmail.com / mihircs2@gmail.com

📍 A- 205 Shiva Blessings 2 Opp. BMC office Landmark : HDFC Bank, Kalanala Branch. Nr. Kalanala Bhavnagar 364001

GST No. : 24AAKPO3980B1ZS | GPCB Approved Auditor | ISO 9001:2015 Certified

Ref. No.: SEC/BVN/2025-26/963

Date: 11/12/2025

WATER ANALYSIS REPORT

DESCRIPTION OF SAMPLE

Customer Name:	Water Sample of Vallabhipur (Nagarpalika)	Date of Sampling	03-12-2025
Description of the Sample	WTP Outlet Sample	Date of Sample Received	04-12-2025
Name of Sampling Team	Swarnim Environment and Consultancy Team	Analysis Start Date	05-12-2025
Sample Quantity	1.0 Liter	Date of Reporting	11-12-2025
Location	WTP Plant, Kalyanpur	Time	07:00 PM

Sr. No.	Characteristics / Parameters	Unit	Result	Limits	Test Method
1.	pH	--	7.86	NLT 6.5 to NMT 9.0	APHA, 23 rd Edition 2017 (Section 4500-H ⁺ B)
2.	Biochemical Oxygen Demand	mg/L	3.2	NMT 10.0	APHA, 23 rd Edition 2017 (Section 2540-D)
3.	Chemical Oxygen Demand	mg/L	9.5	NMT 50.0	APHA, 23 rd Edition 2017 (Section 5220-B)
4.	Dissolved Oxygen (DO)	mg/L	7.0	More than 5.0	APHA, 23 rd Edition (Section 4500-O) Part C 1992
5.	Total Dissolved Solids (TDS)	mg/L	221.11	NMT 500.0	APHA, 23 rd Edition 2017 (Section 2540-C)
6.	Turbidity	NTU	0.3	NMT 2.0	APHA, 22 nd Edition 2012 (Section 2130)
7.	Total Alkalinity	mg/L	7.35	NMT 200.0	APHA, 23 rd Edition 2017 (Section 2340-B)
8.	Chloride	mg/L	3.54	NMT 200.0	APHA, 23 rd Edition 2017 (Section 4500-Cl-B)
9.	Total Hardness	mg/L	10.84	NMT 200.0	APHA, 23 rd Edition 2017 (Section 2340-C)
10.	Sulphate	mg/L	7.12	NMT 200.0	APHA, 23 rd Edition 2017 (Section 4500-SO ₄ ⁻²)
11.	Nitrate as NO ₃ ⁻	mg/L	2.7	NMT 45.0	APHA, 22 nd Edition 2012 (Section 4500-NO ₃ ⁻)
12.	Nitrite as NO ₂ ⁻	mg/L	Nil	NMT 10.0	APHA, 22 nd Edition 2012 (Section 4500-NO ₂ ⁻)
13.	Ammonical Nitrogen (as N)	mg/L	Nil	NMT 0.5	APHA, 23 rd Edition 2017 (Section 4500 NH ₃ -C)
14.	Total Kjeldahl Nitrogen (TKN)	mg/L	Nil	NMT 10.0	APHA, 22 nd Edition 2012 (Section 4500-N)
15.	Total Coliform	MPN/100 ml	Absent	NMT 500.0	APHA, 23 rd Edition (9221 B & E)
16.	Faecal Coliform	MPN/100 ml	Absent	NMT 230.0	APHA, 23 rd Edition (9221 B & E)
17.	Residual Chlorine	mg/L	Nil	NMT 1.0	APHA, 23 rd Edition (4500 Cl B)
18.	Fluoride	mg/L	0.2	NMT 1.5	APHA, 23 rd Edition 2017 (Section 4500-F)
19.	Total Suspended Solids	mg/L	6.8	NMT 20.0	APHA, 23 rd Edition 2017 (Section 2540-D)

Note:

1. The test report refers only to tested sample and applicable parameter.
2. These reports can neither be used as evidence in the court of law nor can it be used in part or full in any media without prior permission.
3. The sample will be destroyed after fifteen days from the date of issues of test reports unless otherwise specified.
4. *NLT: Not Less Than, *NMT: Not More Than


Sample Tested By




Authorised Signatory



Ref. No.: SEC/BVN/2025-26/964

Date: 11/12/2025

WATER ANALYSIS REPORT

DESCRIPTION OF SAMPLE

Customer Name:	Water Sample of Vallabhipur (Nagarpalika)	Date of Sampling	03-12-2025
Description of the Sample	WTP Inlet Sample	Date of Sample Received	04-12-2025
Name of Sampling Team	Swarnim Environment and Consultancy Team	Analysis Start Date	05-12-2025
Sample Quantity	1.0 Liter	Date of Reporting	11-12-2025
Location	WTP Plant, Kalyanpur, Mahipariage Yojana	Time	07:05 PM

Sr. No.	Characteristics / Parameters	Unit	Result	Test Method
1.	pH	--	8.20	APHA, 23 rd Edition 2017 (Section 4500-H ⁺ B)
2.	Biochemical Oxygen Demand	mg/L	3.8	APHA, 23 rd Edition 2017 (Section 2540-D)
3.	Chemical Oxygen Demand	mg/L	11.6	APHA, 23 rd Edition 2017 (Section 5220-B)
4.	Dissolved Oxygen (DO)	mg/L	6.4	APHA, 23 rd Edition (Section 4500-O) Part C 1992
5.	Total Dissolved Solids (TDS)	mg/L	190.40	APHA, 23 rd Edition 2017 (Section 2540-C)
6.	Turbidity	NTU	0.5	APHA, 22 nd Edition 2012 (Section 2130)
7.	Total Alkalinity	mg/L	14.52	APHA, 23 rd Edition 2017 (Section 2340-B)
8.	Chloride	mg/L	7.09	APHA, 23 rd Edition 2017 (Section 4500-Cl-B)
9.	Total Hardness	mg/L	22.33	APHA, 23 rd Edition 2017 (Section 2340-C)
10.	Sulphate	mg/L	13.93	APHA, 23 rd Edition 2017 (Section 4500-SO ₄ ⁻²)
11.	Nitrate as NO ₃ ⁻	mg/L	2.9	APHA, 22 nd Edition 2012 (Section 4500-NO ₃ ⁻)
12.	Nitrite as NO ₂ ⁻	mg/L	1.0	APHA, 22 nd Edition 2012 (Section 4500-NO ₂ ⁻)
13.	Ammonical Nitrogen (as N)	mg/L	Nil	APIIA, 23 rd Edition 2017 (Section 4500 NI13-C)
14.	Total Kjeldahl Nitrogen (TKN)	mg/L	1.0	APHA, 22 nd Edition 2012 (Section 4500-N)
15.	Total Coliform	MPN/10 0 ml	Absent	APHA, 23 rd Edition (9221 B & E)
16.	Faecal Coliform	MPN/10 0 ml	Absent	APHA, 23 rd Edition (9221 B & E)
17.	Residual Chlorine	mg/L	Nil	APHA, 23 rd Edition (4500 Cl B)
18.	Fluoride	mg/L	0.2	APHA, 23 rd Edition 2017 (Section 4500-F)
19.	Total Suspended Solids	mg/L	6.9	APIIA, 23 rd Edition 2017 (Section 2540-D)

Note:

1. The test report refers only to tested sample and applicable parameter.
2. These reports can neither be used as evidence in the court of law nor can it be used in part or full in any media without prior permission.
3. The sample will be destroyed after fifteen days from the date of issues of test reports unless otherwise specified.

Sample Tested By



Authorised Signatory



AN ISO/IEC 17025 NABL ACCREDITED ENVIRONMENT TESTING LABORATORY

GPCB Recognized Environmental Auditor (Schedule -II)

PLOT NO.111. HIRA PARK, OPP- VISHAL HOTEL, JAMNAGAR - 361006

+91 78749 15777 | +91 98794 06097 | tanishkaearthcare@gmail.com

TEST REPORT

Company Name	M/s. BANTVA NAGAR PALIKA	Sample ID	WQ/26/02/55
Address	2.60MLD STP BANTVA NAGAR PALIKA, BANTVA.	Condition of sample	Satisfactory
		Sample Done By	Customer
		Quantity of Sample	1000 ml
Date of Sampling	01.02.2026	Date of Sample Received	01.02.2026
Analysis Starts Date	01.02.2026	Analysis Completion Date	10.02.2026
Sample Description	INLET SAMPLE	Temperature/ Humidity during testing	Temp.- 25-29 deg C / Humidity <50 %
Report Number:	LAB/WQ/26/02/55	Report Date:	10.02.2026

S.No.	PARAMETERS	UNIT	RESULTS	LIMIT	Testing Method/ Standard
PHYSICAL CHEMICAL AND MICRO PARAMETERS					
1	pH @ 27 deg.	--	6.23		APHA 24 th Edition 4500 B: 2023
2	Total Suspended Solids	mg/l	532.16		APHA 24 th Edition 2540 D: 2023
3	Total Phosphorus	mg/l	7.25		APHA 24 th Edition 4500P D: 2023
4	Chemical Oxygen Demand	mg/l	164.31		IS 3025 (Part 58) 2006
5	Biochemical Oxygen Demand	mg/l	78.45		IS 3025 (Part 44) 1993
6	Ammonical Nitrogen	mg/l	22.69		APHA 24 th Edition 4500 NH3 C : 2023
7	Total Nitrogen	mg/l	25.67		APHA 24 th Edition 4500 N113C / Norg B/ NO3 B/NO2 B: 2023
8	Faecal Coliform	MPN/100 ml	≥1600.00		IS 1622
9	Total Coliform	MPN/100 ml	≥1600.00		IS 1622

Checked By :	Nikhil Dudhagara	Authorized Signatory :	Mufaddal Nathani
Signature :		Signature :	
Designation :	Chemist	Designation :	Technical Manager



- Notes:**
1. The report shall not be reproduced except in full without approval of the laboratory can provide assurance that parts of a report are not taken out of context.
 2. This certificate is based on the sample submitted for testing.
 3. Additions to, deviations, or exclusions from the method- NA
 4. Latest Revision of test methods are followed for the test parameter
 5. Disclaimer: When the information is supplied by the customer and can affect the validity of results
 6. Disclaimer: The report that the results apply to the sample as received in case of the sample has been supplied by customer
 7. Disclaimer: The laboratory shall be responsible for all the information provided in the report, except when information is provided by the customer
 8. Regulatory limit reference if any:- NA
 9. Opinion, Interpretation & Statement of Conformity if provided can be referred in the remarks section as "Permissible" "Below acceptable" or whatever is applicable as per the limit
 10. BDL: Below Detection Limit

● End of the Test Report ●

TANISHKA EARTH CARE SERVICES (OPC) PRIVATE LIMITED



TEST REPORT

Company Name	M/s. BANTVA NAGAR PALIKA	Sample ID	WQ/26/02/55
Address	2.60MLD STP BANTVA NAGAR PALIKA, BANTVA.	Condition of sample	Satisfactory
		Sample Done By	Customer
		Quantity of Sample	1000 ml
		Sampling Method	APHA
Date of Sampling	01.02.2026	Date of Sample Received	01.02.2026
Analysis Starts Date	01.02.2026	Analysis Completion Date	10.02.2026
Sample Description	OUTLET SAMPLE	Temperature/ Humidity during testing	Temp.- 25-29 deg C / Humidity <50 %
Report Number:	LAB/WQ/26/02/56	Report Date:	10.02.2026

S.No.	PARAMETERS	UNIT	RESULTS	LIMIT	Testing Method/ Standard
PHYSICAL CHEMICAL AND MICRO PARAMETERS					
1	pH @ 27 deg.	--	7.39	6.5-9	APHA 24 th Edition 4500 B
2	Total Suspended Solids	mg/l	8.74	<10	APHA 24 th Edition 2540 D
3	Total Phosphorus	mg/l	0.95	<1	APHA 24 th Edition 4500P D
4	Chemical Oxygen Demand	mg/l	42.31	<50	IS 3025 (Part 58)
5	Biochemical Oxygen Demand	mg/l	9.16	<10	IS 3025 (Part 44)
6	Ammonical Nitrogen	mg/l	3.49	<5	APHA 24 th Edition 4500 NH3 C
7	Total Nitrogen	mg/l	8.36	<10	APHA 24 th Edition 4500 N113C / Norg B/ NO3 B/NO2 B; 2023
8	Faecal Coliform	MPN/100 ml	70.00	<100	IS 1622
9	Total Coliform	MPN/100 ml	80.00	<100	IS 1622

Checked By :	Nikhil Dudhagara	Authorized Signatory :	Muradul Wathani
Signature :		Signature :	
Designation :	Chemist	Designation :	Technical Manager



- Notes:**
- The report shall not be reproduced except in full without approval of the laboratory can provide assurance that parts of a report are not taken out of context.
 - This certificate is based on the sample submitted for testing.
 - Additions to, deviations, or exclusions from the method- NA
 - Latest Revision of test methods are followed for the test parameter
 - Disclaimer: When the information is supplied by the customer and can affect the validity of results
 - Disclaimer: The report that the results apply to the sample as received in case of the sample has been supplied by customer
 - Disclaimer: The laboratory shall be responsible for all the information provided in the report, except when information is provided by the customer
 - Regulatory limit reference if any:- NA
 - Opinion, Interpretation & Statement of Conformity if provided can be referred in the remarks section as "Permissible" "Below acceptable" or whatever is applicable as per the limit
 - BDL : Below Detection Limit

● End of the Test Report ●



4590

NABL APPROVED LABORATORIES
ISO 9001:2015 APPROVED LABORATORIES

E-Cure
Environment Research and Laboratories

641

Test Report/Certificate


Chemical Analysis Of Waste water

Customer's Name and Address:	Krishna Corpindia Pvt. Ltd. – Ahmedabad 18.40 MLD STP at Deesa		
Report/Certificate No.	ERL/KCPL/WW/4-1/2025-26	Date of Issue	27/02/2026
Sample Description	Plant Inlet	Quantity/Nos.of Sample	2.0 Litre/ 1 Nos.
Date of Sampling	21/02/2026	Sampling Procedure	Grab
Sampling By	ERL Team	Sample ID	ERL/KCPL/WW/8
Sample Receipt Date	21/02/2026	Test Parameters & Methods	As per below Table
Packing/Seal	Sealed	Purpose	QC
Test Start Date	21/02/2026	Test Completion date	26/02/2026

Test Results				
Sr. No.	Parameters	Test Results	Unit	Test Method
1.	pH	8.12	--	IS 3025 (Part 11):1983(RA 2002)
2.	Temperature	29.00	°C	IS 3025 (Part 9):1983(RA 2002)
3.	Biochemical Oxygen Demand (BOD)	119.00	mg/L	IS 3025 (part 44): (RA 2009)
4.	Chemical Oxygen Demand (COD)	323.00	mg/L	IS 3025 (Part 58):2006
5.	Total Suspended Solids (TSS)	234.00	mg/L	IS 3025 (Part 15):1984(RA 2009)
6.	Chlorine	-	mg/L	IS 3025 (Part 32):1988(RA 2007)
7.	Faecal Coliforms	10 ⁴	MPN/100	IS 1622
8.	Total Phosphorus as P	0.008	mg/L	IS 3025 (Part 31)
9.	Total Nitrogen	0.31	mg/L	IS 3025 (Part 34)
10.	Total Coliforms	10 ⁷	MPN/100	IS 1622

Remarks →

- Test results relates to the sample tested only.
- Test Report shall not be reproduced except in full, without written approval of the Laboratory.

 Tested By	 Reviewed and Approved By
--	---

curing and caring Environment.





4591

NABL APPROVED LABORATORIES
ISO 9001:2015 APPROVED LABORATORIES

E-Cure

Environment Research and Laboratories

642

Test Report/Certificate


Chemical Analysis Of Waste water

Customer's Name and Address:	Krishna Corpindia Pvt. Ltd. – Ahmedabad 18.40 MLD STP at Deesa		
Report/Certificate No.	ERL/KCPL/WW/4/2025-26	Date of Issue	27/02/2026
Sample Description	Plant Outlet	Quantity/Nos. of Sample	2.0 Litre/ 1 Nos.
Date of Sampling	21/02/2026	Sampling Procedure	Grab
Sampling By	ERL Team	Sample ID	ERL/KCPL/WW/4
Sample Receipt Date	21/02/2026	Test Parameters & Methods	As per below Table
Packing/Seal	Sealed	Purpose	QC
Test Start Date	21/02/2026	Test Completion date	26/02/2026

Test Results				
Sr. No.	Parameters	Test Results	Unit	Test Method
1.	pH	7.12	--	IS 3025 (Part 11):1983(RA 2002)
2.	Temperature	25.89	°C	IS 3025 (Part 9):1983(RA 2002)
3.	Biochemical Oxygen Demand (BOD)	8.00	mg/L	IS 3025 (part 44): (RA 2009)
4.	Chemical Oxygen Demand (COD)	31.02	mg/L	IS 3025 (Part 58):2006
5.	Total Suspended Solids (TSS)	7.99	mg/L	IS 3025 (Part 15):1984(RA 2009)
6.	Chlorine	0.32	mg/L	IS 3025 (Part 32):1988(RA 2007)
7.	Faecal Coliforms	65	MPN/100	IS 1622
8.	Total Phosphorus as P	0.006	mg/L	IS 3025 (Part 31) Max. 0.03 mg/L
9.	Total Nitrogen	0.08	mg/L	IS 3025 (Part 34) Max 0.5 mg/L
10.	Total Coliforms	241	MPN/100	IS 1622

Remarks →

- Test results relates to the sample tested only.
- Test Report shall not be reproduced except in full, without written approval of the Laboratory.






Tested By
Reviewed and Approved By

TEST REPORT

Water/Wastewater Quality Sampling & Analysis

Company Name	Gujarat Construction Co.	Sample ID	WQ/291/26
Company Contact Number	9978406583	Condition of sample	Satisfactory
Address	Patel Motor Weigh Bridge, Nr. Rajkamal petrol pump, highway, Mehsana, 384002	Sample Drawn By	Customer
		Quantity of Sample	1 L
		Sampling Method	APHA/IS MODE: (GRAB/ COMPOSITE)
Date & Time of Sampling	20-02-2026	Date of Sample Received	20-02-2026
Analysis Starts Date	20-02-2026	Analysis Completion Date	26-02-2026
Sample Description	Inlet at 33.10 MLD Kalol STP	Temperature/ Humidity during testing	Temp.- 25-29 deg C / Humidity <50 %
Report Code:	SWA/LAB/20/02/2026/WQ/291	Report Date:	26-02-2026

S.No.	PARAMETERS	UNIT	RESULTS	Regulatory Limit	Remarks	Testing Method/ Standard
1	pH @27 deg.	-	7.12			APHA 24th Edition 4500 B: 2023
2	Total Suspended Solids	mg/l	234.71			APHA 24th Edition 2540 D: 2023
3	Ammonical Nitrogen	mg/l	7.28			APHA 24th Edition 4500 NH3 C: 2023
4	Total Kjeldahl Nitrogen	mg/l	18.94			APHA 24th Edition 4500 NH3 C/Norg B: 2023
5	Total Phosphorous	mg/l	5.89			APHA 24th Edition 4500 P D: 2017
6	Chemical Oxygen Demand	mg/l	472.34			IS 3025 - Part 58 : 2023
7	Biochemical Oxygen Demand	mg/l	238.75			IS 3025 - Part 44 : 2023
8	Total Coliform	MPN/100 ml	8 x 10 ⁴			IS 1622 - Rea. 2019
Supervised By :		Harshad Salvi		Authorized Signatory :		Pankaj Gothi
Signature :				Signature :		
Designation :		Technical Manager/COO Lab		Designation :		Quality Manager/CEO

Notes:



- The report shall not be reproduced except in full without approval of the laboratory can provide assurance that parts of a report are not taken out of context.
- The results relate only to the items tested and sampled
- Additions to, deviations, or exclusions from the method- NA
- Results which were outsourced to external providers are marked with ** and results which are performed and not in NABL accreditation scope are marked with * in parameter column
- Disclaimer: When the information is supplied by the customer and can affect the validity of results
- Disclaimer: The report that the results apply to the sample as received in case of the sample has been supplied by customer
- Disclaimer: The laboratory shall be responsible for all the information provided in the report, except when information is provided by the customer
- Regulatory limit reference if any:- NA
- Opinion, Interpretation & Statement of Conformity if provided can be referred in the remarks section as "Permissible" "Below acceptable" or whatever is applicable as per the limit
- BDL : Below Detection Limit | RI: Revised report and the number of that times revised

----- End of the Test Report -----



WASTEWATER TREATMENT | ENVIRONMENTAL TESTING | FOOD TESTING

- Head Office : Survey No. 645, Miroli Kamod Circle, Ahmedabad-Dholka Road, Ahmedabad-382425
- Branch Office : Jaipur, Surat, Delhi, Bengaluru
- +91 9227988980 / 9265491610 | swa@swaenviro.com / lab@swaenviro.com | www.swaenviro.com

TEST REPORT						
Water/Wastewater Quality Sampling & Analysis						
Company Name	Gujarat Construction Co.		Sample ID	WQ/292/26		
Company Contact Number	9978406583		Condition of sample	Satisfactory		
Address	Patel Motor Weigh Bridge, Nr. Rajkamal petrol pump, highway, Mehsana, 384002		Sample Drawn By	Customer		
			Quantity of Sample	1 L		
			Sampling Method	APHA/IS MODE: (GRAB/ COMPOSITE)		
Date & Time of Sampling	20-02-2026		Date of Sample Received	20-02-2026		
Analysis Starts Date	20-02-2026		Analysis Completion Date	26-02-2026		
Sample Description	Outlet at 33.10 MLD Kalol STP		Temperature/ Humidity during testing	Temp.- 25-29 deg C / Humidity <50 %		
Report Code:	SWA/LAB/20/02/2026/WQ/292		Report Date:	26-02-2026		
S.No.	PARAMETERS	UNIT	RESULTS	Regulatory Limit	Remarks	Testing Method/ Standard
1	pH @27 deg.	-	7.21	6.5-9	/	APHA 24th Edition 4500 B: 2023
2	Total Suspended Solids	mg/l	6.74	<10		APHA 24th Edition 2540 D: 2023
3	Chemical Oxygen Demand	mg/l	39.46	<50		IS 3025 - Part 58 : 2023
4	Biochemical Oxygen Demand	mg/l	8.00	<10		IS 3025 - Part 44 : 2023
5	Ammonical Nitrogen	mg/l	1.82	<5		APHA 24th Edition 4500 NH3 C: 2023
6	Total Phosphorus	mg/l	0.68	<2		APHA 24th Edition 4500 P D: 2023
7	Total Nitrogen	mg/l	8.13	<10		APHA 24th Edition 4500 NH3 C/ Norg B/NO3 B/NO2 B:2017
8	Faecal Coliforms	MPN/100 ml	50.00	<230		IS 1622 Rea.1981
Supervised By :		Harshad Salvi		Authorized Signatory :		Pankaj Gothi
Signature :				Signature :		
Designation :		Technical Manager/COO Lab		Designation :		Quality Manager/CEO
Notes:						
1. The report shall not be reproduced except in full without approval of the laboratory can provide assurance that parts of a report are not taken out of context.						
2. The results relate only to the items tested and sampled						
3. Additions to, deviations, or exclusions from the method- NA						
4. Results which were outsourced to external providers are marked with ** and results which are performed and not in NABL accreditation scope are marked with * in parameter column						
5. Disclaimer: When the information is supplied by the customer and can affect the validity of results						
6. Disclaimer: The report that the results apply to the sample as received in case of the sample has been supplied by customer						
7. Disclaimer: The laboratory shall be responsible for all the information provided in the report, except when information is provided by the customer						
8. Regulatory limit reference if any:- NA						
9. Opinion: Interpretation & Statement of Conformity if provided can be referred in the remarks section as "Permissible" "Below acceptable" or whatever is applicable as per the limit						
10. BDL : Below Detection Limit R1: Revised report and the number of that times revised						
----- End of the Test Report -----						



WASTEWATER TREATMENT | ENVIRONMENTAL TESTING | FOOD TESTING

-  Head Office : Survey No. 645, Miroli Kamod Circle, Ahmedabad-Dholka Road, Ahmedabad-382425
-  Branch Office : Jaipur, Surat, Delhi, Bengaluru
-  +91 9227988980 / 9265491610  swa@swaenviro.com / lab@swaenviro.com  www.swaenviro.com



ISO 9001:2015 and ISO 17025:2017 NABL certified

No.4, Versetile Industrial Estate, Nr. Kotak Bank, Gate No.5, Kathwada Gidc, Ahmedabad - 382430.

+91 8469130040, +91 6357351655 naturemicrovision@gmail.com GSTIN : 24AAWFN4704G1Z4

Test Report

Report ID: NML/WW/25-26/1203

Date: 07/02/2026


Customer Name	P.DAS INFRASTRUCTURE PVT LTD		
Customer Address	12.80 MLD KADI		
Date & Time of Sampling	02/02/2026	Sampling Plan & Method	IS 3025(Part-1) RA 2019
Date of Receipt of Sample	03/02/2026		
Sample Collected by	Client	Sample Condition	SATISFACTORY
Analysis Starting Date	03/02/2026	Packing / Seal	SEALED
Analysis Completion Date	06/02/2026	Quantity / No. of Samples	Approx. 1 LIT. * 1NO.
Environmental Condition	Temperature: 25 °C ± 2	Relative Humidity (%)	Humidity ≤ 50 %

Sample No.	Sample ID	Sample Type	Location	Description
1.	25-26/1212	Waste Water	Outlet	Treated Water

Analysis Results

Sr. No.	Parameters	Reference Method	Results	Regulatory Limit	Unit
1.	pH	IS 3025 (Part 11): 2022	7.52	6.5-8.5	--
2.	BIOLOGICAL OXYGEN DEMAND (3 days at 27°C)	IS 3025 (Part 44): 2023	8.0	<10	mg/L
3.	CHEMICAL OXYGEN DEMAND	IS 3025 (Part 58) : 2023	41	50	mg/L
4.	TOTAL SUSPENDED SOLIDS	IS 3025 (Part 17): 1988 (RA 2022)	8.32	<10	mg/L
5.	AMMONICAL NITROGEN	IS 3025 (Part 34/sec-1):2023	2.2	-	mg/L
6.	TOTAL NITROGEN	IS 3025 (Part 34/sec- 1):2023	7.8	<10	mg/L
7.	TOTAL PHOSPHOROUS	IS 3025 (Part 31) :Sec 1 : 2022	0.74	<1	mg/L
8.	FECAL COLIFORM	APHA 24th Edition 2023 9221 E	137	<250	(MPN)/100
9.	FREE RESIDUALCHLORINE	IS 3025 (Part 31) : Sec 1 : 2022	0.65	<1	mg/L
10.	TOTAL COLIFORM	APHA 24th Edition 2023 9221 B	208	<250	(MPN)/100

Checked by Senior Chemist



Authorised by Lab Manager/CEO

Remarks:

- BDL: Below Detectable Limit.
- The report pertains only to the sample tested and does not apply to the bulk quantity.
- The test report may not be reproduced, wholly or partially, nor used for promotional or publicity purposes without written consent from the laboratory department.
- Samples will be retained for 15 days after the completion of analysis. A longer retention period can be arranged upon customer request.



ISO 9001:2015 and ISO 17025:2017 NABL certified

No.4, Versetile Industrial Estate, Nr. Kotak Bank, Gate No.5,
Kathwada Gidc, Ahmedabad - 382430.

+91 8469130040, +91 6357351655 naturemicrovision@gmail.com GSTIN : 24AAWFN4704G1Z4

Test Report

Report ID: NML/WW/25-26/1202

Date: 07/02/2026

Customer Name	P.DAS INFRASTRUCTURE PVT LTD		
Customer Address	12.80 MLD KADI		
Date & Time of Sampling	02/02/2026	Sampling Plan & Method	IS 3025(Part-1) RA 2019
Date of Receipt of Sample	03/02/2026		
Sample Collected by	Client	Sample Condition	SATISFACTORY
Analysis Starting Date	03/02/2026	Packing / Seal	SEALED
Analysis Completion Date	06/02/2026	Quantity / No. of Samples	Approx. 1 LIT. * 1NO.
Environmental Condition	Temperature: 25 °C ± 2	Relative Humidity (%)	Humidity ≤ 50 %

Sample No.	Sample ID	Sample Type	Location	Description
1.	25-26/1211	Waste Water	Inlet	Untreated Water

Analysis Results

Sr. No.	Parameters	Reference Method	Results	Regulatory Limit	Unit
1.	pH	IS 3025 (Part 11): 2022	7.29	6.5-7.0	--
2.	BIOLOGICAL OXYGEN DEMAND (3 days at 27°C)	IS 3025 (Part 44): 2023	214.6	<250	mg/L
3.	CHEMICAL OXYGEN DEMAND	IS 3025 (Part 58) : 2023	405	<425	mg/L
4.	TOTAL SUSPENDED SOLIDS	IS 3025 (Part 17): 1988 (RA 2022)	274.12	<375	mg/L
5.	TOTAL NITROGEN	IS 3025 (Part 34/sec- 1):2023	22	<50	mg/L
6.	TOTAL PHOSPHORUS	IS 3025 (Part 31) :Sec 1 : 2022	3.1	<7.1	mg/L
7.	TOTAL COLIFORM	APHA 24th Edition 2023 9221 B	10 ⁷	10 ⁶ -10 ⁸	(MPN)/100
8.	FECAL COLIFORM	APHA 24th Edition 2023 9221 E	10 ³	10 ⁴ -10 ⁸	(MPN)/100

Checked by
Senior Chemist



Authorised by
Lab Manager/CEO

End of Test Report

Remarks:

- BDL: Below Detectable Limit.
- The report pertains only to the sample tested and does not apply to the bulk quantity.
- The test report may not be reproduced, wholly or partially, nor used for promotional or publicity purposes without written consent from the laboratory department.
- Samples will be retained for 15 days after the completion of analysis. A longer retention period can be arranged upon customer request.



ISO 9001:2015 and ISO 17025:2017 NABL certified

No.4, Versetile Industrial Estate, Nr. Kotak Bank, Gate No.5,
Kathwada Gidc, Ahmedabad - 382430.

+91 8469130040, +91 6357351655 naturemicrovision@gmail.com GSTIN : 24AAWFN4704G1Z4

Test Report

Report ID: NML/WW/25-26/1175

Date: 27/02/2026

Customer Name	MEET CONSTRUCTION Co.		
Customer Address	5.30 MLD STP PUDGAM		
Date & Time of Sampling	23/02/2026	Sampling Plan & Method	IS 3025(Part-1) RA 2019
Date of Receipt of Sample	24/02/2026		
Sample Collected by	Client	Sample Condition	SATISFACTORY
Analysis Starting Date	24/02/2026	Packing / Seal	SEALED
Analysis Completion Date	27/02/2026	Quantity / No. of Samples	Approx. 1 LIT. * 1NO.
Environmental Condition	Temperature: 25 °C ± 2	Relative Humidity (%)	Humidity ≤ 50 %

Sample No.	Sample ID	Sample Type	Location	Description
1.	25-26/1184	Waste Water	Inlet	Untreated Water


Analysis Results

Sr. No.	Parameters	Reference Method	Results	Regulatory Limit	Unit
1.	pH	IS 3025 (Part 11): 2022	7.23	6.5-7.0	--
2.	BIOLOGICAL OXYGEN DEMAND (3 days at 27°C)	IS 3025 (Part 44): 2023	201	<250	mg/L
3.	CHEMICAL OXYGEN DEMAND	IS 3025 (Part 58) : 2023	435	<425	mg/L
4.	TOTAL SUSPENDED SOLIDS	IS 3025 (Part 17): 1988 (RA 2022)	264.38	<375	mg/L
5.	TOTAL NITROGEN	IS 3025 (Part 34/sec- 1):2023	36	<50	mg/L
6.	TOTAL PHOSPHORUS	IS 3025 (Part 31) :Sec 1 : 2022	2.7	<7.1	mg/L
7.	TOTAL COLIFORM	APHA 24 th Edition 2023 9221 B	3.8×10 ⁶	10 ⁶ -10 ⁸	(MPN)/100
8.	FECAL COLIFORM	APHA 24 th Edition 2023 9221 E	3.3×10 ²	10 ⁴ -10 ⁸	(MPN)/100


Checked by
Senior Chemist



End of Test Report


Authorised by
Lab Manager/CEO

Remarks:

- BDL: Below Detectable Limit.
- The report pertains only to the sample tested and does not apply to the bulk quantity.
- The test report may not be reproduced, wholly or partially, nor used for promotional or publicity purposes without written consent from the laboratory department.
- Samples will be retained for 15 days after the completion of analysis. A longer retention period can be arranged upon customer request.



ISO 9001:2015 and ISO 17025:2017 NABL certified

No.4, Versetile Industrial Estate, Nr. Kotak Bank, Gate No.5, Kathwada Gidc, Ahmedabad - 382430.

+91 8469130040, +91 6357351655 naturemicrovision@gmail.com GSTIN : 24AAWFN4704G1Z4

Test Report

Report ID: NML/WW/25-26/1231

Date: 27/02/2026

Customer Name	MEET CONSTRUCTION Co.		
Customer Address	5.30 MLD STP PUDGAM		
Date & Time of Sampling	23/02/2026	Sampling Plan & Method	IS 3025(Part-1) RA 2019
Date of Receipt of Sample	24/02/2026		
Sample Collected by	Client	Sample Condition	SATISFACTORY
Analysis Starting Date	24/02/2026	Packing / Seal	SEALED
Analysis Completion Date	27/02/2026	Quantity / No. of Samples	Approx. 1 LIT. * 1NO.
Environmental Condition	Temperature: 25 °C ± 2	Relative Humidity (%)	Humidity ≤ 50 %

Sample No.	Sample ID	Sample Type	Location	Description
1.	25-26/1240	Waste Water	Outlet	Treated Water

Analysis Results

Sr. No.	Parameters	Reference Method	Results	Regulatory Limit	Unit
1.	pH	IS 3025 (Part 11): 2022	7.55	6.5-9.0	--
2.	BIOLOGICAL OXYGEN DEMAND (3 days at 27°C)	IS 3025 (Part 44): 2023	8.3	<10	mg/L
3.	CHEMICAL OXYGEN DEMAND	IS 3025 (Part 58) : 2023	42	<50	mg/L
4.	TOTAL SUSPENDED SOLIDS	IS 3025 (Part 17): 1988 (RA 2022)	8.27	<10	mg/L
5.	AMMONICAL NITROGEN	IS 3025 (Part 34/sec-1):2023	3.7	<5	mg/L
6.	TOTAL NITROGEN	IS 3025 (Part 34/sec-1):2023	8.4	<10	mg/L
7.	TOTAL PHOSPHORUS	IS 3025 (Part 31) :Sec 1 : 2022	0.73	1	mg/L
8.	FECAL COLIFORM	APHA 24 th Edition 2023 9221 E	138	<230	(MPN)/100
9.	RESIDUAL CHLORINE	IS 3025 (Part 31) : Sec 1 : 2022	0.63	0.5-1.0	mg/L
10.	TOTAL COLIFORM	APHA 24 th Edition 2023 9221 B	152	<230	(MPN)/100

Checked by Senior Chemist



End of Test Report

Authorised by Lab Manager/CEO

Remarks:

- BDL: Below Detectable Limit.
- The report pertains only to the sample tested and does not apply to the bulk quantity.
- The test report may not be reproduced, wholly or partially, nor used for promotional or publicity purposes without written consent from the laboratory department.
- Samples will be retained for 15 days after the completion of analysis. A longer retention period can be arranged upon customer request.



ISO 9001:2015 and ISO 17025:2017 NABL certified

No.4, Versetile Industrial Estate, Nr. Kotak Bank, Gate No.5, Kathwada Gidc, Ahmedabad - 382430.

+91 8469130040, +91 6357351655 naturemicrovision@gmail.com GSTIN : 24AAWFN4704G1Z4

Test Report

Report ID: NML/WW/25-26/1179

Date: 27/02/2026

Customer Name	MEET CONSTRUCTION Co.		
Customer Address	12.00 MLD STP VISNAGAR		
Date & Time of Sampling	23/02/2026	Sampling Plan & Method	IS 3025(Part-1) RA 2019
Date of Receipt of Sample	24/02/2026		
Sample Collected by	Client	Sample Condition	SATISFACTORY
Analysis Starting Date	24/02/2026	Packing / Seal	SEALED
Analysis Completion Date	27/02/2026	Quantity / No. of Samples	Approx. 1 LIT. * 1NO.
Environmental Condition	Temperature: 25 °C ± 2	Relative Humidity (%)	Humidity ≤ 50 %

Sample No.	Sample ID	Sample Type	Location	Description
1.	25-26/1188	Waste Water	Inlet	Untreated Water

Analysis Results

Sr. No.	Parameters	Reference Method	Results	Regulatory Limit	Unit
1.	pH	IS 3025 (Part 11): 2022	7.32	6.5-7.0	--
2.	BIOLOGICAL OXYGEN DEMAND (3 days at 27°C)	IS 3025 (Part 44): 2023	221	<250	mg/L
3.	CHEMICAL OXYGEN DEMAND	IS 3025 (Part 58) : 2023	408.6	<425	mg/L
4.	TOTAL SUSPENDED SOLIDS	IS 3025 (Part 17): 1988 (RA 2022)	274.25	<375	mg/L
5.	TOTAL NITROGEN	IS 3025 (Part 34/sec- 1):2023	31	<50	mg/L
6.	TOTAL PHOSPHORUS	IS 3025 (Part 31) :Sec 1 : 2022	2.9	<7.1	mg/L
7.	TOTAL COLIFORM	APHA 24 th Edition 2023 9221 B	4.4×10 ⁵	10 ⁶ -10 ⁸	(MPN)/100
8.	FECAL COLIFORM	APHA 24 th Edition 2023 9221 E	3.6×10 ²	10 ⁴ -10 ⁸	(MPN)/100

Checked by
Senior Chemist



Authorised by
Lab Manager/CEO

End of Test Report

Remarks:

- BDL: Below Detectable Limit.
- The report pertains only to the sample tested and does not apply to the bulk quantity.
- The test report may not be reproduced, wholly or partially, nor used for promotional or publicity purposes without written consent from the laboratory department.
- Samples will be retained for 15 days after the completion of analysis. A longer retention period can be arranged upon customer request.



ISO 9001:2015 and ISO 17025:2017 NABL certified

No.4, Versetile Industrial Estate, Nr. Kotak Bank, Gate No.5, Kathwada Gidc, Ahmedabad - 382430.

+91 8469130040, +91 6357351655 naturemicrovision@gmail.com GSTIN : 24AAWFN4704G1Z4

Test Report

Report ID: NML/WW/25-26/1234

Date: 27/02/2026


Customer Name	MEET CONSTRUCTION Co.		
Customer Address	12.00 MLD STP VISNAGAR		
Date & Time of Sampling	23/02/2026	Sampling Plan & Method	IS 3025(Part-1) RA 2019
Date of Receipt of Sample	24/02/2026		
Sample Collected by	Client	Sample Condition	SATISFACTORY
Analysis Starting Date	24/02/2026	Packing / Seal	SEALED
Analysis Completion Date	27/02/2026	Quantity / No. of Samples	Approx. 1 LIT. * 1NO.
Environmental Condition	Temperature: 25 °C ± 2	Relative Humidity (%)	Humidity ≤ 50 %

Sample No.	Sample ID	Sample Type	Location	Description
1.	25-26/1243	Waste Water	Outlet	Treated Water

Analysis Results

Sr. No.	Parameters	Reference Method	Results	Regulatory Limit	Unit
1.	pH	IS 3025 (Part 11): 2022	7.49	6.5-9.0	--
2.	BIOLOGICAL OXYGEN DEMAND (3 days at 27°C)	IS 3025 (Part 44): 2023	7.3	<10	mg/L
3.	CHEMICAL OXYGEN DEMAND	IS 3025 (Part 58) : 2023	47	<50	mg/L
4.	TOTAL SUSPENDED SOLIDS	IS 3025 (Part 17): 1988 (RA 2022)	8.79	<10	mg/L
5.	AMMONICAL NITROGEN	IS 3025 (Part 34/sec-1):2023	2.4	<5	mg/L
6.	TOTAL NITROGEN	IS 3025 (Part 34/sec- 1):2023	8.2	<10	mg/L
7.	TOTAL PHOSPHORUS	IS 3025 (Part 31) :Sec 1 : 2022	0.61	1	mg/L
8.	FECAL COLIFORM	APHA 24 th Edition 2023 9221 E	144	<230	(MPN)/100
9.	RESIDUAL CHLORINE	IS 3025 (Part 31) : Sec 1 : 2022	0.65	0.5-1.0	mg/L
10.	TOTAL COLIFORM	APHA 24 th Edition 2023 9221 B	162	<230	(MPN)/100


Checked by
Senior Chemist



Authorised by
Lab Manager/CEO


Remarks:

- BDL: Below Detectable Limit.
- The report pertains only to the sample tested and does not apply to the bulk quantity.
- The test report may not be reproduced, wholly or partially, nor used for promotional or publicity purposes without written consent from the laboratory department.
- Samples will be retained for 15 days after the completion of analysis. A longer retention period can be arranged upon customer request.

TEST REPORT						
Water/Wastewater Quality Sampling & Analysis						
Company Name	Vadnagar Nagarpalika		Sample ID	WQ/203/26		
Company Contact Number	NA		Condition of sample	Satisfactory		
Address	5.94 MLD STP at Vadnagar		Sample Drawn By	Customer		
			Quantity of Sample	1 L		
			Sampling Method	APHA/IS MODE: (GRAB/ COMPOSITE)		
Date & Time of Sampling	20-02-2026		Date of Sample Received	20-02-2026		
Analysis Starts Date	20-02-2026		Analysis Completion Date	26-02-2026		
Sample Description	Inlet		Temperature/ Humidity during testing	Temp.- 25-29 deg C/ Humidity <50 %		
Report Code:	SWA/LAB/20/02/2026/WQ/203		Report Date:	26-02-2026		
S.No.	PARAMETERS	UNIT	RESULTS	Regulatory Limit	Remarks	Testing Method/ Standard
1	pH @27 deg.	-	6.79	/		APHA 24th Edition 4500 B: 2023
2	Total Suspended Solids	mg/l	305.24			APHA 24th Edition 2540 D: 2023
3	Total Phosphorus	mg/l	6.92			APHA 24th Edition 4500 P D: 2023
4	Chemical Oxygen Demand	mg/l	352.01			IS 3025 - Part 58 : 2006
5	Biochemical Oxygen Demand	mg/l	124.25			IS 3025 - Part 44 : 1993
6	Total Kjeldhal Nitrogen	mg/l	54.13			APHA 24th Edition 4500 NH3 C/ Norg B: 2023
7	Fecal Coliform	MPN/100 ml	4 x 10 ⁶			IS 1622 - Rea. 1981
8	Total Coliform	MPN/100 ml	5 x 10 ⁶			IS 1622 - Rea. 1981
Supervised By :		Harshad Salvi		Authorized Signatory :		Pankaj Gothi
Signature :				Signature :		
Designation :		Technical Manager/COO Lab		Designation :		Quality Manager/CEO
Sub Note: Testing is carried out as per Gujarat Water Supply & Sewerage Board reference letter no PB/STP/943						
Notes:						
1. The report shall not be reproduced except in full without approval of the laboratory can provide assurance that parts of a report are not taken out of context.						
2. The results relate only to the items tested and sampled						
3. Additions to, deviations, or exclusions from the method- NA						
4. Results which were outsourced to external providers are marked with ** and results which are performed and not in NABL accreditation scope are marked with * in parameter column						
5. Disclaimer: When the information is supplied by the customer and can affect the validity of results						
6. Disclaimer: The report that the results apply to the sample as received in case of the sample has been supplied by customer						
7. Disclaimer: The laboratory shall be responsible for all the information provided in the report, except when information is provided by the customer						
8. Regulatory limit reference if any:- NA						
9. Opinion, Interpretation & Statement of Conformity if provided can be referred in the remarks section as "Permissible" "Below acceptable" or whatever is applicable as per the limit						
10. BDL : Below Detection Limit R1: Revised report and the number of that times revised						
----- End of the Test Report -----						



WASTEWATER TREATMENT | ENVIRONMENTAL TESTING | FOOD TESTING

TEST REPORT						
Water/Wastewater Quality Sampling & Analysis						
Company Name	Vadnagar Nagarpalika		Sample ID	WQ/204/26		
Company Contact Number	NA		Condition of sample	Satisfactory		
Address	5.94 MLD STP at Vadnagar		Sample Drawn By	Customer		
			Quantity of Sample	1 L		
			Sampling Method	APHA/IS MODE: (GRAB/ COMPOSITE)		
Date & Time of Sampling	20-02-2026		Date of Sample Received	20-02-2026		
Analysis Starts Date	20-02-2026		Analysis Completion Date	26-02-2026		
Sample Description	Outlet		Temperature/ Humidity during testing	Temp.- 25-29 deg C / Humidity <50 %		
Report Code:	SWA/LAB/20/02/2026/WQ/204		Report Date:	26-02-2026		
S.No.	PARAMETERS	UNIT	RESULTS	Regulatory Limit	Remarks	Testing Method/ Standard
1	pH @27 deg.	-	7.38	6.5-8.0	/	APHA 23rd Edition 4500 B: 2017
2	Total Suspended Solids	mg/l	8.13	<10		APHA 23rd Edition 2540 D: 2017
3	Amonical Nitrogen	mg/l	2.46	<5		APHA 23rd Edition 4500 NH3 C: 2017
4	Total Phosphorous	mg/l	1.37	<2		APHA 23rd Edition 4500 P D: 2017
5	Total Nitrogen	mg/l	8.21	<10		APHA 24th Edition 4500 NH3 C/ Norg B/ NO3 B/ NO2 B: 2023
6	Chemical Oxygen Demand	mg/l	34.19	<50		IS 3025 - Part 58 : 2006
7	Biochemical Oxygen Demand	mg/l	7.00	<10		IS 3025 - Part 44 : 1993
8	Total Residual Chlorine	mg/l	0.42	<0.5		APHA 23rd Edition 4500-CL B: 2017
9	Faecal Coliform	MPN/100 ml	33.00	<100		IS 1622 - Rea. 1981
10	Total Coliform	MPN/100 ml	50.00	<100		IS 1622 - Rea. 1981
Supervised By :		Harshad Salvi		Authorized Signatory :		Pankaj Gothi
Signature :				Signature :		
Designation :		Technical Manager/COO Lab		Designation :		Quality Manager/CEO
Sub Note: Testing is carried out as per Gujarat Water Supply & Sewerage Board reference letter no PB/STP/943						
Notes:						
1. The report shall not be reproduced except in full without approval of the laboratory can provide assurance that parts of a report are not taken out of context.						
2. The results relate only to the items tested and sampled						
3. Additions to, deviations, or exclusions from the method- NA						
4. Results which were outsourced to external providers are marked with "*" and results which are performed and not in NABL accreditation scope are marked with "*" in parameter column						
5. Disclaimer: When the information is supplied by the customer and can affect the validity of results						
6. Disclaimer: The report that the results apply to the sample as received in case of the sample has been supplied by customer						
7. Disclaimer: The laboratory shall be responsible for all the information provided in the report, except when information is provided by the customer						
8. Regulatory limit reference if any:- NA						
9. Opinion, Interpretation & Statement of Conformity if provided can be refered in the remarks section as "Permissible" "Below acceptable" or whatever is applicable as per the limit						
10. BDL : Below Detection Limit RI: Revised report and the number of that times revised						
----- End of the Test Report -----						



WASTEWATER TREATMENT | ENVIRONMENTAL TESTING | FOOD TESTING

TEST REPORT

Report No. : MaRS/MTL/5418	Report Date : 25-02-26
Sample Received Date : 17-02-26	Description of Sample : Water
Duration of Testing : 17-02-26 to 25-02-26	Condition of Sample : Satisfactory
Sample ID : MTL/5418/1	
Client Name : Chief Officer, Patan Nagarpalika PATAN	
Contractor Name : Harsh Enterprises, Ahmedabad	
Project Name : 25 MLD Capacity STP SBR Type at Makhaniya Para Patan.	
Identification : Inlet (Raw Water Sewage)	

TEST RESULTS

Sr. No.	Parameters	Test Method IS :3025	Results	Units	IS Specification Limit as per 10500
1	pH	IS 3025 – Part – 11	7.44	N/A	6.8 – 8.0
2	Total Suspended Solids	IS 3025 – Part - 17	265.00	mg/L	Max. 400 mg/l
3	Total Dissolved Solids	IS : 3025 - Part 16	328.00	mg/L	Max. 500 mg/l
4	Chemical Oxygen Demand	IS 3025 – Part – 58	405.00	mg/L	Max. 550 mg/l
5	Biological Oxygen Demand	IS 3025 – Part – 44	154.00	mg/L	Max. 250 mg/l
6	Total Phosphorus as P	IS 3025 – Part -31	0.005	mg/L	Max. 0.03 mg/l
7	Total Nitrogen	IS 3025 – Part -34	0.26	mg/L	Max 0.5 mg/l
8	Faecal Coliforms	IS 1622	10 ⁵	MPN/100	-
9	Total Coliforms	IS 1622	10 ⁷	MPN/100	-

Authorized Signatory

MaRS Enviro Research & Engineering Services Pvt. Ltd

Remarks:

1. The test report does not indicate the quality of the product or usage of product or Suitability of the Product or Material.
2. Testing was carried out as per IS Codes.
3. The test result related to the samples supplied by the client/agency.
4. Reproduction of this report in whole or in part by any means except with written Permission of the testing Agency shall be deemed to be an infringement.
5. The report/ result are not to be used for Publicity.
6. We do not undertake or abide by to participate or appear in any legal/court matter or litigation of any kind or dispute or issues existing or arising whatsoever.



TEST REPORT

Report No. : MaRS/MTL/5418	Report Date : 25-02-26
Sample Received Date : 17-02-26	Description of Sample : Water
Duration of Testing : 17-02-26 to 25-02-26	Condition of Sample : Satisfactory
Sample ID : MTL/5418/2	
Client Name : Chief Officer, Patan Nagarpalika PATAN	
Contractor Name : Harsh Enterprises, Ahmedabad	
Project Name : 25 MLD Capacity STP SBR Type at Makhaniya Para Patan.	
Identification : Outlet (Treated Water Sewage)	

TEST RESULTS

Sr. No.	Parameters	Test Method IS :3025	Results	Units	IS Specification Limit as per 10500
1	pH	IS 3025 – Part – 11	7.35	N/A	6.5 – 8.0
2	Total Suspended Solids	IS 3025 – Part - 17	42.00	mg/L	Max. 100 mg/l
3	Total Dissolved Solids	IS : 3025 - Part 16	25.00	mg/L	Max. 500 mg/l
4	Chemical Oxygen Demand	IS 3025 – Part – 58	15.00	mg/L	Max. 250 mg/l
5	Biological Oxygen Demand	IS 3025 – Part – 44	10.00	mg/L	Max. 30 mg/l
6	Total Phosphorus as P	IS 3025 – Part -31	0.009	mg/L	Max. 0.03 mg/l
7	Total Nitrogen	IS 3025 – Part -34	0.07	mg/L	Max 0.5 mg/l
8	Faecal Coliforms	IS 1622	62	MPN/100	-
9	Total Coliforms	IS 1622	228	MPN/100	-

(Signature)
Authorized Signatory

MaRS Enviro Research & Engineering Services Pvt. Ltd

Remarks:

1. The test report does not indicate the quality of the product or usage of product or Suitability of the Product or Material.
2. Testing was carried out as per IS Codes.
3. The test result related to the samples supplied by the client/agency.
4. Reproduction of this report in whole or in part by any means except with written Permission of the testing Agency shall be deemed to be an infringement.
5. The report/ result are not to be used for Publicity.
6. We do not undertake or abide by to participate or appear in any legal/court matter or litigation of any kind or dispute or issues existing or arising whatsoever.





1ST Floor, Shop No. 7&8, Harisiddh Chamber, Near Sakhari Jin Road, Himmatnagar - 383 001.
 GPCB Recognized Schedule II Auditor (ID: 2304) Telephone: 91 – 8460068577
 E-mail: opsconsultants77@gmail.com

TEST REPORT/CERTIFICATE

NAME & ADDRESS OF COSTUMER:

M/s. STP PLANT (POOJA CONSTRUCTION COMPANY, RAJKOT)
 Himmatnagar.

SAMPLE DESCRIPTION:	STP	LAB ID:	--
SAMPLE COLLECTED BY:	Client	PROTOCOL(PURPOSE):	Environmental analysis
SAMPLING DATE:	10/02/2026	SAMPLING TIME:	12:20 Pm
SAMPLE QUANTITY:	05 Liter	SAMPLE ID NO:	OPS/26/02/W/06/07
SAMPLING METHOD:	OPS/SOP/WATER/01	PACKING/SEAL:	Sealed
SAMPLE RECEIVED DATE:	10/02/2026	SAMPLE RECEIVED TIME:	12:50 am
TEST START DATE:	10/02/2026	TEST COMPLETION DATE:	14/02/2026

RESULT TABLE:

Sr. No.	PARAMETER	UNIT	IN LET	OUTLET	TEST METHOD
01	pH	--	7.87	7.15	IS: 3025 (Part 11) 1983 Re. 1996
02	Suspended Solids	mg/L	241	32.54	IS: 3025 (Part 17) 1984 Re. 2012
03	Chemical Oxygen Demand	mg/L	265	60.54	APHA 22 nd ED. 5220 B
04	Biochemical Oxygen Demand	mg/L	82.43	20.4	IS: 3025 (Part 44) 1993 Re. 2009
05	Total Dissolved Solids	mg/L	985	784	IS:3025 (Part 27) 1986 Re.1998
06	Faecal coliforms	MPN/100	10*2	65	IS 1622 (1981)
07	Total colifoam	MPN/100	10*4	243	IS 1622 (1981)

- NOTE: Sample collection by POOJA CONSTRUCTION

For, OPS CONSULTANTS

PREPARED BY:

(AUTHORISED SIGNATORY)

(DEPUTY TECHNICAL MANAGER)



ISO 9001:2015 and ISO 17025:2017 NABL certified

No.4, Versetile Industrial Estate, Nr. Kotak Bank, Gate No.5,
Kathwada Gidc, Ahmedabad - 382430.

+91 8469130040, +91 6357351655 naturemicrovision@gmail.com GSTIN : 24AAWFN4704G1Z4

Test Report

Report ID: NML/WW/25-26/1317

Date: 27/02/2026


Customer Name	MARUTI ENTERPRISE		
Customer Address	7.6 MLD DEHGAM		
Date & Time of Sampling	23/02/2026	Sampling Plan & Method	IS 3025(Part-1) RA 2019
Date of Receipt of Sample	24/02/2026		
Sample Collected by	Client	Sample Condition	SATISFACTORY
Analysis Starting Date	24/02/2026	Packing / Seal	SEALED
Analysis Completion Date	27/02/2026	Quantity / No. of Samples	Approx. 1 LIT. * 1NO.
Environmental Condition	Temperature: 25 °C ± 2	Relative Humidity (%)	Humidity ≤ 50 %

Sample No.	Sample ID	Sample Type	Location	Description
1.	25-26/1326	Waste Water	Inlet	Untreated Water

Analysis Results

Sr. No.	Parameters	Reference Method	Results	Regulatory Limit	Unit
1.	pH	IS 3025 (Part 11): 2022	7.34	6.5-7.0	--
2.	BIOLOGICAL OXYGEN DEMAND (3 days at 27°C)	IS 3025 (Part 44): 2023	228	<250	mg/L
3.	CHEMICAL OXYGEN DEMAND	IS 3025 (Part 58) : 2023	376	<425	mg/L
4.	TOTAL SUSPENDED SOLIDS	IS 3025 (Part 17): 1988 (RA 2022)	245.32	<375	mg/L
5.	TOTAL NITROGEN	IS 3025 (Part 34/sec- 1):2023	29	<50	mg/L
6.	TOTAL PHOSPHORUS	IS 3025 (Part 31) :Sec 1 : 2022	3.0	<7.1	mg/L
7.	TOTAL COLIFORM	APHA 24 th Edition 2023 9221 B	2.5×10^3	$10^7 - 10^8$	(MPN)/100
8.	FECAL COLIFORM	APHA 24 th Edition 2023 9221 E	10^5	$10^4 - 10^8$	(MPN)/100
9.	AMMONICAL NITROGEN	IS 3025 (Part 34/sec-1):2023	20	<50	mg/L

Checked by
Senior Chemist



Authorised by
Lab Manager/CEO

Remarks:

- BDL: Below Detectable Limit.
- The report pertains only to the sample tested and does not apply to the bulk quantity.
- The test report may not be reproduced, wholly or partially, nor used for promotional or publicity purposes without written consent from the laboratory department.
- Samples will be retained for 15 days after the completion of analysis. A longer retention period can be arranged upon customer request.



ISO 9001:2015 and ISO 17025:2017 NABL certified

No.4, Versetile Industrial Estate, Nr. Kotak Bank, Gate No.5,
Kathwada Gidc, Ahmedabad - 382430.

+91 8469130040, +91 6357351655 naturemicrovision@gmail.com GSTIN : 24AAWFN4704G1Z4

Test Report

Report ID: NML/WW/25-26/1316

Date: 27/02/2026


Customer Name	MARUTI ENTERPRISE		
Customer Address	7.6 MLD DEHGAM		
Date & Time of Sampling	23/02/2026	Sampling Plan & Method	IS 3025(Part-1) RA 2019
Date of Receipt of Sample	24/02/2026		
Sample Collected by	Client	Sample Condition	SATISFACTORY
Analysis Starting Date	24/02/2026	Packing / Seal	SEALED
Analysis Completion Date	27/02/2026	Quantity / No. of Samples	Approx. 1 LIT. * 1NO.
Environmental Condition	Temperature: 25 °C ± 2	Relative Humidity (%)	Humidity ≤ 50 %

Sample No.	Sample ID	Sample Type	Location	Description
1.	25-26/1325	Waste Water	Outlet	Treated Water

Analysis Results

Sr. No.	Parameters	Reference Method	Results	Regulatory Limit	Unit
1.	pH	IS 3025 (Part 11): 2022	7.68	6.5-9.0	--
2.	BIOLOGICAL OXYGEN DEMAND (3 days at 27°C)	IS 3025 (Part 44): 2023	7.9	<10	mg/L
3.	CHEMICAL OXYGEN DEMAND	IS 3025 (Part 58) : 2023	38	<50	mg/L
4.	TOTAL SUSPENDED SOLIDS	IS 3025 (Part 17): 1988 (RA 2022)	7.75	<10	mg/L
5.	AMMONICAL NITROGEN	IS 3025 (Part 34/sec-1):2023	2.2	<5	mg/L
6.	TOTAL NITROGEN	IS 3025 (Part 34/sec- 1):2023	7.5	<10	mg/L
7.	TOTAL PHOSPHORUS	IS 3025 (Part 31) :Sec 1 : 2022	0.59	1	mg/L
8.	FECAL COLIFORM	APHA 24 th Edition 2023 9221 E	115	<230	(MPN)/100
9.	RESIDUAL CHLORINE	IS 3025 (Part 31) : Sec 1 : 2022	0.61	0.5-1.0	mg/L
10.	TOTAL COLIFORM	APHA 24 th Edition 2023 9221 B	188	<230	(MPN)/100

Checked by
Senior Chemist



Authorised by
Lab Manager/CEO

Remarks:

- BDL: Below Detectable Limit.
- The report pertains only to the sample tested and does not apply to the bulk quantity.
- The test report may not be reproduced, wholly or partially, nor used for promotional or publicity purposes without written consent from the laboratory department.
- Samples will be retained for 15 days after the completion of analysis. A longer retention period can be arranged upon customer request.



ISO 9001:2015 and ISO 17025:2017 NABL certified

No.4, Versetile Industrial Estate, Nr. Kotak Bank, Gate No.5,
Kathwada Gidc, Ahmedabad - 382430.

+91 8469130040, +91 6357351655 naturemicrovision@gmail.com GSTIN : 24AAWFN4704G1Z4

Test Report

Report ID: NML/WW/25-26/1326

Date: 28/02/2026

Customer Name	P.DAS INFRASTRUCTURE PVT LTD		
Customer Address	11.60 MLD UNJHA		
Date & Time of Sampling	23/02/2026	Sampling Plan & Method	IS 3025(Part-1) RA 2019
Date of Receipt of Sample	24/02/2026		
Sample Collected by	Client	Sample Condition	SATISFACTORY
Analysis Starting Date	24/02/2026	Packing / Seal	SEALED
Analysis Completion Date	28/02/2026	Quantity / No. of Samples	Approx. 1 LIT. * 1NO.
Environmental Condition	Temperature: 25 °C ± 2	Relative Humidity (%)	Humidity ≤ 50 %

Sample No.	Sample ID	Sample Type	Location	Description
1.	25-26/1335	Waste Water	Inlet	Untreated Water

Analysis Results

Sr. No.	Parameters	Reference Method	Results	Regulatory Limit	Unit
1.	pH	IS 3025 (Part 11): 2022	7.36	6.5-7.0	--
2.	BIOLOGICAL OXYGEN DEMAND (3 days at 27°C)	IS 3025 (Part 44): 2023	185	<250	mg/L
3.	CHEMICAL OXYGEN DEMAND	IS 3025 (Part 58) : 2023	386.4	<425	mg/L
4.	TOTAL SUSPENDED SOLIDS	IS 3025 (Part 17): 1988 (RA 2022)	248.7	<375	mg/L
5.	TOTAL NITROGEN	IS 3025 (Part 34/sec- 1):2023	35	<50	mg/L
6.	TOTAL PHOSPHORUS	IS 3025 (Part 31) :Sec 1 : 2022	3.2	<7.1	mg/L
7.	TOTAL COLIFORM	APHA 24 th Edition 2023 9221 B	4.9×10 ⁵	10 ⁶ -10 ⁸	(MPN)/100
8.	FECAL COLIFORM	APHA 24 th Edition 2023 9221 E	3.3×10 ³	10 ⁴ -10 ⁸	(MPN)/100

Checked by
Senior Chemist

Authorised by
Lab Manager/CEO

End of Test Report

Remarks:

- BDL: Below Detectable Limit.
- The report pertains only to the sample tested and does not apply to the bulk quantity.
- The test report may not be reproduced, wholly or partially, nor used for promotional or publicity purposes without written consent from the laboratory department.
- Samples will be retained for 15 days after the completion of analysis. A longer retention period can be arranged upon customer request.



ISO 9001:2015 and ISO 17025:2017 NABL certified

No.4, Versetile Industrial Estate, Nr. Kotak Bank, Gate No.5,
Kathwada Gidc, Ahmedabad - 382430.

+91 8469130040, +91 6357351655

naturemicrovision@gmail.com

GSTIN : 24AAWFN4704G1Z4

Test Report

Date: 28/02/2026

Report ID: NML/WW/25-26/1325


Customer Name	P.DAS INFRASTRUCTURE PVT LTD		
Customer Address	11.60 MLD UNJHA		
Date & Time of Sampling	23/02/2026	Sampling Plan & Method	IS 3025(Part-1) RA 2019
Date of Receipt of Sample	24/02/2026		
Sample Collected by	Client	Sample Condition	SATISFACTORY
Analysis Starting Date	24/02/2026	Packing / Seal	SEALED
Analysis Completion Date	28/02/2026	Quantity / No. of Samples	Approx. 1 LIT. * 1NO.
Environmental Condition	Temperature: 25 °C ± 2	Relative Humidity (%)	Humidity ≤ 50 %

Sample No.	Sample ID	Sample Type	Location	Description
1.	25-26/1334	Waste Water	Outlet	Treated Water

Analysis Results

Sr. No.	Parameters	Reference Method	Results	Regulatory Limit	Unit
1.	pH	IS 3025 (Part 11): 2022	7.53	6.5-9.0	--
2.	BIOLOGICAL OXYGEN DEMAND (3 days at 27°C)	IS 3025 (Part 44): 2023	7.6	<10	mg/L
3.	CHEMICAL OXYGEN DEMAND	IS 3025 (Part 58) : 2023	38	<50	mg/L
4.	TOTAL SUSPENDED SOLIDS	IS 3025 (Part 17): 1988 (RA 2022)	7.11	<10	mg/L
5.	AMMONICAL NITROGEN	IS 3025 (Part 34/sec-1):2023	2.3	<5	mg/L
6.	TOTAL NITROGEN	IS 3025 (Part 34/sec-1):2023	7.0	<10	mg/L
7.	TOTAL PHOSPHORUS	IS 3025 (Part 31) :Sec 1 : 2022	0.56	1	mg/L
8.	FECAL COLIFORM	APHA 24 th Edition 2023 9221 E	159	<230	(MPN)/100
9.	RESIDUAL CHLORINE	IS 3025 (Part 31) : Sec 1 : 2022	0.61	0.5-1.0	mg/L
10.	TOTAL COLIFORM	APHA 24 th Edition 2023 9221 B	171	<230	(MPN)/100



Checked by
Senior Chemist



Authorised by
Lab Manager/CEO


Remarks:

- BDL: Below Detectable Limit.
- The report pertains only to the sample tested and does not apply to the bulk quantity.
- The test report may not be reproduced, wholly or partially, nor used for promotional or publicity purposes without written consent from the laboratory department.
- Samples will be retained for 15 days after the completion of analysis. A longer retention period can be arranged upon customer request

TEST REPORT						
Water/Wastewater Quality Sampling & Analysis						
Company Name	Gujarat Construction Co.		Sample ID	WQ/295/26		
Company Contact Number	9978406583		Condition of sample	Satisfactory		
Address	Patel Motor Weigh Bridge, Nr. Rajkamal petrol pump, highway, Mehsana, 384002		Sample Drawn By	Customer		
			Quantity of Sample	1 L		
			Sampling Method	NA		
Date & Time of Sampling	20-20-2026		Date of Sample Received	20-02-2026		
Analysis Starts Date	20-02-2026		Analysis Completion Date	26-02-2026		
Sample Description	Inlet at Radhanpur 6.0 MLD STP		Temperature/ Humidity during testing	Temp.- 25-29 deg C/ Humidity <50 %		
Report Code:	SWA/LAB/20/02/2026/WQ/295		Report Date:	26-02-2026		
S.No.	PARAMETERS	UNIT	RESULTS	Regulatory Limit	Remarks	Testing Method/ Standard
1	pH @27 deg.	-	7.01	/		APHA 23rd Edition 4500 B: 2017
2	Total Suspended Solids	mg/l	145.38			APHA 23rd Edition 2540 D: 2017
3	Total Dissolved Solids	mg/l	765.32			APHA 23rd Edition 2540 C: 2017
4	Total Kjeldahl Nitrogen	mg/l	19.06			APHA 23rd Edition 4500 NH3 C/Norg B: 2017
5	Total Phosphorous	mg/l	7.32			APHA 23rd Edition 4500 P D: 2017
6	Chemical Oxygen Demand	mg/l	368.41			IS 3025 - Part 5B : 2006
7	Biochemical Oxygen Demand	mg/l	220.00			IS 3025 - Part 44 : 1993
8	Faecal Coliforms	MPN/100 ml	3.5x10 ⁵			IS 1622: Rea.1981
9	Total Coliforms	MPN/100 ml	3 x10 ⁶			IS 1622: Rea.1981
Supervised By :		Harshad Salvi		Authorized Signatory :		Pankaj Gothi
Signature :				Signature :		
Designation :		Technical Manager/COO Lab		Designation :		Quality Manager/CEO
Notes:						
1. The report shall not be reproduced except in full without approval of the laboratory can provide assurance that parts of a report are not taken out of context.						
2. The results relate only to the items tested and sampled						
3. Additions to, deviations, or exclusions from the method- NA						
4. Results which were outsourced to external providers are marked with ** and results which are performed and not in NABL accreditation scope are marked with * in parameter column						
5. Disclaimer: When the information is supplied by the customer and can affect the validity of results						
6. Disclaimer: The report that the results apply to the sample as received in case of the sample has been supplied by customer						
7. Disclaimer: The laboratory shall be responsible for all the information provided in the report, except when information is provided by the customer						
8. Regulatory limit reference if any:- NA						
9. Opinion, Interpretation & Statement of Conformity if provided can be refered in the remarks section as "Permissible" "Below acceptable" or whatever is applicable as per the limit						
10. BDL : Below Detection Limit						
----- End of the Test Report -----						



WASTEWATER TREATMENT | ENVIRONMENTAL TESTING | FOOD TESTING

TEST REPORT						
Water/Wastewater Quality Sampling & Analysis						
Company Name	Gujarat Construction Co.		Sample ID	WQ/296/26		
Company Contact Number	9978406583		Condition of sample	Satisfactory		
Address	Patel Motor Weigh Bridge, Nr. Rajkamal petrol pump, highway, Mehsana, 384002		Sample Drawn By	Customer		
			Quantity of Sample	1 L		
			Sampling Method	NA		
Date & Time of Sampling	20-02-2026		Date of Sample Received	20-02-2026		
Analysis Starts Date	20-02-2026		Analysis Completion Date	26-02-2026		
Sample Description	Outlet at Radhanpur 6.0 MLD STP		Temperature/ Humidity during testing	Temp.- 25-29 deg C / Humidity <50 %		
Report Code:	SWA/LAB/20/02/2026/WQ/296		Report Date:	26-02-2026		
S.No.	PARAMETERS	UNIT	RESULTS	Regulatory Limit	Remarks	Testing Method/ Standard
1	pH @27 deg.	-	7.50	6.5-9	/	APHA 23rd Edition 4500 B: 2017
2	Total Suspended Solids	mg/l	3.26	<10		APHA 23rd Edition 2540 D: 2017
3	Chemical Oxygen Demand	mg/l	40.94	<50		IS 3025 - Part 58 : 2006
4	Biochemical Oxygen Demand	mg/l	7.75	<10		IS 3025 - Part 44 : 1993
5	Ammonical Nitrogen	mg/l	1.23	<5		APHA 23rd Edition 4500 NH3 C: 2017
6	Total Phosphorus	mg/l	0.31	<2		APHA 23rd Edition 4500 P D: 2017
7	Total Nitrogen	mg/l	4.21	<10		APHA 23rd Edition 4500 NH3 C/ Norg B/NO3 B/NO2 B: 2017
8	Faecal Coliforms	MPN/100 ml	33.00	<230		IS 1622 : 1981
9	Total Coliforms	MPN/100 ml	40.00	<230		IS 1622 : 1981
10	Residual Chlorine	mg/l	0.67	0.5-1.0		APHA 23rd Edition 4500 CL B: 2017
Supervised By :		Harshad Salvi		Authorized Signatory :		Pankaj Gothi
Signature :				Signature :		
Designation :		Technical Manager/COO Lab		Designation :		Quality Manager/CEO
Notes:						
1. The report shall not be reproduced except in full without approval of the laboratory can provide assurance that parts of a report are not taken out of context.						
2. The results relate only to the items tested and sampled						
3. Additions to, deviations, or exclusions from the method- NA						
4. Results which were outsourced to external providers are marked with ** and results which are performed and not in NABL accreditation scope are marked with * in parameter column						
5. Disclaimer: When the information is supplied by the customer and can affect the validity of results						
6. Disclaimer: The report that the results apply to the sample as received in case of the sample has been supplied by customer						
7. Disclaimer: The laboratory shall be responsible for all the information provided in the report, except when information is provided by the customer						
8. Regulatory limit reference if any:- NA						
9. Opinion, Interpretation & Statement of Conformity if provided can be referred in the remarks section as "Permissible" "Below acceptable" or whatever is applicable as per the limit						
10. BDL : Below Detection Limit						
----- End of the Test Report -----						



WASTEWATER TREATMENT | ENVIRONMENTAL TESTING | FOOD TESTING

TEST REPORT

Report No. : MaRS/MTL/5419	Report Date : 25-02-26
Sample Received Date : 17-02-26	Description of Sample : Water
Duration of Testing : 17-02-26 to 25-02-26	Condition of Sample : Satisfactory
Sample ID : MTL/5419/1	
Client Name : Chief officer idar Nagarpalika idar	
Contractor Name : Harsh Enterprises, Ahmedabad	
Project Name : 7.40 MLD Capacity STP SBR Type at Idar	
Identification : Inlet (Raw Water Sewage)	

TEST RESULTS

Sr. No.	Parameters	Test Method IS :3025	Results	Units	IS Specification Limit as per 10500
1	pH	IS 3025 – Part – 11	7.43	N/A	6.8 – 8.0
2	Total Suspended Solids	IS 3025 – Part - 17	246.00	mg/L	Max. 400 mg/l
3	Total Dissolved Solids	IS : 3025 - Part 16	309.00	mg/L	Max. 500 mg/l
4	Chemical Oxygen Demand	IS 3025 – Part – 58	330.00	mg/L	Max. 550 mg/l
5	Biological Oxygen Demand	IS 3025 – Part – 44	125.00	mg/L	Max. 250 mg/l
6	Total Phosphorus as P	IS 3025 – Part -31	0.009	mg/L	Max. 0.03 mg/l
7	Total Nitrogen	IS 3025 – Part -34	0.21	mg/L	Max 0.5 mg/l
8	Faecal Coliforms	IS 1622	10 ⁶	MPN/100	-
9	Total Coliforms	IS 1622	10 ⁷	MPN/100	-

Authorized Signatory

MaRS Enviro Research & Engineering Services Pvt. Ltd

Remarks:

1. The test report does not indicate the quality of the product or usage of product or Suitability of the Product or Material.
2. Testing was carried out as per IS Codes.
3. The test result related to the samples supplied by the client/agency.
4. Reproduction of this report in whole or in part by any means except with written Permission of the testing Agency shall be deemed to be an infringement.
5. The report/ result are not to be used for Publicity.
6. We do not undertake or abide by to participate or appear in any legal/court matter or litigation of any kind or dispute or issues existing or arising whatsoever.



TEST REPORT

Report No. : MaRS/MTL/5419	Report Date : 25-02-26
Sample Received Date : 17-02-26	Description of Sample : Water
Duration of Testing : 17-02-26 to 25-02-26	Condition of Sample : Satisfactory
Sample ID : MTL/5419/2	
Client Name : Chief officer idar Nagarpalika idar	
Contractor Name : Harsh Enterprises, Ahmedabad	
Project Name : 7.4 MLD Capacity STP SBR Type at Idar	
Identification : Outlet (Treated Water Sewage)	

TEST RESULTS

Sr. No.	Parameters	Test Method IS :3025	Results	Units	IS Specification Limit as per 10500
1	pH	IS 3025 – Part – 11	7.30	N/A	6.5 – 8.0
2	Total Suspended Solids	IS 3025 – Part - 17	37.00	mg/L	Max. 100 mg/l
3	Total Dissolved Solids	IS : 3025 - Part 16	28.00	mg/L	Max. 500 mg/l
4	Chemical Oxygen Demand	IS 3025 – Part – 58	18.00	mg/L	Max. 250 mg/l
5	Biological Oxygen Demand	IS 3025 – Part – 44	7.00	mg/L	Max. 30 mg/l
6	Total Phosphorus as P	IS 3025 – Part -31	0.009	mg/L	Max. 0.03 mg/l
7	Total Nitrogen	IS 3025 – Part -34	0.08	mg/L	Max 0.5 mg/l
8	Faecal Coliforms	IS 1622	75	MPN/100	-
9	Total Coliforms	IS 1622	214	MPN/100	-

Authorized Signatory


MaRS Enviro Research & Engineering Services Pvt. Ltd

Remarks:

- The test report does not indicate the quality of the product or usage of product or Suitability of the Product or Material.
- Testing was carried out as per IS Codes.
- The test result related to the samples supplied by the client/agency.
- Reproduction of this report in whole or in part by any means except with written Permission of the testing Agency shall be deemed to be an infringement.
- The report/ result are not to be used for Publicity.
- We do not undertake or abide by to participate or appear in any legal/court matter or litigation of any kind or dispute or issues existed or arising whatsoever





4613

664

Satva Environ Consultancy

Environment Testing Laboratory

Analysis Report of Waste Water

REF: SEC/WAT/ROU/23/02/2026

Date: 23/02/2026

Waste Water Analysis	
Name and Address of Unit	Khilari Infrastructure Pvt Ltd 101 Prahat Centre Sector 1 Acbd Belapur Mumbai 400614.
Date of Sample Received	23/02/2026
Sample Collected By/Provided By	Provided by Client
Sample Collected from	4MLD STP at Dhanera
Sample Description	STP Inlet
Quantity Receipt in L	2
Sample Condition During Receipt	Acceptable
Analysis Start Date	23/02/2026
Analysis End Date	27/02/2026

Sr. No.	Parameters	Reference Method	Results	Units	Permissible Limit
1	pH	IS 3025 (Part 11), 1983 (RA 2017)	7.49	--	--
2	Suspended Solid	IS 3025 (Part 17), 1984 (RA 2017)	84.65	mg/l	--
3	Chemical Oxygen Demand	IS 3025 (Part 58), 2006 (RA 2017)	468	mg/l	--
4	BOD (3 Day 27°C)	IS 3025 (Part 44) (RA 2014)	267	mg/l	--
5	Total Coliform	IS: 1622:1981	10 ⁷	MPN/10 0ml	--
6	faecal Coliform	IS: 1622:1981	10 ⁶	MPN/10 0ml	--

**Note:**

- The results listed here with are only for the tested item only.
- This report shall not be reproduced except in full without permission of the CEO of Satva Environ Consultancy.
- Samples shall be disposed after 15 days from the date of issue of the report unless agreed with the customer.
- The result apply to the samples received.

❖ End of Report ❖



4614

665

SatvaEnvironConsultancy

EnvironmentTestingLaboratory

AnalysisReportofWasteWater

REF:SECWAT/ROU/23/02/2026

Date:23/02/2026

WasteWaterAnalysis	
NameandAddressofUnit	KhilarilInfrastructurePvtLtd 101Prahatscentresector1Acbbdelapurmumbai400614.
DateofSampleReceived	23/02/2026
SampleCollectedBy/ProvidedBy	ProvidedbyClient
SampleCollectedfrom	4MLDSTPatDhanera
SampleDescription	STPOutlet
QuantityReceiptinL	2
SampleConditionDuringReceipt	Acceptable
AnalysisStartDate	23/02/2026
AnalysisEndDate	27/02/2026

Sr.No	Parameters	ReferenceMethod	Results	Units	Permissible Limit
1	pH	IS3025(Part11),1983(RA2017)	7.39	--	--
2	SuspendedSolid	IS3025(Part17),1984(RA2017)	7.62	mg/l	--
3	ChemicalOxygen Demand	IS3025(Part58),2006(RA2017)	27.54	mg/l	--
4	BOD(3Day27°C)	IS3025(Part44)(RA2014)	8.82	mg/l	--
5	ResidualChlorine	IS3025(Part26),2021	0.78	mg/l	--
5	TotalColiform	IS:1622:1981	173	MPN/100ml	--
6	faecalColiform	IS:1622:1981	70	MPN/100ml	--

**Note:**

- The results listed here with are only for the tested item only.
- This report shall not be reproduced except in full without permission of the CEO of Satva Environ Consultancy.
- Samples shall be disposed after 15 days from the date of issue of the report unless agreed with the customer.
- The result apply to the samples received.

❖ End of Report ❖



CERTIFICATE OF ANALYSIS

Report No: BECS/WW/710.1/25-26

Issued to	Nagar Palica - Tharad		
Sample Collected By	Self	Test Report as per	IS&APHA
Sample Identity	Waste Water	Sampling Method	SOP Based/APHA
Sampling Description	STP Inlet	Sampling Type	Grab
Sampling Location	STP	Environment Condition	25°C±3
Sample ID	BECS/WW/0207	Sample Condition/Packing	Satisfactory
Sample Quantity	1 Lit × 1 Nos	Date Of Sampling	19/02/2026
Date of Receipt	Date of Start Analysis	Date of Completion	Date of Issue
20/02/2026	20/02/2026	27/02/2026	27/02/2026

Physico-Chemical Requirement

Sr No.	TESTS	REFERENCE	UNIT OF MEASUREMENT	Result
1.	pH	APHA 23rd Edition 4500 B: 2017	----	6.75
2.	Total Suspended Solids (TSS)	APHA 23rd Edition 2540 D: 2017	mg/L	321
3.	Total Phosphorus	APHA 23rd Edition 4500 P C: 2017	mg/L	3.9
4.	Chemical Oxygen Demand (COD)	IS 3025 (Part-58) 2006	mg/L	321
5.	Bio-Chemical Oxygen Demand (BOD)	IS 3025 (Part-44) 1993	mg/L	112
6.	Ammoniacal Nitrogen	APHA 23rd Edition 4500 NH3, C: 2017	mg/L	7.8
7.	Total Nitrogen	APHA 23rd Edition 4500 NH3, N(org) C: 2017	mg/L	8.5
8.	Residual Chlorine	APHA 23rd Edition 4500 Cl-B: 2017	mg/L	1.32
9.	Fecal Coliform	IS: 1622	MPN/100mL	>1600

NOTE:

- 1 This report, in full or in part, shall not be published, advertised, used for any legal action, unless prior permission has been secured from The **BALAJI ENVIRONMENTAL CONSULTANCY SERVICES, RAJKOT.**
- 2 This test report is **ONLY FOR THE SAMPLE TESTED.**
- 3 Sample drawn by us.

Chandey

Analyzed by
Chemist/Microbiologist



Shamrani

Authorize Signatory
Mrs. Siddhi Parakhiya
Quality Manager

* END OF THE REPORT *

GPCB APPROVED SCHEDULE-II ENVIRONMENT AUDITOR

CERTIFICATE OF ANALYSIS

Report No: BECS/WW/710.1.1/25-26

Issued to	Nagar Palika - Tharad.		
Sample Collected By	Self	Test Report as per	IS & APHA
Sample Identity	Waste Water	Sampling Method	SOP Based / APHA
Sample Description	STP Inlet	Sampling Type	Grab
Sampling Location	STP	Environmental Condition	25 °C ± 3
Sample ID	BECS/WW/0207	Sample Condition	Satisfactory
Sample Quantity	1 Lit x 1 Nos.	Date of Sampling	19/02/2026
Date of Receipt	Date of Start Analysis	Date of Completion	Date of Issue
20/02/2026	20/02/2026	27/02/2026	27/02/2026

Biological Analysis

Sr No.	TESTS	REFERANCE	UNIT OF MEASUREMENT	RESULTS
1.	Total Coliform	IS : 1622 - 1981	MPN/100mL	542

NOTE:

- 1 This report, in full or in part, shall not be published, advertised, used for any legal action, unless prior permission has been secured from The **Balaji Environmental Consultancy Services, Rajkot.**
- 2 This test report is **ONLY FOR THE SAMPLE TESTED.**
- 3 Sample drawn by us.



SEAL

 Reviewed & Authorized By
 Chemist / Microbiologist

* END OF REPORT *



CERTIFICATE OF ANALYSIS

Report No: BECS/WW/710.2/25-26

Issued to	Nagar Palica - Tharad		
Sample Collected By	Self	Test Report as per	IS&APHA
Sample Identity	Waste Water	Sampling Method	SOP Based/APHA
Sampling Description	STP Outlet	Sampling Type	Grab
Sampling Location	STP	Environment Condition	25°C±3
Sample ID	BECS/WW/0208	Sample Condition/Packing	Satisfactory
Sample Quantity	1 Lit × 1 Nos	Date Of Sampling	19/02/2026
Date of Receipt	Date of Start Analysis	Date of Completion	Date of Issue
20/02/2026	20/02/2026	27/02/2026	27/02/2026

Physico-Chemical Requirements

Sr No.	TESTS	REFERENCE	UNIT OF MEASUREMENT	Permissible Limit	Result
1.	pH	APHA 23rd Edition 4500 B: 2017	----	6.5 - 9.0	7.32
2.	Total Suspended Solids (TSS)	APHA 23rd Edition 2540 D: 2017	mg/L	< 10	7.2
3.	Total Phosphorus	APHA 23rd Edition 4500 P C: 2017	mg/L	< 1	0.66
4.	Chemical Oxygen Demand (COD)	IS 3025 (Part-58) 2006	mg/L	< 50	33.6
5.	Bio-Chemical Oxygen Demand (BOD)	IS 3025 (Part-44) 1993	mg/L	< 10	8.8
6.	Ammoniacal Nitrogen	APHA 23rd Edition 4500 NH ₃ , C: 2017	mg/L	< 5	1.12
7.	Total Nitrogen	APHA 23rd Edition 4500 NH ₃ , N(org) C: 2017	mg/L	< 10	4.31
8.	Residual Chlorine	APHA 23rd Edition 4500 Cl- B: 2017	mg/L	0.5 - 1	0.71
9.	Fecal Coliform	IS: 1622	MPN/100mL	< 230	48

NOTE:

- 1 This report, in full or in part, shall not be published, advertised, used for any legal action, unless prior permission has been secured from The **BALAJI ENVIRONMENTAL CONSULTANCY SERVICES, RAJKOT.**
- 2 This test report is **ONLY FOR THE SAMPLE TESTED.**
- 3 Sample drawn by us.



Analyzed by
Chemist/Microbiologist




Authorize Signatory
Mrs. Siddhi Parakhiya
Quality Manager

* END OF THE REPORT *

GPCB APPROVED SCHEDULE-II ENVIRONMENT AUDITOR

**BALAJI****BECS ENVIRONMENTAL CONSULTANCY SERVICES**

Page 2 of 2

CERTIFICATE OF ANALYSIS

Report No: BECS/WW/710.2.1/25-26

Issued to	Nagar Palika - Tharad.		
Sample Collected By	Self	Test Report as per	IS & APHA
Sample Identity	Waste Water	Sampling Method	SOP Based / APHA
Sample Description	STP Outlet	Sampling Type	Grab
Sampling Location	STP	Environmental Condition	25 °C ± 3
Sample ID	BECS/WW/0208	Sample Condition	Satisfactory
Sample Quantity	1 Lit x 1 Nos.	Date of Sampling	19/02/2026
Date of Receipt	Date of Start Analysis	Date of Completion	Date of Issue
20/02/2026	20/02/2026	27/02/2026	27/02/2026

Biological Analysis

Sr No.	TESTS	REFERENCE	UNIT OF MEASUREMENT	RESULTS
1.	Total Coliform	IS : 1622 - 1981	MPN/100mL	141

NOTE:

- 1 This report, in full or in part, shall not be published, advertised, used for any legal action, unless prior permission has been secured from The **Balaji Environmental Consultancy Services, Rajkot.**
- 2 This test report is **ONLY FOR THE SAMPLE TESTED.**
- 3 Sample drawn by us.



SEAL

* END OF REPORT *

Reviewed & Authorized By
Chemist / Microbiologist



4619

670

Satva Environ Consultancy

Environment Testing Laboratory

Analysis Report of Waste Water

REF: SEC/WAT/ROU/24/02/2026

Date: 24.02.2026

Name and Address of Unit	Gujarat Construction Company Patel Motor Way Bridge, Near Rajkamal Petrol Pump, Highway Mehsana, Gujarat, 384002.
Date of Sample Received	24.02.2026
Sample Collected By/ Provided By	Provided by Client
Sample Collected from	BHABHAR 3.5MLD-STP
Sample Description	Inlet and Outlet of STP
Quantity Receipt in L	2
Sample Condition During Receipt	Acceptable
Analysis Start Date	24.02.2026
Analysis End Date	28.02.2026

Sr. No.	Parameters	Reference Method	Inlet Results	Outlet Results	Units	Permissible Limit
1	pH	IS3025(Part11),2022	8.12	7.18	--	--
2	Total Dissolved Solid	IS3025(Part16),1984(RA 2017)	878	813	mg/l	--
3	Suspended Solid	IS3025(Part17),1984(RA 2021)	968	7.33	mg/l	--
4	Chemical Oxygen Demand	IS3025(Part58),2006(RA 2017)	462	38.18	mg/l	--
5	BOD(3Day 27°C)	IS3025(Part44),1993(RA 2019)	238	7.34	mg/l	--
6	Faecal coliforms	IS1622-Rea1981	10 ⁶	71	MPN/100	--
7	Total Coliform	IS 1622-Rea 1981	10 ⁷	224	MPN/100	



Authorized Signatory
Pratik Nayak (CEO)

Note:

- The results listed here with are only for the tested item only.
- This report shall not be reproduced except in full without permission of the CEO of Satva Environ Consultancy.
- Samples shall be disposed after 15 days from the date of issue of the report unless agreed with the customer.
- The results apply to the samples received.

❖ End of Report ❖



AnalysisReportofWasteWater

REF:SEC/WAT/ROU/23/02/2026

Date:23/02/2026

WasteWaterAnalysis	
NameandAddressofUnit	KhilariInfrastructurePvtLtd 101Prahatcentresector1Acdbelapurmumbai400614.
Dateof SampleReceived	23/02/2026
SampleCollectedBy/ProvidedBy	ProvidedbyClient
SampleCollectedfrom	Thara 3.3 MLD-STP
SampleDescription	STP Inlet
QuantityReceiptinL	2
SampleConditionDuringReceipt	Acceptable
AnalysisStartDate	23/02/2026
AnalysisEndDate	27/02/2026

Sr. No.	Parameters	ReferenceMethod	Results	Units	Permissible Limit
1	pH	IS3025(Part11),1983(RA2017)	8.53	--	--
2	SuspendedSolid	IS3025(Part17),1984(RA2017)	84.81	mg/l	--
3	ChemicalOxygenDemand	IS3025(Part58),2006(RA2017)	457	mg/l	--
4	BOD(3Day27°C)	IS3025(Part44)(RA2014)	235	mg/l	--



Note:

- The results listed herewith are only for the tested item only.
- This report shall not be reproduced except in full without permission of the CEO of Satva Environ Consultancy.
- Samples shall be disposed after 15 days from the date of issue of the report unless agreed with the customer.
- The results apply to the samples received.

❖ End of Report ❖



4621

672

SatvaEnvironConsultancy

EnvironmentTestingLaboratory

AnalysisReportofWasteWater

REF:SEC/WAT/ROU/23/02/2026

Date:23/02/2026

WasteWaterAnalysis	
NameandAddressofUnit	KhilarilInfrastructurePvtLtd 101Prahatcentresector1Acdbbelapurmumbai400614.
Dateof SampleReceived	23/02/2026
SampleCollectedBy/ProvidedBy	ProvidedByClient
SampleCollectedfrom	Thara 3.3 MLD-STP
SampleDescription	STP Outlet
QuantityReceiptinL	2
SampleConditionDuringReceipt	Acceptable
AnalysisStartDate	23/02/2026
AnalysisEndDate	27/02/2026

Sr.No	Parameters	ReferenceMethod	Results	Units	Permissible Limit
1	pH	IS3025(Part11),1983(RA2017)	7.11	--	--
2	SuspendedSolid	IS3025(Part17),1984(RA2017)	7.42	mg/l	--
3	Chemical Oxygen Demand	IS3025(Part58),2006(RA2017)	34.38	mg/l	--
4	BOD(3Day27°C)	IS3025(Part44)(RA2014)	7.56	mg/l	--
5	ResidualChlorine	IS3025(Part26),2021	0.83	mg/l	--
5	TotalColiform	IS:1622:1981	229	MPN/100ml	--
6	faecalColiform	IS:1622:1981	74	MPN/100ml	--

**Note:**

- The results listed here with are only for the tested item only.
- This report shall not be reproduced except in full without permission of the CEO of Satva Environ Consultancy.
- Samples shall be disposed after 15 days from the date of issue of the report unless agreed with the customer.
- The result apply to the samples received.

❖ End of Report ❖



4622

Satva Environ Consultancy

Environment Testing Laboratory

673

Analysis Report of Waste Water

REF: SEC/WAT/ROU/23/02/2026

Date: 23/02/2026

Waste Water Analysis	
Name and Address of Unit	Khilari Infrastructure Pvt Ltd 101 Prahat Centre Sector 1 Acbd Belapur Mumbai 400614.
Date of Sample Received	23/02/2026
Sample Collected By/Provided By	Provided by Client
Sample Collected from	5 MLD STP at Mansa
Sample Description	STP Inlet
Quantity Receipt in L	2
Sample Condition During Receipt	Acceptable
Analysis Start Date	23/02/2026
Analysis End Date	27/02/2026

Sr. No.	Parameters	Reference Method	Results	Units	Permissible Limit
1	pH	IS3025(Part11),1983(RA2017)	8.18	--	--
2	Suspended Solid	IS3025(Part17),1984(RA2017)	86.85	mg/l	--
3	Chemical Oxygen Demand	IS3025(Part58),2006(RA2017)	438	mg/l	--
4	BOD(3Day27°C)	IS3025(Part44)(RA2014)	251	mg/l	--

**Note:**

- The results listed here with are only for the tested item only.
- This report shall not be reproduced except in full without the permission of the CEO of Satva Environ Consultancy.
- Samples shall be disposed after 15 days from the date of issue of the report unless agreed with the customer.
- The result applies to the samples received.

❖ End of Report ❖



4623

674

SatvaEnvironConsultancy

EnvironmentTestingLaboratory

AnalysisReportofWasteWater

REF:SEC/WAT/ROU/23/02/2026

Date:23/02/2026

WasteWaterAnalysis	
NameandAddressofUnit	KhilariInfrastructurePvtLtd 101Prahatcentresector1Acdbelapurmumbai400614.
Dateof SampleReceived	23/02/2026
SampleCollectedBy/ProvidedBy	ProvidedbyClient
SampleCollectedfrom	5MLDSTPat Mansa
SampleDescription	STP Outlet
QuantityReceiptinL	2
SampleConditionDuringReceipt	Acceptable
AnalysisStartDate	23/02/2026
AnalysisEndDate	27/02/2026

Sr.No	Parameters	ReferenceMethod	Results	Units	Permissible Limit
1	pH	IS3025(Part11),1983(RA2017)	7.11	--	--
2	SuspendedSolid	IS3025(Part17),1984(RA2017)	8.23	mg/l	--
3	Chemical Oxygen Demand	IS3025(Part58),2006(RA2017)	26.75	mg/l	--
4	BOD(3Day27°C)	IS3025(Part44)(RA2014)	8.11	mg/l	--
5	ResidualChlorine	IS3025(Part26),2021	0.71	mg/l	--
5	TotalColiform	IS:1622:1981	228	MPN/100ml	--
6	faecalColiform	IS:1622:1981	71	MPN/100ml	--

**Note:**

- The results listed here with are only for the tested item only.
- This report shall not be reproduced except in full without permission of the CEO of Satva Environ Consultancy.
- Samples shall be disposed after 15 days from the date of issue of the report unless agreed with the customer.
- The result apply to the samples received.

❖ End of Report ❖



Test Report
Water Sample Analysis Report

Client's Name & Address: M/s. Greenleaf Envirotech Limited, Surat. 2.9 MLD STP Kheralu, GWSSB, Mehsana Division.	Report No: GLEL/160226/01 Issue Date: 23/02/2026
--	---

Lab ID Code	:	GLEL/160226/WL ₁ , WL ₂		
Sample Description	:	Waste Water	Purpose	: As per Client requirement
Date of Sampling	:	Submitted by Client	Sample Collected/Submitted by	: Submitted by Client
Date of Sample Received	:	16/02/2026	Test Parameters	: As per Client requirement
Date of starting Analysis	:	16/02/2026	Quantity/No. of sample	: 2 Lit./02
Date of completion Analysis	:	23/02/2026	Packed/Seal	: Sealed

Result Table

Sr. No.	Test Parameters	Test Method	Unit	Results	
				WL ₁	WL ₂
1	pH at 25 °C	IS 3025 (P-11) 2022	-	6.42	7.08
2	Total Suspended Solids	IS 3025 (P-17) 2022	mg/L	221.2	17.6
3	Chemical Oxygen Demand	IS 3025 (P-58) 2023	mg/L	399.8	26.4
4	BOD (5 days at 20°C)	APHA 24thEd. 2023 5210 B (533) (Iodometric Method)	mg/L	132.1	8.4
5	Ammonical Nitrogen	IS 3025 (P-34/Sec 1) 2023	mg/L	16.2	BDL(MDL:1.0)
6	Phosphate	IS 3025 (P-31/Sec 1) 2022	mg/L	BDL(MDL:0.1)	BDL(MDL:0.1)
7	Total Nitrogen	IS 3025 (P-34/Sec 1) 2023	mg/L	16.5	BDL(MDL:1.0)
8	Residual Chlorine	IS 3025 (P-26) 2021	mg/L	BDL(MDL:0.5)	0.68
9	Fecal Coliform	IS 1622:1981	MPN/100mL	116	21
10	Total Coliform	IS 1622:1981	MPN/100mL	130	40

Note: BDL: Below Detection Limit, MDL: Minimum Detection Limit.

WL₁: STP Inlet Water, WL₂: STP Outlet Water from CCT

[Signature]

Chemist

[Signature]

Authorized Signatory

Rekha Der

- Notes: (1) The results pertain to tested items only.
(2) This report shall not be reproduced, except in full, without written approval of the laboratory.
(3) Authenticity of this Report could be validated with office copy at Greenleaf Envirotech Ltd.
(4) The samples will be destroyed after 10 days from the date of issue of the report, unless otherwise agreed with the customer or as required by the applicable regulations.

CIN: U29253GJ2010PLC059798

Recognized by MoEF, Govt of India, EP Act 1986; NABL accredited; GPCB Schedule II Environment Auditor; ISO-45001: 2018, ISO 9001:2015 certified Laboratory.



Test Report
Water Sample Analysis Report

Client's Name & Address: Krishna Construction Co, Ahmedabad 4.1 MLD STP Vijapur, GWSSB, Mehsana Division.	Report No: GLEL/160226/01 Issue Date: 23/02/2026
---	---

Lab ID Code	:	GLEL/160226/WL ₁ , WL ₂			
Sample Description	:	Waste Water	Purpose	:	As per Client requirement
Date of Sampling	:	Submitted by Client	Sample Collected/Submitted by	:	Submitted by Client
Date of Sample Received	:	16/02/2026	Test Parameters	:	As per Client requirement
Date of starting Analysis	:	16/02/2026	Quantity/No. of sample	:	2 Lit./02
Date of completion Analysis	:	23/02/2026	Packed/Seal	:	Sealed

Result Table

Sr. No.	Test Parameters	Test Method	Unit	Results	
				WL ₁	WL ₂
1	pH at 25 °C	IS 3025 (P-11) 2022	-	6.43	7.32
2	Total Suspended Solids	IS 3025 (P-17) 2022	mg/L	372.1	16.2
3	Chemical Oxygen Demand	IS 3025 (P-58) 2023	mg/L	401.2	31.6
4	BOD (5 days at 20°C)	APHA 24thEd. 2023 5210 B (533) (Iodometric Method)	mg/L	131.6	10.1
5	Ammonical Nitrogen	IS 3025 (P-34/Sec 1) 2023	mg/L	15.9	BDL (MDL:1.0)
6	Phosphate	IS 3025 (P-31/Sec 1) 2022	mg/L	BDL (MDL:0.1)	BDL (MDL:0.1)
7	Total Nitrogen	IS 3025 (P-34/Sec 1) 2023	mg/L	17.8	BDL (MDL:1.0)
8	Residual Chlorine	IS 3025 (P-26) 2021	mg/L	BDL (MDL:0.5)	0.64
9	Fecal Coliform	IS 1622:1981	MPN/100mL	121	15
10	Total Coliform	IS 1622:1981	MPN/100mL	170	60

Note: BDL: Below Detection Limit, MDL: Minimum Detection Limit.

WL₁: STP Inlet Water, WL₂: STP Outlet Water from CCT

[Signature]

Chemist

[Signature]

Authorized Signatory
Rekha Der

Notes: (1) The results pertain to tested items only.

(2) This report shall not be reproduced, except in full, without written approval of the laboratory.

(3) Authenticity of this Report could be validated with office copy at Greenleaf Envirotech Ltd.



(4) The samples will be destroyed after 10 days from the date of issue of the report, unless otherwise agreed with the customer or as required by the applicable regulations.

CIN: U29253GJ2010PLC059798

Recognized by MoEF, Govt of India, EP Act 1986; NABL accredited; GPCB Schedule II Environment Auditor; ISO-45001: 2018, ISO 9001:2015 certified Laboratory.

Greenleaf Envirotech Ltd., E-mail: sales@glepl.com, lab@glepl.com, Web: www.greenleafenvirotech.in

Registered Office: 304, Kankavati Complex, Singanpor-Cauzway Road, Katargam, Surat- 395004, Tel.: +91-9327565428/761.

TEST REPORT						
Water/Wastewater Quality Sampling & Analysis						
Company Name	Krishna Construction Company		Sample ID	WQ/263/26		
Company Contact Number	9099454400		Condition of sample	Satisfactory		
Address	1st Floor, H-110, Shreedhar Flora, Amar Javan Circle, Nikol Gam Road, Ahmedabad 382350		Sample Drawn By	Customer		
			Quantity of Sample	1 L.		
			Sampling Method	APHA/IS MODE: (GRAB/ COMPOSITE)		
Date & Time of Sampling	17-02-2026		Date of Sample Received	17-02-2026		
Analysis Starts Date	17-02-2026		Analysis Completion Date	23-02-2026		
Sample Description	Inlet at HARIJ 3.0 MLD STP		Temperature/ Humidity during testing	Temp.- 25-29 deg C / Humidity <50 %		
Report Code:	SWA/LAB/17/02/2026/WQ/263		Report Date:	23-02-2026		
S.No.	PARAMETERS	UNIT	RESULTS	Regulatory Limit	Remarks	Testing Method/ Standard
1	pH @27 deg.	-	7.42			APHA 24th Edition 4500 B: 2023
2	Total Suspended Solids	mg/l	285.17			APHA 24th Edition 2540 D: 2023
3	Total Phosphorus	mg/l	5.49			APHA 24th Edition 4500 P D: 2023
4	Chemical Oxygen Demand	mg/l	624.12			IS 3025 - Part 58 : 2006
5	Biochemical Oxygen Demand	mg/l	204.25			IS 3025 - Part 44 : 1993
6	Ammonical Nitrogen	mg/l	11.03			APHA 24th Edition 4500 NH3 C: 2023
7	Total Kjeldhal Nitrogen	mg/l	20.52			APHA 24th Edition 4500 NH3 C/ Norg B: 2023
8	Nitrate	mg/l	2.38			APHA 24th Edition 4500 NO3 B: 2023
9	Nitrite	mg/l	0.05			APHA 24th Edition 4500 NO2 B: 2023
10	Total Nitrogen	mg/l	22.94			APHA 24th Edition 4500 NH3 C/ Norg B/NO3 B/NO2 B:2023
11	Faecal Coliforms	MPN/100 ml	5x10 ⁵			IS 1622: Rea.1981
12	Total Coliforms	MPN/100 ml	7x10 ⁶			IS 1622: Rea.1981
Supervised By :		Harshad Salvi		Authorized Signatory :		Pankaj Gothi
Signature :				Signature :		
Designation :		Technical Manager/COO Lab		Designation :		Quality Manager/CEO
Notes:						
1. The report shall not be reproduced except in full without approval of the laboratory can provide assurance that parts of a report are not taken out of context.						
2. The results relate only to the items tested and sampled						
3. Additions to, deviations, or exclusions from the method- NA						
4. Results which were outsourced to external providers are marked with ** and results which are performed and not in NABL accreditation scope are marked with * in parameter column						
5. Disclaimer: When the information is supplied by the customer and can affect the validity of results						
6. Disclaimer: The report that the results apply to the sample as received in case of the sample has been supplied by customer						
7. Disclaimer: The laboratory shall be responsible for all the information provided in the report, except when information is provided by the customer						
8. Regulatory limit reference if any:- NA						
9. Opinion, Interpretation & Statement of Conformity if provided can be refered in the remarks section as "Permissible" "Below acceptable" or whatever is applicable as per the limit						
10. BDL : Below Detection Limit RI: Revised report and the number of that times revised						
----- End of the Test Report -----						





WASTEWATER TREATMENT | ENVIRONMENTAL TESTING | FOOD TESTING

-  Head Office : Survey No. 645, Miroli Kamod Circle, Ahmedabad-Dholka Road, Ahmedabad-382425
-  Branch Office : Jaipur, Surat, Delhi, Bengaluru
-  +91 9227988980 / 9265491610  swa@swaenviro.com / lab@swaenviro.com  www.swaenviro.com

TEST REPORT			
Water/Wastewater Quality Sampling & Analysis			
Company Name	Krishna Construction Company	Sample ID	WQ/264/26
Company Contact Number	9099454400	Condition of sample	Satisfactory
Address	1st Floor, H-110, Shreedhar Flora, Amar Javan Circle, Nikol Gam Road, Ahmedabad 382350	Sample Drawn By	Customer
		Quantity of Sample	1 L
		Sampling Method	APHA/IS MODE: (GRAB/ COMPOSITE)
Date & Time of Sampling	17-02-2026	Date of Sample Received	17-02-2026
Analysis Starts Date	17-02-2026	Analysis Completion Date	23-02-2026
Sample Description	Outlet at HARIJ 3.0 MLD STP	Temperature/ Humidity during testing	Temp.- 25-29 deg C / Humidity <50 %
Report Code:	SWA/LAB/17/02/2026/WQ/264	Report Date:	23-02-2026

S.No.	PARAMETERS	UNIT	RESULTS	Regulatory Limit	Remarks	Testing Method/ Standard
1	pH @27 deg.	-	8.61	6.5-9		APHA 24th Edition 4500 B: 2023
2	Total Suspended Solids	mg/l	8.03	<10		APHA 24th Edition 2540 D: 2023
3	Total Phosphorus	mg/l	0.59	<1		APHA 24th Edition 4500 P D: 2023
4	Chemical Oxygen Demand	mg/l	25.94	<50		IS 3025 - Part 58 : 2006
5	Biochemical Oxygen Demand	mg/l	8.50	<10		IS 3025 - Part 44 : 1993
6	Ammonical Nitrogen	mg/l	3.01	<5		APHA 24th Edition 4500 NH3 C: 2023
7	Residual Chlorine	mg/l	0.76	0.5-1		APHA 24th Edition 4500 NH3 C/ Norg B/NO3 B/NO2 B:2023
8	Total Nitrogen	mg/l	8.10	<10		APHA 24th Edition 4500CL- B: 2023
9	Faecal Coliform	MPN/100 ml	33.00	<230		IS 1622 - Rea. 1981
10	Total Coliforms	MPN/100 ml	50.00	<230		IS 1622: Rea.1981

Supervised By :	Harshad Salvi	Authorized Signatory :	Pankaj Gothi
Signature :		Signature :	
Designation :	Technical Manager/COO Lab	Designation :	Quality Manager/CEO

Notes:

- The report shall not be reproduced except in full without approval of the laboratory can provide assurance that parts of a report are not taken out of context.
- The results relate only to the items tested and sampled
- Additions to, deviations, or exclusions from the method- NA
- Results which were outsourced to external providers are marked with ** and results which are performed and not in NABL accreditation scope are marked with * in parameter column
- Disclaimer: When the information is supplied by the customer and can affect the validity of results
- Disclaimer: The report that the results apply to the sample as received in case of the sample has been supplied by customer
- Disclaimer: The laboratory shall be responsible for all the information provided in the report, except when information is provided by the customer
- Regulatory limit reference if any:- NA
- Opinion, Interpretation & Statement of Conformity if provided can be referred in the remarks section as "Permissible" "Below acceptable" or whatever is applicable as per the limit
- BDL : Below Detection Limit | R1: Revised report and the number of that times revised

----- End of the Test Report -----



WASTEWATER TREATMENT | ENVIRONMENTAL TESTING | FOOD TESTING

 Head Office : Survey No. 645, Mirol Kamod Circle, Ahmedabad-Dholka Road, Ahmedabad-382425
 Branch Office : Jaipur, Surat, Delhi, Bengaluru
 +91 9227988980 / 9265491610  swa@swaenviro.com / lab@swaenviro.com  www.swaenviro.com



ISO 9001:2015 and ISO 17025:2017 NABL certified

No.4, Versetile Industrial Estate, Nr. Kotak Bank, Gate No.5,
Kathwada Gidc, Ahmedabad - 382430.

+91 8469130040, +91 6357351655 naturemicrovision@gmail.com GSTIN : 24AAWFN4704G1Z4

Test Report

Report ID: NML/WW/25-26/1296

Date: 24/02/2026


Customer Name	Rajkamal Builders Infrastructure Private Limited.		
Customer Address	5.80 MLD STP Khedbrahma		
Date & Time of Sampling	20/02/2026	Sampling Plan & Method	IS 3025(Part-1) RA 2019
Date of Receipt of Sample	21/02/2026		
Sample Collected by	Client	Sample Condition	SATISFACTORY
Analysis Starting Date	21/02/2026	Packing / Seal	SEALED
Analysis Completion Date	24/02/2026	Quantity / No. of Samples	Approx. 1 LIT. * 1NO.
Environmental Condition	Temperature: 25 °C ± 2	Relative Humidity (%)	Humidity ≤ 50 %

Sample No.	Sample ID	Sample Type	Location	Description
1.	25-26/1305	Waste Water	Inlet	Untreated Water

Analysis Results

Sr. No.	Parameters	Reference Method	Results	Unit
1.	pH	IS 3025 (Part 11): 2022	7.11	--
2.	BIOLOGICAL OXYGEN DEMAND (3 days at 27°C)	IS 3025 (Part 44): 2023	241.6	mg/L
3.	CHEMICAL OXYGEN DEMAND	IS 3025 (Part 58) : 2023	428.8	mg/L
4.	TOTAL SUSPENDED SOLIDS	IS 3025 (Part 17): 1988 (RA 2022)	347.55	mg/L
5.	TOTAL NITROGEN	IS 3025 (Part 34/sec- 1):2023	36	mg/L
6.	TOTAL PHOSPHORUS	IS 3025 (Part 31) :Sec 1 : 2022	3.5	mg/L
7.	TOTAL COLIFORM	APHA 24 th Edition 2023 9221 B	6.1 × 10 ⁶	(MPN)/100
8.	FECAL COLIFORM	APHA 24 th Edition 2023 9221 E	2.4 × 10 ²	(MPN)/100

Checked by
Senior Chemist



Authorised by
Lab Manager/CEO

Remarks:

- BDL: Below Detectable Limit.
- The report pertains only to the sample tested and does not apply to the bulk quantity.
- The test report may not be reproduced, wholly or partially, nor used for promotional or publicity purposes without written consent from the laboratory department.
- Samples will be retained for 15 days after the completion of analysis. A longer retention period can be arranged upon customer request.



ISO 9001:2015 and ISO 17025:2017 NABL certified

No.4, Versetile Industrial Estate, Nr. Kotak Bank, Gate No.5,
Kathwada Gidc, Ahmedabad - 382430.

+91 8469130040, +91 6357351655 naturemicrovision@gmail.com GSTIN : 24AAWFN4704G1Z4

Test Report

Report ID: NML/WW/25-26/1297

Date: 24/02/2026

Customer Name	Rajkamal Builders Infrastructure Private Limited.			
Customer Address	5.80 MLD STP Khedbrahma			
Date & Time of Sampling	20/02/2026	Sampling Plan & Method	IS 3025(Part-1) RA 2019	
Date of Receipt of Sample	21/02/2026			
Sample Collected by	Client	Sample Condition	SATISFACTORY	
Analysis Starting Date	21/02/2026	Packing / Seal	SEALED	
Analysis Completion Date	24/02/2026	Quantity / No. of Samples	Approx. 1 LIT. * 1NO.	
Environmental Condition	Temperature: 25 °C ± 2	Relative Humidity (%)	Humidity ≤ 50 %	
Sample No.	Sample ID	Sample Type	Location	Description
1.	25-26/1306	Waste Water	Outlet	Treated Water

Analysis Results

Sr. No.	Parameters	Reference Method	Results	Regulatory Limit	Unit
1.	pH	IS 3025 (Part 11): 2022	7.45	6.5-9.0	--
2.	BIOLOGICAL OXYGEN DEMAND (3 days at 27°C)	IS 3025 (Part 44): 2023	7.8	<10	mg/L
3.	CHEMICAL OXYGEN DEMAND	IS 3025 (Part 58) : 2023	40	<50	mg/L
4.	TOTAL SUSPENDED SOLIDS	IS 3025 (Part 17): 1988 (RA 2022)	7.16	<10	mg/L
5.	AMMONICAL NITROGEN	IS 3025 (Part 34/sec-1):2023	1.7	<5	mg/L
6.	TOTAL NITROGEN	IS 3025 (Part 34/sec- 1):2023	5.8	<10	mg/L
7.	TOTAL PHOSPHORUS	IS 3025 (Part 31) :Sec 1 : 2022	0.62	<2	mg/L
8.	FECAL COLIFORM	APHA 24 th Edition 2023 9221 E	90	<230	(MPN)/100
9.	RESIDUAL CHLORINE	IS 3025 (Part 31) : Sec 1 : 2022	0.64	0.5-1.0	mg/L
10.	TOTAL COLIFORM	APHA 24 th Edition 2023 9221 B	180	<230	(MPN)/100

Checked by
Senior ChemistAuthorised by
Lab Manager/CEO

Remarks:

- BDL: Below Detectable Limit.
- The report pertains only to the sample tested and does not apply to the bulk quantity.
- The test report may not be reproduced, wholly or partially, nor used for promotional or publicity purposes without written consent from the laboratory department.
- Samples will be retained for 15 days after the completion of analysis. A longer retention period can be arranged upon customer request.



ISO 9001:2015 and ISO 17025:2017 NABL certified

No.4, Versetile Industrial Estate, Nr. Kotak Bank, Gate No.5,
Kathwada Gidc, Ahmedabad - 382430.

+91 8469130040, +91 6357351655

naturemicrovision@gmail.com

GSTIN : 24AAWFN4704G1Z4

Test Report

Report ID: NML/WW/25-26/1316

Date: 24/02/2026

Customer Name	PRANTIJ NAGAR PALIKA		
Customer Address	3.70 MLD STP Prantij		
Date & Time of Sampling	20/02/2026	Sampling Plan & Method	IS 3025(Part-1) RA 2019
Date of Receipt of Sample	21/02/2026		
Sample Collected by	Client	Sample Condition	SATISFACTORY
Analysis Starting Date	21/02/2026	Packing / Seal	SEALED
Analysis Completion Date	24/02/2026	Quantity / No. of Samples	Approx. 1 LIT. * 1NO.
Environmental Condition	Temperature: 25 °C ± 2	Relative Humidity (%)	Humidity ≤ 50 %

Sample No.	Sample ID	Sample Type	Location	Description
1.	25-26/1325	Waste Water	Inlet	Untreated Water

Analysis Results

Sr. No.	Parameters	Reference Method	Results	Unit
1.	pH	IS 3025 (Part 11): 2022	7.19	--
2.	BIOLOGICAL OXYGEN DEMAND (3 days at 27°C)	IS 3025 (Part 44): 2023	220.2	mg/L
3.	CHEMICAL OXYGEN DEMAND	IS 3025 (Part 58) : 2023	411	mg/L
4.	TOTAL SUSPENDED SOLIDS	IS 3025 (Part 17): 1988 (RA 2022)	358.92	mg/L
5.	TOTAL NITROGEN	IS 3025 (Part 34/sec- 1):2023	35	mg/L
6.	TOTAL PHOSPHORUS	IS 3025 (Part 31) :Sec 1 : 2022	2.8	mg/L
7.	Total Coliform	APHA 24th Edition 2023 9221 B	4.1×10 ⁵	(MPN)/100
8.	FECAL COLIFORM	APHA 24th Edition 2023 9221 E	3.6×10 ²	(MPN)/100

Checked by
Senior Chemist

Authorised by
Lab Manager/CEO

End of Test Report

Remarks:

- BDL: Below Detectable Limit.
- The report pertains only to the sample tested and does not apply to the bulk quantity.
- The test report may not be reproduced, wholly or partially, nor used for promotional or publicity purposes without written consent from the laboratory department.
- Samples will be retained for 15 days after the completion of analysis. A longer retention period can be arranged upon customer request.



ISO 9001:2015 and ISO 17025:2017 NABL certified

No.4, Versetile Industrial Estate, Nr. Kotak Bank, Gate No.5,
Kathwada Gidc, Ahmedabad - 382430.

+91 8469130040, +91 6357351655 naturemicrovision@gmail.com GSTIN : 24AAWFN4704G1Z4

Test Report

Date: 24/02/2026

Report ID: NML/WW/25-26/1317

Customer Name	PRANTIJ NAGAR PALIKA		
Customer Address	3.70 MLD STP Prantij		
Date & Time of Sampling	20/02/2026	Sampling Plan & Method	IS 3025(Part-1) RA 2019
Date of Receipt of Sample	21/02/2026		
Sample Collected by	Client	Sample Condition	SATISFACTORY
Analysis Starting Date	21/02/2026	Packing / Seal	SEALED
Analysis Completion Date	24/02/2026	Quantity / No. of Samples	Approx. 1 LIT. * 1NO.
Environmental Condition	Temperature: 25 °C ± 2	Relative Humidity (%)	Humidity ≤ 50 %

Sample No.	Sample ID	Sample Type	Location	Description
1.	25-26/1326	Waste Water	Outlet	Treated Water

Analysis Results

Sr. No.	Parameters	Reference Method	Results	Regulatory Limit	Unit
1.	pH	IS 3025 (Part 11): 2022	7.56	6.5-9.0	--
2.	BIOLOGICAL OXYGEN DEMAND (3 days at 27°C)	IS 3025 (Part 44): 2023	7.4	<10	mg/L
3.	CHEMICAL OXYGEN DEMAND	IS 3025 (Part 58) : 2023	36	<50	mg/L
4.	TOTAL SUSPENDED SOLIDS	IS 3025 (Part 17): 1988 (RA 2022)	7.44	<10	mg/L
5.	AMMONICAL NITROGEN	IS 3025 (Part 34/sec-1):2023	2.3	<5	mg/L
6.	TOTAL NITROGEN	IS 3025 (Part 34/sec- 1):2023	7.2	<10	mg/L
7.	TOTAL PHOSPHORUS	IS 3025 (Part 31) :Sec 1 : 2022	0.71	<2	mg/L
8.	FECAL COLIFORM	APHA 24th Edition 2023 9221 E	139	<230	(MPN)/100
9.	RESIDUAL CHLORINE	IS 3025 (Part 31) : Sec 1 : 2022	0.58	0.5-1.0	mg/L
10.	TOTAL COLIFORM	APHA 24th Edition 2023 9221 B	154	<230	(MPN)/100


Checked by
Senior Chemist


Authorised by
Lab Manager/CEO

End of Test Report

Remarks:

- BDL: Below Detectable Limit.
- The report pertains only to the sample tested and does not apply to the bulk quantity.
- The test report may not be reproduced, wholly or partially, nor used for promotional or publicity purposes without written consent from the laboratory department.
- Samples will be retained for 15 days after the completion of analysis. A longer retention period can be arranged upon customer request.



ISO 9001:2015 and ISO 17025:2017 NABL certified

No.4, Versetile Industrial Estate, Nr. Kotak Bank, Gate No.5,
Kathwada Gidc, Ahmedabad - 382430.

+91 8469130040, +91 6357351655 naturemicrovision@gmail.com GSTIN : 24AAWFN4704G1Z4

Test Report

Report ID: NML/WW/25-26/1310

Date: 24/02/2026


Customer Name	Yash Construction co, Bhavnagar		
Customer Address	3.60 MLD STP Talod		
Date & Time of Sampling	20/02/2026	Sampling Plan & Method	IS 3025(Part-1) RA 2019
Date of Receipt of Sample	21/02/2026		
Sample Collected by	Client	Sample Condition	SATISFACTORY
Analysis Starting Date	21/02/2026	Packing / Seal	SEALED
Analysis Completion Date	24/02/2026	Quantity / No. of Samples	Approx. 1 LIT. * 1NO.
Environmental Condition	Temperature: 25 °C ± 2	Relative Humidity (%)	Humidity ≤ 50 %

Sample No.	Sample ID	Sample Type	Location	Description
1.	25-26/1319	Waste Water	INLET	Untreated Water

Analysis Results

Sr. No.	Parameters	Reference Method	Results	Unit
1.	pH	IS 3025 (Part 11): 2022	7.26	--
2.	BIOLOGICAL OXYGEN DEMAND (3 days at 27°C)	IS 3025 (Part 44): 2023	227.6	mg/L
3.	CHEMICAL OXYGEN DEMAND	IS 3025 (Part 58) : 2023	445	mg/L
4.	TOTAL SUSPENDED SOLIDS	IS 3025 (Part 17): 1988 (RA 2022)	321.82	mg/L
5.	TOTAL NITROGEN	IS 3025 (Part 34/sec- 1):2023	34	mg/L
6.	TOTAL PHOSPHORUS	IS 3025 (Part 31) :Sec 1 : 2022	2.8	mg/L
7.	TOTAL COLIFORM	APHA 24 th Edition 2023 9221 B	7.2 × 10 ⁶	(MPN)/100
8.	FECAL COLIFORM	APHA 24 th Edition 2023 9221 E	1.8 × 10 ³	(MPN)/100

Checked by
Senior Chemist



Authorised by
Lab Manager/CEO

End of Test Report

Remarks:

- BDL: Below Detectable Limit.
- The report pertains only to the sample tested and does not apply to the bulk quantity.
- The test report may not be reproduced, wholly or partially, nor used for promotional or publicity purposes without written consent from the laboratory department.
- Samples will be retained for 15 days after the completion of analysis. A longer retention period can be arranged upon customer request.



ISO 9001:2015 and ISO 17025:2017 NABL certified

No.4, Versetile Industrial Estate, Nr. Kotak Bank, Gate No.5, Kathwada Gidc, Ahmedabad - 382430.

+91 8469130040, +91 6357351655 naturemicrovision@gmail.com GSTIN : 24AAWFN4704G1Z4

Test Report

Report ID: NML/WW/25-26/1311

Date: 24/02/2026


Customer Name	Yash Construction co, Bhavnagar		
Customer Address	3.60 MLD STP Talod		
Date & Time of Sampling	20/02/2026	Sampling Plan & Method	IS 3025(Part-1) RA 2019
Date of Receipt of Sample	21/02/2026		
Sample Collected by	Client	Sample Condition	SATISFACTORY
Analysis Starting Date	21/02/2026	Packing / Seal	SEALED
Analysis Completion Date	24/02/2026	Quantity / No. of Samples	Approx. 1 LIT. * 1NO.
Environmental Condition	Temperature: 25 °C ± 2	Relative Humidity (%)	Humidity ≤ 50 %

Sample No.	Sample ID	Sample Type	Location	Description
1.	25-26/1320	Waste Water	Outlet	Treated Water

Analysis Results

Sr. No.	Parameters	Reference Method	Results	Regulatory Limit	Unit
1.	pH	IS 3025 (Part 11): 2022	7.52	6.5-9.0	--
2.	BIOLOGICAL OXYGEN DEMAND (3 days at 27°C)	IS 3025 (Part 44): 2023	7.3	<10	mg/L
3.	CHEMICAL OXYGEN DEMAND	IS 3025 (Part 58) : 2023	33	<50	mg/L
4.	TOTAL SUSPENDED SOLIDS	IS 3025 (Part 17): 1988 (RA 2022)	6.45	<10	mg/L
5.	AMMONICAL NITROGEN	IS 3025 (Part 34/sec-1):2023	2.1	<5	mg/L
6.	TOTAL NITROGEN	IS 3025 (Part 34/sec- 1):2023	6.7	<10	mg/L
7.	TOTAL PHOSPHORUS	IS 3025 (Part 31) :Sec 1 : 2022	0.65	<2	mg/L
8.	FECAL COLIFORM	APHA 24 th Edition 2023 9221 E	127	<230	(MPN)/100
9.	RESIDUAL CHLORINE	IS 3025 (Part 31) : Sec 1 : 2022	0.58	0.5-1.0	mg/L
10.	TOTAL COLIFORM	APHA 24 th Edition 2023 9221 B	270	<230	(MPN)/100

Checked by Senior Chemist



Authorised by Lab Manager/CEO

End of Test Report

Remarks:

- BDL: Below Detectable Limit.
- The report pertains only to the sample tested and does not apply to the bulk quantity.
- The test report may not be reproduced, wholly or partially, nor used for promotional or publicity purposes without written consent from the laboratory department.
- Samples will be retained for 15 days after the completion of analysis. A longer retention period can be arranged upon customer request.



ISO 9001:2015 and ISO 17025:2017 NABL certified

No.4, Versetile Industrial Estate, Nr. Kotak Bank, Gate No.5,
Kathwada Gidc, Ahmedabad - 382430.

+91 8489130040, +91 6357351858 naturemicrovision@gmail.com GSTIN : 24AAWFN4704G124

Test Report

Report ID: NML/WW/25-26/1312

Date: 24/02/2026

Customer Name	Yash Construction co, Bhavnagar		
Customer Address	3.80 MLD STP Vadail		
Date & Time of Sampling	20/02/2026	Sampling Plan & Method	IS 3025(Part-1) RA 2019
Date of Receipt of Sample	21/02/2026		
Sample Collected by	Client	Sample Condition	SATISFACTORY
Analysis Starting Date	21/02/2026	Packing / Seal	SEALED
Analysis Completion Date	24/02/2026	Quantity / No. of Samples	Approx. 1 LIT. * 1NO.
Environmental Condition	Temperature: 25 °C ± 2	Relative Humidity (%)	Humidity ≤ 50 %

Sample No.	Sample ID	Sample Type	Location	Description
1.	25-26/1321	Waste Water	Inlet	Untreated Water

Analysis Results

Sr. No.	Parameters	Reference Method	Results	Unit
1.	pH	IS 3025 (Part 11): 2022	7.31	-
2.	BIOLOGICAL OXYGEN DEMAND (3 days at 27°C)	IS 3025 (Part 44): 2023	240.6	mg/L
3.	CHEMICAL OXYGEN DEMAND	IS 3025 (Part 58) : 2023	451.2	mg/L
4.	TOTAL SUSPENDED SOLIDS	IS 3025 (Part 17): 1988 (RA 2022)	311.48	mg/L
5.	TOTAL NITROGEN	IS 3025 (Part 34/sec- 1):2023	40	mg/L
6.	TOTAL PHOSPHORUS	IS 3025 (Part 31) :Sec 1 : 2022	3.0	mg/L
7.	TOTAL COLIFORM	APHA 24 th Edition 2023-9221-B	4.8 × 10 ²	(MPN)/100
8.	FECAL COLIFORM	APHA 24 th Edition 2023-9221 E	1.6 × 10 ³	(MPN)/100

Checked by
Senior Chemist



Authorised by
Lab Manager/CEO

Remarks:

1. BDL- Below Detectable Limit.
2. The report pertains only to the sample tested and does not apply to the bulk quantity.
3. The test report may not be reproduced, wholly or partially, nor used for promotional or publicity purposes without written consent from the laboratory department.
4. Samples will be retained for 15 days after the completion of analysis. A longer retention period can be arranged upon customer request.



ISO 9001:2015 and ISO 17025:2017 NABL certified

No.4, Versatle Industrial Estate, Nr. Kotak Bank, Gate No.5, Kathwada Gide, Ahmedabad - 382430.

+91-8489230040, +91-6357351655 naturemicrovision@gmail.com GSTIN : 24AAWPN47040124

Test Report

Report ID: NML/WW/25-26/1313

Date: 24/02/2026

Customer Name	Yash Construction co, Bhavnagar		
Customer Address	3.80 MLD STP Vadali		
Date & Time of Sampling	20/02/2026	Sampling Plan & Method	IS 3025(Part-1) RA 2019
Date of Receipt of Sample	21/02/2026		
Sample Collected by	Client	Sample Condition	SATISFACTORY
Analysis Starting Date	21/02/2026	Packing / Seal	SEALED
Analysis Completion Date	24/02/2026	Quantity / No. of Samples	Approx. 1 LIT. * 1NO.
Environmental Condition	Temperature: 25 °C ± 2	Relative Humidity (%)	Humidity ≤ 50 %

Sample No.	Sample ID	Sample Type	Location	Description
1.	25-26/1322	Waste Water	Outlet	Treated Water

Analysis Results

Sr. No.	Parameters	Reference Method	Results	Regulatory Limit	Unit
1.	pH	IS 3025 (Part 11): 2022	7.58	6.5-9.0	--
2.	BIOLOGICAL OXYGEN DEMAND (3 days at 27°C)	IS 3025 (Part 44): 2023	8.0	<10	mg/L
3.	CHEMICAL OXYGEN DEMAND	IS 3025 (Part 58) : 2023	40	<50	mg/L
4.	TOTAL SUSPENDED SOLIDS	IS 3025 (Part 17)- 1988 (RA 2022)	5.2	<10	mg/L
5.	AMMONICAL NITROGEN	IS 3025 (Part 34/sec-1):2023	1.4	<5	mg/L
6.	TOTAL NITROGEN	IS 3025 (Part 34/sec- 1):2023	5.2	<10	mg/L
7.	TOTAL PHOSPHORUS	IS 3025 (Part 31) :Sec 1 : 2022	0.64	<2	mg/L
8.	FECAL COLIFORM	APHA 24 th Edition 2023-9221 E	114	<230	(MPN)/100
9.	RESIDUAL CHLORINE	IS 3025 (Part 31) : Sec 1 : 2022	0.71	0.5-1.0	mg/L
10.	TOTAL COLIFORM	APHA 24 th Edition 2023-9221 B	170	<230	(MPN)/100



Checked by
Senior Chemist



Authorised by
Lab Manager/CEO


Remarks:

- BDL: Below Detectable Limit.
- The report pertains only to the sample tested and does not apply to the bulk quantity.
- The test report may not be reproduced, wholly or partially, nor used for promotional or publicity purposes without written consent from the laboratory department.
- Samples will be retained for 15 days after the completion of analysis. A longer retention period can be arranged upon customer request.

TEST REPORT						
Water/Wastewater Quality Sampling & Analysis						
Company Name	Krishna Construction Company		Sample ID	WQ/261/26		
Company Contact Number	9099454400		Condition of sample	Satisfactory		
Address	1st Floor, H-110, Shreedhar Flora, Amar Javan Circle, Nikol Gam Road, Ahmedabad 382350		Sample Drawn By	Customer		
			Quantity of Sample	1 L		
			Sampling Method	APHA/IS MODE: (GRAB/ COMPOSITE)		
Date & Time of Sampling	17-02-2026		Date of Sample Received	17-02-2026		
Analysis Starts Date	17-02-2026		Analysis Completion Date	23-02-2026		
Sample Description	Inlet at CHANSMA 2.50 MLD STP		Temperature/ Humidity during testing	Temp.- 25-29 deg C / Humidity <50 %		
Report Code:	SWA/LAB/17/02/2026/WQ/261		Report Date:	23-02-2026		
S.No.	PARAMETERS	UNIT	RESULTS	Regulatory Limit	Remarks	Testing Method/ Standard
1	pH @27 deg.	-	7.27			APHA 24th Edition 4500 B: 2023
2	Total Suspended Solids	mg/l	326.14			APHA 24th Edition 2540 D: 2023
3	Total Phosphorus	mg/l	6.52			APHA 24th Edition 4500 P D: 2023
4	Chemical Oxygen Demand	mg/l	656.21			IS 3025 - Part 58 : 2006
5	Biochemical Oxygen Demand	mg/l	222.75			IS 3025 - Part 44 : 1993
6	Ammonical Nitrogen	mg/l	9.13			APHA 24th Edition 4500 NH3 C: 2023
7	Total Kjeldhal Nitrogen	mg/l	16.98			APHA 24th Edition 4500 NH3 C/ Norg B: 2023
8	Nitrate	mg/l	1.97			APHA 24th Edition 4500 NO3 B: 2023
9	Nitrite	mg/l	0.02			APHA 24th Edition 4500 NO2 B: 2023
10	Total Nitrogen	mg/l	18.97			APHA 24th Edition 4500 NH3 C/ Norg B/NO3 B/NO2 B:2023
11	Faecal Coliforms	MPN/100 ml	5x10 ⁵			IS 1622: Rea.1981
12	Total Coliforms	MPN/100 ml	6x10 ⁶			IS 1622: Rea.1981
Supervised By :		Harshad Salvi		Authorized Signatory :		Pankaj Gothi
Signature :				Signature :		
Designation :		Technical Manager/COO Lab		Designation :		Quality Manager/CEO
Notes:						
1. The report shall not be reproduced except in full without approval of the laboratory can provide assurance that parts of a report are not taken out of context.						
2. The results relate only to the items tested and sampled						
3. Additions to, deviations, or exclusions from the method- NA						
4. Results which were outsourced to external providers are marked with ** and results which are performed and not in NABL accreditation scope are marked with * in parameter column						
5. Disclaimer: When the information is supplied by the customer and can affect the validity of results						
6. Disclaimer: The report that the results apply to the sample as received in case of the sample has been supplied by customer						
7. Disclaimer: The laboratory shall be responsible for all the information provided in the report, except when information is provided by the customer						
8. Regulatory limit reference if any:- NA						
9. Opinion, Interpretation & Statement of Conformity if provided can be referred in the remarks section as "Permissible" "Below acceptable" or whatever is applicable as per the limit						
10. BDL : Below Detection Limit RI: Revised report and the number of that times revised						
----- End of the Test Report -----						



WASTEWATER TREATMENT | ENVIRONMENTAL TESTING | FOOD TESTING

TEST REPORT						
Water/Wastewater Quality Sampling & Analysis						
Company Name	Krishna Construction Company		Sample ID	WQ/262/26		
Company Contact Number	9099454400		Condition of sample	Satisfactory		
Address	1st Floor, H-110, Shreedhar Flora, Amar Javan Circle, Nikol Gam Road, Ahmedabad 382350		Sample Drawn By	Customer		
			Quantity of Sample	1 L		
			Sampling Method	APHA/IS MODE: (GRAB/ COMPOSITE)		
Date & Time of Sampling	17-02-2026		Date of Sample Received	17-02-2026		
Analysis Starts Date	17-02-2026		Analysis Completion Date	23-02-2026		
Sample Description	Outlet at CHANSMA 2.50 MLD STP		Temperature/ Humidity during testing	Temp.- 25-29 deg C / Humidity <50 %		
Report Code:	SWA/LAB/17/02/2026/WQ/263		Report Date:	23-02-2026		
S.No.	PARAMETERS	UNIT	RESULTS	Regulatory Limit	Remarks	Testing Method/ Standard
1	pH @27 deg.	-	7.17	6.5-9	/	APHA 24th Edition 4500 B: 2023
2	Total Suspended Solids	mg/l	7.94	<10		APHA 24th Edition 2540 D: 2023
3	Total Phosphorus	mg/l	0.63	<1		APHA 24th Edition 4500 P D: 2023
4	Chemical Oxygen Demand	mg/l	29.91	<50		IS 3025 - Part 58 : 2006
5	Biochemical Oxygen Demand	mg/l	8.50	<10		IS 3025 - Part 44 : 1993
6	Ammonical Nitrogen	mg/l	3.46	<5		APHA 24th Edition 4500 NH3 C: 2023
7	Total Nitrogen	mg/l	3.87	<10		APHA 24th Edition 4500 NH3 C/ Norg B/NO3 B/NO2 B:2023
8	Residual Chlorine	mg/l	0.58	0.5-1		APHA 24th Edition 4500CL- B: 2023
9	Faecal Coliforms	MPN/100 ml	40.00	<230		IS 1622 - Rea. 1981
10	Total Coliforms	MPN/100 ml	50.00	<230		IS 1622: Rea.1981
Supervised By :		Harshad Salvi		Authorized Signatory :		Pankaj Gothi
Signature :				Signature :		
Designation :		Technical Manager/COO Lab		Designation :		Quality Manager/CEO
Notes:						
1. The report shall not be reproduced except in full without approval of the laboratory can provide assurance that parts of a report are not taken out of context.						
2. The results relate only to the items tested and sampled						
3. Additions to, deviations, or exclusions from the method- NA						
4. Results which were outsourced to external providers are marked with ** and results which are performed and not in NABL accreditation scope are marked with * in parameter column						
5. Disclaimer: When the information is supplied by the customer and can affect the validity of results						
6. Disclaimer: The report that the results apply to the sample as received in case of the sample has been supplied by customer						
7. Disclaimer: The laboratory shall be responsible for all the information provided in the report, except when information is provided by the customer						
8. Regulatory limit reference if any:- NA						
9. Opinion, Interpretation & Statement of Conformity if provided can be referred in the remarks section as "Permissible" "Below acceptable" or whatever is applicable as per the limit						
10. BDL : Below Detection Limit RI: Revised report and the number of that times revised						
----- End of the Test Report -----						



WASTEWATER TREATMENT | ENVIRONMENTAL TESTING | FOOD TESTING



-  Head Office : Survey No. 645, Mirolji Kamod Circle, Ahmedabad-Dholka Road, Ahmedabad-382425
-  Branch Office : Jaipur, Surat, Delhi, Bengaluru
-  +91 9227988980 / 9265491610  swa@swaenviro.com / lab@swaenviro.com  www.swaenviro.com

TEST REPORT

Water/Wastewater Quality Sampling & Analysis

Company Name	Jay Corporation - Shivam Builders, JV	Sample ID	WQ/288/26
Company Contact Number	7874886393	Condition of sample	Satisfactory
Address	71 first floor, Someshwar mall, Modhera Road, Mahsana, 384002	Sample Drawn By	Customer
		Quantity of Sample	1 L
		Sampling Method	APHA/IS MODE: (GRAB/COMPOSITE)
Date & Time of Sampling	11-02-2026	Date of Sample Received	11-02-2026
Analysis Starts Date	11-02-2026	Analysis Completion Date	17-02-2026
Sample Description	STP Inlet - Bechraji 3.0 MLD	Temperature/ Humidity during testing	Temp.- 25-29 deg C / Humidity <50 %
Report Code:	SWA/LAB/11/02/2026/WQ/288	Report Date:	17-02-2026

S.No.	PARAMETERS	UNIT	RESULTS	Regulatory Limit	Remarks	Testing Method/ Standard
1	pH @27 deg.	-	7.36			APHA 24th Edition 4500 B: 2023
2	Total Suspended Solids	mg/l	134.58			APHA 24th Edition 2540 D: 2023
3	Total Kjeldahl Nitrogen	mg/l	24.93			APHA 24th Edition 4500 NH3 C/Norg B: 2023
4	Total Phosphorous	mg/l	5.48			APHA 24th Edition 4500 P D: 2023
5	Chemical Oxygen Demand	mg/l	241.39			IS 3025 - Part 58 : 2023
6	Biochemical Oxygen Demand	mg/l	90.75			IS 3025 - Part 44 : 2023
7	Total Coliform	MPN/100 ml	9 x 10 ⁵			IS 1622 - Rea. 1981

Supervised By :	Harshad Salvi	Authorized Signatory :	Pankaj Gothi
Signature :		Signature :	
Designation :	Technical Manager/COO Lab	Designation :	Quality Manager/CEO

- Notes:**
- The report shall not be reproduced except in full without approval of the laboratory can provide assurance that parts of a report are not taken out of context.
 - The results relate only to the items tested and sampled
 - Additions to, deviations, or exclusions from the method-NA
 - Results which were outsourced to external providers are marked with ** and results which are performed and not in NABL accreditation scope are marked with * in parameter column
 - Disclaimer: When the information is supplied by the customer and can affect the validity of results
 - Disclaimer: The report that the results apply to the sample as received in case of the sample has been supplied by customer
 - Disclaimer: The laboratory shall be responsible for all the information provided in the report, except when information is provided by the customer
 - Regulatory limit reference if any:- NA
 - Opinion, Interpretation & Statement of Conformity if provided can be referred in the remarks section as "Permissible" "Below acceptable" or whatever is applicable as per the limit
 - BDL : Below Detection Limit | RI: Revised report and the number of that times revised
- End of the Test Report -----



WASTEWATER TREATMENT | ENVIRONMENTAL TESTING | FOOD TESTING



- Head Office : Survey No. 645, Miroli Kamod Circle, Ahmedabad-Dholka Road, Ahmedabad-382425
- Branch Office : Jaipur, Surat, Delhi, Bengaluru
- +91 9227988980 / 9265491610 swa@swaenviro.com / lab@swaenviro.com www.swaenviro.com

TEST REPORT

Water/Wastewater Quality Sampling & Analysis

Company Name	Jay Corporation - Shivam Builders, JV	Sample ID	WQ/289/26
Company Contact Number	7874886393	Condition of sample	Satisfactory
Address	71 first floor, Someshwar mall, Modhera Road, Mahsana, 384002	Sample Drawn By	Customer
		Quantity of Sample	1 L
		Sampling Method	APHA/IS MODE: (GRAB/ COMPOSITE)
Date & Time of Sampling	11-02-2026	Date of Sample Received	11-02-2026
Analysis Starts Date	11-02-2026	Analysis Completion Date	17-02-2026
Sample Description	STP Outlet - Bechraji 3.0 MLD	Temperature/ Humidity during testing	Temp.- 25-29 deg C / Humidity <50 %
Report Code:	SWA/LAB/11/02/2026/WQ/289	Report Date:	17-02-2026


S.No.	PARAMETERS	UNIT	RESULTS	Regulatory Limit	Remarks	Testing Method/ Standard
1	pH @27 deg.	-	6.88	6.5-9	/	APHA 24th Edition 4500 B: 2023
2	Total Suspended Solids	mg/l	4.76	<10		APHA 24th Edition 2540 D: 2023
3	Ammonical Nitrogen	mg/l	1.89	<5		APHA 24th Edition 4500 NH3 C: 2023
4	Residual Chlorine	mg/l	0.71	0.5-1		APHA 24th Edition 4500 CLB: 2023
5	Chemical Oxygen Demand	mg/l	33.54	<50		IS 3025 - Part 58 : 2023
6	Total Nitrogen	mg/l	4.93	<10		APHA 24th Edition 4500 NH3 C/Norg B/NO3 B/NO2 B: 2023
7	Total Phosphorous	mg/l	0.36	<1		APHA 24th Edition 4500 P D: 2023
8	Biochemical Oxygen Demand	mg/l	65.00	<10		IS 3025 - Part 44 : 2023
9	Faecal Coliform	MPN/100 ml	27.00	<230		IS 1622 - Rea. 1981

Supervised By :	Harshad Salvi	Authorized Signatory :	Pankaj Gothi
Signature :		Signature :	
Designation :	Technical Manager/COO Lab	Designation :	Quality Manager/CEO

Notes:

- The report shall not be reproduced except in full without approval of the laboratory can provide assurance that parts of a report are not taken out of context.
- The results relate only to the items tested and sampled
- Additions to, deviations, or exclusions from the method- NA
- Results which were outsourced to external providers are marked with ** and results which are performed and not in NABL accreditation scope are marked with * in parameter column
- Disclaimer: When the information is supplied by the customer and can affect the validity of results
- Disclaimer: The report that the results apply to the sample as received in case of the sample has been supplied by customer
- Disclaimer: The laboratory shall be responsible for all the information provided in the report, except when information is provided by the customer
- Regulatory limit reference if any- NA
- Opinion, Interpretation & Statement of Conformity if provided can be referred in the remarks section as "Permissible" "Below acceptable" or whatever is applicable as per the limit
- BDL : Below Detection Limit | RL: Revised report and the number of that times revised

----- End of the Test Report -----



WASTEWATER TREATMENT | ENVIRONMENTAL TESTING | FOOD TESTING

- Head Office : Survey No. 645, Miroli Kamod Circle, Ahmedabad-Dholka Road, Ahmedabad-382425
- Branch Office : Jaipur, Surat, Delhi, Bengaluru
- +91 9227988980 / 9265491610 swa@swaenviro.com / lab@swaenviro.com www.swaenviro.com



AN ISO/IEC 17025 NABL ACCREDITED ENVIRONMENT TESTING LABORATORY

GPCB Recognized Environmental Auditor (Schedule -II)

📍 PLOT NO.111. HIRA PARK, OPP- VISHAL HOTEL, JAMNAGAR - 361006

☎ +91 78749 15777 | +91 98794 06097 ✉ tanishkaearthcare@gmail.com

Testing solution for a better tomorrow

TEST REPORT

Company Name	M/s. DWARKA NAGAR PALIKA	Sample ID	WQ/26/02/33
Address	STP DWARKA NAGAR PALIKA, DWARKA	Condition of sample	Satisfactory
		Sample Done By	Customer
		Quantity of Sample	1000 ml
		Sampling Method	APHA
Date of Sampling	20.02.2026	Date of Sample Received	20.02.2026
Analysis Starts Date	20.02.2026	Analysis Completion Date	24.02.2026
Sample Description	OUTLET AT DWARKA STP	Temperature/ Humidity during testing	Temp.- 25-29 deg C / Humidity <50 %
Report Number:	LAB/WQ/26/02/33	Report Date:	24.02.2026

S.No.	PARAMETERS	UNIT	RESULTS	LIMIT	Testing Method/ Standard
PHYSICAL CHEMICAL AND MICRO PARAMETERS					
1	pH @ 27 deg.	--	7.62	6.5-9	APHA 24 th Edition 4500 B
2	Total Suspended Solids	mg/l	9.00	<10	APHA 24 th Edition 2540 D
3	Total Phosphorus	mg/l	0.53	<1	APHA 24 th Edition 4500P D
4	Chemical Oxygen Demand	mg/l	38.22	<50	IS 3025 (Part 58)
5	Biochemical Oxygen Demand	mg/l	7.36	<10	IS 3025 (Part 44)
6	Ammonical Nitrogen	mg/l	3.70	<5	APHA 24 th Edition 4500 NH3 C
8	Total Nitrogen	mg/l	6.20	<10	APHA 24 th Edition 4500 N113C / Norg B/ NO3 B/NO2 B; 2023
9	Total Coliform	MPN/100 ml	60.00	<100	IS 1622
10	Faecal Coliform	MPN/100 ml	70.00	<100	IS 1622

Checked By :	Nikhil Dudhagara	Authorized Signatory :	Maddal Natham
Signature :		Signature :	
Designation :	Chemist	Designation :	Technical Manager



- Notes:**
1. The report shall not be reproduced except in full without approval of the laboratory can provide assurance that parts of a report are not taken out of context.
 2. This certificate is based on the sample submitted for testing.
 3. Additions to, deviations, or exclusions from the method- NA
 4. Latest Revision of test methods are followed for the test parameter
 5. Disclaimer: When the information is supplied by the customer and can affect the validity of results
 6. Disclaimer: The report that the results apply to the sample as received in case of the sample has been supplied by customer
 7. Disclaimer: The laboratory shall be responsible for all the information provided in the report, except when information is provided by the customer
 8. Regulatory limit reference if any:- NA
 9. Opinion, Interpretation & Statement of Conformity if provided can be referred in the remarks section as "Permissible" "Below acceptable" or whatever is applicable as per the limit
 10. BDL : Below Detection Limit

● End of the Test Report ●

TANISHKA EARTH CARE SERVICES (OPC) PRIVATE LIMITED



TANISHKA EARTH CARE SERVICES (OPC) PRIVATE LIMITED

AN ISO/IEC 17025 NABL ACCREDITED ENVIRONMENT TESTING LABORATORY

GPCB Recognized Environmental Auditor (Schedule -II)

PLOT NO.111. HIRA PARK, OPP- VISHAL HOTEL, JAMNAGAR - 361006

+91 78749 15777 | +91 98794 06097 | tanishkaearthcare@gmail.com

Testing solution for a better tomorrow

TEST REPORT

Company Name	M/s. DWARKA NAGAR PALIKA	Sample ID	WQ/26/02/32
Address	STP DWARKA NAGAR PALIKA, DWARKA	Condition of sample	Satisfactory
		Sample Done By	Customer
		Quantity of Sample	1000 ml
		Sampling Method	APHA
Date of Sampling	20.02.2026	Date of Sample Received	20.02.2026
Analysis Starts Date	20.02.2026	Analysis Completion Date	24.02.2026
Sample Description	INLET AT DWARKA STP	Temperature/ Humidity during testing	Temp.- 25-29 deg C / Humidity <50 %
Report Number:	LAB/WQ/26/02/32	Report Date:	24.02.2026

S.No.	PARAMETERS	UNIT	RESULTS	LIMIT	Testing Method/ Standard
PHYSICAL CHEMICAL AND MICRO PARAMETERS					
1	pH @ 27 deg.	--	7.35		APHA 24 th Edition 4500 B: 2023
2	Total Suspended Solids	mg/l	265.00		APHA 24 th Edition 2540 D: 2023
3	Total Phosphorus	mg/l	8.65		APHA 24 th Edition 4500P D: 2023
4	Chemical Oxygen Demand	mg/l	342.56		IS 3025 (Part 58) 2006
5	Biochemical Oxygen Demand	mg/l	110.26		IS 3025 (Part 44) 1993
6	Ammonical Nitrogen	mg/l	22.64		APHA 24 th Edition 4500 NH3 C : 2023
7	Total Kjeldhal Nitrogen	mg/l	42.86		APHA 24 th Edition 4500 NH3 C/Norg B:2017
8	Nitrate	mg/l	20.62		APHA 24 th Edition 4500 NO3 B: 2023
9	Nitrite	mg/l	0.20		APHA 24 th Edition 4500 NO2 B: 2023
10	Total Nitrogen	mg/l	63.68		APHA 24 th Edition 4500 N113C / Norg B/ NO3 B/NO2 B; 2023
11	Faecal Coliform	MPN/100 ml	500.00		IS 1622
12	Total Coliform	MPN/100 ml	900.00		IS 1622

Checked By :	Nikhil Dudhagara	Authorized Signatory :	Mufaddal Namani
Signature :		Signature :	
Designation :	Chemist	Designation :	Technical Manager

- Notes:**
- The report shall not be reproduced except in full without approval of the laboratory can provide assurance that parts of a report are not taken out of context.
 - This certificate is based on the sample submitted for testing.
 - Additions to, deviations, or exclusions from the method- NA
 - Latest Revision of test methods are followed for the test parameter
 - Disclaimer: When the information is supplied by the customer and can affect the validity of results
 - Disclaimer: The report that the results apply to the sample as received in case of the sample has been supplied by customer
 - Disclaimer: The laboratory shall be responsible for all the information provided in the report, except when information is provided by the customer
 - Regulatory limit reference if any:- NA
 - Opinion, Interpretation & Statement of Conformity if provided can be referred in the remarks section as "Permissible" "Below acceptable" or whatever is applicable as per the limit
 - BDL : Below Detection Limit

● End of the Test Report ●

TANISHKA EARTH CARE SERVICES (OPC) PRIVATE LIMITED

23.70 MLD STP BHUJ NAGOR

SR. NO	January/2026	INLET PARAMETERS					OUTLET PARAMETERS					30 Fecal Coliform	Remarks
		M3/hr	PH	BOD (mg/l)	TSS (mg/l)	COD (mg/l)	M3/hr	PH	TSS (mg/l)	COD (mg/l)	BOD (mg/l)		
1	02-16-2026	1.42	7.97	341.12	426.58	512.37	1.34	7.94	9.38	32.15	8.94	5.00	
2	02-17-2026	1.11	7.94	312.25	413.21	514.37	1.29	7.82	8.18	29.37	8.67	4.50	
3	02-18-2026	1.56	8.32	342.16	412.39	521.37	1.24	7.84	9.17	28.00	8.29	6.00	
4	02-19-2026	3.81	8.12	298.56	389.29	497.31	3.21	7.18	9.35	35.39	8.27	4.50	
5	02-20-2026	4.77	8.35	287.35	368.27	428.35	4.65	7.28	8.24	31.38	8.17	4.50	
6	02-21-2026	5.71	8.15	268.31	397.18	476.29	5.21	7.95	8.35	35.36	9.31	5.00	
7	02-22-2026	4.94	8.24	311.18	421.91	512.37	4.29	7.28	8.49	35.36	9.31	4.50	
8	02-23-2026	5.77	8.27	316.35	431.61	523.78	5.98	7.95	8.27	35.18	8.28	6.00	
9	02-24-2026	4.73	8.37	295.00	395.28	534.29	4.26	7.60	8.67	31.54	8.67	4.50	
10	02-25-2026	4.73	8.45	267.16	367.29	497.34	4.38	7.28	9.15	32.55	8.49	6.00	
11	02-26-2026	3.44	8.47	321.18	378.29	416.95	3.15	7.95	9.57	34.28	8.67	4.50	
12	02-27-2026	4.54	8.57	393.15	398.37	467.29	4.53	7.28	9.28	34.78	8.95	6.00	
13	02-28-2026	3.30	8.65	296.78	359.00	438.57	3.12	7.95	8.34	29.78	8.21	6.00	

[Signature]
 Deputy Executive Engineer
 P.H.S. Sub Div. Bhuj

[Signature]
 Chief Officer
 Bhuj Municipality





4643

694

Royal**Environment Auditing & Consultancy Service**Plot No. 19 & 20, B/s. The North Star Nest School, Masoom School Road, Mota Mava, RAJKOT - 360 005.
Ph.: +91 9099919954 ■ E-mail : royaleenvironment@live.com ■ admin@royalconsultancy.com

Ref. No. : 125/03/2025-26

Date: 16/03/2026

REPORT OF DOMESTIC EFFLUENT ANALYSIS (40 MLD STP PLANT)

Name of company : Welspun Living Limited,
Plot No/Survey No.675,
Village: Varasamedi, Taluka: Anjar,
District: Kutch

Date of Sampling : 09/03/2026

Sample Collected by : Royal Environment

Type of Sample : Domestic Effluent

Location of Sample Collection: STP Plant (40 MLD)

Sr. No.	Parameters	Unit	STP Inlet
01.	pH	pH Unit	9.03
02.	Ammonical Nitrogen	mg/l	22.4
03.	BOD (3 Days at 27 °C)	mg/l	67.4
04.	COD	mg/l	205.9
05.	Total Suspended Solids	mg/l	48
06.	Fecal Coliform	(MPN/100ml)	N.A.
07.	Total Coliform	(MPN/100ml)	N.A.
08.	N-Total	mg/l	25.4

N.A. = Not Applicable


Royal Environment Auditing & Consultancy Service




Analyst



4644

695

Royal**Environment Auditing & Consultancy Service**Plot No. 19 & 20, B/s. The North Star Nest School, Masoom School Road, Mota Mava, RAJKOT - 360 005.
Ph.: +91 9099919954 ■ E-mail : royalservice@live.com ■ admin@royalconsultancy.com

Ref. No. :126/03/2025-26

Date: 16/03/2026

REPORT OF DOMESTIC EFFLUENT ANALYSIS (40 MLD STP PLANT)

Name of company : Welspun Living Limited,
Plot No/Survey No.675,
Village: Varasamedi, Taluka: Anjar,
District: Kutch

Date of Sampling : 09/03/2026

Sample Collected by : Royal Environment

Type of Sample : Domestic Effluent

Location of Sample Collection: STP Plant (40 MLD)

Sr. No. Parameters	Unit	GPCB limits	STP Outlet
01. pH	pH Unit	6.5-9.5	7.54
02. Ammonical Nitrogen	mg/l	5	2.1
03. BOD (3 Days at 27 °C)	mg/l	10	7.5
04. COD	mg/l	50	22.5
05. Total Suspended Solids	mg/l	20	15
06. Fecal Coliform	(MPN/100ml)	100	58
07. Total Coliform	(MPN/100ml)	--	70
08. N-Total	mg/l	10	7.4

* Permissible Limits are as per GPCB CC&A, and it's only applicable to STP O/L.

N.A. = Not Applicable

Royal Environment Auditing & Consultancy Service


Analyst


TEST REPORT OF WASTEWATER

Report No.:	TEL/LAB/022026/284		Date: 11/02/2026
Client Name	M/s. PHOENIX PROJECTS PVT. LTD.		
Client Address	"Phoenix House", Jalaram -3, Ravi Ratna Road, Nr. Kohinoor Tower, Opp. 150 feet ring road, Rajkot.		
Sample Description	Wastewater	Date of Sampling	--
Point of Sample Collection	STP Inlet & Outlet	Sample Received Date	04/02/2026
Sample Quantity	2 L+ 1 L	Date of Analysis Start	04/02/2026
Sampling Method	Grab	Date of Analysis Completed	10/02/2026
Sample Code	TEL/LAB/STP/0226/076 TEL/LAB/STP/0226/077	Sampling Done by	By Party
Environmental Condition During Testing		Temp.: 27 ± 2 °C & Humidity: 65 ± 5 % RH	

TEST REPORT

Sr. No.	Parameters	Unit	STP Inlet	STP Outlet	Test Method
1.	pH Value	---	5.97	7.83	IS 3025 (Part-11)
2.	Total Suspended Solids (TSS)	mg/L	372	9.0	APHA 24 th Edition: 2540 D
3.	Chemical Oxygen Demand (COD)	mg/L	160	20.0	APHA 24 th Edition: 5220 D
4.	Biochemical Oxygen Demand (BOD)	mg/L	242	8.4	IS 3025 (Part-44)
5.	Ammonical Nitrogen	mg/L	19	2.6	IS 3025 (Part-34)
6.	Total Phosphorous	mg/L	7.2	1.4	APHA 24 th Edition: 4500 P
7.	Residual Chlorine	mg/L	ND	ND	IS 3025 (Part-26)
8.	Total Nitrogen	mg/L	38	11.5	APHA 24 th Edition: 4500 N
9.	Fecal Coliform	MPN/100 mL	240	94	APHA 24 th Edition: 9221 E
10.	Total Coliform	MPN/100 mL	194	82	APHA 24 th Edition: 9221 E

ND = Not Detected

Notes:

1. The results relate only to the samples tested.
2. The report shall not be reproduced except in full, without the written approval of the laboratory.
3. Report cannot be used as evidence anywhere without prior permission of laboratory.
4. The test samples will be disposed off after two weeks from the date of issue of test report, unless specified by the customer.


Analysed By:


Authorized Signatory



TEST REPORT OF WASTEWATER

Report No.:	TEL/LAB/022026/299		Date: 21/02/2026
Client Name	M/s. PHOENIX PROJECTS PVT. LTD.		
Client Address	"Phoenix House", Jalaram -3, Ravi Ratna Road, Nr. Kohinoor Tower, Opp. 150 feet ring road, Rajkot.		
Sample Description	Wastewater	Date of Sampling	--
Point of Sample Collection	STP Inlet & Outlet	Sample Received Date	16/02/2026
Sample Quantity	2 L+ 1 L	Date of Analysis Start	16/02/2026
Sampling Method	Grab	Date of Analysis Completed	21/02/2026
Sample Code	TEL/LAB/STP/0226/079 TEL/LAB/STP/0226/080	Sampling Done by	By Party
Environmental Condition During Testing	Temp.: 27 ± 2 °C & Humidity: 65 ± 5 % RH		

TEST REPORT

Sr. No.	Parameters	Unit	STP Inlet	STP Outlet	Test Method
1.	pH Value	---	6.86	7.34	IS 3025 (Part-11)
2.	Total Suspended Solids (TSS)	mg/L	492.2	6.8	APHA 24 th Edition: 2540 D
3.	Chemical Oxygen Demand (COD)	mg/L	186	24.6	APHA 24 th Edition: 5220 D
4.	Biochemical Oxygen Demand (BOD)	mg/L	262	8.8	IS 3025 (Part-44)
5.	Ammonical Nitrogen	mg/L	28	1.0	IS 3025 (Part-34)
6.	Total Phosphorous	mg/L	7.8	* 1.2	APHA 24 th Edition: 4500 P
7.	Residual Chlorine	mg/L	ND	ND	IS 3025 (Part-26)
8.	Total Nitrogen	mg/L	42	14	APHA 24 th Edition: 4500 N
9.	Fecal Coliform	MPN/100 mL	252	86	APHA 24 th Edition: 9221 E
10.	Total Coliform	MPN/100 mL	190	77	APHA 24 th Edition: 9221 E

ND = Not Detected

Notes:

1. The results relate only to the samples tested.
2. The report shall not be reproduced except in full, without the written approval of the laboratory.
3. Report cannot be used as evidence anywhere without prior permission of laboratory.
4. The test samples will be disposed off after two weeks from the date of issue of test report, unless specified by the customer.

Analysed By:

Authorized Signatory




SLT/REPORT/106

Report Date : 24-02-2026

Analysis Report of Waste Water

Customer's Name :	Gujarat Water Supply & Sewerage Board-Sewage Treatment Plant (16.5 MLD) Based on SBR Technology at Gondal, Gujarat.
Customer's Name :	Phoenix Projects Pvt Ltd, Rajkot
Name of Department :	D.E.E. Gondal (GWSSB)
Description of Sample :	STP Inlet (Waste Water)
Qty./No. of Samples :	2.0 Lit.
Appearance of Sample :	Colourless Liquid
Sampling Procedure :	Grab
Job No:	SLT/26-27/2355
Lab No:	SLT/3505
Date of Sampling :	21-02-2026
Date of Starting of Test :	21-02-2026
Date of Completion of Test :	24-02-2026

Sr No.	Parameters	Result Obtained	Reference Method
		SLT/7462	
1	pH @ 25 ° C	6.56	IS 3025(Part 11) :2022
2	Total Suspended Solids (mg/l)	24.15	IS 3025(Part 17):2022
3	Chemical Oxygen Demand (mg/l)	223.98	IS 3025(Part 58) :2023
4	Biochemical Oxygen Demand (mg/l)	113.58	IS 3025(Part 44) :2019
5	Total Phosphorous (mg/l)	5.46	IS 3025(Part 31) :2021
6	Ammonical Nitrogen (mg/l)	23.63	APHA 23rd Ed 4500 NH3 2017
7	Fecal Coliform (MPN/100 ml)	1958	IS 1622:2003
8	Total Coliform	1325	APHA 24th Edition 2023 9221 B

Note:

- 1) Test results related to sample submitted by customer only .
- 2) Results/Reports are issued with specific understanding that SLT MORBI LLP. will not in any case be involved in action following the interpretation of test results.
- 3) The reports/results are not supposed to be used for publicity.
- 4) Test report should not be reproduced except with full written approval of SLT MORBI LLP.



End of Report



+91 97141 62416, +91 99799 60128



sltmorbi@gmail.com

Laxmi Industries, Behind Hemratna Chamber, Near Trajpar Char Rasta, 8-A N/H,
Morbi-363642. (Guj.) INDIA.



SLT/REPORT/300

Report Date : 24-02-2026

Analysis Report of Waste Water

Customer's Name :	Gujarat Water Supply & Sewerage Board-Sewage Treatment Plant (16.5 MLD) Based on SBR Technology at Gondal, Gujarat.
Customer's Name :	Phoenix Projects Pvt Ltd, Rajkot
Name of Department :	D.E.E. Gondal (GWSSB)
Description of Sample :	STP Outlet (Waste Water)
Qty./No. of Samples :	2.0 Lit.
Appearance of Sample :	Colourless Liquid
Sampling Procedure :	Grab
Job No:	SLT/26-27/2356
Lab No:	SLT/3506
Date of Sampling :	21-02-2026
Date of Starting of Test :	21-02-2026
Date of Completion of Test :	24-02-2026

Sr No.	Parameters	Result Obtained	Reference Method	Standard Limit
		SLT/7467		
1	pH @ 25 ° C	6.98	IS 3025(Part 11) :2022	6.5-9.0
2	Total Suspended Solids (mg/l)	6.10	IS 3025(Part 17):2022	<10
3	Chemical Oxygen Demand (mg/l)	21.25	IS 3025(Part 58) :2023	<50
4	Biochemical Oxygen Demand (mg/l)	5.97	IS 3025(Part 44) :2019	<10
5	Total Phosphorous (mg/l)	0.46	IS 3025(Part 31) :2021	<1
6	Ammonical Nitrogen (mg/l)	4.10	APHA 23rd Ed 4500 NH3 2017	<5
7	Fecal Coliform (MPN/100 ml)	176	IS 1622:2003	<230
8	Total Coliform	187	APHA 24th Edition 2023 9221 B	<230

- Note:**
- 1) Test results related to sample submitted by customer only .
 - 2) Results/Reports are issued with specific understanding that SLT MORBI LLP. will not in any case be involved in action following the interpretation of test results.
 - 3) The reports/results are not supposed to be used for publicity.
 - 4) Test report should not be reproduced except with full written approval of SLT MORBI LLP.



Authorized Signature

End of Report



+91 97141 62416, +91 99799 60128



sltmorbi@gmail.com

Laxmi Industries, Behind Hemratna Chamber, Near Trajpar Char Rasta, 8-A N/H,
Morbi-363642. (Guj.) INDIA.

CERTIFICATE OF ANALYSIS
Report No: BECS/DS/WW/REPORTS/709/25-26

Issued to	12.9 MLD STP - DHORAJI		
Sample Collected By	Self	Test Report as per	IS:3025, APHA:2017
Sample Identity	Waste Water	Sampling Method	SOP Based/APHA
Sampling Description	STP Outlet	Sampling Type	Grab
Sampling Location	STP	Environment Condition	25°C±3
Sample ID	BECS/DS/WW/0206	Sample Condition/Packing	Satisfactory
Sample Quantity	1 Lit × 1 Nos	Date Of Sampling	21/02/2026
Date of Receipt	Date of Start Analysis	Date of Completion	Date of Issue
22/02/2026	22/02/2026	27/02/2026	27/02/2026

Physico-Chemical Requirements


Sr No.	TESTS	REFERENCE	UNIT OF MEASUREMENT	Permissible Limit	Result
1.	pH	IS 3025 (Part 11):2022	---	6.5 - 9.0	7.52
2.	Total Suspended Solids (TSS)	APHA 23rd Edition 2017 2540 D	mg/L	< 10	7.7
3.	Ammoniacal Nitrogen	APHA 23rd Edition 2017 4500 NH ₃ , B, C	mg/L	< 5	3.8
4.	Chemical Oxygen Demand (COD)	IS 3025 (Part-58) 2017	mg/L	< 50	38
5.	Bio-Chemical Oxygen Demand (BOD)	IS 3025 (Part-44) 2022	mg/L	< 10	9.1
6.	Total Nitrogen	APHA 23rd Edition 2017 4500 NH ₃ , N(org) C	mg/L	< 10	3.6
7.	Total Phosphorus	APHA 23rd Edition 2017 4500 P C	mg/L	< 2	0.64
8.	Residual Chlorine	APHA 23rd Edition 2017 4500 Cl-B	mg/L	0.5 - 1.0	0.69
9.	Fecal Coliform	APHA 23rd Edition 2017 9221-D	MPN/100mL	< 230	212

NOTE:

- 1 This report, in full or in part, shall not be published, advertised, used for any legal action, unless prior permission has been secured from The **BALAJI ENVIRONMENTAL CONSULTANCY SERVICES, RAJKOT.**
- 2 This test report is **ONLY FOR THE SAMPLE TESTED.**
- 3 Sample drawn by us.



 Analyzed by
 Chemist/Microbiologist



 Authorize Signatory
 Mrs. Siddhi Parakhiya
 Quality Manager

* END OF THE REPORT *

GPCB APPROVED SCHEDULE-II ENVIRONMENT AUDITOR

CERTIFICATE OF ANALYSIS
Report No: BECS/DS/WW/REPORTS/708/25-26

Issued to	12.9 MLD STP - DHORAJI		
Sample Collected By	Self	Test Report as per	IS:3025, APHA:2017
Sample Identity	Waste Water	Sampling Method	SOP Based/APHA
Sampling Description	STP Inlet	Sampling Type	Grab
Sampling Location	STP	Environment Condition	25°C±3
Sample ID	BECS/DS/WW/0205	Sample Condition/Packing	Satisfactory
Sample Quantity	1 Lit × 1 Nos	Date Of Sampling	21/02/2026
Date of Receipt	Date of Start Analysis	Date of Completion	Date of Issue
22/02/2026	22/02/2026	27/02/2026	27/02/2026

Physico-Chemical Requirements


Sr No.	TESTS	REFERENCE	UNIT OF MEASUREMENT	Result
1.	pH	IS 3025 (Part 11):2022	----	7.35
2.	Total Suspended Solids (TSS)	APHA 23rd Edition 2017 2540 D	mg/L	236
3.	Ammonical Nitrogen	APHA 23rd Edition 2017 4500 NH3, B, C	mg/L	7.2
4.	Chemical Oxygen Demand (COD)	IS 3025 (Part-58) 2017	mg/L	325
5.	Bio-Chemical Oxygen Demand (BOD)	IS 3025 (Part-44) 2022	mg/L	109
6.	Total Nitrogen	APHA 23rd Edition 2017 4500 NH3, N(org) C	mg/L	18
7.	Total Phosphorus	APHA 23rd Edition 2017 4500 P C	mg/L	4.3
8.	Fecal Coliform	APHA 23rd Edition 2017 9221-D	MPN/100mL	>1600

NOTE:

- 1 This report, in full or in part, shall not be published, advertised, used for any legal action, unless prior permission has been secured from The **BALAJI ENVIRONMENTAL CONSULTANCY SERVICES, RAJKOT.**
- 2 This test report is **ONLY FOR THE SAMPLE TESTED.**
- 3 Sample drawn by us.



 Analyzed by
 Chemist/Microbiologist



 Authorize Signatory
 Mrs. Siddhi Parakhiya
 Quality Manager

* END OF THE REPORT *

GPCB APPROVED SCHEDULE-II ENVIRONMENT AUDITOR

CERTIFICATE OF ANALYSIS

Report No: BECS/DS/WW/REPORTS/708.1/25-26

Issued to	12.9 MLD STP - DHORAJI.		
Sample Collected By	Self	Test Report as per	IS & APHA
Sample Identity	Waste Water	Sampling Method	SOP Based / APHA
Sample Description	STP Inlet	Sampling Type	Grab
Sampling Location	STP	Environmental Condition	25 °C ± 3
Sample ID	BECS/DS/WW/0205	Sample Condition	Satisfactory
Sample Quantity	1 Lit x 1 Nos.	Date of Sampling	21/02/2026
Date of Receipt	Date of Start Analysis	Date of Completion	Date of Issue
22/02/2026	22/02/2026	27/02/2026	27/02/2026

Biological Analysis

Sr No.	TESTS	REFERANCE	UNIT OF MEASUREMENT	RESULTS
1.	Total Coliform	IS : 1622 - 1981	MPN/100mL	>1600

NOTE:

- 1 This report, in full or in part, shall not be published, advertised, used for any legal action, unless prior permission has been secured from The **Balaji Environmental Consultancy Services, Rajkot.**
- 2 This test report is **ONLY FOR THE SAMPLE TESTED.**
- 3 Sample drawn by us.



SEAL

Reviewed & Authorized By
Chemist / Microbiologist

* END OF REPORT*

CERTIFICATE OF ANALYSIS

Report No: BECS/DS/WW/REPORTS/709.1/25-26

Issued to	12.9 MLD STP - DHORAJI.		
Sample Collected By	Self	Test Report as per	IS & APHA
Sample Identity	Waste Water	Sampling Method	SOP Based / APHA
Sample Description	STP Outlet	Sampling Type	Grab
Sampling Location	STP	Environmental Condition	25 °C ± 3
Sample ID	BECS/DS/WW/0206	Sample Condition	Satisfactory
Sample Quantity	1 Lit x 1 Nos.	Date of Sampling	21/02/2026
Date of Receipt	Date of Start Analysis	Date of Completion	Date of Issue
22/02/2026	22/02/2026	27/02/2026	27/02/2026

Biological Analysis

Sr No.	TESTS	REFERANCE	UNIT OF MEASUREMENT	RESULTS
1.	Total Coliform	IS : 1622 - 1981	MPN/100mL	109

NOTE:

- 1 This report, in full or in part, shall not be published, advertised, used for any legal action, unless prior permission has been secured from The **Balaji Environmental Consultancy Services, Rajkot.**
- 2 This test report is **ONLY FOR THE SAMPLE TESTED.**
- 3 Sample drawn by us.



SEAL

Reviewed & Authorized By
Chemist / Microbiologist

* END OF REPORT*

TEST REPORT

Report No :: BGCD/F/WATER/Inlet/20260207 Date :: 07.02.2026

Name of Agency :: Okha NagarPalika

Name of Loction :: Sr.No.433 Aarambhada STP 10 MLD

Letter no :: Sample Submission:-05.02.2026

Quantity Of Sample :: 1 Littrre Bottle

Test Started :: 05.02.2026

Sample Description :: Inlet At Okha 10
MLD STP (Waste)

Test Completed :: 07.02.2026

Water/Wastewater Quality Sampling & Analysis

Sr No.	Name of Test	Method of Test	Result	Unit
1	pH	APHA 23rd Edition 4500 B-2017	7.63	--
2	Total Suspended Solids	APHA 23rd Edition 2540 D-2017	252.3	mg/l
3	Total Phosphorus	APHA 23rd Edition 4500 PD-2017	4.94	mg/l
4	ChemicalOxygen Demand	IS 3025-Part 58-2006	356.3	mg/l
5	Biochemical Oxygen Demand	IS 3025-Part 44-1993	192.6	mg/l
6	Ammonica Nitrogen	APHA 23rd Edition 4500 NH3 C-2017	11.96	mg/l
7	Fecal Coliform (MPN/100 ml)	IS 1622-2003	1752	--
8	Total coliform	APHA 24th Edition 2023 9221 B	1144	--

B.D.L.=Below Detection Limit, D.L.=Detection Limit

Note :-

- 1.The results are given only for the sample submitted by the Customer.
2. The test report shall not be reproduced except in full, without written approval of the laboraory.
3. Bhavya Geostruc Consultancy Services is not responsible for any kind of interpretation of
4. The results/report is not used for publicity.


Authorized Signatory

TEST REPORT

Report No :: BGCD/F/WATER/Outlet/20260207 Date :: 07.02.2026

Name of Agency :: Okha NagarPalika

Name of Location :: Sr.No.433 Aarambhada STP 10 MLD

Letter no :: Sample Submission:-05.02.2026

Quantity Of Sample :: 1 Litre Bottle

Test Started :: 05.02.2026

Sample Description :: Outlet At Okha
10 MLD STP

Test Completed :: 07.02.2026

Water/Wastewater Quality Sampling & Analysis

Sr No.	Name of Test	Method of Test	Result	Unit
1	pH	APHA 23rd Edition 4500 B-2017	6.85	--
2	Total Suspended Solids	APHA 23rd Edition 2540 D-2017	5.82	mg/l
3	Total Phosphorus	APHA 23rd Edition 4500 PD-2017	0.69	mg/l
4	Chemical Oxygen Demand	IS 3025-Part 58-2006	32	mg/l
5	Biochemical Oxygen Demand	IS 3025-Part 44-1993	7.05	mg/l
6	Ammonia Nitrogen	APHA 23rd Edition 4500 NH3 C-2017	3.45	mg/l
7	Fecal Coliform (MPN/100 ml)	IS 1622-2003	172	--
8	Total coliform	APHA 24th Edition 2023 9221 B	184	--


B.D.L.=Below Detection Limit, D.L.=Detection Limit

Note :-

1. The results are given only for the sample submitted by the Customer.
2. The test report shall not be reproduced except in full, without written approval of the laboratory.
3. Bhavya Geostruc Consultancy Services is not responsible for any kind of interpretation of
4. The results/report is not used for publicity.




Authorized Signatory

TEST REPORT						
Water/Wastewater Quality Sampling & Analysis						
Company Name	Krishna Construction Company		Sample ID	WQ/251/26		
Company Contact Number	9099454400		Condition of sample	Satisfactory		
Address	1st Floor, H-110, Shreedhar Flora, Amar Javan Circle, Nikol Gam Road, Ahmedabad 382350		Sample Drawn By	Customer		
			Quantity of Sample	1 L		
			Sampling Method	APHA/IS MODE: (GRAB/ COMPOSITE)		
Date & Time of Sampling	19-02-2026		Date of Sample Received	19-02-2026		
Analysis Starts Date	19-02-2026		Analysis Completion Date	25-02-2026		
Sample Description	Inlet at Bhachau STP 5.5 MLD STP		Temperature/ Humidity during testing	Temp.- 25-29 deg C / Humidity <50 %		
Report Code:	SWA/LAB/19/02/2026/WQ/251		Report Date:	25-02-2026		
S.No.	PARAMETERS	UNIT	RESULTS	Regulatory Limit	Remarks	Testing Method/ Standard
1	pH @27 deg.	-	7.93			APHA 24th Edition 4500 B: 2023
2	Total Suspended Solids	mg/l	391.24			APHA 24th Edition 2540 D: 2023
3	Total Phosphorus	mg/l	7.38			APHA 24th Edition 4500 P D: 2023
4	Chemical Oxygen Demand	mg/l	397.14			IS 3025 - Part 58 : 2006
5	Biochemical Oxygen Demand	mg/l	132.25			IS 3025 - Part 44 : 1993
6	Ammonical Nitrogen	mg/l	12.29			APHA 24th Edition 4500 NH3 C: 2023
7	Total Kjeldhal Nitrogen	mg/l	22.86			APHA 24th Edition 4500 NH3 C/ Norg B: 2023
8	Nitrate	mg/l	2.65			APHA 24th Edition 4500 NO3 B: 2023
9	Nitrite	mg/l	0.03			APHA 24th Edition 4500 NO2 B: 2023
10	Total Nitrogen	mg/l	25.54			APHA 24th Edition 4500 NH3 C/ Norg B/NO3 B/NO2 B:2023
11	Faecal Coliforms	MPN/100 ml	7x10 ⁵			IS 1622: Rea.1981
12	Total Coliforms	MPN/100 ml	9x10 ⁶			IS 1622: Rea.1981
Supervised By :		Harshad Salvi		Authorized Signatory :		Pankaj Gothi
Signature :				Signature :		
Designation :		Technical Manager/COO Lab		Designation :		Quality Manager/CEO
Sub Note: Testing is carried out as per Gujarat Water Supply & Sewerage Board reference letter no PB/STP/943						
Notes:						
1. The report shall not be reproduced except in full without approval of the laboratory can provide assurance that parts of a report are not taken out of context.						
2. The results relate only to the items tested and sampled						
3. Additions to, deviations, or exclusions from the method- NA						
4. Results which were outsourced to external providers are marked with ** and results which are performed and not in NABL accreditation scope are marked with * in parameter column						
5. Disclaimer: When the information is supplied by the customer and can affect the validity of results						
6. Disclaimer: The report that the results apply to the sample as received in case of the sample has been supplied by customer						
7. Disclaimer: The laboratory shall be responsible for all the information provided in the report, except when information is provided by the customer						
8. Regulatory limit reference if any:- NA						
9. Opinion, Interpretation & Statement of Conformity if provided can be refered in the remarks section as "Permissible" "Below acceptable" or whatever is applicable as per the limit						
10. BDL : Below Detection Limit R1: Revised report and the number of that times revised						
----- End of the Test Report -----						



WASTEWATER TREATMENT | ENVIRONMENTAL TESTING | FOOD TESTING

-  Head Office : Survey No. 645, Miroli Kamod Circle, Ahmedabad-Dholka Road, Ahmedabad-382425
-  Branch Office : Jaipur, Surat, Delhi, Bengaluru
-  +91 9227988980 / 9265491610  swa@swaenviro.com / lab@swaenviro.com  www.swaenviro.com

TEST REPORT						
Water/Wastewater Quality Sampling & Analysis						
Company Name	Krishna Construction Company		Sample ID	WQ/252/26		
Company Contact Number	9099454400		Condition of sample	Satisfactory		
Address	1st Floor, H-110, Shreedhar Flora, Amar Javan Circle, Nikol Gam Road, Ahmedabad 382350		Sample Drawn By	Customer		
			Quantity of Sample	1 L		
			Sampling Method	APHA/IS MODE: (GRAB/ COMPOSITE)		
Date & Time of Sampling	19-02-2026		Date of Sample Received	19-02-2026		
Analysis Starts Date	19-02-2026		Analysis Completion Date	25-02-2026		
Sample Description	Outlet at Bhachau STP 5.5 MLD STP		Temperature/ Humidity during testing	Temp.- 25-29 deg C / Humidity <50 %		
Report Code:	SWA/LAB/19/02/2026/WQ/252		Report Date:	25-02-2026		
S.No.	PARAMETERS	UNIT	RESULTS	Regulatory Limit	Remarks	Testing Method/ Standard
1	pH @27 deg.	-	7.81	6.5-9	/	APHA 24th Edition 4500 B: 2023
2	Total Suspended Solids	mg/l	5.17	<10		APHA 24th Edition 2540 D: 2023
3	Total Phosphorus	mg/l	0.63	<1		APHA 24th Edition 4500 P D: 2023
4	Chemical Oxygen Demand	mg/l	25.94	<50		IS 3025 - Part 58 : 2006
5	Biochemical Oxygen Demand	mg/l	8.00	<10		IS 3025 - Part 44 : 1993
6	Ammonical Nitrogen	mg/l	3.49	<5		APHA 24th Edition 4500 NH3 C: 2023
7	Total Nitrogen	mg/l	5.20	<10		APHA 24th Edition 4500 NH3 C/ Norg B/NO3 B/NO2 B:2023
8	Residual Chlorine	mg/l	0.78	0.5-1		APHA 24th Edition 4500CL- B: 2023
9	Faecal Coliforms	MPN/100 ml	30.00	<230		IS 1622 - Rea. 1981
10	Total Coliforms	MPN/100 ml	40.00	<230		IS 1622: Rea.1981
Supervised By :		Harshad Salvi		Authorized Signatory :		Pankaj Gothi
Signature :				Signature :		
Designation :		Technical Manager/COO Lab		Designation :		Quality Manager/CEO
Sub Note: Testing is carried out as per Gujarat Water Supply & Sewerage Board reference letter no PB/STP/943						
Notes:						
1. The report shall not be reproduced except in full without approval of the laboratory can provide assurance that parts of a report are not taken out of context.						
2. The results relate only to the items tested and sampled						
3. Additions, deviations, or exclusions from the method- NA						
4. Results which were outsourced to external providers are marked with ** and results which are performed and not in NABL accreditation scope are marked with * in parameter column						
5. Disclaimer: When the information is supplied by the customer and can affect the validity of results						
6. Disclaimer: The report that the results apply to the sample as received in case of the sample has been supplied by customer						
7. Disclaimer: The laboratory shall be responsible for all the information provided in the report, except when information is provided by the customer						
8. Regulatory limit reference if any:- NA						
9. Opinion, Interpretation & Statement of Conformity if provided can be referred in the remarks section as "Permissible" "Below acceptable" or whatever is applicable as per the limit						
10. BDL : Below Detection Limit RJ: Revised report and the number of that times revised						
----- End of the Test Report -----						



WASTEWATER TREATMENT | ENVIRONMENTAL TESTING | FOOD TESTING



SLT/REPORT/1155

Report Date : 05-03-2026

Analysis Report of Waste Water

Customer's Name :	M/S Effwa infra & research Pvt. ltd.
Customer's Address :	5.8 MLD Sewage Treatment Plan, Between ratidevadi and panchasar, Wankaner, morbi, 363621
Description of Sample :	STP Outlet (Waste Water)
Qty./No. of Samples :	2.0 Lit.
Appearance of Sample :	Colourless Liquid
Sampling Procedure :	Grab
Job No:	SLT/25-26/14019
Lab No:	SLT/20626
Date of Sampling :	28-02-2026
Date of Starting of Test :	28-02-2026
Date of Completion of Test :	05-03-2026

Sr No.	Parameters	Result Obtained	Reference Method	Standard Limit
		SLT/20626		
1	pH @ 25 ° C	8.19	IS 3025(Part 11) :2022	6.5-9.0
2	Total Suspended Solids (mg/l)	8.47	IS 3025(Part 17):2022	<10
3	Chemical Oxygen Demand (mg/l)	41.50	IS 3025(Part 58) :2023	<50
4	Biochemical Oxygen Demand (mg/l)	7.35	IS 3025(Part 44) :2019	<10
5	Total Phosphorous (mg/l)	0.22	IS 3025(Part 31) :2021	<1
6	Ammonical Nitrogen (mg/l)	3.91	APHA 23rd Ed 4500 NH3 2017	<5
7	Fecal Coliform (MPN/100 ml)	195	IS 1622:2003	<230
8	Total Nitrogen (mg/l)	7.60	IS3025 (Part 34) : sec-1 : 2023	<10
9	Total Coliform (MPN)/100	845	IS 15185:2016	<1000

Note:

- 1) Test results related to sample submitted by customer only .
- 2) Results/Reports are issued with specific understanding that SLT MORBI LLP. will not in any case be involved in action following the interpretation of test results.
- 3) The reports/results are not supposed to be used for publicity.
- 4) Test report should not be reproduced except with full written approval of SLT MORBI LLP.



****End of Report****



+91 97141 62416, +91 99799 60128



sltmorbi@gmail.com

Laxmi Industries, Behind Hemratna Chamber, Near Trajpar Char Rasta, 8-A N/H,
Morbi-363642. (Guj.) INDIA.



SLT/REPORT/1156

Report Date : 05-03-2026

Analysis Report of Waste Water

Customer's Name :	M/S Effwa infra & research Pvt. Ltd.
Customer's Address :	5.8 MLD Sewage Treatment Plan, Between ratidevadi and panchasar, Wankaner, morbi, 363621
Description of Sample :	STP Inlet (Waste Water)
Qty./No. of Samples :	2.0 Lit.
Appearance of Sample :	Colourless Liquid
Sampling Procedure :	Grab
Job No:	SLT/25-26/14018
Lab No:	SLT/20625
Date of Sampling :	28-02-2026
Date of Starting of Test :	28-02-2026
Date of Completion of Test :	05-03-2026

Sr No.	Parameters	Result Obtained	Reference Method
		SLT/20625	
1	pH @ 25 ° C	7.25	IS 3025(Part 11) :2022
2	Total Suspended Solids (mg/l)	305.00	IS 3025(Part 17):2022
3	Chemical Oxygen Demand (mg/l)	412.00	IS 3025(Part 58) :2023
4	Biochemical Oxygen Demand (mg/l)	244.00	IS 3025(Part 44) :2019
5	Total Phosphorous (mg/l)	3.87	IS 3025(Part 31) :2021
6	Ammonical Nitrogen (mg/l)	13.20	APHA 23rd Ed 4500 NH3 2017
7	Fecal Coliform (MPN/100 ml)	>1600	IS 1622:2003
8	Total Nitrogen (mg/l)	52	IS3025 (Part 34) : sec-1 : 2023
9	Total Coliform (MPN)/100	Present	IS 15185:2016

Note:

- 1) Test results related to sample submitted by customer only .
- 2) Results/Reports are issued with specific understanding that SLT MORBI LLP. will not in any case be involved in action following the Interpretation of test results.
- 3) The reports/results are not supposed to be used for publicity.
- 4) Test report should not be reproduced except with full written approval of SLT MORBI LLP.



****End of Report****



TANISHKA EARTH CARE SERVICES (OPC) PRIVATE LIMITED

AN ISO/IEC 17025 NABL ACCREDITED ENVIRONMENT TESTING LABORATORY

GPCB Recognized Environmental Auditor (Schedule -II)

📍 PLOT NO.111. HIRA PARK, OPP- VISHAL HOTEL, JAMNAGAR - 361006

☎ +91 78749 15777 | +91 98794 06097 ✉ tanishkaearthcare@gmail.com

TEST REPORT

Company Name	M/s. Krishna Construction Company	Sample ID	WQ/26/02/35
Address	1st Floor,H-110, Shreedhar Flora, Amar JavanCircle, Nikol Gam Road, Ahmedabad.382350	Condition of sample	Satisfactory
		Sample Done By	Customer
		Quantity of Sample	1000 ml
		Sampling Method	APHA
Date of Sampling	19.02.2026	Date of Sample Received	19.02.2026
Analysis Starts Date	19.02.2026	Analysis Completion Date	23.02.2026
Sample Description	OUTLET AT JASDAN 8.3 MLD STP	Temperature/ Humidity during testing	Temp.- 25-29 deg C / Humidity <50 %
Report Number:	LAB/WQ/26/02/35	Report Date:	23.02.2026

S.No.	PARAMETERS	UNIT	RESULTS	LIMIT	Testing Method/ Standard
PHYSICAL CHEMICAL AND MICRO PARAMETERS					
1	pH @ 27 deg.	--	7.42	6.5-9	APHA 24 th Edition 4500 B: 2023
2	Total Suspended Solids	mg/l	7.00	<10	APHA 24 th Edition 2540 D: 2023
3	Total Phosphorus	mg/l	0.34	<1	APHA 24 th Edition 4500P D: 2023
4	Chemical Oxygen Demand	mg/l	28.06	<50	IS 3025 (Part 58) 2006
5	Biochemical Oxygen Demand	mg/l	8.44	<10	IS 3025 (Part 44) 1993
6	Ammonical Nitrogen	mg/l	2.53	<5	APHA 24 th Edition 4500 NH3 C : 2023
7	Total Nitrogen	mg/l	5.87	<10	APHA 24 th Edition 4500 N113C / Norg B/ NO3 B/NO2 B; 2023
8	Residual Chlorine	mg/l	0.67	0.5-1	APHA 24 th Edition 4500 CL-B:2023
8	Faecal Coliform	MPN/100 ml	50.00	<100	IS 1622
9	Total Coliform	MPN/100 ml	70.00	<100	IS 1622

Checked By :	Nikhil Dudhagara	Authorized Signatory :	Muraddal Nathani
Signature :	<i>Nikhil</i>	Signature :	<i>Muraddal Nathani</i>
Designation :	Chemist	Designation :	Technical Manager



Notes:

- The report shall not be reproduced except in full without approval of the laboratory can provide assurance that parts of a report are not taken out of context.
- This certificate is based on the sample submitted for testing.
- Additions to, deviations, or exclusions from the method- NA
- Results which were outsourced to external providers are marked with ** and results which are performed and not in NABL accreditation scope are marked with * in parameter column
- Disclaimer: When the information is supplied by the customer and can affect the validity of results
- Disclaimer: The report that the results apply to the sample as received in case of the sample has been supplied by customer
- Disclaimer: The laboratory shall be responsible for all the information provided in the report, except when information is provided by the customer
- Regulatory limit reference if any:- NA
- Opinion, Interpretation & Statement of Conformity if provided can be referred in the remarks section as "Permissible" "Below acceptable" or whatever is applicable as per the limit
- BDL : Below Detection Limit

● End of the Test Report ●

TANISHKA EARTH CARE SERVICES (OPC) PRIVATE LIMITED



TANISHKA EARTH CARE SERVICES (OPC) PRIVATE LIMITED

AN ISO/IEC 17025 NABL ACCREDITED ENVIRONMENT TESTING LABORATORY

GPCB Recognized Environmental Auditor (Schedule -II)

PLOT NO.111. HIRA PARK, OPP- VISHAL HOTEL, JAMNAGAR - 361006

+91 78749 15777 | +91 98794 06097 | tanishkaearthcare@gmail.com

TEST REPORT

Company Name	M/s. Krishna Construction Company	Sample ID	WQ/26/02/34
Address	1st Floor,H-110, Shreedhar Flora, Amar JavanCircle, Nikol Gam Road, Ahmedabad.382350	Condition of sample	Satisfactory
		Sample Done By	Customer
		Quantity of Sample	1000 ml
		Sampling Method	APHA
Date of Sampling	19.02.2026	Date of Sample Received	19.02.2026
Analysis Starts Date	19.02.2026	Analysis Completion Date	23.02.2026
Sample Description	INLET AT JASDAN 8.3 MLD STP	Temperature/ Humidity during testing	Temp.- 25-29 deg C / Humidity <50 %
Report Number:	LAB/WQ/26/02/34	Report Date:	23.02.2026

S.No.	PARAMETERS	UNIT	RESULTS	LIMIT	Testing Method/ Standard
PHYSICAL CHEMICAL AND MICRO PARAMETERS					
1	pH @ 27 deg.	--	7.27		APHA 24 th Edition 4500 B: 2023
2	Total Suspended Solids	mg/l	360.00		APHA 24 th Edition 2540 D: 2023
3	Total Phosphorus	mg/l	1.53		APHA 24 th Edition 4500P D: 2023
4	Chemical Oxygen Demand	mg/l	432.46		IS 3025 (Part 58) 2006
5	Biochemical Oxygen Demand	mg/l	156.34		IS 3025 (Part 44) 1993
6	Ammonical Nitrogen	mg/l	21.36		APHA 24 th Edition 4500 NH3 C : 2023
7	Total Kjeldhal Nitrogen	mg/l	46.68		APHA 24 th Edition 4500 NH3 C/Norg B:2017
8	Nitrate	mg/l	22.68		APHA 24 th Edition 4500 NO3 B: 2023
9	Nitrite	mg/l	1.02		APHA 24 th Edition 4500 NO2 B: 2023
10	Total Nitrogen	mg/l	70.38		APHA 24 th Edition 4500 N113C / Norg B/ NO3 B/NO2 B; 2023
11	Faecal Coliform	MPN/100 ml	900.00		IS 1622
12	Total Coliform	MPN/100 ml	1600.00		IS 1622

Checked By :	Nikhil Dudhagara	Authorized Signatory :	Mufaddal Nathani
Signature :		Signature :	
Designation :	Chemist	Designation :	Technical Manager

- Notes:**
- The report shall not be reproduced except in full without approval of the laboratory can provide assurance that parts of a report are not taken out of context.
 - This certificate is based on the sample submitted for testing.
 - Additions to, deviations, or exclusions from the method- NA
 - Results which were outsourced to external providers are marked with ** and results which are performed and not in NABL accreditation scope are marked with * in parameter column
 - Disclaimer: When the information is supplied by the customer and can affect the validity of results
 - Disclaimer: The report that the results apply to the sample as received in case of the sample has been supplied by customer
 - Disclaimer: The laboratory shall be responsible for all the information provided in the report, except when information is provided by the customer
 - Regulatory limit reference if any:- NA
 - Opinion, Interpretation & Statement of Conformity if provided can be referred in the remarks section as "Permissible" "Below acceptable" or whatever is applicable as per the limit
 - BDL : Below Detection Limit

● End of the Test Report ●

TANISHKA EARTH CARE SERVICES (OPC) PRIVATE LIMITED



TANISHKA EARTH CARE SERVICES (OPC) PRIVATE LIMITED

AN ISO/IEC 17025 NABL ACCREDITED ENVIRONMENT TESTING LABORATORY

GPCB Recognized Environmental Auditor (Schedule -II)

📍 PLOT NO.111. HIRA PARK, OPP- VISHAL HOTEL, JAMNAGAR - 361006

☎ +91 78749 15777 | +91 98794 06097 ✉ tanishkaearthcare@gmail.com

TEST REPORT

Company Name	M/s. Krishna Construction Company	Sample ID	WQ/26/03/19
Address	1st Floor,H-110, Shreedhar Flora, Amar JavanCircle, Nikol Gam Road, Ahmedabad.382350	Condition of sample	Satisfactory
		Sample Done By	Customer
		Quantity of Sample	1000 ml
		Sampling Method	APHA
Date of Sampling	09.03.2026	Date of Sample Received	09.03.2026
Analysis Starts Date	09.03.2026	Analysis Completion Date	12.03.2026
Sample Description	OUTLET AT DHROL 5.30 MLD STP	Temperature/ Humidity during testing	Temp.- 25-29 deg C / Humidity <50 %
Report Number:	LAB/WQ/26/03/19	Report Date:	12.03.2026

S.No.	PARAMETERS	UNIT	RESULTS	LIMIT	Testing Method/ Standard
PHYSICAL CHEMICAL AND MICRO PARAMETERS					
1	pH @ 27 deg.	--	8.10	6.5-9	APHA 24 th Edition 4500 B: 2023
2	Total Suspended Solids	mg/l	7.00	<10	APHA 24 th Edition 2540 D: 2023
3	Total Phosphorus	mg/l	0.34	<1	APHA 24 th Edition 4500P D: 2023
4	Chemical Oxygen Demand	mg/l	32.56	<50	IS 3025 (Part 58) 2006
5	Biochemical Oxygen Demand	mg/l	8.12	<10	IS 3025 (Part 44) 1993
6	Ammonical Nitrogen	mg/l	1.98	<5	APHA 24 th Edition 4500 NH3 C: 2023
7	Total Nitrogen	mg/l	5.24	<10	APHA 24 th Edition 4500 N113C / Norg B/ NO3 B/NO2 B; 2023
8	Faecal Coliform	MPN/100 ml	50.00	<100	IS 1622
9	Total Coliform	MPN/100 ml	60.00	<100	IS 1622

Checked By :	Parth Bandhiya	Authorized Signatory :	M. Naresh
Signature :		Signature :	
Designation :	Chemist	Designation :	Technical Manager



- Notes:**
- The report shall not be reproduced except in full without approval of the laboratory can provide assurance that parts of a report are not taken out of context.
 - This certificate is based on the sample submitted for testing.
 - Additions to, deviations, or exclusions from the method- NA
 - Results which were outsourced to external providers are marked with ** and results which are performed and not in NABL accreditation scope are marked with * in parameter column
 - Disclaimer: When the information is supplied by the customer and can affect the validity of results
 - Disclaimer: The report that the results apply to the sample as received in case of the sample has been supplied by customer
 - Disclaimer: The laboratory shall be responsible for all the information provided in the report, except when information is provided by the customer
 - Regulatory limit reference if any:- NA
 - Opinion, Interpretation & Statement of Conformity if provided can be referred in the remarks section as "Permissible" "Below acceptable" or whatever is applicable as per the limit
 - BDL : Below Detection Limit

● End of the Test Report ●

TANISHKA EARTH CARE SERVICES (OPC) PRIVATE LIMITED

TANISHKA EARTH CARE SERVICES (OPC) PRIVATE LIMITED

AN ISO/IEC 17025 NABL ACCREDITED ENVIRONMENT TESTING LABORATORY

GPCB Recognized Environmental Auditor (Schedule -II)

PLOT NO.111. HIRA PARK, OPP- VISHAL HOTEL, JAMNAGAR - 361006

+91 78749 15777 | +91 98794 06097 | tanishkaearthcare@gmail.com



Testing solution for a better tomorrow

TEST REPORT

Company Name	M/s. Krishna Construction Company	Sample ID	WQ/26/03/18
Address	1st Floor,H-110, Shreedhar Flora, Amar JavanCircle, Nikol Gam Road, Ahmedabad.382350	Condition of sample	Satisfactory
		Sample Done By	Customer
		Quantity of Sample	1000 ml
		Sampling Method	APHA
Date of Sampling	09.03.2026	Date of Sample Received	09.03.2026
Analysis Starts Date	09.03.2026	Analysis Completion Date	12.03.2026
Sample Description	INLET AT DHROL 5.30 MLD STP	Temperature/ Humidity during testing	Temp.- 25-29 deg C / Humidity <50 %
Report Number:	LAB/WQ/26/03/18	Report Date:	12.03.2026

S.No.	PARAMETERS	UNIT	RESULTS	LIMIT	Testing Method/ Standard
PHYSICAL CHEMICAL AND MICRO PARAMETERS					
1	pH @ 27 deg.	--	8.20		APHA 24 th Edition 4500 B: 2023
2	Total Suspended Solids	mg/l	260.00		APHA 24 th Edition 2540 D: 2023
3	Total Phosphorus	mg/l	3.78		APHA 24 th Edition 4500P D: 2023
4	Chemical Oxygen Demand	mg/l	422.64		IS 3025 (Part 58) 2006
5	Biochemical Oxygen Demand	mg/l	186.48		IS 3025 (Part 44) 1993
6	Ammonical Nitrogen	mg/l	26.09		APHA 24 th Edition 4500 NH3 C: 2023
7	Total Kjeldhal Nitrogen	mg/l	40.96		APHA 24 th Edition 4500 NH3 C/Norg B:2017
8	Nitrate	mg/l	26.02		APHA 24 th Edition 4500 NO3 B: 2023
9	Nitrite	mg/l	0.06		APHA 24 th Edition 4500 NO2 B: 2023
10	Total Nitrogen	mg/l	67.04		APHA 24 th Edition 4500 N113C / Norg B/ NO3 B/NO2 B; 2023
11	Faecal Coliform	MPN/100 ml	900.00		IS 1622
12	Total Coliform	MPN/100 ml	1600.00		IS 1622

Checked By :	Nikhil Dudhagra	Authorized Signatory :	Mufaddal Nathani
Signature :		Signature :	
Designation :	Chemist	Designation :	Technical Manager

- Notes:**
- The report shall not be reproduced except in full without approval of the laboratory can provide assurance that parts of a report are not taken out of context.
 - This certificate is based on the sample submitted for testing.
 - Additions to, deviations, or exclusions from the method- NA
 - Results which were outsourced to external providers are marked with ** and results which are performed and not in NABL accreditation scope are marked with * in parameter column
 - Disclaimer: When the information is supplied by the customer and can affect the validity of results
 - Disclaimer: The report that the results apply to the sample as received in case of the sample has been supplied by customer
 - Disclaimer: The laboratory shall be responsible for all the information provided in the report, except when information is provided by the customer
 - Regulatory limit reference if any:- NA
 - Opinion, Interpretation & Statement of Conformity if provided can be referred in the remarks section as "Permissible" "Below acceptable" or whatever is applicable as per the limit
 - BDL : Below Detection Limit

● End of the Test Report ●

TANISHKA EARTH CARE SERVICES (OPC) PRIVATE LIMITED





4663

714

ALCONE ENGINEERING LABORATORY LLP

alconlab.co.in

NABL & GOVERNMENT APPROVED LABORATORY

Material Test Report For Water

Report No.	AELJ/Build/447-03/2025-26	Date	26-02-2026
Name of Customer	-		
Name of Agency	P. Das Infrastructure Pvt. Ltd.		
Name of Work	3.6 MLD STP Jamjodhpur - Inlet		
Letter Ref. No.	-		
Sample Received Date	19-02-2026	Test Started	19-02-2026
Condition of Sample	Good	Test Completed	26-02-2026

Sr. No.	Test	Result Obtained	Test Perform As per IS	Regulatory Limit	Remarks
1	PH Value	8.02	IS 3025 (Part-11)	-	-
2	Total Suspended Solide (TSS) (mg/l)	529.32	IS 3025 (Part-16)	-	-
3	Total Phosphors (mg/l)	7.11	IS 3025 (Part-31)	-	-
4	Chemical Oxygen Demand (mg/l)	275.32	IS 3025 (Part-58)	-	-
5	Biological Oxygen Demand (mg/l)	185.16	IS 3025 (Part-44)	-	-
6	Ammonical Nitrogen (mg/l)	14.11	IS 3025 (Part-34)	-	-
7	Total Kjeldhal Nitrogen (mg/l)	27.28	IS 3025 (Part-34)	-	-
8	Nitrate (as No3) (mg/l)	6.15	IS 3025 (Part-34)	-	-
9	Nitrite (as No3) (mg/l)	0.09	IS 3025 (Part-34)	-	-
10	Total Nitrogen (mg/l)	26.31	IS 3025 (Part-34)	-	-
11	Feacel coliform	8.95	-	-	-
12	Total coliform	3996	-	-	-

Note:

- 1) Test results related to sample sent by the agency.
- 2) Results/ Reports are issued with specific understanding that Alcone Engineering Laboratory LLP will not be in any case involved in actions following the interpretation of test results.
- 3) The reports / Results are not supposed to be used for publicity.
- 4) Results are varied due to technical limitations,hence co-relation with the technical finding is to be made.



For Alcone Engineering Laboratory LLP

Authorised Signatory



4664

715

ALCONE ENGINEERING LABORATORY LLP

alconlab.co.in

NABL & GOVERNMENT APPROVED LABORATORY

Material Test Report For Water

Report No.	AELJ/Build/447-04/2025-26		Date	01-03-2026
Name of Customer	-			
Name of Agency	P. Das Infrastructure Pvt. Ltd.			
Name of Work	3.6 MLD STP Jamjodhpur - Outlet			
Letter Ref. No.	-			
Sample Received Date	24-02-2026	Test Started	24-02-2026	
Condition of Sample	Good	Test Completed	01-03-2026	

Sr. No.	Test	Result Obtained	Test Perform As per IS	Regulatory Limit	Remarks
1	PH Value	7.26	IS 3025 (Part-11)	6.5-9	-
2	Total Suspended Solide (TSS) (mg/l)	7.86	IS 3025 (Part-16)	<10	-
3	Total Phosphors (mg/l)	0.92	IS 3025 (Part-31)	<1	-
4	Chemical Oxygen Demand (mg/l)	42.26	IS 3025 (Part-58)	<50	-
5	Biological Oxygen Demand (mg/l)	9.43	IS 3025 (Part-44)	<10	-
6	Ammonical Nitrogen (mg/l)	4.87	IS 3025 (Part-34)	<5	-
7	Total Nitrogen (as No3) (mg/l)	9.15	IS 3025 (Part-34)	<10	-
8	Residual Chlorine (mg/l)	0.88	IS 3025 (Part-26)	0.5-1	-
9	Feacel coliform	28.42	-	-	-
10	Total coliform	489	-	-	-

Note:

- 1) Test results related to sample sent by the agency.
- 2) Results/ Reports are issued with specific understanding that Alcone Engineering Laboratory LLP will not be in any case involved in actions following the interpretation of test results.
- 3) The reports / Results are not supposed to be used for publicity.
- 4) Results are varied due to technical limitations, hence co-relation with the technical finding is to be made.

For, Alcone Engineering Laboratory LLP

Authorised Signatory



TEST REPORT OF WATER

Report No.	: TLS/RJT/26023181/16595	Issue Date	: 19-02-2026
Name of Client	: KALAVAD NAGARPALIKA		
Name of Work	: JIVAPAR ROAD 4.5 MLD STP		
Name of Agency	: KALAVAD NAGARPALIKA		
Description of Sample	: Waste Water	Date of Receiving	: 16-02-2026
Sample Qty.	: Inlate Water sample	Test Started	: 17-02-2026
		Test Completed	: 19-02-2026

Test Result				
Sr. No.	Parameters	Test Method	Unit	Results
Physical Quality				
1	PH	IS 3025 (Part-11)	"-	7.19
2	Total Dissolved Solids	IS 3025 (Part-16)	mg/l	1259.27
3	Sulphide	IS 3025 (Part-29)	mg/l	1.98
4	Total Suspended Solids	IS 3025 (Part-17)	mg/l	37.28
5	COD	IS 3025 (Part-25)	mg/l	375.86
6	BOD	IS 3025 (Part-44)	mg/l	145.5
7	Residual Free Chlorine	IS 3025 (Part-32)	mg/l	BDL (D.L.0.05)
8	Ammonical Nitrogen	IS 3025 (Part-34)	mg/l	41.15
9	Flow Meter	--	20ltr.	3min 19sec.
10	Total Phosphorus	apha 23rd 4500	mg/l	4.1
11	Total Nitrogen	--	mg/l	43.21
12	Fecal Coliform	--	mpn/100ml	125
Microbiological Parameters				
Sr. No.	Organisms	Unit	Requirements	Results
1	E coli or thermotolerant Coliform Bacteria	CFU/100 ML	Shall not be detectable in any 100 ml sample	81
2	Total Coliform Bacteria	CFU/100 ML	Shall not be detectable in any 100 ml sample	249
*All Test Parameters Result has reviewed by Authorized Signatory.				
DISCIPLINE : CHEMICAL TESTING				
** End of Report **				

Note:-

1. The Result relate only to the item tested.
2. Test Report shall not be reproduced except in full without approval of the Tatven Engineering Services Pvt.Ltd.can Provide assurance that parts of a report are not taken of context.
3. The Information is Supplied by the customer and can effect the validity of Result.
4. The result applied to the Sample as received.



Authorized Signatory
Mr. Pratik Sagpariya
Quality Manager

Page No. 1/1



TEST REPORT OF WATER

Report No.	: TLS/RJT/26023181/16595	Issue Date	: 19-02-2026
Name of Client	: KALAVAD NAGARPALIKA		
Name of Work	: JIVAPAR ROAD 4.5 MLD STP.		
Name of Agency	: KALAVAD NAGARPALIKA		
Description of Sample	: Waste Water	Date of Receiving	: 16-02-2026
Sample Qty.	: Outlate Water sample	Test Started	: 17-02-2026
		Test Completed	: 19-02-2026

Test Result				
Sr. No.	Parameters	Test Method	Unit	Results
Physical Quality				
1	PH	IS 3025 (Part-11)	"-	7.34
2	Total Dissolved Solids	IS 3025 (Part-16)	mg/l	847.24
3	Sulphide	IS 3025 (Part-29)	mg/l	1.47
4	Total Suspended Solids	IS 3025 (Part-17)	mg/l	34.64
5	COD	IS 3025 (Part-25)	mg/l	372.19
6	BOD	IS 3025 (Part-44)	mg/l	112.94
7	Residual Free Chlorine	IS 3025 (Part-32)	mg/l	BDL (D.L.0.05)
8	Ammonical Nitrogen	IS 3025 (Part-34)	mg/l	22.26
9	Flow Meter	--	20ltr.	3min 19sec.
10	Total Phosphorus	apha 23rd 4500	mg/l	1.54
11	Total Nitrogen	--	mg/l	24.27
12	Fecal Coliform	--	mpn/100ml	32
Microbiological Parameters				
Sr. No.	Organisms	Unit	Requirements	Results
1	E coli or thermotolerant Coliform Bacteria	CFU/100 ML	Shall not be detectable in any 100 ml sample	60.2
2	Total Coliform Bacteria	CFU/100 ML	Shall not be detectable in any 100 ml sample	182
*All Test Parameters Result has reviewed by Authorized Signatory.				
DISCIPLINE : CHEMICAL TESTING				
•• End of Report ••				

Note:-

1. The Result relate only to the item tested.
2. Test Report shall not be reproduced except in full without approval of the Tatven Engineering Services Pvt.Ltd.can Provide assurance that parts of a report are not taken of context.
3. The Information is Supplied by the customer and can effect the validity of Result.



Authorized Signatory
Mr. Pratik Sagpariya
Quality Manager

Page No. 1/1



TANISHKA EARTH CARE SERVICES (OPC) PRIVATE LIMITED

AN ISO/IEC 17025 NABL ACCREDITED ENVIRONMENT TESTING LABORATORY

GPCB Recognized Environmental Auditor (Schedule -II)

PLOT NO.111. HIRA PARK, OPP- VISHAL HOTEL, JAMNAGAR - 361006

+91 78749 15777 | +91 98794 06097 | tanishkaearthcare@gmail.com

TEST REPORT

Company Name	M/s. Krishna Construction Company	Sample ID	WQ/26/02/29
Address	1st Floor,H-110, Shreedhar Flora, Amar JavanCircle, Nikol Gam Road, Ahmedabad.382350	Condition of sample	Satisfactory
		Sample Done By	Customer
		Quantity of Sample	1000 ml
		Sampling Method	APHA
Date of Sampling	22.02.2026	Date of Sample Received	22.02.2026
Analysis Starts Date	22.02.2026	Analysis Completion Date	26.02.2026
Sample Description	OUTLET AT SIKKA 2.9 MLD STP	Temperature/ Humidity during testing	Temp. 25-29 deg C / Humidity <50 %
Report Number:	LAB/WQ/26/02/29	Report Date:	26.02.2026

S.No.	PARAMETERS	UNIT	RESULTS	LIMIT	Testing Method/ Standard
PHYSICAL CHEMICAL AND MICRO PARAMETERS					
1	pH @ 27 deg.	--	7.34	6.5-9	APHA 24 th Edition 4500 B: 2023
2	Total Suspended Solids	mg/l	6.00	<10	APHA 24 th Edition 2540 D: 2023
3	Total Phosphorus	mg/l	0.57	<1	APHA 24 th Edition 4500P D: 2023
4	Chemical Oxygen Demand	mg/l	32.87	<50	IS 3025 (Part 58) 2006
5	Biochemical Oxygen Demand	mg/l	7.45	<10	IS 3025 (Part 44) 1993
6	Ammonical Nitrogen	mg/l	2.56	<5	APHA 24 th Edition 4500 NH3 C: 2023
7	Total Nitrogen	mg/l	6.23	<10	APHA 24 th Edition 4500 N113C / Norg B/ NO3 B/NO2 B: 2023
8	Residual Chlorine	mg/l	0.66	0.5-1	APHA 24 th Edition 4500 CL-B:2023
8	Faecal Coliform	MPN/100 ml	50.00	<100	IS 1622
9	Total Coliform	MPN/100 ml	60.00	<100	IS 1622

Checked By :	Hardevsinh	Authorized Signatory :	Mufaddal Nathani
Signature :		Signature :	
Designation :	Chemist	Designation :	Technical Manager

- Notes:**
- The report shall not be reproduced except in full without approval of the laboratory can provide assurance that parts of a report are not taken out of context.
 - This certificate is based on the sample submitted for testing.
 - Additions to, deviations, or exclusions from the method- NA
 - Results which were outsourced to external providers are marked with ** and results which are performed and not in NABL accreditation scope are marked with * in parameter column
 - Disclaimer: When the information is supplied by the customer and can affect the validity of results
 - Disclaimer: The report that the results apply to the sample as received in case of the sample has been supplied by customer
 - Disclaimer: The laboratory shall be responsible for all the information provided in the report, except when information is provided by the customer
 - Regulatory limit reference if any:- NA
 - Opinion, Interpretation & Statement of Conformity if provided can be referred in the remarks section as "Permissible" "Below acceptable" or whatever is applicable as per the limit
 - BDL : Below Detection Limit

● End of the Test Report ●

TANISHKA EARTH CARE SERVICES (OPC) PRIVATE LIMITED



TANISHKA EARTH CARE SERVICES (OPC) PRIVATE LIMITED

AN ISO/IEC 17025 NABL ACCREDITED ENVIRONMENT TESTING LABORATORY

GPCB Recognized Environmental Auditor (Schedule -II)

PLOT NO.111. HIRA PARK, OPP- VISHAL HOTEL, JAMNAGAR - 361006

+91 78749 15777 | +91 98794 06097 | tanishkaearthcare@gmail.com

TEST REPORT

Company Name	M/s. Krishna Construction Company	Sample ID	WQ/26/02/28
Address	1st Floor,H-110, Shreedhar Flora, Amar JavanCircle, Nikol Gam Road, Ahmedabad.382350	Condition of sample	Satisfactory
		Sample Done By	Customer
		Quantity of Sample	1000 ml
		Sampling Method	APHA
Date of Sampling	22.02.2026	Date of Sample Received	22.02.2026
Analysis Starts Date	22.02.2026	Analysis Completion Date	26.02.2026
Sample Description	INLET AT SIKKA 2.9 MLD STP	Temperature/ Humidity during testing	Temp.- 25-29 deg C / Humidity <50 %
Report Number:	LAB/WQ/26/02/28	Report Date:	26.02.2026

S.No.	PARAMETERS	UNIT	RESULTS	LIMIT	Testing Method/ Standard
PHYSICAL CHEMICAL AND MICRO PARAMETERS					
1	pH @ 27 deg.	--	8.78		APHA 24 th Edition 4500 B: 2023
2	Total Suspended Solids	mg/l	310.00		APHA 24 th Edition 2540 D: 2023
3	Total Phosphorus	mg/l	2.21		APHA 24 th Edition 4500P D: 2023
4	Chemical Oxygen Demand	mg/l	424.56		IS 3025 (Part 58) 2006
5	Biochemical Oxygen Demand	mg/l	156.51		IS 3025 (Part 44) 1993
6	Ammonical Nitrogen	mg/l	20.59		APHA 24 th Edition 4500 NH3 C : 2023
7	Total Kjeldhal Nitrogen	mg/l	24.64		APHA 24 th Edition 4500 NH3 C/Norg B:2017
8	Nitrate	mg/l	18.48		APHA 24 th Edition 4500 NO3 B: 2023
9	Nitrite	mg/l	0.43		APHA 24 th Edition 4500 NO2 B: 2023
10	Total Nitrogen	mg/l	43.55		APHA 24 th Edition 4500 N113C / Norg B/ NO3 B/NO2 B: 2023
11	Faecal Coliform	MPN/100 ml	900.00		IS 1622
12	Total Coliform	MPN/100 ml	1600.00		IS 1622

Checked By :	Hardevsinh	Authorized Signatory :	Muraddal Nathani
Signature :		Signature :	
Designation :	Chemist	Designation :	Technical Manager



Notes:

- The report shall not be reproduced except in full without approval of the laboratory can provide assurance that parts of a report are not taken out of context.
- This certificate is based on the sample submitted for testing.
- Additions to, deviations, or exclusions from the method- NA
- Results which were outsourced to external providers are marked with ** and results which are performed and not in NABL accreditation scope are marked with * in parameter column
- Disclaimer: When the information is supplied by the customer and can affect the validity of results
- Disclaimer: The report that the results apply to the sample as received in case of the sample has been supplied by customer
- Disclaimer: The laboratory shall be responsible for all the information provided in the report, except when information is provided by the customer
- Regulatory limit reference if any:- NA
- Opinion, Interpretation & Statement of Conformity if provided can be referred in the remarks section as "Permissible" "Below acceptable" or whatever is applicable as per the limit
- BDL : Below Detection Limit

● End of the Test Report ●

TANISHKA EARTH CARE SERVICES (OPC) PRIVATE LIMITED



AN ISO/IEC 17025 NABL ACCREDITED ENVIRONMENT TESTING LABORATORY

GPCB Recognized Environmental Auditor (Schedule -II)

PLOT NO.111. HIRA PARK, OPP- VISHAL HOTEL, JAMNAGAR - 361006

+91 78749 15777 | +91 98794 06097 tanishkaearthcare@gmail.com

TEST REPORT

Company Name	M/s. Krishna Construction Company	Sample ID	WQ/26/02/23
Address	1st Floor,H-110, Shreedhar Flora, Amar JavanCircle, Nikol Gam Road, Ahmedabad.382350	Condition of sample	Satisfactory
		Sample Done By	Customer
		Quantity of Sample	1000 ml
		Sampling Method	APHA
Date of Sampling	16.02.2026	Date of Sample Received	16.02.2026
Analysis Starts Date	16.02.2026	Analysis Completion Date	20.02.2026
Sample Description	OUTLET AT SIKKA 2.9 MLD STP	Temperature/ Humidity during testing	Temp.- 25-29 deg C / Humidity <50 %
Report Number:	LAB/WQ/26/02/23	Report Date:	20.02.2026

S.No.	PARAMETERS	UNIT	RESULTS	LIMIT	Testing Method/ Standard
PHYSICAL CHEMICAL AND MICRO PARAMETERS					
1	pH @ 27 deg.	--	7.92	6.5-9	APHA 24 th Edition 4500 B: 2023
2	Total Suspended Solids	mg/l	5.00	<10	APHA 24 th Edition 2540 D: 2023
3	Total Phosphorus	mg/l	0.34	<1	APHA 24 th Edition 4500P D: 2023
4	Chemical Oxygen Demand	mg/l	36.89	<50	IS 3025 (Part 58) 2006
5	Biochemical Oxygen Demand	mg/l	7.00	<10	IS 3025 (Part 44) 1993
6	Ammonical Nitrogen	mg/l	2.34	<5	APHA 24 th Edition 4500 NH3 C : 2023
7	Total Nitrogen	mg/l	5.87	<10	APHA 24 th Edition 4500 N113C / Norg B/ NO3 B/NO2 B; 2023
8	Residual Chlorine	mg/l	0.62	0.5-1	APHA 24 th Edition 4500 CL-B:2023
8	Faecal Coliform	MPN/100 ml	40.00	<100	IS 1622
9	Total Coliform	MPN/100 ml	60.00	<100	IS 1622
Signature :				Signature :	
Designation :		Chemist		Designation : Technical Manager	



Notes:

1. The report shall not be reproduced except in full without approval of the laboratory can provide assurance that parts of a report are not taken out of context.
2. This certificate is based on the sample submitted for testing.
3. Additions to, deviations, or exclusions from the method- NA
4. Results which were outsourced to external providers are marked with ** and results which are performed and not in NABL accreditation scope are marked with * in parameter column
5. Disclaimer: When the information is supplied by the customer and can affect the validity of results
6. Disclaimer: The report that the results apply to the sample as received in case of the sample has been supplied by customer
7. Disclaimer: The laboratory shall be responsible for all the information provided in the report, except when information is provided by the customer
8. Regulatory limit reference if any:- NA
9. Opinion, Interpretation & Statement of Conformity if provided can be referred in the remarks section as "Permissible" "Below acceptable" or whatever is applicable as per the limit
10. BDL : Below Detection Limit

● End of the Test Report ●

TANISHKA EARTH CARE SERVICES (OPC) PRIVATE LIMITED



TANISHKA EARTH CARE SERVICES (OPC) PRIVATE LIMITED

AN ISO/IEC 17025 NABL ACCREDITED ENVIRONMENT TESTING LABORATORY

GPCB Recognized Environmental Auditor (Schedule -II)

PLOT NO.111. HIRA PARK, OPP- VISHAL HOTEL, JAMNAGAR - 361006

+91 78749 15777 | +91 98794 06097 | tanishkaearthcare@gmail.com

TEST REPORT

Company Name	M/s. Krishna Construction Company	Sample ID	WQ/26/02/22
Address	1st Floor,H-110, Shreedhar Flora, Amar JavanCircle, Nikol Gam Road, Ahmedabad.382350	Condition of sample	Satisfactory
		Sample Done By	Customer
		Quantity of Sample	1000 ml
		Sampling Method	APHA
Date of Sampling	16.02.2026	Date of Sample Received	16.02.2026
Analysis Starts Date	16.02.2026	Analysis Completion Date	20.02.2026
Sample Description	INLET AT SIKKA 2.9 MLD STP	Temperature/ Humidity during testing	Temp.- 25-29 deg C / Humidity <50 %
Report Number:	LAB/WQ/26/02/22	Report Date:	20.02.2026

S.No.	PARAMETERS	UNIT	RESULTS	LIMIT	Testing Method/ Standard
PHYSICAL CHEMICAL AND MICRO PARAMETERS					
1	pH @ 27 deg.	--	7.66		APHA 24 th Edition 4500 B: 2023
2	Total Suspended Solids	mg/l	240.00		APHA 24 th Edition 2540 D: 2023
3	Total Phosphorus	mg/l	1.59		APHA 24 th Edition 4500P D: 2023
4	Chemical Oxygen Demand	mg/l	427.30		IS 3025 (Part 58) 2006
5	Biochemical Oxygen Demand	mg/l	141.20		IS 3025 (Part 44) 1993
6	Ammonical Nitrogen	mg/l	20.33		APHA 24 th Edition 4500 NH3 C: 2023
7	Total Kjeldhal Nitrogen	mg/l	28.48		APHA 24 th Edition 4500 NH3 C/Norg B:2017
8	Nitrate	mg/l	18.62		APHA 24 th Edition 4500 NO3 B: 2023
9	Nitrite	mg/l	0.52		APHA 24 th Edition 4500 NO2 B: 2023
10	Total Nitrogen	mg/l	47.62		APHA 24 th Edition 4500 N113C / Norg B/ NO3 B/NO2 B; 2023
11	Faecal Coliform	MPN/100 ml	900.00		IS 1622
12	Total Coliform	MPN/100 ml	1600.00		IS 1622

Checked By :	Hardevsinh	Authorized Signatory :	Mufaddal Nathani
Signature :		Signature :	
Designation :	Chemist	Designation :	Technical Manager

Notes:

- The report shall not be reproduced except in full without approval of the laboratory can provide assurance that parts of a report are not taken out of context.
- This certificate is based on the sample submitted for testing.
- Additions to, deviations, or exclusions from the method- NA
- Results which were outsourced to external providers are marked with ** and results which are performed and not in NABL accreditation scope are marked with * in parameter column
- Disclaimer: When the information is supplied by the customer and can affect the validity of results
- Disclaimer: The report that the results apply to the sample as received in case of the sample has been supplied by customer
- Disclaimer: The laboratory shall be responsible for all the information provided in the report, except when information is provided by the customer
- Regulatory limit reference if any:- NA
- Opinion, Interpretation & Statement of Conformity if provided can be referred in the remarks section as "Permissible" "Below acceptable" or whatever is applicable as per the limit
- BDL : Below Detection Limit

● End of the Test Report ●

TANISHKA EARTH CARE SERVICES (OPC) PRIVATE LIMITED



TANISHKA EARTH CARE SERVICES (OPC) PRIVATE LIMITED

AN ISO/IEC 17025 NABL ACCREDITED ENVIRONMENT TESTING LABORATORY

GPCB Recognized Environmental Auditor (Schedule -II)

PLOT NO.111. HIRA PARK, OPP- VISHAL HOTEL, JAMNAGAR - 361006

+91 78749 15777 | +91 98794 06097 | tanishkaearthcare@gmail.com

TEST REPORT

Company Name	M/s. Krishna Construction Company	Sample ID	WQ/26/02/17
Address	1st Floor,H-110, Shreedhar Flora, Amar JavanCircle, Nikol Gam Road, Ahmedabad.382350	Condition of sample	Satisfactory
		Sample Done By	Customer
		Quantity of Sample	1000 ml
		Sampling Method	APHA
Date of Sampling	09.02.2026	Date of Sample Received	09.02.2026
Analysis Starts Date	09.02.2026	Analysis Completion Date	13.02.2026
Sample Description	OUTLET AT SIKKA 2.9 MLD STP	Temperature/ Humidity during testing	Temp.- 25-29 deg C / Humidity <50 %
Report Number:	LAB/WQ/26/02/17	Report Date:	13.02.2026

S.No.	PARAMETERS	UNIT	RESULTS	LIMIT	Testing Method/ Standard
PHYSICAL CHEMICAL AND MICRO PARAMETERS					
1	pH @ 27 deg.	--	7.28	6.5-9	APHA 24 th Edition 4500 B: 2023
2	Total Suspended Solids	mg/l	6.00	<10	APHA 24 th Edition 2540 D: 2023
3	Total Phosphorus	mg/l	0.21	<1	APHA 24 th Edition 4500P D: 2023
4	Chemical Oxygen Demand	mg/l	36.42	<50	IS 3025 (Part 58) 2006
5	Biochemical Oxygen Demand	mg/l	7.40	<10	IS 3025 (Part 44) 1993
6	Ammonical Nitrogen	mg/l	2.34	<5	APHA 24 th Edition 4500 NH3 C : 2023
7	Total Nitrogen	mg/l	6.07	<10	APHA 24 th Edition 4500 N113C / Norg B/ NO3 B/NO2 B: 2023
8	Residual Chlorine	mg/l	0.62	0.5-1	APHA 24 th Edition 4500 CL-B:2023
8	Faecal Coliform	MPN/100 ml	60.00	<100	IS 1622
9	Total Coliform	MPN/100 ml	70.00	<100	IS 1622

Signature :		Signature :	
Designation :	Chemist	Designation :	Technical Manager



Notes:

- The report shall not be reproduced except in full without approval of the laboratory can provide assurance that parts of a report are not taken out of context.
- This certificate is based on the sample submitted for testing.
- Additions to, deviations, or exclusions from the method- NA
- Results which were outsourced to external providers are marked with ** and results which are performed and not in NABL accreditation scope are marked with * in parameter column
- Disclaimer: When the information is supplied by the customer and can affect the validity of results
- Disclaimer: The report that the results apply to the sample as received in case of the sample has been supplied by customer
- Disclaimer: The laboratory shall be responsible for all the information provided in the report, except when information is provided by the customer
- Regulatory limit reference if any:- NA
- Opinion, Interpretation & Statement of Conformity if provided can be referred in the remarks section as "Permissible" "Below acceptable" or whatever is applicable as per the limit
- BDL : Below Detection Limit

● End of the Test Report ●

TANISHKA EARTH CARE SERVICES (OPC) PRIVATE LIMITED



TANISHKA EARTH CARE SERVICES (OPC) PRIVATE LIMITED

AN ISO/IEC 17025 NABL ACCREDITED ENVIRONMENT TESTING LABORATORY

GPCB Recognized Environmental Auditor (Schedule -II)

PLOT NO.111. HIRA PARK, OPP- VISHAL HOTEL, JAMNAGAR - 361006

+91 78749 15777 | +91 98794 06097 | tanishkaearthcare@gmail.com

TEST REPORT

Company Name	M/s. Krishna Construction Company	Sample ID	WQ/26/02/16
Address	1st Floor,H-110, Shreedhar Flora, Amar JavanCircle, Nikol Gam Road, Ahmedabad.382350	Condition of sample	Satisfactory
		Sample Done By	Customer
		Quantity of Sample	1000 ml
		Sampling Method	APHA
Date of Sampling	09.02.2026	Date of Sample Received	09.02.2026
Analysis Starts Date	09.02.2026	Analysis Completion Date	13.02.2026
Sample Description	INLET AT SIKKA 2.9 MLD STP	Temperature/ Humidity during testing	Temp.- 25-29 deg C / Humidity <50 %
Report Number:	LAB/WQ/26/02/16	Report Date:	13.02.2026

S.No.	PARAMETERS	UNIT	RESULTS	LIMIT	Testing Method/ Standard
PHYSICAL CHEMICAL AND MICRO PARAMETERS					
1	pH @ 27 deg.	--	7.56		APHA 24 th Edition 4500 B: 2023
2	Total Suspended Solids	mg/l	260.00		APHA 24 th Edition 2540 D: 2023
3	Total Phosphorus	mg/l	2.32		APHA 24 th Edition 4500P D: 2023
4	Chemical Oxygen Demand	mg/l	428.34		IS 3025 (Part 58) 2006
5	Biochemical Oxygen Demand	mg/l	156.32		IS 3025 (Part 44) 1993
6	Ammonical Nitrogen	mg/l	16.80		APHA 24 th Edition 4500 NH3 C : 2023
7	Total Kjeldhal Nitrogen	mg/l	24.48		APHA 24 th Edition 4500 NH3 C/Norg B:2017
8	Nitrate	mg/l	18.26		APHA 24 th Edition 4500 NO3 B: 2023
9	Nitrite	mg/l	0.86		APHA 24 th Edition 4500 NO2 B: 2023
10	Total Nitrogen	mg/l	43.60		APHA 24 th Edition 4500 N113C / Norg B/ NO3 B/NO2 B: 2023
11	Faecal Coliform	MPN/100 ml	500.00		IS 1622
12	Total Coliform	MPN/100 ml	900.00		IS 1622

Checked By :	Hardevsinh	Authorized Signatory :	Mufaddal Nishant
Signature :		Signature :	
Designation :	Chemist	Designation :	Technical Manager

Notes:

- The report shall not be reproduced except in full without approval of the laboratory can provide assurance that parts of a report are not taken out of context.
- This certificate is based on the sample submitted for testing.
- Additions to, deviations, or exclusions from the method- NA
- Results which were outsourced to external providers are marked with ** and results which are performed and not in NABL accreditation scope are marked with * in parameter column
- Disclaimer: When the information is supplied by the customer and can affect the validity of results
- Disclaimer: The report that the results apply to the sample as received in case of the sample has been supplied by customer
- Disclaimer: The laboratory shall be responsible for all the information provided in the report, except when information is provided by the customer
- Regulatory limit reference if any:- NA
- Opinion, Interpretation & Statement of Conformity if provided can be referred in the remarks section as "Permissible" "Below acceptable" or whatever is applicable as per the limit
- BDL : Below Detection Limit

● End of the Test Report ●

TANISHKA EARTH CARE SERVICES (OPC) PRIVATE LIMITED



TANISHKA EARTH CARE SERVICES (OPC) PRIVATE LIMITED

AN ISO/IEC 17025 NABL ACCREDITED ENVIRONMENT TESTING LABORATORY

GPCB Recognized Environmental Auditor (Schedule -II)

📍 PLOT NO.111. HIRA PARK, OPP- VISHAL HOTEL, JAMNAGAR - 361006

☎ +91 78749 15777 | +91 98794 06097 ✉ tanishkaearthcare@gmail.com

TEST REPORT

Company Name	M/s. Krishna Construction Company	Sample ID	WQ/26/02/11
Address	1st Floor,H-110, Shreedhar Flora, Amar JavanCircle, Nikol Gam Road, Ahmedabad.382350	Condition of sample	Satisfactory
		Sample Done By	Customer
		Quantity of Sample	1000 ml
		Sampling Method	APHA
Date of Sampling	02.02.2026	Date of Sample Received	02.02.2026
Analysis Starts Date	02.02.2026	Analysis Completion Date	06.02.2026
Sample Description	OUTLET AT SIKKA 2.9 MLD STP	Temperature/ Humidity during testing	Temp.- 25-29 deg C / Humidity <50 %
Report Number:	LAB/WQ/26/02/11	Report Date:	06.02.2026

S.No.	PARAMETERS	UNIT	RESULTS	LIMIT	Testing Method/ Standard
PHYSICAL CHEMICAL AND MICRO PARAMETERS					
1	pH @ 27 deg.	--	8.20	6.5-9	APHA 24 th Edition 4500 B: 2023
2	Total Suspended Solids	mg/l	7.50	<10	APHA 24 th Edition 2540 D: 2023
3	Total Phosphorus	mg/l	0.24	<1	APHA 24 th Edition 4500P D: 2023
4	Chemical Oxygen Demand	mg/l	28.86	<50	IS 3025 (Part 58) 2006
5	Biochemical Oxygen Demand	mg/l	8.32	<10	IS 3025 (Part 44) 1993
6	Ammonical Nitrogen	mg/l	2.40	<5	APHA 24 th Edition 4500 NH3 C : 2023
7	Total Nitrogen	mg/l	5.60	<10	APHA 24 th Edition 4500 N113C / Norg B/ NO3 B/NO2 B; 2023
8	Residual Chlorine	mg/l	0.56	0.5-1	APHA 24 th Edition 4500 CL-B:2023
9	Faecal Coliform	MPN/100 ml	50.00	<100	IS 1622
10	Total Coliform	MPN/100 ml	60.00	<100	IS 1622

Checked By :	Hardevsinh	Authorized Signatory :	Mufaddal Nathani
Signature :		Signature :	
Designation :	Chemist	Designation :	Technical Manager



Notes:

- The report shall not be reproduced except in full without approval of the laboratory can provide assurance that parts of a report are not taken out of context.
- This certificate is based on the sample submitted for testing.
- Additions to, deviations, or exclusions from the method- NA
- Results which were outsourced to external providers are marked with ** and results which are performed and not in NABL accreditation scope are marked with * in parameter column
- Disclaimer: When the information is supplied by the customer and can affect the validity of results
- Disclaimer: The report that the results apply to the sample as received in case of the sample has been supplied by customer
- Disclaimer: The laboratory shall be responsible for all the information provided in the report, except when information is provided by the customer
- Regulatory limit reference if any:- NA
- Opinion, Interpretation & Statement of Conformity if provided can be referred in the remarks section as "Permissible" "Below acceptable" or whatever is applicable as per the limit
- BDL : Below Detection Limit

● End of the Test Report ●

TANISHKA EARTH CARE SERVICES (OPC) PRIVATE LIMITED



TANISHKA EARTH CARE SERVICES (OPC) PRIVATE LIMITED

AN ISO/IEC 17025 NABL ACCREDITED ENVIRONMENT TESTING LABORATORY

GPCB Recognized Environmental Auditor (Schedule -II)

PLOT NO.111. HIRA PARK, OPP- VISHAL HOTEL, JAMNAGAR - 361006

+91 78749 15777 | +91 98794 06097 | tanishkaearthcare@gmail.com

TEST REPORT

Company Name	M/s. Krishna Construction Company	Sample ID	WQ/26/02/10
Address	1st Floor,H-110, Shreedhar Flora, Amar JavanCircle, Nikol Gam Road, Ahmedabad.382350	Condition of sample	Satisfactory
		Sample Done By	Customer
		Quantity of Sample	1000 ml
		Sampling Method	APHA
Date of Sampling	02.02.2026	Date of Sample Received	02.02.2026
Analysis Starts Date	02.02.2026	Analysis Completion Date	06.02.2026
Sample Description	INLET AT SIKKA 2.9 MLD STP	Temperature/ Humidity during testing	Temp.- 25-29 deg C / Humidity <50 %
Report Number:	LAB/WQ/26/02/10	Report Date:	06.02.2026

S.No.	PARAMETERS	UNIT	RESULTS	LIMIT	Testing Method/ Standard
PHYSICAL CHEMICAL AND MICRO PARAMETERS					
1	pH @ 27 deg.	--	8.15		APHA 24 th Edition 4500 B: 2023
2	Total Suspended Solids	mg/l	280.00		APHA 24 th Edition 2540 D: 2023
3	Total Phosphorus	mg/l	2.53		APHA 24 th Edition 4500P D: 2023
4	Chemical Oxygen Demand	mg/l	424.68		IS 3025 (Part 58) 2006
5	Biochemical Oxygen Demand	mg/l	142.26		IS 3025 (Part 44) 1993
6	Ammonical Nitrogen	mg/l	20.46		APHA 24 th Edition 4500 NH3 C: 2023
7	Total Kjeldhal Nitrogen	mg/l	26.78		APHA 24 th Edition 4500 NH3 C/Norg B:2017
8	Nitrate	mg/l	18.42		APHA 24 th Edition 4500 NO3 B: 2023
9	Nitrite	mg/l	0.40		APHA 24 th Edition 4500 NO2 B: 2023
10	Total Nitrogen	mg/l	45.60		APHA 24 th Edition 4500 N113C / Norg B/ NO3 B/NO2 B: 2023
11	Faecal Coliform	MPN/100 ml	900.00		IS 1622
12	Total Coliform	MPN/100 ml	1600.00		IS 1622

Checked By :	Hardevsinh	Authorized Signatory :	Mufaddal Nathani
Signature :		Signature :	
Designation :	Chemist	Designation :	Technical Manager

Notes:

- The report shall not be reproduced except in full without approval of the laboratory can provide assurance that parts of a report are not taken out of context.
- This certificate is based on the sample submitted for testing.
- Additions to, deviations, or exclusions from the method- NA
- Results which were outsourced to external providers are marked with ** and results which are performed and not in NABL accreditation scope are marked with * in parameter column
- Disclaimer: When the information is supplied by the customer and can affect the validity of results
- Disclaimer: The report that the results apply to the sample as received in case of the sample has been supplied by customer
- Disclaimer: The laboratory shall be responsible for all the information provided in the report, except when information is provided by the customer
- Regulatory limit reference if any:- NA
- Opinion, Interpretation & Statement of Conformity if provided can be referred in the remarks section as "Permissible" "Below acceptable" or whatever is applicable as per the limit
- BDL : Below Detection Limit

● End of the Test Report ●



TANISHKA EARTH CARE SERVICES (OPC) PRIVATE LIMITED

TEST REPORT

Water/Wastewater Quality Sampling & Analysis

Company Name	Krishna Construction Company	Sample ID	WQ/247/26
Company Contact Number	9099454400	Condition of sample	Satisfactory
Address	1st Floor, H-110, Shreedhar Flora, Amar Javan Circle, Nikol Gam Road, Ahmedabad 382350	Sample Drawn By	Customer
		Quantity of Sample	1 L
		Sampling Method	APHA/IS MODE: (GRAB/ COMPOSITE)
Date & Time of Sampling	12-02-2026	Date of Sample Received	12-02-2026
Analysis Starts Date	12-02-2026	Analysis Completion Date	18-02-2026
Sample Description	Inlet at Rapar 5.2 MLD STP	Temperature/ Humidity during testing	Temp.- 25-29 deg C / Humidity <50 %
Report Code:	SWA/LAB/12/02/2026/WQ/247	Report Date:	18-02-2026

S.No.	PARAMETERS	UNIT	RESULTS	Regulatory Limit	Remarks	Testing Method/ Standard
1	pH @27 deg.	-	7.51			APHA 24th Edition 4500 B: 2023
2	Total Suspended Solids	mg/l	324.76			APHA 24th Edition 2540 D: 2023
3	Total Phosphorus	mg/l	5.02			APHA 24th Edition 4500 P D: 2023
4	Chemical Oxygen Demand	mg/l	403.19			IS 3025 - Part 58 : 2006
5	Biochemical Oxygen Demand	mg/l	227.25			IS 3025 - Part 44 : 1993
6	Ammonical Nitrogen	mg/l	12.17			APHA 24th Edition 4500 NH3 C: 2023
7	Total Kjeldhal Nitrogen	mg/l	22.64			APHA 24th Edition 4500 NH3 C/ Norg B: 2023
8	Nitrate	mg/l	2.62			APHA 24th Edition 4500 NO3 B: 2023
9	Nitrite	mg/l	0.03			APHA 24th Edition 4500 NO2 B: 2023
10	Total Nitrogen	mg/l	25.29			APHA 24th Edition 4500 NH3 C/ Norg B/NO3 B/NO2 B:2023
11	Faecal Coliforms	MPN/100 ml	6 x 10 ⁴			IS 1622 - Rea. 1981
12	Total Coliform	MPN/100 ml	8 x 10 ⁶			IS 1622 - Rea. 1981


Supervised By :	Harshad Salvi	Authorized Signatory :	Pankaj Gothi
Signature :		Signature :	
Designation :	Technical Manager/COO Lab	Designation :	Quality Manager/CEO

Sub Note: Testing is carried out as per Gujarat Water Supply & Sewerage Board reference letter no PB/STP/943

Notes:

- The report shall not be reproduced except in full without approval of the laboratory can provide assurance that parts of a report are not taken out of context.
- The results relate only to the items tested and sampled
- Additions to, deviations, or exclusions from the method- NA
- Results which were outsourced to external providers are marked with ** and results which are performed and not in NABL accreditation scope are marked with * in parameter column
- Disclaimer: When the information is supplied by the customer and can affect the validity of results
- Disclaimer: The report that the results apply to the sample as received in case of the sample has been supplied by customer
- Disclaimer: The laboratory shall be responsible for all the information provided in the report, except when information is provided by the customer
- Regulatory limit reference if any:- NA
- Opinion, Interpretation & Statement of Conformity if provided can be referred in the remarks section as "Permissible" "Below acceptable" or whatever is applicable as per the limit
- BDL : Below Detection Limit | RI: Revised report and the number of that times revised

----- End of the Test Report -----



WASTEWATER TREATMENT | ENVIRONMENTAL TESTING | FOOD TESTING

- Head Office : Survey No. 645, Miroli Kamod Circle, Ahmedabad-Dholka Road, Ahmedabad-382425
- Branch Office : Jaipur, Surat, Delhi, Bengaluru
- +91 9227988980 / 9265491610 swa@swaenviro.com / lab@swaenviro.com www.swaenviro.com

TEST REPORT

Water/Wastewater Quality Sampling & Analysis

Company Name	Krishna Construction Company	Sample ID	WQ/248/26
Company Contact Number	9099454400	Condition of sample	Satisfactory
Address	1st Floor, H-110, Shreedhar Flora, Amar Javan Circle, Nikol Gam Road, Ahmedabad 382350	Sample Drawn By	Customer
		Quantity of Sample	1 L
		Sampling Method	APHA/IS MODE: (GRAB/ COMPOSITE)
Date & Time of Sampling	12-02-2026	Date of Sample Received	12-02-2026
Analysis Starts Date	12-02-2026	Analysis Completion Date	18-02-2026
Sample Description	Outlet at Rapar 5.2 MLD STP	Temperature/ Humidity during testing	Temp.- 25-29 deg C / Humidity <50 %
Report Code:	SWA/LAB/12/02/2026/WQ/248	Report Date:	18-02-2026

S.No.	PARAMETERS	UNIT	RESULTS	Regulatory Limit	Remarks	Testing Method/ Standard
1	pH @27 deg.	-	7.12	6.5-9	/	APHA 24th Edition 4500 B: 2023
2	Total Suspended Solids	mg/l	6.37	<10		APHA 24th Edition 2540 D: 2023
3	Total Phosphorus	mg/l	0.59	<1		APHA 24th Edition 4500 P D: 2023
4	Chemical Oxygen Demand	mg/l	24.19	<50		IS 3025 - Part 58 : 2006
5	Biochemical Oxygen Demand	mg/l	6.50	<10		IS 3025 - Part 44 : 1993
6	Ammonical Nitrogen	mg/l	3.19	<5		APHA 24th Edition 4500 NH3 C: 2023
7	Total Nitrogen	mg/l	8.58	<10		APHA 24th Edition 4500 NH3 C/ Norg B/N03 B/N02 B:2023
8	Residual Chlorine	mg/l	0.56	0.5-1		APHA 24th Edition 4500CL- B: 2023
9	Faecal Coliforms	MPN/100 ml	33.00	<230		IS 1622 - Rea. 1981
10	Total Coliform	MPN/100 ml	40.00	<230		IS 1622 - Rea. 1981

Supervised By :	Harshad Salvi	Authorized Signatory :	Pankaj Gothi
Signature :		Signature :	
Designation :	Technical Manager/COO Lab	Designation :	Quality Manager/CEO

Sub Note: Testing is carried out as per Gujarat Water Supply & Sewerage Board reference letter no PB/STP/943

Notes:

- The report shall not be reproduced except in full without approval of the laboratory can provide assurance that parts of a report are not taken out of context.
- The results relate only to the items tested and sampled
- Additions to, deviations, or exclusions from the method- NA
- Results which were outsourced to external providers are marked with "*" and results which are performed and not in NABL accreditation scope are marked with "*" in parameter column
- Disclaimer: When the information is supplied by the customer and can affect the validity of results
- Disclaimer: The report that the results apply to the sample as received in case of the sample has been supplied by customer
- Disclaimer: The laboratory shall be responsible for all the information provided in the report, except when information is provided by the customer
- Regulatory limit reference if any:- NA
- Opinion, Interpretation & Statement of Conformity if provided can be refered in the remarks section as "Permissible" "Below acceptable" or whatever is applicable as per the limit
- BDL : Below Detection Limit | R1: Revised report and the number of that times revised

----- End of the Test Report -----



WASTEWATER TREATMENT | ENVIRONMENTAL TESTING | FOOD TESTING

- Head Office : Survey No. 645, Miroli Kamod Circle, Ahmedabad-Dholka Road, Ahmedabad-382425
- Branch Office : Jaipur, Surat, Delhi, Bengaluru
- +91 9227988980 / 9265491610 swa@swaenviro.com / lab@swaenviro.com www.swaenviro.com



SLT/REPORT/852

Report Date : 27-02-2026

Analysis Report of Waste Water

Name of work :	Construction of 6.70 M.L.D. Capacity And Open Technology (B.N.R Technology) Based S.T.P With Repairing and Maintenance for 7 Years at Halvad, Dist. Morbi.
-----------------------	--

Name of Client :	Deputy Executive Engineer, GWSSB	Date Of Sampling:	20-02-2026
Sample brought by:	Representative	Sample Collected from	STP
Name and Address of Unit	Halvad Stp 6.70 MLD	Name of Agency :	Gujarat Construction Co., Mehsana
Sample Collected By / Provided By	-	Sample Description	STP Inlet
Job No. :	SLT/13716	Method of sampling :	Random
Lab No. :	SLT/20266	Date Of Testing:	20-02-2026

Sr No.	Tests	Result Obtained	Reference Method
		SLT/20266	
1	pH Value	6.83	IS3025 (Part 11)
2	Chemical Oxygen Demand (mg/l)	347.36	IS3025 (Part 58)
3	Biochemical Oxygen Demand (BOD) (3 Day 27°C) (mg/l)	235.79	IS3025 (Part 44)
4	Total Suspended Solid (mg/l)	335.29	IS3025 (Part 17)
5	NH3 (mg/l)	38.25	APHA:22ND edition-(3500-Cr B)
6	Total organic carbon (TOC) (mg/l)	103.30	-
7	Total Nitrogen (mg/l)	25.00	IS3025 (Part 34)
8	Chloramines (Cl ₂), (mg/l)	0.45	IS 3025 (Part 26)* or APHA 4500-Cl G
9	Total Phosphorus, (mg/l)	3.00	IS3025 (Part 31)
10	Fecal Coliform (MPN/100 ml)	840	IS 1622:2003
11	Total Coliform (MPN)/100	246	IS 15185:2016

Note:

- 1) Test results related to sample submitted by customer only .
- 2) Results/Reports are issued with specific understanding that SLT MORBI LLP. will not in any case be involved in action following the interpretation of test results.
- 3) The reports/results are not supposed to be used for publicity.
- 4) Test report should not be reproduced except with full written approval of SLT MORBI LLP.



+91 97141 62416, +91 99799 60128



sltmorbi@gmail.com

Laxmi Industries, Behind Hemratna Chamber, Near Trajpar Char Rasta, 8-A N/H,
Morbi-363642. (Guj.) INDIA.



SLT/REPORT/452

Report Date : 25-02-2026

Analysis Report of Waste Water

Name of work :	Construction of 6.70 M.L.D. Capacity And Open Technology (B.N.R Technology) Based S.T.P With Repairing and Maintenance for 7 Years at Halvad, Dist. Morbi.
-----------------------	--

Name of Client :	Deputy Executive Engineer, GWSSB	Date Of Sampling:	20-02-2026
Sample brought by:	Representative	Sample Collected from	STP
Name and Address of Unit	Halvad Stp 6.70 MLD	Name of Agency :	Gujarat Construction Co., Mehsana
Sample Collected By / Provided By	-	Sample Description	STP Outlet
Job No. :	SLT/13708	Method of sampling :	Random
Lab No. :	SLT/20258	Date Of Testing:	20-02-2026

Sr No.	Tests	Result Obtained	Reference Method
		SLT/20258	
1	pH Value	7.39	IS3025 (Part 11)
2	Chemical Oxygen Demand (mg/l)	42.80	IS3025 (Part 58)
3	Biochemical Oxygen Demand (BOD) (3 Day 27°C) (mg/l)	8.39	IS3025 (Part 44)
4	Total Suspended Solid (mg/l)	7.97	IS3025 (Part 17)
5	NH3 (mg/l)	0.41	APHA:22ND edition-(3500-Cr B)
6	Total organic carbon (TOC) (mg/l)	8.56	-
7	Total Nitrogen (mg/l)	2.99	IS3025 (Part 34)
8	Chloramines (Cl ₂), (mg/l)	0.53	IS 3025 (Part 26)* or APHA 4500-Cl G
9	Total Phosphorus, (mg/l)	0.30	IS3025 (Part 31)
10	Fecal Coliform (MPN/100 ml)	185	IS 1622:2003
11	Total Coliform (MPN)/100	842	IS 15185:2016

Note:

- 1) Test results related to sample submitted by customer only .
- 2) Results/Reports are issued with specific understanding that SLT MORBI LLP. will not in any case be involved in action following the interpretation of test results.
- 3) The reports/results are not supposed to be used for publicity.
- 4) Test report should not be reproduced except with full written approval of SLT MORBI LLP.



+91 97141 62416, +91 99799 60128



sltmorbi@gmail.com

Laxmi Industries, Behind Hemratna Chamber, Near Trajpar Char Rasta, 8-A N/H,
Morbi-363642. (Guj.) INDIA.

**TEST REPORT**

REPORT NO: AEPL/26-02/0055

ISSUE DATE: 21-02-2026

NAME OF CLIENT: M/s BHAYAVADAR NAGARPALIKA STP (3.10 MLD)

ADDRESS: Plot No. Survey No 0, Bin Numbari 1/Paiki 3, Vill. Bhayavadar, Ta. Upleta, Dist. Rajkot, Bhayavadar - 360450
Tal. Upleta, Dist. Rajkot.

SAMPLE TYPE	: Wastewater
LOCATION OF SAMPLE	: 3.10 MLD STP
DESCRIPTION	: Inlet
SAMPLING PROTOCOL / STANDARD	: NA
TYPE OF SAMPLING	: Grab
SAMPLE COLLECTED BY/ RECEIVED IN	: Client / Plastic Carboy
QUANTITY	: 2.0 Liter
SAMPLE CONDITION	: Acceptable
SAMPLING DATE	: NA
SAMPLE RECEIPT DATE	: 14-02-2026
ANALYSIS START DATE	: 14-02-2026
ANALYSIS END DATE	: 21-02-2026
TEST CONDITIONS	Temperature (°C): 24.8 Relative Humidity (%): 46

RESULTS

SR.NO	PARAMETERS	UNIT	INLET	REFERENCE METHOD
1.	pH @ 25 °C	--	7.52	IS 3025 (Part-11) 2022
2.	Total Suspended Solids	mg/L	239	APHA 24th Edition 2023 2540-D
3.	BOD (3 Days@ 27 °C)	mg/L	208	IS 3025 (Part-44) 2023
4.	Chemical Oxygen Demand	mg/L	549	IS 3025 (Part-58) 2023
5.	Ammonical Nitrogen	mg/L	36	IS 3025 Part – 34: Sec 4: 2023
6.	Total Nitrogen	mg/L	43	IS 3025 Part – 34: Sec 4: 2023
7.	Total Phosphorus	mg/L	7.2	APHA 24th Edition 2023 4500 P C
8.	Fecal Coliform	MPN/100mL	748	APHA 24th Edition 2023 9221 B
9.	Total Coliform	MPN/100mL	1270	APHA 24th Edition 2023 9221 B

Remark: NA

Authorized Signatory
Hardik Pathak
Quality Manager

End of Report

Information provided by the Customer: NA

Note:

1. This report shall not be reproduced in part or full without prior permission of Aagam Environment Pvt Ltd
2. The results listed here with are only for the items tested.
3. Sample shall be disposed after 15 days from the date of issue of the report unless agreed with the customer.
4. Incase when laboratory is not involved in sampling, the results apply to the samples as received.
5. This report shall not be used for publicity or litigation.
6. Tests performed by External Provider shall be identified/marked by "***" sign.
7. Any additions to, deviations or exclusions from the method shall be identified by "*" sign



TEST REPORT

REPORT NO: AEPL//26-02/0056

ISSUE DATE: 21-02-2026

NAME OF CLIENT: M/s BHAYAVADAR NAGARPALIKA STP (3.10 MLD)

ADDRESS: Plot No. Survey No 0, Bin Numbari 1/Paiki 3, Vill. Bhayavadar, Ta. Upleta, Dist. Rajkot, Bhayavadar – 360450
Tal. Upleta, Dist. Rajkot.

SAMPLE TYPE : Wastewater

LOCATION OF SAMPLE : 3.10 MLD STP

DESCRIPTION : Outlet

SAMPLING PROTOCOL / STANDARD : NA

TYPE OF SAMPLING : Grab

SAMPLE COLLECTED BY/ RECEIVED IN : Client / Plastic Carboy

QUANTITY : 2.0 Liter

SAMPLE CONDITION : Acceptable

SAMPLING DATE : NA

SAMPLE RECEIPT DATE : 14-02-2026

ANALYSIS START DATE : 14-02-2026

ANALYSIS END DATE : 21-02-2026

TEST CONDITIONS Temperature (°C): 24.8 Relative Humidity (%): 46

RESULTS

SR.NO	PARAMETERS	UNIT	OUTLET	REFERENCE METHOD
1.	pH @ 25 °C	--	7.09	IS 3025 (Part-11) 2022
2.	Total Suspended Solids	mg/L	<5.0	APHA 24th Edition 2023 2540-D
3.	BOD (3 Days@ 27 °C)	mg/L	08	IS 3025 (Part-58) 2023
4.	Chemical Oxygen Demand	mg/L	36	IS 3025 (Part-44) 2023
5.	Ammonical Nitrogen	mg/L	2.7	IS 3025 Part – 34: Sec 4: 2023
6.	Total Nitrogen	mg/L	5.3	IS 3025 Part – 34: Sec 4: 2023
7.	Total Phosphorus	mg/L	0.8	APHA 24th Edition 2023 4500 P C
8.	Residual Chlorine	mg/L	0.7	APHA 24th Edition 2023 4500 Cl-B
9.	Fecal Coliform	MPN/100mL	76	APHA 24th Edition 2023 9221 B
10.	Total Coliform	MPN/100mL	180	APHA 24th Edition 2023 9221 B

Remark: NA


Authorized Signatory
Hardik Pathak
Quality Manager

End of Report

Information provided by the Customer: NA

Note:

1. This report shall not be reproduced in part or full without prior permission of Aagam Environment Pvt Ltd.
2. The results listed here with are only for the items tested.
3. Sample shall be disposed after 15 days from the date of issue of the report unless agreed with the customer.
4. In case when laboratory is not involved in sampling, the results apply to the samples as received.
5. This report shall not be used for publicity or litigation.
6. Tests performed by External Provider shall be identified/marked by "***" sign.
7. Any additions to, deviations or exclusions from the method shall be identified by "**" sign

**TEST REPORT**

Company Name	M/s. Krishna Construction Company	Sample ID	WQ/26/03/11
Address	1st Floor,H-110, Shreedhar Flora, Amar JavanCircle, Nikol Gam Road, Ahmedabad.382350	Condition of sample	Satisfactory
		Sample Done By	Customer
		Quantity of Sample	1000 ml
		Sampling Method	APHA
Date of Sampling	03.03.2026	Date of Sample Received	03.03.2026
Analysis Starts Date	03.03.2026	Analysis Completion Date	07.03.2026
Sample Description	OUTLET AT MALIYA 2.5 MLD STP	Temperature/ Humidity during testing	Temp.- 25-29 deg C / Humidity <50 %
Report Number:	LAB/WQ/26/03/11	Report Date:	07.03.2026

S.No.	PARAMETERS	UNIT	RESULTS	LIMIT	Testing Method/ Standard
PHYSICAL CHEMICAL AND MICRO PARAMETERS					
1	pH @ 27 deg.	--	7.30	6.5-9	APHA 24 th Edition 4500 B: 2023
2	Total Suspended Solids	mg/l	8.00	<10	APHA 24 th Edition 2540 D: 2023
3	Total Phosphorus	mg/l	0.42	<1	APHA 24 th Edition 4500P D: 2023
4	Chemical Oxygen Demand	mg/l	28.64	<50	IS 3025 (Part 58) 2006
5	Biochemical Oxygen Demand	mg/l	8.08	<10	IS 3025 (Part 44) 1993
6	Ammonical Nitrogen	mg/l	2.17	<5	APHA 24 th Edition 4500 NH3 C : 2023
7	Total Nitrogen	mg/l	5.42	<10	APHA 24 th Edition 4500 N113C / Norg B/ NO3 B/NO2 B; 2023
8	Faecal Coliform	MPN/100 ml	60.00	<100	IS 1622
9	Total Coliform	MPN/100 ml	70.00	<100	IS 1622

Checked By :	Parth Bandhiya	Authorized Signatory :	Mufaddal Nathani
Signature :		Signature :	
Designation :	Chemist	Designation :	Technical Manager

Notes:

- The report shall not be reproduced except in full without approval of the laboratory can provide assurance that parts of a report are not taken out of context.
- This certificate is based on the sample submitted for testing.
- Additions to, deviations, or exclusions from the method- NA
- Results which were outsourced to external providers are marked with ** and results which are performed and not in NABL accreditation scope are marked with * in parameter column
- Disclaimer: When the information is supplied by the customer and can affect the validity of results
- Disclaimer: The report that the results apply to the sample as received in case of the sample has been supplied by customer
- Disclaimer: The laboratory shall be responsible for all the information provided in the report, except when information is provided by the customer
- Regulatory limit reference if any:- NA
- Opinion, Interpretation & Statement of Conformity if provided can be referred in the remarks section as "Permissible" "Below acceptable" or whatever is applicable as per the limit
- BDL : Below Detection Limit

● End of the Test Report ●



TANISHKA EARTH CARE SERVICES (OPC) PRIVATE LIMITED

AN ISO/IEC 17025 NABL ACCREDITED ENVIRONMENT TESTING LABORATORY

GPCB Recognized Environmental Auditor (Schedule -II)

PLOT NO.111. HIRA PARK, OPP- VISHAL HOTEL, JAMNAGAR - 361006

+91 78749 15777 | +91 98794 06097 | tanishkaearthcare@gmail.com

TEST REPORT

Company Name	M/s. Krishna Construction Company	Sample ID	WQ/26/03/10
Address	1st Floor,H-110, Shreedhar Flora, Amar JavanCircle, Nikol Gam Road, Ahmedabad.382350	Condition of sample	Satisfactory
		Sample Done By	Customer
		Quantity of Sample	1000 ml
		Sampling Method	APHA
Date of Sampling	03.03.2026	Date of Sample Received	03.03.2026
Analysis Starts Date	03.03.2026	Analysis Completion Date	07.03.2026
Sample Description	INLET AT MALIYA 2.5 MLD STP	Temperature/ Humidity during testing	Temp.- 25-29 deg C / Humidity <50 %
Report Number:	LAB/WQ/26/03/10	Report Date:	07.03.2026

S.No.	PARAMETERS	UNIT	RESULTS	LIMIT	Testing Method/ Standard
PHYSICAL CHEMICAL AND MICRO PARAMETERS					
1	pH @ 27 deg.	--	7.25		APHA 24 th Edition 4500 B: 2023
2	Total Suspended Solids	mg/l	330.00		APHA 24 th Edition 2540 D: 2023
3	Total Phosphorus	mg/l	1.56		APHA 24 th Edition 4500P D: 2023
4	Chemical Oxygen Demand	mg/l	438.98		IS 3025 (Part 58) 2006
5	Biochemical Oxygen Demand	mg/l	152.32		IS 3025 (Part 44) 1993
6	Ammonical Nitrogen	mg/l	22.86		APHA 24 th Edition 4500 NH3 C : 2023
7	Total Kjeldhal Nitrogen	mg/l	40.55		APHA 24 th Edition 4500 NH3 C/Norg B:2017
8	Nitrate	mg/l	28.64		APHA 24 th Edition 4500 NO3 B: 2023
9	Nitrite	mg/l	1.22		APHA 24 th Edition 4500 NO2 B: 2023
10	Total Nitrogen	mg/l	70.41		APHA 24 th Edition 4500 N113C / Norg B/ NO3 B/NO2 B; 2023
11	Faecal Coliform	MPN/100 ml	900.00		IS 1622
12	Total Coliform	MPN/100 ml	1600.00		IS 1622

Checked By :	Parth Bandhiya	Authorized Signatory :	Mufaddal Nathan
Signature :		Signature :	
Designation :	Chemist	Designation :	Technical Manager

- Notes:**
- The report shall not be reproduced except in full without approval of the laboratory can provide assurance that parts of a report are not taken out of context.
 - This certificate is based on the sample submitted for testing.
 - Additions to, deviations, or exclusions from the method- NA
 - Results which were outsourced to external providers are marked with ** and results which are performed and not in NABL accreditation scope are marked with * in parameter column
 - Disclaimer: When the information is supplied by the customer and can affect the validity of results
 - Disclaimer: The report that the results apply to the sample as received in case of the sample has been supplied by customer
 - Disclaimer: The laboratory shall be responsible for all the information provided in the report, except when information is provided by the customer
 - Regulatory limit reference if any:- NA
 - Opinion, Interpretation & Statement of Conformity if provided can be referred in the remarks section as "Permissible" "Below acceptable" or whatever is applicable as per the limit
 - BDL : Below Detection Limit

● End of the Test Report ●

TANISHKA EARTH CARE SERVICES (OPC) PRIVATE LIMITED



Environmental Private Limited



TC-4142

TEST REPORT

Water/Wastewater Quality Sampling & Analysis

Company Name	HNB Engineers Pvt Ltd (29.30 MLD STP at Bharuch)	Sample ID	WQ/203/26
Company Contact Number	Mr. Mahesh Patil: 9881998486 Mr Ashok Das: 6295696850	Condition of sample	Satisfactory
Address	Gelani Kua, Idgah Road, Near: Police Head Quarter, Bambakhana, Bharuch, Gujarat-392001	Sample Drawn By	Customer
		Quantity of Sample	2 L
		Sampling Method	APHA/IS MODE: (GRAB/ COMPOSITE)
Date & Time of Sampling	02-02-2026	Date of Sample Received	02-02-2026
Analysis Starts Date	02-02-2026	Analysis Completion Date	07-02-2026
Sample Description	Inlet chamber of Primary Unit	Temperature/ Humidity during testing	Temp:- 25-29 deg C / Humidity <50 %
Report ULR Number:	TC414226000000349P	Report Date:	07-02-2026
		Report Code:	SWA/LAB/02/02/2026/WQ/203

S.No.	PARAMETERS	UNIT	RESULTS	Regulatory Limit	Remarks	Testing Method/ Standard
1	pH @27 deg.	-	7.23			APHA 24th Edition 4500 H: 2023
2	Biochemical Oxygen Demand	mg/l	183.50			IS 3025 - Part 44: 1993
3	Chemical Oxygen Demand	mg/l	341.23			IS 3025 - Part 50: 2006
4	Total Suspended Solids	mg/l	163.46			APHA 24th Edition 2540 D:2023
5	Total Kjeldahl Nitrogen	mg/l	13.17			APHA 24th Edition 4500 NH3 C/Norg B:2023
6	Total Nitrogen	mg/l	27.66			APHA 24th Edition 4500 NH3 C/ Norg B/NO3 B/NO2 B:2023
7	Total Phosphorous	mg/l	5.03			APHA 24th Edition 4500 P D: 2023
8	Faecal Coliforms	MPN/100 ml	6x10 ⁴			IS 1622 - Rev. 1981
9	Total Coliform	MPN/100 ml	17x10 ⁴			IS 1622 - Rev. 1981
Supervised By:	Pankaj Gothi		Authorized Signatory:	Urv Patel		
Signature:			Signature:			
Designation:	Technical Manager/COO Lab		Designation:	Quality Manager/CEO		

Notes:

1. The report shall not be reproduced except in full without approval of the laboratory, can provide assurance that parts of a report are not taken out of context.
2. The results relate only to the items tested and sampled.
3. Additions to, deviations to, or variations from the method- NA
4. Results which were outsourced to external providers are marked with ** and results which are performed and not in NABL accreditation scope are marked with * in parameter column.
5. Disclaimer: When the information is supplied by the customer and can affect the validity of results.
6. Disclaimer: The report that the results apply to the sample as received in case of the sample has been supplied by customer.
7. Disclaimer: The laboratory shall be responsible for all the information provided in the report, except when information is provided by the customer.
8. Regulatory limit reference if any - NA
9. Opinion, Interpretation & Statement of Conformity if provided can be revised in the remarks section as "Permissible" "Below acceptable" or whatever is applicable as per
10. BSL: Below Detection Limit; RL: Revised report and the number of that times revised
----- End of the Test Report -----



WASTEWATER TREATMENT | ENVIRONMENTAL TESTING | ENVIRO-LEGAL SERVICES

- 📍 Head Office : Survey No. 645, Miroli Kamod Circle, Ahmedabad-Dholka Road, Ahmedabad-382425
 📍 Jaipur Branch: 2-A, Bajrang Vihar, Opposite Dungarpur Railway Station, Near Ck Birla Hospital, Jaipur, 302018
 📞 +91 9227988980 / 9265491610 📧 swa@swaenviro.com / lab@swaenviro.com 🌐 www.swaenviro.com



Environmental Private Limited



TC-4142

TEST REPORT

Water/Wastewater Quality Sampling & Analysis

Company Name	HNB Engineers Pvt Ltd. (29.30 MLD STP at Bharuch)	Sample ID	WQ/204/26
Company Contact Number	Mr. Mahesh Patil: 9881993486 Mr Ashok Das: 6295696850	Condition of sample	Satisfactory
Address	Gelani Kua, Idgah Road, Near Police Head Quarter, Bambakhana, Bharuch, Gujarat-392001.	Sample Drawn By	Customer
		Quantity of Sample	2 L
		Sampling Method	APHA/IS MODE: (GRAB/ COMPOSITE)
Date & Time of Sampling	02-02-2026	Date of Sample Received	02-02-2026
Analysis Starts Date	02-02-2026	Analysis Completion Date	07-02-2026
Sample Description	CCT Outlet	Temperature/ Humidity during testing	Temp.- 25-29 deg C / Humidity <50 %
Report ULR Number:	TC414226000000350F	Report Date:	07-02-2026
		Report Code:	SWA/LAB/02/02/2026/WQ/204

S.No.	PARAMETERS	UNIT	RESULTS	Regulatory Limit	Remarks	Testing Method/ Standard
1	pH @27 deg.	-	7.14	6.5-9		APHA 24th Edition 4500 B: 2023
2	Biochemical Oxygen Demand	mg/l	5.50	<10		IS 3025 - Part 44 : 1993
3	Chemical Oxygen Demand	mg/l	26.13	<50		IS 3025 - Part 58 : 2006
4	Total Suspended Solids	mg/l	4.62	<10		APHA 24th Edition 2540 D: 2023
5	Ammonical Nitrogen	mg/l	1.31	<5		APHA 24th Edition 4500 NH3 C: 2023
6	Total Nitrogen	mg/l	5.03	<10		APHA 24th Edition 4500 NH3 C/ Norg B/NO3 B/N/2: B: 2023
7	Total Phosphorous	mg/l	0.57	<1		APHA 24th Edition 4500 P D: 2023
8	Faecal Coliform	MPN/100 ml	50.00	<230		IS 1622 - Rea. 1981
9	Total Coliform	MPN/100 ml	90.00	<230		IS 1622 - Rea. 1981
10	Total Residual Chlorine	mg/l	0.59	0.5-1		APHA 24th Edition 4500-CL B: 2023

Supervised By:	Pankaj Gothi	Authorized Signatory:	Urv Patel
Signature:		Signature:	
Designation:	Technical Manager/COO Lab	Designation:	Quality Manager/CEO

Notes:

- The report shall not be reproduced except in full without approval of the laboratory can provide assurance that parts of a report are not taken out of context.
- The results relate only to the items tested and sampled.
- Additions, omissions, or exclusions from the method: NA
- Results which were outsourced to external providers are marked with ** and results which are performed and not in NABL accreditation scope are marked with * in parameter column.
- Disclaimer: When the information is supplied by the customer and can affect the validity of results.
- Disclaimer: The report that the results apply to the samples received in case of the sample has been signed by customer.
- Disclaimer: The laboratory shall be responsible for all the information provided in the report, except where information is provided by the customer.
- Regulatory limit reference if any: NA
- Opinion, Interpretation & Statement of Conformity if provided can be referred in the remarks section as "Permissible", "Below acceptable" or whatever is applicable as per the standard.
- BDL: Below Detection Limit; RP: Revised report and the number of times revised.

End of the Test Report



WASTEWATER TREATMENT | ENVIRONMENTAL TESTING | ENVIRO-LEGAL SERVICES

- Head Office : Survey No. 645, Mirrol Kamod Circle, Ahmedabad-Dholka Road, Ahmedabad-382425
- Jaipur Branch: 2-A, Bajrang Vihar, Opposite Dungarpur Railway Station, Near Ck Birla Hospital, Jaipur, 302018
- +91 9227988980 / 9265491610 • swa@swaenviro.com / lab@swaenviro.com • www.swaenviro.com



Environmental Private Limited



TC-4142

TEST REPORT

Water/Wastewater Quality Sampling & Analysis

Company Name	HNB Engineers Pvt Ltd. (29.30 MLD STP at Bharuch)	Sample ID	WQ/282/26
Company Contact Number	Mr. Mahesh Patil: 9801998486 Mr Ashok Das: 6295696850	Condition of sample	Satisfactory
Address	Gelani Kua, Idgah Road, Near: Police Head Quarter, Bambakhana, Bharuch, Gujarat-392001.	Sample Drawn By	Customer
		Quantity of Sample	2 L
		Sampling Method	APHA/IS MODE: (GRAB/COMPOSITE)
Date & Time of Sampling	19-02-2026	Date of Sample Received	19-02-2026
Analysis Starts Date	19-02-2026	Analysis Completion Date	25-02-2026
Sample Description	Inlet chamber of Primary Unit	Temperature/ Humidity during testing	Temp.- 25-29 deg C / Humidity <50 %
Report ULR Number:	TC414226000000502F	Report Date:	25-02-2026
		Report Code:	SWA/LAB/19/02/2026/WQ/282

S.No.	PARAMETERS	UNIT	RESULTS	Regulatory Limit	Remarks	Testing Method/ Standard
1	pH @27 deg	-	7.34			APHA 24th Edition 4500 B: 2023
2	Biochemical Oxygen Demand	mg/l	203.25			IS 3025 - Part 44 : 1993
3	Chemical Oxygen Demand	mg/l	354.08			IS 3025 - Part 58 : 2006
4	Total Suspended Solids	mg/l	173.39			APHA 24th Edition 2540 D:2023
5	Total Kjeldahl Nitrogen	mg/l	13.42			APHA 24th Edition 4500 NH3 C/ Norg B:2023
6	Total Nitrogen	mg/l	28.18			APHA 24th Edition 4500 NH3 C/ Norg B/NO3 B/NO2 B:2023
7	Total Phosphorus	mg/l	5.29			APHA 24th Edition 4500 P D: 2023
8	Faecal Coliforms	MPN/100 ml	7x10 ⁴			IS 1622 - Rea. 1981
9	Total Coliform	MPN/100 ml	18x10 ³			IS 1622 - Rea. 1981

Supervised By :	Pankaj Gothi	Authorized Signatory :	Urv Patel
Signature :		Signature :	
Designation :	Technical Manager/COO Lab	Designation :	Quality Manager/CEO

Notes:

- The report shall not be reproduced except in full without approval of the laboratory can provide assurance that parts of a report are not taken out of context.
- The results relate only to the items tested and sampled.
- Additions to, omissions, or exclusions from the method- NA
- Results which were outsourced to external providers are marked with ** and results which are performed and not in NABL accreditation scope are marked with * in parameter column.
- Disclaimer: When the information is supplied by the customer and can affect the validity of results.
- Disclaimer: The report that the results apply to the sample as received in case of the sample has been supplied by customer.
- Disclaimer: The laboratory shall be responsible for all the information provided in the report, except when information is provided by the customer.
- Regulatory limit reference (if any)- NA
- Optimum, Interpretation & Statement of Conformity if provided can be referred in the remarks section as "Permissible" "Below acceptable" or whatever is applicable as per the limit.
- B/D: Below Detection Limit; R: Revised report and the number of that times revised.

End of the Test Report



WASTEWATER TREATMENT | ENVIRONMENTAL TESTING | ENVIRO-LEGAL SERVICES

- Head Office : Survey No. 645, Miroli Kamod Circle, Ahmedabad-Dholka Road, Ahmedabad-382425
- Jaipur Branch: 2-A, Bajrang Vihar, Opposite Durgapur Railway Station, Near Ck Birla Hospital, Jaipur, 302018
- +91 9227988980 / 9265491610 • swa@swaenviro.com / lab@swaenviro.com • www.swaenviro.com



Environmental Private Limited



TC-4142

TEST REPORT

Water/Wastewater Quality Sampling & Analysis

Company Name	HNB Engineers Pvt Ltd. (29.30 MLD STP at Bharuch)	Sample ID	WQ/203/26
Company Contact Number	Mr. Mahesh Patil: 9881996486 Mr. Ashok Das: 6295696850	Condition of sample	Satisfactory
Address	Gelani Kua, Idgah Road, Near. Police Head Quarter, Bambakhana, Bharuch, Gujarat-392001.	Sample Drawn By	Customer
		Quantity of Sample	2 L
		Sampling Method	APHA/IS MODE (GRAB/ COMPOSITE)
Date & Time of Sampling	19-02-2026	Date of Sample Received	19-02-2026
Analysis Starts Date	19-02-2026	Analysis Completion Date	25-02-2026
Sample Description	CCT Outlet	Temperature/ Humidity during testing	Temp. 25-29 deg C / Humidity <50 %
Report ULR Number:	TC414226000000503P	Report Date:	25-02-2026
		Report Code:	SWA/LAB/19/02/2026/WQ/263

S.No.	PARAMETERS	UNIT	RESULTS	Regulatory Limit	Remarks	Testing Method/ Standard
1	pH @27 deg	-	7.21	6.5-9		APHA 24th Edition 4500 B: 2023
2	Biochemical Oxygen Demand	mg/l	6.00	<10		IS 3025 - Part 44 : 1993
3	Chemical Oxygen Demand	mg/l	28.64	<50		IS 3025 - Part 56 : 2006
4	Total Suspended Solids	mg/l	4.89	<10		APHA 24th Edition 2540 D: 2023
5	Ammonical Nitrogen	mg/l	1.38	<5		APHA 24th Edition 4500 NH3 C: 2023
6	Total Nitrogen	mg/l	5.46	<10		APHA 24th Edition 4500 N/NO3 B/NO2 B: 2023
7	Total Phosphorous	mg/l	0.63	<1		APHA 24th Edition 4500 P D: 2023
8	Faecal Coliform	MPN/100 ml	40.00	<230		IS 1622 - Rea. 1981
9	Total Coliform	MPN/100 ml	70.00	<230		IS 1622 - Rea. 1981
10	Total Residual Chlorine	mg/l	0.69	0.5-1		APHA 24th Edition 4500-CL B: 2023

Supervised By :

Pankaj Gothi

Authorized Signatory :

Urv Patel

Signature :

Signature :

Designation :

Technical Manager/COO Lab

Designation :

Quality Manager/CEO

Notes:

- The report shall not be reproduced except in full without approval of the laboratory can provide assurance that parts of a report are not taken out of context.
- The results relate only to the items tested and sampled.
- Additions to, deletions or exclusions from the method: NA
- Results which were outsourced to external providers are marked with ** and results which are performed and not in NABL accreditation scope are marked with * in parameter column.
- Disclaimer: When the information is supplied by the customer and can affect the validity of results.
- Disclaimer: The report that the results apply to the sample as received in case of the sample has been supplied by customer.
- Disclaimer: The laboratory shall be responsible for all the information provided in the report, except when information is provided by the customer.
- Regulatory limit reference if any: NA
- Opinion, Interpretation & Statement of Conformity if provided can be referred in the remarks section as "Permissible", "Below acceptable" or whatever is applicable as per the limit.
- BDL: Below Detection Limit; RE: Revised report and the number of that times revised.

End of the Test Report



WASTEWATER TREATMENT | ENVIRONMENTAL TESTING | ENVIRO-LEGAL SERVICES

- Head Office : Survey No. 645, Miroli Kamod Circle, Ahmedabad-Dholka Road, Ahmedabad-382425
- Jaipur Branch: 2-A, Bajrang Vihar, Opposite Dungarpur Railway Station, Near Ck Birla Hospital, Jaipur, 302018
- +91 9227988980 / 9265491610 swa@swaenviro.com / lab@swaenviro.com www.swaenviro.com



NATURE MICROVISION LLP

ISO 9001:2015 and ISO 17025:2017 NABL certified

No.4, Versetile Industrial Estate, Nr. Kotak Bank, Gate No.5,
Kathwada Gidc, Ahmedabad - 382430.

+91 8469130040, +91 6357351655 naturemicrovision@gmail.com GSTIN : 24AAWFN4704G1Z4

Test Report

Report ID: NML/WW/25-26/1236

Date: 14/02/2026

Customer Name	P.DAS INFRASTRUCTURE PVT LTD		
Customer Address	6.5 MLD VYARA		
Date & Time of Sampling	09/02/2026	Sampling Plan & Method	IS 3025(Part-1) RA 2019
Date of Receipt of Sample	10/02/2026		
Sample Collected by	Client	Sample Condition	SATISFACTORY
Analysis Starting Date	10/02/2026	Packing / Seal	SEALED
Analysis Completion Date	14/02/2026	Quantity / No. of Samples	Approx. 1 LIT. * 1NO.
Environmental Condition	Temperature: 25 °C ± 2	Relative Humidity (%)	Humidity ≤ 50 %

Sample No.	Sample ID	Sample Type	Location	Description
1.	25-26/1245	Waste Water	Outlet	Treated Water

Analysis Results

Sr. No.	Parameters	Reference Method	Results	Regulatory Limit	Unit
1.	pH	IS 3025 (Part 11): 2022	7.46	6.5-9.0	---
2.	BIOLOGICAL OXYGEN DEMAND (3 days at 27°C)	IS 3025 (Part 44): 2023	7.8	<10	mg/L
3.	CHEMICAL OXYGEN DEMAND	IS 3025 (Part 58) : 2023	38	<50	mg/L
4.	TOTAL SUSPENDED SOLIDS	IS 3025 (Part 17): 1988 (RA 2022)	7.65	<10	mg/L
5.	AMMONICAL NITROGEN	IS 3025 (Part 34/sec-1):2023	2.0	<5	mg/L
6.	TOTAL NITROGEN	IS 3025 (Part 34/sec- 1):2023	7.1	<10	mg/L
7.	TOTAL PHOSPHORUS	IS 3025 (Part 31) :Sec 1 : 2022	0.62	1	mg/L
8.	FECAL COLIFORM	IS 15185 : 2016	102	<230	(MPN)/ 100
9.	RESIDUAL CHLORINE	IS 3025 (Part 31) : Sec 1 : 2022	0.58	0.5-1.0	mg/L

Checked by
Senior Chemist



Authorised by
Lab Manager/CEO

Remarks:

- BDL: Below Detectable Limit.
- The report pertains only to the sample tested and does not apply to the bulk quantity.
- The test report may not be reproduced, wholly or partially, nor used for promotional or publicity purposes without written consent from the laboratory department.
- Samples will be retained for 15 days after the completion of analysis. A longer retention period can be arranged upon customer request.



NATURE MICROVISION LLP

ISO 9001:2015 and ISO 17025:2017 NABL certified

No.4, Versatile Industrial Estate, Nr. Kotak Bank, Gate No.5,
Kathwade Gide, Ahmedabad - 382430.

+91 8469130040, +91 6357351655 naturemicrovision@gmail.com GSTIN : 24AAWFN4704G1Z4

Test Report

Report ID: NML/WW/25-26/1235

Date: 14/02/2026

Customer Name	P.DAS INFRASTRUCTURE PVT LTD		
Customer Address	6.5 MLD VYARA		
Date & Time of Sampling	09/02/2026	Sampling Plan & Method	IS 3025(Part-1) RA 2019
Date of Receipt of Sample	10/02/2026		
Sample Collected by	Client	Sample Condition	SATISFACTORY
Analysis Starting Date	10/02/2026	Packing / Seal	SEALED
Analysis Completion Date	14/02/2026	Quantity / No. of Samples	Approx. 1 LIT. * 1NO.
Environmental Condition	Temperature: 25 °C ± 2	Relative Humidity (%)	Humidity ≤ 50 %

Sample No.	Sample ID	Sample Type	Location	Description
1.	25-26/1244	Waste Water	Inlet	Untreated Water

Analysis Results

Sr. No.	Parameters	Reference Method	Results	Regulatory Limit	Unit
1.	pH	IS 3025 (Part 11): 2022	6.98	6.5-7.0	--
2.	BIOLOGICAL OXYGEN DEMAND (3 days at 27°C)	IS 3025 (Part 44): 2023	216	<250	mg/L
3.	CHEMICAL OXYGEN DEMAND	IS 3025 (Part 58) : 2023	398.4	<425	mg/L
4.	TOTAL SUSPENDED SOLIDS	IS 3025 (Part 17): 1988 (RA 2022)	280.75	<375	mg/L
5.	TOTAL NITROGEN	IS 3025 (Part 34/sec- 1):2023	30	<50	mg/L
6.	TOTAL PHOSPHORUS	IS 3025 (Part 31) :Sec 1 : 2022	2.9	<7.1	mg/L
7.	TOTAL COLIFORM	IS 15185 : 2016	10 ⁶	10 ⁷ -10 ⁸	(MPN)/100

Checked by
Senior Chemist



Authorised by
Lab Manager/CEO

End of Test Report

Remarks:

- BDL: Below Detectable Limit.
- The report pertains only to the sample tested and does not apply to the bulk quantity.
- The test report may not be reproduced, wholly or partially, nor used for promotional or publicity purposes without written consent from the laboratory department.
- Samples will be retained for 15 days after the completion of analysis. A longer retention period can be arranged upon customer request.



NATURE MICROVISION LLP

ISO 9001:2015 and ISO 17025:2017 NABL certified

No.4, Versetile Industrial Estate, Nr. Kotak Bank, Gate No.5,
Kathwada Gldc, Ahmedabad - 382430.

+91 8469130040, +91 6357351655 naturemicrovision@gmail.com GSTIN : 24AAWFN4704G1Z4

Test Report

Report ID: NML/WW/25-26/1315

Date: 24/02/2026

Customer Name	P.DAS INFRASTRUCTURE PVT LTD		
Customer Address	6.5 MLD VYARA		
Date & Time of Sampling	20/02/2026	Sampling Plan & Method	IS 3025(Part-1) RA 2019
Date of Receipt of Sample	21/02/2026	Sample Condition	SATISFACTORY
Sample Collected by	Client	Packing / Seal	SEALED
Analysis Starting Date	21/02/2026	Quantity / No. of Samples	Approx. 1 LIT. * 1NO.
Analysis Completion Date	24/02/2026	Relative Humidity (%)	Humidity ≤ 50 %
Environmental Condition	Temperature: 25 °C ± 2		

Sample No.	Sample ID	Sample Type	Location	Description
1.	25-26/1324	Waste Water	Outlet	Treated Water

Analysis Results

Sr. No.	Parameters	Reference Method	Results	Regulatory Limit	Unit
1.	pH	IS 3025 (Part 11): 2022	7.49	6.5-9.0	--
2.	BIOLOGICAL OXYGEN DEMAND (3 days at 27°C)	IS 3025 (Part 44): 2023	7.5	<10	mg/L
3.	CHEMICAL OXYGEN DEMAND	IS 3025 (Part 58) : 2023	36	<50	mg/L
4.	TOTAL SUSPENDED SOLIDS	IS 3025 (Part 17): 1988 (RA 2022)	7.43	<10	mg/L
5.	AMMONICAL NITROGEN	IS 3025 (Part 34/sec-1):2023	2.3	<5	mg/L
6.	TOTAL NITROGEN	IS 3025 (Part 34/sec- 1):2023	6.9	<10	mg/L
7.	TOTAL PHOSPHORUS	IS 3025 (Part 31) :Sec 1 : 2022	0.60	1	mg/L
8.	FECAL COLIFORM	IS 15185 : 2016	119	<230	(MPN)/ 100
9.	RESIDUAL CHLORINE	IS 3025 (Part 31) : Sec 1 : 2022	0.55	0.5-1.0	mg/L

Checked by
Senior Chemist



Authorised by
Lab Manager/CEO

Remarks:

- BDL: Below Detectable Limit.
- The report pertains only to the sample tested and does not apply to the bulk quantity.
- The test report may not be reproduced, wholly or partially, nor used for promotional or publicity purposes without written consent from the laboratory department.
- Samples will be retained for 15 days after the completion of analysis. A longer retention period can be arranged upon customer request.



NATURE MICROVISION LLP

ISO 9001:2015 and ISO 17025:2017 NABL certified

No.4, Versetile Industrial Estate, Nr. Kotak Bank, Gate No.5,
Kathwada Gldc, Ahmedabad - 382430.

+91 8469130040, +91 6357351655 naturemicrovision@gmail.com GSTIN : 24AAWFN470461Z4

Test Report

Report ID: NML/WW/25-26/1314

Date: 24/02/2026

Customer Name	P.DAS INFRASTRUCTURE PVT LTD		
Customer Address	6.5 MLD VYARA		
Date & Time of Sampling	20/02/2026	Sampling Plan & Method	IS 3025(Part-1) RA 2019
Date of Receipt of Sample	21/02/2026		
Sample Collected by	Client	Sample Condition	SATISFACTORY
Analysis Starting Date	21/02/2026	Packing / Seal	SEALED
Analysis Completion Date	24/02/2026	Quantity / No. of Samples	Approx. 1 LIT. * 1NO.
Environmental Condition	Temperature: 25 °C ± 2	Relative Humidity (%)	Humidity ≤ 50 %

Sample No.	Sample ID	Sample Type	Location	Description
1.	25-26/1323	Waste Water	Inlet	Untreated Water

Analysis Results

Sr. No.	Parameters	Reference Method	Results	Regulatory Limit	Unit
1.	pH	IS 3025 (Part 11): 2022	7.12	6.5-7.0	--
2.	BIOLOGICAL OXYGEN DEMAND (3 days at 27°C)	IS 3025 (Part 44): 2023	223	<250	mg/L
3.	CHEMICAL OXYGEN DEMAND	IS 3025 (Part 58) : 2023	408.4	<425	mg/L
4.	TOTAL SUSPENDED SOLIDS	IS 3025 (Part 17): 1988 (RA 2022)	248.65	<375	mg/L
5.	TOTAL NITROGEN	IS 3025 (Part 34/sec- 1):2023	35	<50	mg/L
6.	TOTAL PHOSPHORUS	IS 3025 (Part 31) :Sec 1 : 2022	2.7	<7.1	mg/L
7.	TOTAL COLIFORM	IS 15185 : 2016	10 ⁷	10 ⁷ -10 ⁸	(MPN)/100

Checked by
Senior Chemist



Authorised by
Lab Manager/CEO

End of Test Report

Remarks:

- BDL: Below Detectable Limit.
- The report pertains only to the sample tested and does not apply to the bulk quantity.
- The test report may not be reproduced, wholly or partially, nor used for promotional or publicity purposes without written consent from the laboratory department.
- Samples will be retained for 15 days after the completion of analysis. A longer retention period can be arranged upon customer request.



GREEN CIRCLE CONSULTANTS (INDIA) PVT. LTD

Integrated HSEQR Consulting Engineers, Scientists & Trainers

NABL ISO/IEC 17025:2017 Certified Organization



Report No.: - GCI/V/LAB/G356/25/RS/25-26/Feb-00/0605

Date: 14/02/2026

ANALYSIS REPORT (For the Month of Feb-2026)

ULR: TC1363525000001244F

Client Details		Sample Details	
Name	M/s. HNB Engineers Pvt Ltd.	Sample Code	GCI//25/J15/WW1
		Location	STP Inlet
Address	20.20 MLD Sewage Treatment Plant, Kailash Road, Valsad - 396001	Quantity	1 liter
		Sampling Done By	-
Date of Analysis	08/02/2026	Date of Sampling	-
		Date of Sample Received	07/02/2026
Date of Completion	14/02/2026	Sampling Method	-
		Reference Method	APHA 24 th Edition

WASTE WATER ANALYSIS RESULTS

Sr. No.	Parameters	Unit	Results	Reference Method
1.	pH	-	7.25	APHA 4500-H+
2.	Total Suspended Solids(TSS)	mg/L	169.32	APHA 2540 D
3.	Chemical Oxygen Demand (COD)	mg/L	212.00	APHA 5220 B
4.	Biochemical Oxygen Demand(BOD) (3 days at 27 °C)	mg/L	128.11	IS 3025 Part - 44
5.	Total Phosphate	mg/L	6.08	APHA 4500 - P
6.	Ammonical Nitrogen	mg/L	41.03	APHA 4500-NH3
7.	Chlorine Residual(RFC)	ppm	0.2	APHA 4500 - Cl - B

BDL: Below Detectable Limit



Authorized Signatory
Dixshant Shastri
Technical Manager

- Results relate to the items tested and sampled only.
- Reports cannot be used as evidence anywhere including judiciary purpose without our prior permission.
- Sample will be retained till 15 days from the date of sampling.



GREEN CIRCLE CONSULTANTS (INDIA) PVT. LTD

Integrated HSEQR Consulting Engineers, Scientists & Trainers

NABL ISO/IEC 17025:2017 Certified Organization

Report No.: - GCI/V/LAB/G356/25/RS/25-26/Feb-00/0605

Date: 14/02/2026

ANALYSIS REPORT (For the Month of Feb-2026)

Client Details		Sample Details	
Name	M/s. HNB Engineers Pvt Ltd	Sample Code	GCI//25/J15/WW1
Address	20.20 MLD Sewage Treatment Plant, Kailash Road, Valsad - 396001	Location	STP Inlet
		Quantity	1 liter
Date of Analysis	08/02/2026	Sampling Done By	-
		Date of Sampling	-
Date of Completion	14/02/2026	Date of Sample Received	07/02/2026
		Sampling Method	-
		Reference Method	APHA 24h Edition

WASTE WATER ANALYSIS RESULTS

Sr. No.	Parameters	Unit	Results	Reference Method
8.	Total Nitrogen	mg/L	47.52	APHA 4500-NORG-B
9.	Total Coliform	MPN/100 ml	16*10 ⁸	APHA 24 th Edition-9221-E
10.	Fecal Coliform	MPN/100 ml	16*10 ⁷	APHA 9221-E

BDL: Below Detectable Limit



Authorized Signatory
Dixshant Shastri
Technical Manager

- Results relate to the items tested and sampled only.
- Reports cannot be used as evidence anywhere including judiciary purpose without our prior permission.
- Sample will be retained till 15 days from the date of sampling.



GREEN CIRCLE CONSULTANTS (INDIA) PVT. LTD

Integrated HSEQR Consulting Engineers, Scientists & Trainers

NABL ISO/IEC 17025:2017 Certified Organization



Report No.: - GCI/V/LAB/G356/25/RS/25-26/Feb-00/0605

Date: 14/02/2026

ANALYSIS REPORT (For the Month of Feb-2026)

ULR: TC1363525000001245F

Client Details		Sample Details	
Name	M/s. HNB Engineers Pvt Ltd.	Sample Code	GCI//25/J15/WW1
		Location	STP Outlet
Address	20.20 MLD Sewage Treatment Plant, Kailash Road, Valsad - 396001	Quantity	1 liter
		Sampling Done By	-
Date of Analysis	08/02/2026	Date of Sampling	-
		Date of Sample Received	0702/2026
Date of Completion	14/02/2026	Sampling Method	-
		Reference Method	APHA 24 th Edition

WASTE WATER ANALYSIS RESULTS

Sr. No.	Parameters	Unit	Results	Permissible Limit	Reference Method
1.	pH	-	7.85	6.5-9.00	APHA 4500-H+
2.	Total Suspended Solids(TSS)	mg/L	9.07	10	APHA 2540 D
3.	Chemical Oxygen Demand (COD)	mg/L	43.25	50	APHA 5220 B
4.	Biochemical Oxygen Demand(BOD) (3 days at 27 °C)	mg/L	7.95	10	IS 3025 Part - 44
5.	Total Phosphate	mg/L	1.40	2	APHA 4500 - P
6.	Ammonical Nitrogen	mg/L	4.25	5	APHA 4500-NH3
7.	Chlorine Residual(RFC)	ppm	0.79	1	APHA 4500 - Cl - B

BDL: Below Detectable Limit



Authorized Signatory
Dixshant Shastri
Technical Manager

- Results relate to the items tested and sampled only.
- Reports cannot be used as evidence anywhere including judiciary purpose without our prior permission.
- Sample will be retained till 15 days from the date of sampling.



GREEN CIRCLE CONSULTANTS (INDIA) PVT. LTD

Integrated HSEQR Consulting Engineers, Scientists & Trainers

NABL ISO/IEC 17025:2017 Certified Organization

Report No.: - GCI/V/LAB/G356/25/RS/25-26/Feb-00/0605

Date: 14/02/2026

ANALYSIS REPORT (For the Month of Feb-2026)

Client Details		Sample Details	
Name	M/s. HNB Engineers Pvt Ltd	Sample Code	GCI//25/J15/WW1
		Location	STP Outlet
Address	20.20 MLD Sewage Treatment Plant, Kailash Road, Valsad - 396001	Quantity	1 liter
		Sampling Done By	-
Date of Analysis	08/02/2026	Date of Sampling	-
		Date of Sample Received	07/02/2026
Date of Completion	14/02/2026	Sampling Method	-
		Reference Method	APHA 24 th Edition

WASTE WATER ANALYSIS RESULTS

Sr. No.	Parameters	Unit	Results	Permissible Limit	Reference Method
8.	Total Nitrogen	mg/l	8.00	10	APHA 4500-NORG-B
9.	Total Coliform	MPN/100 ml	88.00	<1000 MPN/100 ml	APHA 24 th Edition-9221-E
10.	Fecal Coliform	MPN/100 ml	93.00	<1000 MPN/100 ml	APHA 9221-E

BDL: Below Detectable Limit



Authorized Signatory
Dixshant Shastri
Technical Manager

- Results relate to the items tested and sampled only.
- Reports cannot be used as evidence anywhere including judiciary purpose without our prior permission.
- Sample will be retained till 15 days from the date of sampling.



Report No.: - GCI/V/LAB/G356/25/RS/25-26/Feb-00/0689

Date: 27/02/2026

ANALYSIS REPORT
 (For the Month of Feb-2026)

ULR: TC1363525000001244F

Client Details		Sample Details	
Name	M/s. HNB Engineers Pvt Ltd.	Sample Code	GCI//25/J15/WW1
		Location	STP Inlet
Address	20.20 MLD Sewage Treatment Plant, Kailash Road, Valsad - 396001	Quantity	1 liter
		Sampling Done By	-
Date of Analysis	21/02/2026	Date of Sampling	-
		Date of Sample Received	20/02/2026
Date of Completion	27/02/2026	Sampling Method	-
		Reference Method	APHA 241 h Edition

WASTE WATER ANALYSIS RESULTS

Sr. No.	Parameters	Unit	Results	Reference Method
1.	pH	-	7.41	APHA 4500-H+
2.	Total Suspended Solids (TSS)	mg/L	178.96	APHA 2540 D
3.	Chemical Oxygen Demand (COD)	mg/L	244.00	APHA 5220 B
4.	Biochemical Oxygen Demand (BOD) (3 days at 27°C)	mg/L	145.95	IS 3025 Part - 44
5.	Total Phosphate	mg/L	7.11	APHA 4500 - P
6.	Ammonical Nitrogen	mg/L	38.52	APHA 4500-NH3
7.	Chlorine Residual (RFC)	ppm	0.1	APHA 4500 - Cl - B

BDL: Below Detectable Limit


 Authorized Signatory
 Dixshant Shastri
 Technical Manager

- Results relate to the items tested and sampled only.
- Reports cannot be used as evidence anywhere including judiciary purpose without our prior permission.
- Sample will be retained till 15 days from the date of sampling.



GREEN CIRCLE CONSULTANTS (INDIA) PVT. LTD

Integrated HSEQR Consulting Engineers, Scientists & Trainers

NABL ISO/IEC 17025:2017 Certified Organization

Report No.: - GCI/V/LAB/G356/25/RS/25-26/Feb-00/0689

Date: 27/02/2026

ANALYSIS REPORT (For the Month of Feb-2026)

Client Details		Sample Details	
Name	M/s. HNB Engineers Pvt Ltd	Sample Code	GCI//25/J15/WW1
		Location	STP Inlet
Address	20.20 MLD Sewage Treatment Plant, Kailash Road, Valsad - 396001	Quantity	1 liter
		Sampling Done By	-
Date of Analysis	21/02/2026	Date of Sampling	-
		Date of Sample Received	20/02/2026
Date of Completion	27/02/2026	Sampling Method	-
		Reference Method	APHA 24h Edition

WASTE WATER ANALYSIS RESULTS

Sr. No.	Parameters	Unit	Results	Reference Method
8.	Total Nitrogen	mg/L	44.83	APHA 4500-NORG-B
9.	Total Coliform	MPN/100 ml	16*10 ⁶	APHA 24 th Edition-9221-E
10.	Fecal Coliform	MPN/100 ml	16*10 ⁷	APHA 9221-E

BDL: Below Detectable Limit



Authorized Signatory
Dixshant Shastri
Technical Manager

- Results relate to the items tested and sampled only.
- Reports cannot be used as evidence anywhere including judiciary purpose without our prior permission.
- Sample will be retained till 15 days from the date of sampling.



GREEN CIRCLE CONSULTANTS (INDIA) PVT. LTD

Integrated HSEQR Consulting Engineers, Scientists & Trainers

NABL ISO/IEC 17025:2017 Certified Organization



Report No.: - GCI/V/LAB/G356/25/RS/25-26/Feb-00/0689

Date: 27/02/2026

ANALYSIS REPORT (For the Month of Feb-2026)

ULR: TC1363525000001245F

Client Details		Sample Details	
Name	M/s. HNB Engineers Pvt Ltd.	Sample Code	GCI//25/J15/WW1
		Location	STP Outlet
Address	20.20 MLD Sewage Treatment Plant, Kailash Road, Valsad - 396001	Quantity	1 liter
		Sampling Done By	-
Date of Analysis	21/02/2026	Date of Sampling	-
		Date of Sample Received	20/02/2026
Date of Completion	27/02/2026	Sampling Method	-
		Reference Method	APHA 24 th Edition

WASTE WATER ANALYSIS RESULTS

Sr. No.	Parameters	Unit	Results	Permissible Limit	Reference Method
1.	pH	-	7.90	6.5-9.00	APHA 4500-H+
2.	Total Suspended Solids(TSS)	mg/L	8.85	10	APHA 2540 D
3.	Chemical Oxygen Demand (COD)	mg/L	48.16	50	APHA 5220 B
4.	Biochemical Oxygen Demand(BOD) (3 days at 27 °C)	mg/L	8.09	10	IS 3025 Part - 44
5.	Total Phosphate	mg/L	1.30	2	APHA 4500 - P
6.	Ammonical Nitrogen	mg/L	3.82	5	APHA 4500-NH3
7.	Chlorine Residual(RFC)	ppm	0.92	1	APHA 4500 - Cl - B

BDL: Below Detectable Limit



Authorized Signatory
Dixshant Shastri
Technical Manager

- Results relate to the items tested and sampled only.
- Reports cannot be used as evidence anywhere including judiciary purpose without our prior permission.
- Sample will be retained till 15 days from the date of sampling.



GREEN CIRCLE CONSULTANTS (INDIA) PVT. LTD

Integrated HSEQR Consulting Engineers, Scientists & Trainers

NABL ISO/IEC 17025:2017 Certified Organization

Report No.: - GCI/V/LAB/G356/25/RS/25-26/Feb-00/0689

Date: 27/02/2026

ANALYSIS REPORT (For the Month of Feb-2026)

Client Details		Sample Details	
Name	M/s. HNB Engineers Pvt Ltd	Sample Code	GCI//25/J15/WW1
		Location	STP Outlet
Address	20.20 MLD Sewage Treatment Plant, Kailash Road, Valsad - 396001	Quantity	1 liter
		Sampling Done By	-
Date of Analysis	21/02/2026	Date of Sampling	-
		Date of Sample Received	20/02/2026
Date of Completion	27/02/2026	Sampling Method	-
		Reference Method	APHA 24 th Edition

WASTE WATER ANALYSIS RESULTS

Sr. No.	Parameters	Unit	Results	Permissible Limit	Reference Method
8.	Total Nitrogen	mg/L	9.15	10	APHA 4500-NORG-B
9.	Total Coliform	MPN/100 ml	92.00	<1000 MPN/100 ml	APHA 24 th Edition-9221-E
10.	Fecal Coliform	MPN/100 ml	91.00	<1000 MPN/100 ml	APHA 9221-E

BDL: Below Detectable Limit



Authorized Signatory
Dixshant Shastri
Technical Manager

- Results relate to the items tested and sampled only.
- Reports cannot be used as evidence anywhere including judiciary purpose without our prior permission.
- Sample will be retained till 15 days from the date of sampling.



Test Report
Water Sample Analysis Report

Client's Name & Address GWSSB, Bharuch, Gujarat Construction, company Mahesana, JAMBUSAR 5.90 MLD STP	Report No: GLEPL/241050/2810 Issue Date: 12/02/2026
---	--

Lab ID Code	: GLEPL/230222/WL ₁
Sample Description	: Waste Water (STP Inlet) Purpose : As per Client requirement
Date of Sampling	: Submitted by Client Sample Collected/Submitted by : Submitted by Client
Date of Sample Received	: 02/02/2026 Test Parameters : As per Client requirement
Date of starting Analysis	: 03/02/2026 Quantity/No. of sample : 2 Lit./01
Date of completion Analysis	: 09/02/2026 Packed/Seal : Sealed

Result Table

Sr. No.	Test Parameters	Test Method	Unit	Results
1	pH @30 °C	IS 3025 (P-11) 1983 (Reaffirmed 2017)	pH Unit	9.88
2	Total Suspended Solids	IS 3025 (P-17) 1984 (Reaffirmed 2017)	mg/L	333.14
3	Chemical Oxygen Demand	IS 3025 (P-58) 2006 (Reaffirmed 2017)	mg/L	178.65
4	BOD (5 days at 20°C)	IS 3025 (P-44) 1993 (Reaffirmed 2019)	mg/L	110.54
5	Ammonical Nitrogen	IS 3025 (P-34) 1988 (Reaffirmed 2019)	mg/L	9.65
6	Total Phosphorus	IS 3025 (P-31) 1988 (Reaffirmed 2019)	mg/L	BDL
7	Total Kjeldahl Nitrogen	IS 3025 (P-34) 1988 (Reaffirmed 2019)	mg/L	21.45
8	Residual Chlorine	IS 3025 (P-26) 1986 (Reaffirmed 2019)	mg/L	ND
9	Total Coliform	APHA & AWWA 23 rd Ed. 9221 E (9-77)	MPN/100MI	357

Note: BDL: Below Detection Limit, ND: Not Detected.

WL₁: STP Inlet Water

N. A. Khant

Chemist

N. A. Khant

Authorized Signatory
KHANT NILESH

Notes: (1) The results pertain to tested items only.

(2) This report shall not be reproduced, except in full, without written approval of the laboratory.

(3) Authenticity of this Report could be validated with office copy at Greenleaf Evirotech Pvt. Ltd.

(4) Perishable samples will be destroyed after testing, others after 7 days from the date of issue of the report, unless otherwise agreed with the customer or as required by the applicable regulations.

Recognized by MoEF, Govt. of India, EP Act 1986; NABL accredited; GPCB Schedule II Environment Auditor; OHSAS – 18001:2017 Certified Laboratory.

Greenleaf Evirotech Pvt. Ltd.

304, Kankavati Complex, Singanpor-Cauzway Road, Katargam, Surat – 395004, Tel: 0261-6430044

E-mail: lab@glepl.com | Web: www.glepl.com



Test Report
Water Sample Analysis Report

Client's Name & Address GWSSB, Bharuch, Gujarat Construction, company Mahesana, JAMBUSAR 5.90 MLD STP	Report No: GLEPL/241051/2811 Issue Date: 13/02/2026
---	--

Lab ID Code	: GLEPL/230222/WL ₂
Sample Description	: Waste Water (STP Outlet) Purpose : As per Client requirement
Date of Sampling	: Submitted by Client Sample Collected/Submitted by : Submitted by Client
Date of Sample Received	: 02/02/2026 Test Parameters : As per Client requirement
Date of starting Analysis	: 03/02/2026 Quantity/No. of sample : 2 Lit./02
Date of completion Analysis	: 09/02/2026 Packed/Seal : Sealed

Result Table

Sr. No.	Test Parameters	Test Method	Unit	Results	Permissible Limit
1	pH @30 °C	IS 3025 (P-11) 1983 (Reaffirmed 2017)	pH Unit	7.2	6.5-9.0
2	Total Suspended Solids	IS 3025 (P-17) 1984 (Reaffirmed 2017)	mg/L	8.1	<10
3	Chemical Oxygen Demand	IS 3025 (P-58) 2006 (Reaffirmed 2017)	mg/L	18.35	<50
4	BOD (5 days at 20°C)	IS 3025 (P-44) 1993 (Reaffirmed 2019)	mg/L	7.8	<10
5	Ammonical Nitrogen	IS 3025 (P-34) 1988 (Reaffirmed 2019)	mg/L	3.4	<5.0
6	Total Phosphorus	IS 3025 (P-31) 1988 (Reaffirmed 2019)	mg/L	BDL	<1.0
7	Total Nitrogen	IS 3025 (P-34) 1988 (Reaffirmed 2019)	mg/L	6.8	<10.0
8	Residual Chlorines	IS 3025 (P-26) 1986 (Reaffirmed 2019)	mg/L	0.7	0.5-1.0
9	Faecal Coliform	APHA & AWWA 23 rd Ed. 9221 E (9-77)	MPN/100mL	96	<230

Note: BDL: Below Detection Limit.
WL₁: STP Outlet Water

N.A. Khant
Chemist

N.A. Khant
Authorized Signatory
KHANT NILESH

- Notes: (1) The results pertain to tested items only.
(2) This report shall not be reproduced, except in full, without written approval of the laboratory.
(3) Authenticity of this Report could be validated with office copy at Greenleaf Envirotech Pvt. Ltd.
(4) Perishable samples will be destroyed after testing, others after 7 days from the date of issue of the report, unless otherwise agreed with the customer or as required by the applicable regulations.

Recognized by MoEF, Govt. of India, EP Act 1986; NABL accredited; GPCB Schedule II Environment Auditor; OHSAS – 18001:2017 Certified Laboratory.

Greenleaf Envirotech Pvt. Ltd.

304, Kankavati Complex, Singanpor-Cauzway Road, Katargam, Surat – 395004, Tel: 0261-6430044
E-mail: lab@glepl.com | Web: www.glepl.com



Test Report
Water Sample Analysis Report

Client's Name & Address GWSSB, Bharuch, Gujarat Construction, company Mahesana, JAMBUSAR 5.90 MLD STP	Report No: GLEPL/241055/2815 Issue Date: 26/02/2026
---	--

Lab ID Code	: GLEPL/230222/WL ₁		
Sample Description	: Waste Water (STP Inlet)	Purpose	: As per Client requirement
Date of Sampling	: Submitted by Client	Sample Collected/Submitted by	: Submitted by Client
Date of Sample Received	: 16/02/2026	Test Parameters	: As per Client requirement
Date of starting Analysis	: 17/02/2026	Quantity/No. of sample	: 2 Lit./01
Date of completion Analysis	: 24/02/2026	Packed/Seal	: Sealed

Result Table

Sr. No.	Test Parameters	Test Method	Unit	Results
1	pH @30 °C	IS 3025 (P-11) 1983 (Reaffirmed 2017)	pH Unit	9.98
2	Total Suspended Solids	IS 3025 (P-17) 1984 (Reaffirmed 2017)	mg/L	312.75
3	Chemical Oxygen Demand	IS 3025 (P-58) 2006 (Reaffirmed 2017)	mg/L	182.45
4	BOD (5 days at 20°C)	IS 3025 (P-44) 1993 (Reaffirmed 2019)	mg/L	112.34
5	Ammonical Nitrogen	IS 3025 (P-34) 1988 (Reaffirmed 2019)	mg/L	9.65
6	Total Phosphorus	IS 3025 (P-31) 1988 (Reaffirmed 2019)	mg/L	BDL
7	Total Kjeldahl Nitrogen	IS 3025 (P-34) 1988 (Reaffirmed 2019)	mg/L	32.54
8	Residual Chlorine	IS 3025 (P-26) 1986 (Reaffirmed 2019)	mg/L	ND
9	Total Coliform	APHA & AWWA 23 rd Ed. 9221 E (9-77)	MPN/100MI	310

Note: BDL: Below Detection Limit, ND: Not Detected.

WL₁: STP Inlet Water

N.A. Khant

Chemist

N.A. Khant

Authorized Signatory
KHANT NILESH

Notes: (1) The results pertain to tested items only.

(2) This report shall not be reproduced, except in full, without written approval of the laboratory.

(3) Authenticity of this Report could be validated with office copy at Greenleaf Envirotech Pvt. Ltd.

(4) Perishable samples will be destroyed after testing, others after 7 days from the date of issue of the report, unless otherwise agreed with the customer or as required by the applicable regulations.

Recognized by MoEF, Govt. of India, EP Act 1986; NABL accredited; GPCB Schedule II Environment Auditor; OHSAS – 18001:2017 Certified Laboratory.

Greenleaf Envirotech Pvt. Ltd.

304, Kankavati Complex, Singanpor-Cauzway Road, Katargam, Surat – 395004, Tel: 0261-6430044

E-mail: lab@glepl.com | Web: www.glepl.com



Test Report
Water Sample Analysis Report

Client's Name & Address GWSSB, Bharuch, Gujarat Construction, company Mahesana, JAMBUSAR 5.90 MLD STP	Report No: GLEPL/241056/2816 Issue Date: 27/02/2026
---	--

Lab ID Code	: GLEPL/230222/WL ₂		
Sample Description	: Waste Water (STP Outlet)	Purpose	: As per Client requirement
Date of Sampling	: Submitted by Client	Sample Collected/Submitted by	: Submitted by Client
Date of Sample Received	: 16/02/2026	Test Parameters	: As per Client requirement
Date of starting Analysis	: 17/02/2026	Quantity/No. of sample	: 2 Lit./02
Date of completion Analysis	: 24/02/2026	Packed/Seal	: Sealed

Result Table

Sr. No.	Test Parameters	Test Method	Unit	Results	Permissible Limit
1	pH @30 °C	IS 3025 (P-11) 1983 (Reaffirmed 2017)	pH Unit	8.9	6.5-9.0
2	Total Suspended Solids	IS 3025 (P-17) 1984 (Reaffirmed 2017)	mg/L	6.8	<10
3	Chemical Oxygen Demand	IS 3025 (P-58) 2006 (Reaffirmed 2017)	mg/L	16.37	<50
4	BOD (5 days at 20°C)	IS 3025 (P-44) 1993 (Reaffirmed 2019)	mg/L	7.7	<10
5	Ammonical Nitrogen	IS 3025 (P-34) 1988 (Reaffirmed 2019)	mg/L	2.1	<5.0
6	Total Phosphorus	IS 3025 (P-31) 1988 (Reaffirmed 2019)	mg/L	BDL	<1.0
7	Total Nitrogen	IS 3025 (P-34) 1988 (Reaffirmed 2019)	mg/L	7.6	<10.0
8	Residual Chlorines	IS 3025 (P-26) 1986 (Reaffirmed 2019)	mg/L	0.3	0.5-1.0
9	Faecal Coliform	APHA & AWWA 23 rd Ed. 9221 E (9-77)	MPN/100mL	76	<230

Note: BDL: Below Detection Limit.
WL: STP Outlet Water

N.A. Khant
Chemist

N.A. Khant
Authorized Signatory
KHANT NILESH

- Notes: (1) The results pertain to tested items only.
(2) This report shall not be reproduced, except in full, without written approval of the laboratory.
(3) Authenticity of this Report could be validated with office copy at Greenleaf Evirotech Pvt. Ltd.
(4) Perishable samples will be destroyed after testing, others after 7 days from the date of issue of the report, unless otherwise agreed with the customer or as required by the applicable regulations.

Recognized by MoEF, Govt. of India, EP Act 1986; NABL accredited; GPCB Schedule II Environment Auditor; OHSAS – 18001:2017 Certified Laboratory.

Greenleaf Evirotech Pvt. Ltd.

304, Kankavati Complex, Singanpor-Cauzway Road, Katargam, Surat – 395004, Tel: 0261-6430044
E-mail: lab@glepl.com | Web: www.glepl.com



**TEST REPORT
(WASTE WATER)**



Customer:	Jayanti Super Construction Pvt. Ltd.	Ref. No.:	25267911
Location:	5.5 MLD STP, Rajpipla, Gujarat, India	Report Date:	25/02/2026
Authorised Person:	Mr. Vimal Bhagat	Analysis Date:	20/02/2026
Sample Description:	Raw Domestic Effluent	Receipt Date:	19/02/2026
Sampling Point:	Stilling Inlet Chamber (T-101)	Receipt Time:	16:30
Sample Type:	Grab	Received By:	Kiran
Field Observation:	-	Collection Date:	18/02/2026
Sampling Method:	-	Collection Time:	12:00
Applicable Standard:	-	Collected By:	Customer

CHEMICAL TESTING: POLLUTION AND ENVIRONMENT

SN	PARAMETERS	UNITS	METHOD REFERENCE	ANLYST	RESULTS	PERMISSIBLE LIMIT
1	pH	-	APHA 4500 H ⁺ B (24th Edition): 2023	Yogita	7.10	-
2	Total Suspended Solids	mg/L	APHA 2540 D (24th Edition): 2023	Yogita	143.00	-
3	Biochemical Oxygen Demand (3d at 27°C as BOD)	mg/L	IS: 3025 (Part 44): 2023	Visha	90.00	-
4	Chemical Oxygen Demand (as COD)	mg/L	APHA 5220 B (24th Edition): 2023	Sukhdevsinh	276.00	-
5	Nitrogen (Kjeldahl Nitrogen as TKN)	mg/L	APHA 4500-N _{org} B (24th Edition): 2023	Vaishnavi	19.60	-
6	Phosphorus (as P)	mg/L	APHA 4500-P C (24th Edition): 2023	Vaishnavi	0.95	-

BIOLOGICAL TESTING: POLLUTION AND ENVIRONMENT

SN	PARAMETERS	UNITS	METHOD REFERENCE	ANLYST	RESULTS	PERMISSIBLE LIMIT
1	Fecal Coliform	MPN/100 mL	APHA 9221 B & E2 (24th Edition): 2023	Visha	>1600	-

Checked By: G. M. Desai (Lab in-charge)  Authorised Signatory: Krishna Desai (Partner) 

Note:

- The above tests are accredited by NABL.
- The results refer only to the tested sample(s) and applicable parameter(s).
- Sample(s) will be destroyed after 10 days from the report date unless otherwise specified.
- This report is not to be reproduced wholly or in part without written approval from Prakruti Environmental Engineers LLP.
- Prakruti Environmental Engineer LLP is not responsible for the authenticity of the sample(s) not collected by our Environmental Laboratory.
- Measurement Uncertainty is not mentioned in the test report and the same can be communicated to the customer on request.

End of Report

Prakruti Environmental Engineers LLP

"PRAKRUTI" 3rd & 4th Floor, Next to Sarsawani Distributory Canal,
On Bil Road, Village Bil, Vadodara - 391 410, Gujarat, India
Contact No.: +91 265 2356171, 9409100037, 9409100067, 9409100073
Email: info@prakruti.co.in • Web: www.prakruti.co.in



**TEST REPORT
(WASTE WATER)**

Customer:	Jayanti Super Construction Pvt. Ltd.	Ref. No.:	25267912
Location:	5.5 MLD STP, Rajpipla, Gujarat, India	Report Date:	25/02/2026
Authorised Person:	Mr. Vimal Bhagat	Analysis Date:	20/02/2026
Sample Description:	Treated Domestic Effluent	Receipt Date:	19/02/2026
Sampling Point:	Outlet Chamber	Receipt Time:	16:30
Sample Type:	Grab	Received By:	Kiran
Field Observation:	-	Collection Date:	18/02/2026
Sampling Method:	-	Collection Time:	12:10
Applicable Standard:	As per Customer	Collected By:	Customer

CHEMICAL TESTING: POLLUTION AND ENVIRONMENT

SN	PARAMETERS	UNITS	METHOD REFERENCE	ANLYST	RESULTS	PERMISSIBLE LIMIT
1	pH	-	APHA 4500 H ⁺ B (24th Edition): 2023	Yogita	7.40	6.5 - 9.0
2	Chlorine (Residual as Cl ₂)	mg/L	APHA 4500-Cl F (24th Edition): 2023	Vaishnavi	0.60	0.5 - 1.0
3	Total Suspended Solids	mg/L	APHA 2540 D (24th Edition): 2023	Yogita	9.00	<10
4	Biochemical Oxygen Demand (3d at 27°C as BOD)	mg/L	IS: 3025 (Part 44): 2023	Visha	BDL (DL:4)	<10
5	Chemical Oxygen Demand (as COD)	mg/L	APHA 5220 B (24th Edition): 2023	Sukhdevsinh	12.20	<50
6	Nitrogen (Total as N)	mg/L	APHA 4500-N C (24th Edition): 2023	Vaishnavi	8.69	<10
7	Nitrogen (Ammonia as NH ₃ -N)	mg/L	APHA 4500-NH ₃ C (24th Edition): 2023	Vaishnavi	2.24	<5
8	Phosphorus (as P)	mg/L	APHA 4500-P C (24th Edition): 2023	Vaishnavi	BDL (DL:0.5)	<1

BIOLOGICAL TESTING: POLLUTION AND ENVIRONMENT

SN	PARAMETERS	UNITS	METHOD REFERENCE	ANLYST	RESULTS	PERMISSIBLE LIMIT
1	Fecal Coliform	MPN/100 mL	APHA 9221 B & E2 (24th Edition): 2023	Visha	<1.8	< 230

Remarks:

1. BDL: Below Detectable Limit, DL: Detectable Limit

Checked By: G. M. Desai (Lab in-charge)

Authorised Signatory: Krishna Desai (Partner)

Note:

- The above tests are accredited by NABL
- The results refer only to the tested sample(s) and applicable parameter(s).
- Sample(s) will be destroyed after 10 days from the report date unless otherwise specified.
- This report is not to be reproduced wholly or in part without written approval from Prakruti Environmental Engineers LLP.
- Prakruti Environmental Engineer LLP is not responsible for the authenticity of the sample(s) not collected by our Environmental Laboratory.
- Measurement Uncertainty is not mentioned in the test report and the same can be communicated to the customer on request.

End of Report

Prakruti Environmental Engineers LLP

"PRAKRUTI" 3rd & 4th Floor, Next to Sarsawani Distributory Canal,
On Bil Road, Village Bil, Vadodara - 391 410, Gujarat, India
Contact No.: +91 265 2356171, 9409100037, 9409100067, 9409100073
Email: info@prakruti.co.in • Web: www.prakruti.co.in



AAGAM ENVIRONMENT PRIVATE LIMITED
 GPCB Recognized Schedule - II Environmental Auditor & NABL Accredited Laboratory

23

TEST REPORT

REPORT NO: AEPL/26-02/0029		ISSUE DATE: 10-02-2026
NAME OF CLIENT: BILIMORA NAGARPALIKA STP		
ADDRESS: Survey No. 395, Nagar Seva Sadan, Near Somnath Temple, Bilimora- 396321, Ta: Gandevi, Dist: Navsari.		
SAMPLE TYPE	: Wastewater	
LOCATION OF SAMPLE	: STP	
DESCRIPTION	: Inlet	
SAMPLING PROTOCOL / STANDARD	: NA	
TYPE OF SAMPLING	: Grab	
SAMPLE COLLECTED/ RECEIVED IN	: Plastic Carboy	
QUANTITY	: 2.0 Ltrs	
SAMPLE CONDITION	: Acceptable	
SAMPLING DATE	: NA	
SAMPLE RECEIPT DATE	: 03-02-2026	
ANALYSIS START DATE	: 03-02-2026	
ANALYSIS END DATE	: 10-02-2026	
TEST CONDITIONS	Temperature (°C): 24.5	Relative Humidity (%):40

RESULTS

SR.NO	PARAMETERS	UNIT	INLET	REFERENCE METHOD
1.	pH @ 25 °C	-	6.85	IS 3025 (Part-11) 2022
2.	Total Suspended Solids	mg/L	539	APHA 24 th Edition 2023 2540-D
3.	Chemical Oxygen Demand	mg/L	442	IS 3025 (Part-58) 2023
4.	BOD (3 Days@ 27 °C)	mg/L	160	IS 3025 (Part-44) 2023
5.	Ammonical Nitrogen	mg/L	43	IS 3025 Part - 34: Sec 4: 2023
6.	Total Nitrogen	mg/L	68	IS 3025 Part - 34: Sec 4: 2023
7.	Total Phosphorus	mg/L	5.6	APHA 24 th Edition 2023 4500 P C
8.	Total Coliform	MPN/100 ml	1470	APHA 24 th Edition 2023 9221 B
9.	Fecal Coliform	MPN/100 ml	996	APHA 24 th Edition 2023 9221 D


 Authorized Signatory
 Hardik Pathak
 Quality Manager

* End of Report *

Information provided by the Customer: N.A.

Note:

1. This report shall not be reproduced in part or full without prior permission of Aagam Environment Pvt Ltd.
2. The results listed herewith are only for the items tested.
3. Sample shall be disposed after 15 days from the date of issue of the report unless agreed with the customer.
4. In case when laboratory is not involved in sampling, the results apply to the samples as received.
5. This report shall not be used for publicity or litigation.
6. Tests performed by External Provider shall be identified/ marked by *** sign.
7. Any additions to, deviations or exclusions from the method shall be identified by ** sign.



AAGAM ENVIRONMENT PRIVATE LIMITED
 GPCB Recognized Schedule - II Environmental Auditor & NABL Accredited Laboratory

20

TEST REPORT

REPORT NO: AEPL/26-01/0030

ISSUE DATE: 10-02-2026

NAME OF CLIENT: BILIMORA NAGARPALIKA STP

ADDRESS: Survey No. 395, Nagar Seva Sadan, Near Somnath Temple, Bilimora- 396321, Ta: Gandevi, Dist: Navsari.

SAMPLE TYPE	: Wastewater
LOCATION OF SAMPLE	: STP
DESCRIPTION	: Outlet
SAMPLING PROTOCOL / STANDARD	: NA
TYPE OF SAMPLING	: NA
SAMPLE COLLECTED/ RECEIVED IN	: Plastic Carboy
QUANTITY	: 2.0 Ltrs
SAMPLE CONDITION	: Acceptable
SAMPLING DATE	: NA
SAMPLE RECEIPT DATE	: 03-02-2026
ANALYSIS START DATE	: 03-02-2026
ANALYSIS END DATE	: 10-02-2026
TEST CONDITIONS	Temperature (°C): 24.5 Relative Humidity (%):40

RESULTS

SR.NO	PARAMETERS	UNIT	OUTLET	REFERENCE METHOD
1.	pH @ 25 °C	-	7.41	IS 3025 (Part-11) 2022
2.	Total Suspended Solids	mg/L	08	APHA 24 th Edition 2023 2540-D
3.	Chemical Oxygen Demand	mg/L	32	IS 3025 (Part-58) 2023
4.	BOD (3 Days@ 27 °C)	mg/L	5.8	IS 3025 (Part-44) 2023
5.	Ammonical Nitrogen	mg/L	3.0	IS 3025 Part - 34: Sec 4: 2023
6.	Total Nitrogen	mg/L	5.8	IS 3025 Part - 34: Sec 4: 2023
7.	Total Phosphorus	mg/L	0.9	APHA 24 th Edition 2023 4500 P C
8.	Residual Chlorine	mg/L	0.6	APHA 24 th Edition 2023 4500 Cl- B
9.	Total Coliform	MPN/100 ml	184	APHA 24 th Edition 2023 9221 B
10.	Fecal Coliform	MPN/100 ml	96	APHA 24 th Edition 2023 9221 D


 Authorized Signatory
 Hardik Pathak
 Quality Manager

* End of Report *

Information provided by the Customer: N.A.

Note:

1. This report shall not be reproduced in part or full without prior permission of Aagam Environment Pvt Ltd.
2. The results listed herewith are only for the items tested.
3. Sample shall be disposed after 15 days from the date of issue of the report unless agreed with the customer.
4. In case when laboratory is not involved in sampling, the results apply to the samples as received.
5. This report shall not be used for publicity or litigation.
6. Tests performed by External Provider shall be identified/marked by "*" sign.
7. Any additions to, deviations or exclusions from the method shall be identified by "" sign.



BHARTI
Enviro Services Pvt. Ltd.
ENVIRONMENTAL ENGINEERING & EMS CONSULTANT

TEST REPORT

Report No.: BES/139-26/1089	T/OPH/07, ISSUE NO.: 02		
Name & address of customer	Date: 21-02-2026		
: M/s. Bilimora Nagarpalika STP Survey No. 395, Nagar Seva Sadan, Near Somnath Temple, Bilimora-396321, Ta: Gandevi, Dist: Navsari.			
GENERAL INFORMATION			
Sampling date	: 15-02-2026	Sample Id. no.	: BES/02-26/W-1089
Sampling collected/ submitted by	: Party	Sampling method	: NA
Type of sampling	: Grab Sampling	Sample type	: Wastewater
Sampling location	: STP Inlet	Sample description	: Untreated Water
Sample quantity received	: 2 Lit.	Sample receipt date	: 16-02-2026
Sample collected in	: Plastic Carboy	Analysis start date	: 16-02-2026
Condition of sample received	: Acceptable	Analysis completion date	: 21-02-2026
Environment condition during sampling	: Satisfactory	Environment condition during test	: 25±2 °C

RESULTS

S.N.	Parameters	Test Method	Results	Unit	GPCB Limit
1.	pH	IS 3025 (Part 11) RA 2022	6.74	--	--
2.	Total Suspended solids	IS 3025 (Part 17) RA 2022	547	mg/L	--
3.	Chemical Oxygen Demand	IS 3025 (Part 58) RA 2023	451	mg/L	--
4.	Bio Chemical Oxygen Demand (27 °C for 3 Days)	IS 3025 (Part 44) RA 2023	166	mg/L	--
5.	Ammonical Nitrogen as NH ₄ -N	IS 3025 (Part 34) RA 2019	48	mg/L	--
6.	Total Nitrogen	IS 3025 (Part 34) RA 2019 (Spectrophotometric Method)	75	mg/L	--
7.	Total Phosphorous	IS 3025 (Part 31/Sec 1):2022	5.8	mg/L	--
8.	Total Coliform	APHA 24 th Edition 2023 9221 B	1458	MPN/100 ml	--
9.	Fecal Coliform	APHA 24 th Edition 2023 9221 D	982	MPN/100 ml	--

Remarks : B.D.L.=Below Detection Limit; D.L.=Detection Limit; N.D.=Not Detectable;

Reviewed By : *Sunita*
Name : Sunita Mochi
Designation : Sr. Chemist

Authorized By : *Chandalekha*
Name : Chandalekha Bharti
Designation : Director

****END OF REPORT****

This Report is issued under the following terms & Condition:

- This report shall not be reproduced except in full without approval of the laboratory (Bharti Enviro Services Pvt. Ltd.) can provide assurance that parts of a report are not taken out of context.
- The results listed herewith are only for the item.
- Sample shall be disposed after 15 days from the date of issue of the report unless agreed with the customer.
- In case when laboratory is not involved in sampling, the results apply to the sample are received.
- This report should not be used for publicity or litigation.

Sustainable Development is our Motto...

A 304, Ganesh Glory 11, Nr. BSNL Office, Jagatpur Road, Off SG Highway, Nr. Nirma University, Ahmedabad, Gujarat-382481.
(079) 4900 0655 | (+91) 90168 62780 | info.bhartienviro@gmail.com / bhartienviro@yahoo.com | bhartienviro.com



ISO 9001:2015
ISO 14001:2015


TEST REPORT

Report No.:	BES/139-26/1090	FIGURE 107, ISSUE NO.: 02
Name & address of customer	M/s. Bilimora Nagarpalika STP Survey No. 395, Nagar Seva Sadan, Near Somnath Temple, Bilimora-396321, Ta: Gandevi, Dist: Navsari.	Date: 21-02-2026
GENERAL INFORMATION		
Sampling date	: 15-02-2026	Sample Id. no.
Sampling collected/ submitted by	: Party	: BES/02-26/W-1090
Type of sampling	: Grab Sampling	Sampling method
Sampling location	: STP Outlet	: NA
Sample quantity received	: 2 Lit.	Sample type
Sample collected in	: Plastic Carboy	: Wastewater
Condition of sample received	: Acceptable	Sample description
Environment condition during sampling	: Satisfactory	: Treated Water
		Sample receipt date
		: 16-02-2026
		Analysis start date
		: 16-02-2026
		Analysis completion date
		: 21-02-2026
		Environment condition during test
		: 25±2 °C

S.N.	Parameters	RESULTS			
		Test Method	Results	Unit	GPCB Limit
1.	pH				
2.	Total Suspended solids	IS 3025 (Part 11) RA 2022	7.35	--	--
3.	Chemical Oxygen Demand	IS 3025 (Part 17) RA 2022	10	mg/L	--
4.	Bio Chemical Oxygen Demand (27 °C for 3 Days)	IS 3025 (Part 58) RA 2023	35	mg/L	--
5.	Ammoniacal Nitrogen as NH ₄ -N	IS 3025 (Part 44) RA 2023	6.2	mg/L	--
6.	Total Nitrogen	IS 3025 (Part 34) RA 2019	2.5	mg/L	--
7.	Total Phosphorous	(Spectrophotometric Method)	8.7	mg/L	--
8.	Residual Chlorine	IS 3025 (Part 31/Sec 1): 2022	0.67	mg/L	--
9.	Total Coliform	IS 3025 (Part 26) RA 2021	0.5	mg/L	--
10.	Fecal Coliform	APHA 24 th Edition 2023 9221 B	167	MPN/100 ml	--
		APHA 24 th Edition 2023 9221 D	91	MPN/100 ml	--

Remarks : B.D.L. = Below Detection Limit; D.L. = Detection Limit; N.D. = Not Detectable;

Reviewed By : *Sunita*
 Name : Sunita Mochi
 Designation : Sr. Chemist

Authorized By : *Chandralekha*
 Name : Chandralekha Bharti
 Designation : Director

****END OF REPORT****

This Report is issued under the following terms & Condition:

- This report shall not be reproduced except in full without approval of the laboratory (Bharti Enviro Services Pvt. Ltd.) can provide assurance that parts of a report are not taken out of context.
- The results listed herewith are only for the item.
- Sample shall be disposed after 15 days from the date of issue of the report unless agreed with the customer.
- In case when laboratory is not involved in sampling, the results apply to the sample are received.
- This report should not be used for publicity or litigation.

Sustainable Development is our Motto...

A 304, Ganesh Glory 11, Nr. BSNL Office, Jagatpur Road, Off SG Highway, Nr. Nirma University, Ahmedabad, Gujarat-382481.
 (079) 4900 0655 | (+91) 90168 62780 | info.bhartienviro@gmail.com / bhartienviro@yahoo.com | bhartienviro.com



ISO 9001:2015
 ISO 14001:2015

ISO 9001:2015, 14001:2015 Certified | ISO 9001:2015 Environmental Auditing (Sub. III)

TEST REPORT
Water


Report No	: ACS/TL/WT/26020519-1	Report Date	: 12/02/2026
Sample ID	: 26020519/1	Dated	: 05/02/2026
Letter Reference No.	: Nil		
Name of Client	: Deputy Executive Engineer, G. W. S. S. B., Surat.		
Name of Work	: Sewage Treatment Plant Bardoli.		
Name of Agency	: Krishna Construction Company		
Sample Condition	: Acceptable	Date of Receipt	: 05/02/2026
Temperature/Humidity	: 25-29 °C/ Humidity < 50%	Date of Test Start	: 06/02/2026
Material Identification	: Inlet (1 L Bottle)	Date of Test Completed	: 12/02/2026


RESULT TABLE

Sr. No.	Characteristic	Test Method	Result	Regulatory Limit
1	pH @27 deg.	APHA 23rd Edition 4500 B: 2017	8.86	***
2	Total Suspended Solids (mg/l)	APHA 23rd Edition 2540 D: 2017	122.90	***
3	Total Phosphorus (mg/l)	APHA 23rd Edition 4500 P D: 2017	6.82	***
4	Chemical Oxygen Demand (mg/l)	IS 3025 - Part 58 : 2006	290.74	***
5	Biochemical Oxygen Demand (mg/l)	IS 3025 - Part 44 : 1993	196.11	***
6	Total Kjeldhal Nitrogen (mg/l)	APHA 23rd Edition 4500 NH3 C/ Norg B: 2017	28.95	***
7	Total Coliforms (MNP/100 ml)	IS 1622	128.12	***

#BDL=Below Detection Limit

- Note:
1. The report shall not be reproduced, except in full, without the written approval of the laboratory.
 2. The results indicated above are based on the tests carried out on the samples received in the laboratory.
 3. Reports are issued with specific understanding that Aakar Consultancy Services will not be in any case involved in actions following the interpretation of test results.
 4. The reports are not supposed to be used for any kind of publicity.
 5. Test has been performed by third party laboratory


 Reviewed By
 Engineer


 Authorized Signatory
 Technical Manager

** End of Test Report **

Page 1 of 1

TEST REPORT
Water


Report No	: ACS/TL/WT/26020519-2	Report Date	: 12/02/2026
Sample ID	: 26020519/2	Dated	: 05/02/2026
Letter Reference No.	: Nil		
Name of Client	: Deputy Executive Engineer, G. W. S. S. B., Surat.		
Name of Work	: Sewage Treatment Plant Bardoli.		
Name of Agency	: Krishna Construction Company		
Sample Condition	: Acceptable	Date of Receipt	: 05/02/2026
Temperature/Humidity	: 25-29 °C/ Humidity < 50%	Date of Test Start	: 06/02/2026
Material Identification	: Outlet (1 L Bottle)	Date of Test Completed	: 12/02/2026

RESULT TABLE


Sr.	Characteristic	Test Method	Result	Regulatory Limit
1	pH @27 deg	APHA 23rd Edition 4500 B: 2017	7.52	6.5-9
2	Total Suspended Solids(mg/l)	APHA 23rd Edition 2540 D: 2017	8.32	<10
3	Total Phosphorus(mg/l)	APHA 23rd Edition 4500 P D: 2017	0.21	<1
4	Chemical Oxygen Demand (mg/l)	IS 3025 - Part 58 : 2006	34.02	<50
5	Biochemical Oxygen Demand (mg/l)	IS 3025 - Part 44 : 1993	8.29	<10
6	Ammonical Nitrogen (mg/l)	APHA 23rd Edition 4500 NH3 C: 2017	1.75	<5
7	Total Nitrogen (mg/l)	APHA 23rd Edition 4500 NH3 C/ Norg B/NO3 B/NO2 B:2017	6.21	<10
8	Total Residual Chlorine	APHA 23rd Edition 4500CL- B: 2017	0.67	1.0
9	Fecal Coliforms (MNP/100 ml)	IS 1622	11	<100

#BDL=Below Detection Limit

- Note:
1. The report shall not be reproduced, except in full, without the written approval of the laboratory.
 2. The results indicated above are based on the tests carried out on the samples received in the laboratory.
 3. Reports are issued with specific understanding that Aakar Consultancy Services will not be in any case involved in actions following the interpretation of test results.
 4. The reports are not supposed to be used for any kind of publicity.
 5. Test has been performed by third party laboratory


 Reviewed By
 Engineer


** End of Test Report **


 Authorized Signatory
 Technical Manager

Page 1 of 1

TEST REPORT
Water


Report No	: ACS/TL/WT/26021786-1	Report Date	: 23/02/2026
Sample ID	: 26021786/1	Dated	: 17/02/2026
Letter Reference No.	: Nil		
Name of Client	: Deputy Executive Engineer, G. W. S. S. B., Surat.		
Name of Work	: Sewage Treatment Plant Bardoli.		
Name of Agency	: Krishna Construction Company		
Sample Condition	: Acceptable	Date of Receipt	: 17/02/2026
Temperature/Humidity	: 25-29 °C/ Humidity < 50%	Date of Test Start	: 17/02/2026
Material Identification	: Inlet (1 L. Bottle)	Date of Test Completed	: 23/02/2026

RESULT TABLE


Sr. No.	Characteristic	Test Method	Result	Regulatory Limit
1	pH @27 deg.	APHA 23rd Edition 4500 B: 2017	8.79	***
2	Total Suspended Solids (mg/l)	APHA 23rd Edition 2540 D: 2017	121.76	***
3	Total Phosphorus (mg/l)	APHA 23rd Edition 4500 P D: 2017	6.52	***
4	Chemical Oxygen Demand (mg/l)	IS 3025 - Part 58 : 2006	289.24	***
5	Biochemical Oxygen Demand (mg/l)	IS 3025 - Part 44 : 1993	195.63	***
6	Total Kjeldhal Nitrogen (mg/l)	APHA 23rd Edition 4500 NH3 C/ Norg B: 2017	29.41	***
7	Total Coliforms (MNP/100 ml)	IS 1622	129.06	***

#BDL=Below Detection Limit

- Note:**
1. The report shall not be reproduced, except in full, without the written approval of the laboratory.
 2. The results indicated above are based on the tests carried out on the samples received in the laboratory.
 3. Reports are issued with specific understanding that Aakar Consultancy Services will not be in any case involved in actions following the interpretation of test results.
 4. The reports are not supposed to be used for any kind of publicity.
 5. Test has been performed by third party laboratory


 Reviewed By
 Engineer


** End of Test Report **


 Authorized Signatory
 Technical Manager

Page 1 of 1

TEST REPORT
Water


Report No	: ACS/TL/WT/26021786-2	Report Date	: 23/02/2026
Sample ID	: 26021786/2		
Letter Reference No.	: Nil	Dated	: 17/02/2026
Name of Client	: Deputy Executive Engineer, G. W. S. S. B., Surat.		
Name of Work	: Sewage Treatment Plant Bardoli.		
Name of Agency	: Krishna Construction Company		
Sample Condition	: Acceptable	Date of Receipt	: 17/02/2026
Temperature/Humidity	: 25-29 °C/ Humidity < 50%	Date of Test Start	: 17/02/2026
Material Identification	: Outlet (1 L Bottle)	Date of Test Completed	: 23/02/2026


RESULT TABLE

Sr. No.	Characteristic	Test Method	Result	Regulatory Limit
1	pH @27 deg	APHA 23rd Edition 4500 B: 2017	7.49	6.5-9
2	Total Suspended Solids(mg/l)	APHA 23rd Edition 2540 D: 2017	8.12	<10
3	Total Phosphorus(mg/l)	APHA 23rd Edition 4500 P D: 2017	0.23	<1
4	Chemical Oxygen Demand (mg/l)	IS 3025 - Part 58 : 2006	33.86	<50
5	Biochemical Oxygen Demand (mg/l)	IS 3025 - Part 44 : 1993	8.26	<10
6	Ammonical Nitrogen (mg/l)	APHA 23rd Edition 4500 NH3 C: 2017	1.39	<5
7	Total Nitrogen (mg/l)	APHA 23rd Edition 4500 NH3 C/ Norg B/NO3 B/NO2 B:2017	6.36	<10
8	Total Residual Chlorine	APHA 23rd Edition 4500CL- B: 2017	0.58	1.0
9	Fecal Coliforms (MNP/100 ml)	IS 1622	13	<100

#BDL=Below Detection Limit

- Note:
1. The report shall not be reproduced, except in full, without the written approval of the laboratory.
 2. The results indicated above are based on the tests carried out on the samples received in the laboratory.
 3. Reports are issued with specific understanding that Aakar Consultancy Services will not be in any case involved in actions following the interpretation of test results.
 4. The reports are not supposed to be used for any kind of publicity.
 5. Test has been performed by third party laboratory


 Reviewed By
 Engineer


 Authorized Signatory
 Technical Manager

** End of Test Report **

Page 1 of 1



Climate Care

Environmental Services

TEST REPORT

Client Name - Deputy Executive Engineer Sub division, Mandavi		Test	: Waste Water
Agency Name - Vishal Builders		Test Report No.:	: CCES/20260207/01
Sampling By	: Party	Issue Date:	: 07/02/2026
Date of Sampling	: 04/02/2026	Location of Sampling	: 3.5 MLD STP Mandvi (Sewage Inlet)
Date of starting	: 05/02/2026	Date of Sample Received	: 04/02/2026
Date of Completion	: 07/02/2026	Quantity of sample	: 5 Litre
		Test results / Sampling Methods	: As per table

RESULTS

Sr. No.	Test Parameters	Unit	Results	Test /Sampling Methods
1	pH	-	7.10	IS: 3025 (Part -11) 1983
2	Suspended Solids	mg/L	122	IS: 3025 (Part -17) 1984
3	Chemical Oxygen Demand	mg/L	211	IS:3025 (Part- 50) 2006
4	Bio-chemical Oxygen Demand, (3 Days at 27° C)	mg/L	64	IS:3025(Part -44) 1993
5	Total Phosphorus	mg/L	3.60	APHA 23rd Edition 4500 P D: 2017
6	Total Nitrogen	mg/L	11.74	APHA 23rd Edition 4500 NH3 C/Norg B/ NO3 B/ NO2 B: 2017
7	Fecal Coliform (FC)	MPN/100 ml	2017	APHA 4500NH ₃ B & C (23 rd d)

Authorised by:

Prepared by:

- Note:
- (1) The results pertain to tested items only.
 - (2) This report shall not be reproduced, except in full, without written approval of the laboratory.
 - (3) Authenticity of this Report could be validated with office copy at Climate Care Environmental Services.
 - (4) Perishable samples shall be destroyed after testing, others after 7 days from the date of issue of the report, unless otherwise agreed with the customer or as required by the applicable regulations.

-----End of Test Report-----

GPCB (Govt. of Gujarat) Recognized Schedule -2 No: GPCB/EAC /SCH-II/107/850557/07/01/2025
Environmental Auditor (Laboratory)

Chief Officer
Mandvi Nagarpalika,
Dist. Surat.



Climate Care

Environmental Services

TEST REPORT

Client Name - Deputy Executive Engineer Sub division, Mandavi		Test	: Waste Water
Agency Name - Vishal Builders		Test Report No.:	: CCES/20260207/01
Sampling By : Party		Issue Date:	: 07/02/2026
Date of Sampling	: 04/02/2026	Location of Sampling	: 3.5 MLD STP Mandvi (Sewage Outlet)
Date of starting	: 05/02/2026	Date of Sample Received	: 04/02/2026
Date of Completion	: 07/02/2026	Quantity of sample	: 5 Litre
		Test results / Sampling Methods	: As per table

RESULTS

Sr. No.	Test Parameters	Unit	Results	Test /Sampling Methods
1	pH	-	8.34	IS: 3025 (Part -11) 1983
2	Suspended Solids	mg/L	12	IS: 3025 (Part -17) 1984
3	Chemical Oxygen Demand	mg/L	47	IS:3025 (Part- 58) 2006
4	Bio-chemical Oxygen Demand. (3 Days at 27° C)	mg/L	13	IS:3025(Part -44) 1993
5	Total Phosphorus	mg/L	<1	APHA 23rd Edition 4500 P D: 2017
6	Total Nitrogen	mg/L	7.70	APHA 23rd Edition 4500 NH3 C/Norg B/ NO3 B/ NO2 B: 2017
7	Fecal Coliform (FC)	MPN/100 ml	188	APHA 4500NH ₃ B & C (23 rd d)
8	Total Coliform	MPN/100 mL	521	APHA 23rd Edition 9221 B

Authorised by:

Prepared by:

- Notes:
- (1) The results pertain to tested items only.
 - (2) This report shall not be reproduced, except in full, without written approval of the laboratory.
 - (3) Authenticity of this Report could be validated with office copy at Climate Care Environmental Services.
 - (4) Perishable samples will be destroyed after testing, others after 7 days from the date of issue of the report, unless otherwise agreed with the customer or as required by the applicable regulations.

-----End of Test Report-----

GPCB (Govt. of Gujarat) Recognized Schedule -2
Environmental Auditor (Laboratory)

No: GPCB/EAC /SCH-II/107/850557/07/01/2025

Chief Officer
Mandvi Nagarpalika,
Dist. Surat.



33

TEST REPORT

Client Name - Deputy Executive Engineer Sub division, Mandavi		Test	: Waste Water
Agency Name - Vishal Builders		Test Report No.:	: CCES/20260228/01
Sampling By : Party		Issue Date:	: 28/02/2026
Date of Sampling	: 24/02/2026	Location of Sampling	: 3.5 MLD STP Mandvi (Sewage Outlet)
Date of starting	: 25/02/2026	Date of Sample Received	: 24/02/2026
Date of Completion	: 28/02/2026	Quantity of sample	: 5 Litre
		Test results / Sampling Methods	: As per table

RESULTS

Sr. No.	Test Parameters	Unit	Results	Test /Sampling Methods
1	pH	-	7.86	IS: 3025 (Part -11) 1983
2	Suspended Solids	mg/L	14	IS: 3025 (Part -17) 1984
3	Chemical Oxygen Demand	mg/L	55	IS:3025 (Part- 58) 2006
4	Bio-chemical Oxygen Demand, (3 Days at 27° C)	mg/L	16	IS:3025(Part -44) 1993
5	Total Phosphorus	mg/L	< 1	APHA 23rd Edition 4500 P D: 2017
6	Total Nitrogen	mg/L	8.12	APHA 23rd Edition 4500 NH3 C/Norg B/ NO3 B/ NO2 B: 2017
7	Fecal Coliform (FC)	MPN/100 ml	215	APHA 4500NH ₃ B &C. (23 rd d)
8	Total Coliform	MPN/100 mL	523	APHA 23rd Edition 9221 B

Authorised by:

Prepared by:

- Notes:
- (1) The results pertain to tested items only.
 - (2) This report shall not be reproduced, except in full, without written approval of the laboratory.
 - (3) Authenticity of this Report could be validated with office copy at Climate Care Environmental Services.
 - (4) Perishable samples will be destroyed after testing, others after 7 days from the date of issue of the report, unless otherwise agreed with the customer or as required by the applicable regulations.

-----End of Test Report-----

GPCB (Govt. of Gujarat) Recognized Schedule -2 No: GPCB/EAC/SCH-II/107/850557/07/01/2025
Environmental Auditor (Laboratory)



Climate Care

Environmental Services

Best Solution with Better Technology

ISO 9001:2015 Certified Organization

34

TEST REPORT

Client Name - Deputy Executive Engineer Sub division, Mandavi		Test	: Waste Water
Agency Name - Vishal Builders		Test Report No.:	: CCES/20260228/01
Sampling By : Party		Issue Date:	: 28/02/2026
Date of Sampling	: 24/02/2026	Location of Sampling	: 3.5 MLD STP Mandvi (Sewage Inlet)
Date of starting	: 25/02/2026	Date of Sample Received	: 24/02/2026
Date of Completion	: 28/02/2026	Quantity of sample	: 5 Litre
		Test results / Sampling Methods	: As per table

RESULTS

Sr. No.	Test Parameters	Unit	Results	Test /Sampling Methods
1	pH	-	7.26	IS: 3025 (Part -11) 1983
2	Suspended Solids	mg/L	140	IS: 3025 (Part -17) 1984
3	Chemical Oxygen Demand	mg/L	202	IS:3025 (Part- 58) 2006
4	Bio-chemical Oxygen Demand. (3 Days at 27° C)	mg/L	67	IS:3025(Part -44) 1993
5	Total Phosphorus	mg/L	3.75	APHA 23rd Edition 4500 P D: 2017
6	Total Nitrogen	mg/L	12.42	APHA 23rd Edition 4500 NH3 C/Norg B/ NO3 B/ NO2 B: 2017
7	Fecal Coliform (FC)	MPN/100 ml	2065	APHA 4500NH ₃ B & C (23 rd d)

Authorised by:

Prepared by:

- Notes:
- (1) The results pertain to tested items only.
 - (2) This report shall not be reproduced, except in full, without written approval of the laboratory.
 - (3) Authenticity of this Report could be validated with office copy at Climate Care Environmental Services.
 - (4) Perishable samples will be destroyed after testing, others after 7 days from the date of issue of the report, unless otherwise agreed with the customer or as required by the applicable regulations.

-----End of Test Report-----

GPCB (Govt. of Gujarat) Recognized Schedule -2 No: GPCB/EAC./SCH-II/107/850557/07/01/2025
Environmental Auditor (Laboratory)

ADITYA ENVIRONGPCB approved schedule II auditor & ISO 17025 : 2017 NABL Accredited
ISO 9001:2015 certified

Office 1 : Plot No. 190, 4th Floor, Aum Auto Hub, Vibrant Business Park, Opp. UPL Company Ltd., GIDC, Vapi - 396195. Tal - Vapi, Dist -Valsad, Gujarat.
Mobile : +91 99250 44987, +91 91737 93913 | E-mail: sejal@adityainfra.com, sejalmapate145@gmail.com | Web: www.adityaenviron.com

ISO/IEC 17025:2017 NABL Accredited Company	Gujarat Pollution Control Board (Govt. of Gujarat) Authorized Environmental Auditor (Schedule -II)	ISO 9001: 2015 Certified Company
--	--	----------------------------------

TEST REPORT

Sample ID. No. (LAB)	AE/LAB-B/02/26/1819	Issue Date :	14/02/2026
		Environmental Condition:	25±5°C
Customer's Name & Address	M/S EFFWA INFRA & RESEARCH PVT.LTD. 4.5 MLD Sewage Treatment Plant, Opposite Songadh fort, Songadh Vyara.		

Description of Sample	STP Inlet (Waste Water)	Qty./No. of Samples	2.0 Lit.
Sampling Date	12/02/2026	Sample Received Date	12/02/2026
Date of Starting of Test	12/02/2026	Date of Completion of Test	14/02/2026
Appearance of Sample	Colourless Liquid	Sampling Procedure	Grab

TEST RESULTS

Sr. No.	Parameters	Test Method	Units	Results	Standard Limit
PHYSICAL QUALITY					
1.	pH @ 25 ° C	IS 3025(Part 11) :2022	--	7.28	--
CHEMICAL QUALITY					
2.	Total Suspended Solids	IS 3025(Part 17):2022	mg/l	86.00	--
3.	Chemical Oxygen Demand	IS 3025(Part 58) :2023	mg/l	212.56	--
4.	Biochemical Oxygen Demand	IS 3025(Part 44) :2019	mg/l	68.80	--
5.	Total Phosphorous	IS 3025(Part 31) :2021	mg/l	4.68	--
6.	Ammonical Nitrogen	APHA 23 rd Ed 4500 NH ₃ 2017	mg/l	18.00	--
MICROBIOLOGICAL QUALITY					
7.	Fecal Coliform	IS 1622:2003	MPN/100 ml	2048.00	--

*BDL: Below Detection Limit ND: Not Detected

Note: This report is subject to terms & conditions mentioned overleaf

End of Report

Authorized By

(Technical Manager)

ADITYA ENVIRONGPCB approved schedule II auditor & ISO 17025 : 2017 NABL Accredited
ISO 9001:2015 certified

Office 1 : Plot No. 190, 4th Floor, Aum Auto Hub, Vibrant Business Park, Opp. UPL Company Ltd., GIDC, Vapi - 396195. Tal - Vapi, Dist -Valsad, Gujarat.
Mobile : +91 99250 44987, +91 91737 93913 | E-mail: sejal@adityainfra.com, sejalmapate145@gmail.com | Web: www.adityaenviron.com

ISO/IEC 17025:2017 NABL Accredited Company	Gujarat Pollution Control Board (Govt. of Gujarat) Authorized Environmental Auditor (Schedule -II)	ISO 9001: 2015 Certified Company
--	---	----------------------------------

TEST REPORT

Sample ID. No. (LAB)	AE/LAB-B/02/26/1820	Issue Date :	14/02/2026
		Environmental Condition:	25±5°C
Customer's Name & Address	M/S EFFWA INFRA & RESEARCH PVT.LTD. 4.5 MLD Sewage Treatment Plant, Opposite Songadh fort, Songadh Vyara.		

Description of Sample	STP Outlet (Waste Water)	Qty./No. of Samples	2.0 Lit.
Sampling Date	12/02/2026	Sample Received Date	12/02/2026
Date of Starting of Test	12/02/2026	Date of Completion of Test	14/02/2026
Appearance of Sample	Colourless Liquid	Sampling Procedure	Grab

TEST RESULTS

Sr. No.	Parameters	Test Method	Units	Results	Standard Limit
PHYSICAL QUALITY					
1.	pH @ 25 ° C	IS 3025(Part 11) :2022	--	7.77	6.5-9.0
CHEMICAL QUALITY					
2.	Total Suspended Solids	IS 3025(Part 17):2022	mg/l	6.00	NMT 10
3.	Chemical Oxygen Demand	IS 3025(Part 58) :2023	mg/l	32.54	NMT 50
4.	Biochemical Oxygen Demand	IS 3025(Part 44) :2019	mg/l	8.82	NMT 10
5.	Total Phosphorous	IS 3025(Part 31) :2021	mg/l	0.40	NMT 1
6.	Ammonical Nitrogen	APHA 23 rd Ed 4500 NH ₃ 2017	mg/l	2.68	NMT 5
MICROBIOLOGICAL QUALITY					
7.	Fecal Coliform	IS 1622:2003	MPN/100 ml	172.00	NMT 230

*BDL: Below Detection Limit ND: Not Detected

Note: This report is subject to terms & conditions mentioned overleaf

End of Report

Authorized By

(Technical Manager)



Shreepad Eco Solutions

GPCB Regd. Environment Auditor (Sch II) | Environmental Consultants & Engineers

Test Report

Customer: M/S EFFWA INFRA & RESEARCH PVT.LTD.	Test Report No. : SES/26021403W
Address: 4.5 MLD STP, Opposite Songadh fort, Songadh Vyara.	Issue Date : 24-Feb-2026
Contact:	Customer's Ref. : Telephonic

Sample Description : Waste-Water	Sample Quantity : 2 L
Sampling by : Customer	No. of Samples : 1
Sample Receipt Dt. : 14-Feb-2026	Purpose/Protocol : Analysis
Packaging/ Seal : Sealed	Lab ID : 26021403W
Analysis began : 14-Feb-2026	Test Parameters : As per table
Sample identity : Raw Effluent	Analysis completed : 22-Feb-2026

Result Table

No.	Parameters	Unit	Test Method	Permissible Limit	Result
1	pH	pH Unit	IS 3025 (Part 11)	--	7.95
2	Total Suspended Solids (TSS)	mg/L	IS 3025 (Part 15)	--	214
3	Chemical Oxygen Demand (COD)	mg/L	IS 3025 (Part 58)	--	780
4	Biochemical Oxygen Demand (BOD)	mg/L	IS 3025 (Part 44)	--	278
5	Total Phosphorus	mg/L	IS 3025 (Part 31)	--	3.45
6	Ammoniacal Nitrogen	mg/L	IS 3025 (Part 34)	--	32
7	Fecal Coliform	MPN/100 ml	IS 1622	--	1692

As Per Details provided by Customer

S. R. Rana

Mr. Shashank Rana
Sr. Chemist



Mr. Padmnabh P.
Manager (Q)

Terms & Conditions:

- Reports can only be produced for legal procedure with the prior consent of the Laboratory
- Reports are subjected to the state of sample received in the laboratory
- Laboratory is not responsible if report is tampered for any reason
- Subject to Navsari Jurisdiction

-: End of Test Report :-



Shreepad Eco Solutions

GPCB Regd. Environment Auditor (Sch II) | Environmental Consultants & Engineers

Test Report

Customer: M/S EFFWA INFRA & RESEARCH PVT.LTD.	Test Report No. : SES/26021404W
Address: 4.5 MLD STP, Opposite Songadh fort, Songadh Vyara.	Issue Date : 24-Feb-2026
Contact:	Customer's Ref. : Telephonic

Sample Description : Waste-Water	Sample Quantity : 2 L
Sampling by : Customer	No. of Samples : 1
Sample Receipt Dt. : 14-Feb-2026	Purpose/Protocol : Analysis
Packaging/ Seal : Sealed	Lab ID : 26021404W
Analysis began : 14-Feb-2026	Test Parameters : As per table
Sample identity : Treated Effluent	Analysis completed : 22-Feb-2026

Result Table

No.	Parameters	Unit	Test Method	Permissible Limit	Result
1	pH	pH Unit	IS 3025 (Part 11)	6.5 to 8.5	7.48
2	Total Suspended Solids (TSS)	mg/L	IS 3025 (Part 15)	NMT 10	8
3	Chemical Oxygen Demand (COD)	mg/L	IS 3025 (Part 58)	NMT 50	34.60
4	Biochemical Oxygen Demand (BOD)	mg/L	IS 3025 (Part 44)	NMT 10	8.40
5	Total Phosphorus	mg/L	IS 3025 (Part 31)	NMT 1	0.58
6	Ammoniacal Nitrogen	mg/L	IS 3025 (Part 34)	NMT 5	3.25
7	Fecal Coliform	MPN/100 ml	IS 1622	NMT 100	-ND-

As Per Details provided by Customer

S. R. Rana

Mr. Shashank Rana
Sr. Chemist



Mr. Padmnabh P.
Manager (Q)

Terms & Conditions:

- Reports can only be produced for legal procedure with the prior consent of the Laboratory
- Reports are subjected to the state of sample received in the laboratory
- Laboratory is not responsible if report is tampered for any reason
- Subject to Navsari Jurisdiction

-: End of Test Report :-

Registered Address: 6, Narayan Park, Behind Adarsh Park Society, Chhapra Road, Navsari- 396445
Office Address: 103-104, City Point, Nr. Ashapuri Temple, Navsari - Jalalpore Rd, Navsari- 396445
Mobile: +91 9106832201 | +91 8141145192 Email: shreepad.eco@gmail.com GST: 24AERFS5890P1ZW



ENPRO Enviro Tech and Engineers Pvt. Ltd.

Environmental Testing Laboratory

Plot No. D/29/16, Road No. 17, Hojiwala Industrial Estate, Gate No. 3,
Sachin-Palsana Road, Sachin, Surat - 394 230. Gujarat, INDIA.
Lab Ph. : +91-95128 74754 E-mail : lab@enpro.co.in



Test Report


TC - 5885

Format No : QR/7.8/01	Test Report No : TC588526000001115F	Issue Date : 07-02-2026
ULR No : TC588526000001115F	Discipline : Biological	Group : Environment & Pollution

Customer's Name & Address : Phoenix Projects Pvt. Ltd. Nagarpalika Dharampur	
Description of Sample : STP Inlet	
Sampling By : Sample Sent By Party	Qty / Nos of Sample : 2 L / 1 No.
Date of Sampling : -	Packing / Seal : Sealed
Sample Received Date : 04-02-2026	Protocol / Purpose : Waste Water Analysis
Date of Starting of Test : 04-02-2026	Date of Completion : 07-02-2026
Sampling Method : N.A	Sample ID : 0226/WW01115

RESULT TABLE

S.NO.	TEST PARAMETER	UNIT	RESULT	LIMIT	METHOD REFERENCE
1	Fecal Coliform	MPN/100 ml	140	-	IS:1622-1981(Reaffirmed 2019)


CHECKED BY
Divya Gupta

ENPRO Enviro Tech and Engineers Pvt. Ltd.(ETL)


REVIEWED AND AUTHORISED BY
Megha Gowda (Dy. TM)

Note 1 : This Report is subject to terms & conditions mentioned overleaf.
Note 2 : Details about MU and Decision Rules are available with laboratory and same will be provided upon request.

*** End of Report ***

Page 1 of 1





ENPRO Enviro Tech and Engineers Pvt. Ltd.

Environmental Testing Laboratory

Plot No. D/29/16, Road No. 17, Hojiwala Industrial Estate, Gate No. 3,
Sachin-Palsana Road, Sachin, Surat - 394 230, Gujarat, INDIA.
Lab Ph. : +91-95128 74754 E-mail : lab@enpro.co.in



Test Report


TC - 5885

Format No : QR/7.8/01	Test Report No : TC588526000001115F	Issue Date : 07-02-2026
ULR No : TC588526000001115F	Discipline : Chemical	Group : Pollution & Environment


Customer's Name & Address : Phoenix Projects Pvt. Ltd. Nagarpalika Dharampur		
Description of Sample : STP Inlet		
Sampling By : Sample Sent By Party	Qty / Nos of Sample : 2 L / 1 No.	
Date of Sampling : -	Packing / Seal : Sealed	
Sample Received Date : 04-02-2026	Protocol / Purpose : Waste Water Analysis	
Date of Starting of Test : 04-02-2026	Date of Completion : 07-02-2026	
Sampling Method : N.A	Sample ID : 0226/WW01115	

RESULT TABLE

S.NO.	TEST PARAMETER	UNIT	RESULT	LIMIT	METHOD REFERENCE
1	pH	--	7.45(at 25.5°C)	-	IS 3025 (Part-11):2022
2	Biochemical Oxygen Demand (3 Days at 27°C)	mg/L	182	-	IS 3025 (Part 44) : 2023
3	Chemical Oxygen Demand (COD)	mg/L	627	-	IS 3025 (Part 58) : 2023
4	Ammonical Nitrogen (as NH ₄ -N)	mg/L	15.5	-	IS 3025 (Part 34):1988 Clause 2
5	Total Suspended Solids	mg/L	218	-	IS 3025 (Part 17) : 2022
6	Chlorine Residual (as RfCl)	mg/L	2.2	-	IS 3025 (Part-26):2021 Clause 5
7	Phosphate (as PO ₄)	mg/L	15.1	-	IS 3025 (Part 37Sec 1) : 2022 Clause 5


CHECKED BY
Hiral Pavar

ENPRO Enviro Tech and Engineers Pvt. Ltd.(ETL)


REVIEWED AND AUTHORISED BY
Chintan Desai (TM)

Note 1 : This Report is subject to terms & conditions mentioned overleaf.

Note 2 : Details about MU and Decision Rules are available with laboratory and same will be provided upon request.

*** End of Report ***

Page 1 of 1





ENPRO Enviro Tech and Engineers Pvt. Ltd.

Environmental Testing Laboratory

Plot No. D/29/16, Road No. 17, Hojiwala Industrial Estate, Gate No. 3,
Sachin-Palsana Road, Sachin, Surat - 394 230. Gujarat, INDIA.
Lab Ph. : +91-95128 74754 E-mail : lab@enpro.co.in

Test Report


Format No : QR/7.8/01	Test Report No : ETL/000530/26-	Issue Date : 07-02-2026
ULR No : N.A.	Discipline : Chemical	Group : Pollution & Environment

Customer's Name & Address : **Phoenix Projects Pvt. Ltd.**
Nagarpalika Dharampur


Description of Sample : STP Inlet	Qty / Nos of Sample : 2 L / 1 No.
Sampling By : Sample Sent By Party	Packing / Seal : Sealed
Date of Sampling : -	Protocol / Purpose : Waste Water Analysis
Sample Received Date : 04-02-2026	Date of Completion : 07-02-2026
Date of Starting of Test : 04-02-2026	Sample ID : 0226/WW01115
Sampling Method : N.A.	

RESULT TABLE

S.NO.	TEST PARAMETER	UNIT	RESULT	LIMIT	METHOD REFERENCE
1	Total Nitrogen	mg/L	30.00	-	Calculation Method


CHECKED BY
Hiral Pavar

ENPRO Enviro Tech and Engineers Pvt. Ltd.(ETL)


REVIEWED AND AUTHORISED BY
Chintan Desai (TM)

Note 1 : This Report is subject to terms & conditions mentioned overleaf.

Note 2 : Details about MU and Decision Rules are available with laboratory and same will be provided upon request.

*** End of Report ***

Page 1 of 1



ENPRO Enviro Tech and Engineers Pvt. Ltd.

Environmental Testing Laboratory

Plot No. D/29/16, Road No. 17, Hojiwala Industrial Estate, Gate No. 3,
Sachin-Palsana Road, Sachin, Surat - 394 230. Gujarat, INDIA.

Lab Ph. : +91-95128 74754 E-mail : lab@enpro.co.in



TC - 5885

Test Report

Format No : QR/7.8/01	Test Report No : TC588526000001116F	Issue Date : 07-02-2026
ULR No : TC588526000001116F	Discipline : Biological	Group : Environment & Pollution

Customer's Name & Address : **Phoenix Projects Pvt. Ltd.**
Nagarpalika Dharampur

Description of Sample : STP Outlet	Qty / Nos of Sample : 2 L / 1 No.
Sampling By : Sample Sent By Party	Packing / Seal : Sealed
Date of Sampling : -	Protocol / Purpose : Waste Water Analysis
Sample Received Date : 04-02-2026	Date of Completion : 07-02-2026
Date of Starting of Test : 04-02-2026	Sample ID : 0226/WW01116
Sampling Method : N.A	

RESULT TABLE

S.NO.	TEST PARAMETER	UNIT	RESULT	LIMIT	METHOD REFERENCE
1	Fecal Coliform	MPN/100 ml	27	-	IS:1622-1981(Reaffirmed 2019)

ENPRO Enviro Tech and Engineers Pvt. Ltd.(ETL)

Divya
CHECKED BY
Divya Gupta

Megha
REVIEWED AND AUTHORISED BY
Megha Gowda (Dy. TM)

Note 1 : This Report is subject to terms & conditions mentioned overleaf.

Note 2 : Details about MU and Decision Rules are available with laboratory and same will be provided upon request.

*** End of Report ***

Page 1 of 1





ENPRO
Environment,
Energy, Water
Project Consultants

ENPRO Enviro Tech and Engineers Pvt. Ltd.

Environmental Testing Laboratory

Plot No. D/29/16, Road No. 17, Hojiwala Industrial Estate, Gate No. 3,
Sachin-Palsana Road, Sachin, Surat - 394 230. Gujarat, INDIA.
Lab Ph. : +91-95128 74754 E-mail : lab@enpro.co.in



TC - 5885

Test Report

Format No : QR/7.8/01	Test Report No : TC588526000001116F	Issue Date : 07-02-2026
ULR No : TC588526000001116F	Discipline : Chemical	Group : Pollution & Environment

Customer's Name & Address : **Phoenix Projects Pvt. Ltd.**
Nagarpalika Dharampur

Description of Sample : STP Outlet

Sampling By : Sample Sent By Party

Qty / Nos of Sample : 2 L / 1 No.

Date of Sampling : -

Packing / Seal : Sealed

Sample Received Date : 04-02-2026

Protocol / Purpose : Waste Water Analysis

Date of Starting of Test : 04-02-2026

Date of Completion : 07-02-2026

Sampling Method : N.A

Sample ID : 0226/WW01116

RESULT TABLE

S.NO.	TEST PARAMETER	UNIT	RESULT	LIMIT	METHOD REFERENCE
1	pH	--	7.26(at 25.5°C)	-	IS 3025 (Part-11):2022
2	Biochemical Oxygen Demand (3 Days at 27°C)	mg/L	22.7	-	IS 3025 (Part 44) : 2023
3	Chemical Oxygen Demand (COD)	mg/L	78.4	-	IS 3025 (Part 58) : 2023
4	Ammonical Nitrogen (as NH ₃ -N)	mg/L	7.1	-	IS 3025 (Part 34):1988 Clause 2
5	Total Suspended Solids	mg/L	16.0	-	IS 3025 (Part 17) : 2022
6	Chlorine Residual (as RfCl)	mg/L	BDL(<0.5)	-	IS 3025 (Part-26):2021 Clause 5
7	Phosphate (as PO ₄)	mg/L	5.8	-	IS 3025 (Part 31/Sec 1) : 2022 Clause 5

Note : BDL :- Below Detectable Limit

ENPRO Enviro Tech and Engineers Pvt. Ltd.(ETL)

CHECKED BY
Hiral Pavar

REVIEWED AND AUTHORISED BY
Chintan Desai (TM)

Note 1 : This Report is subject to terms & conditions mentioned overleaf.

Note 2 : Details about MU and Decision Rules are available with laboratory and same will be provided upon request.

*** End of Report ***

Page 1 of 1





ENPRO
Environment,
Energy, Water
Project Consultant

ENPRO Enviro Tech and Engineers Pvt. Ltd.

Environmental Testing Laboratory

Plot No. D/29/16, Road No. 17, Hojiwala Industrial Estate, Gate No. 3,

Sachin-Palsana Road, Sachin, Surat - 394 230. Gujarat, INDIA.

Lab Ph. : +91-95128 74754 E-mail : lab@enpro.co.in

Test Report

Format No : QR/7.8/01	Test Report No : ETL/000439/26-	Issue Date : 07-02-2026
ULR No : N.A.	Discipline : Chemical	Group : Pollution & Environment

Customer's Name & Address : **Phoenix Projects Pvt. Ltd.**
Nagarpalika Dharampur

Description of Sample : STP Outlet

Sampling By : Sample Sent By Party

Date of Sampling : -

Sample Received Date : 04-02-2026

Date of Starting of Test : 04-02-2026

Sampling Method : N.A.

Qty / Nos of Sample : 2 L / 1 No.

Packing / Seal : Sealed

Protocol / Purpose : Waste Water Analysis


Date of Completion : 07-02-2026


Sample ID : 0226/WW01116

RESULT TABLE

S.NO.	TEST PARAMETER	UNIT	RESULT	LIMIT	METHOD REFERENCE
1	Total Nitrogen	mg/L	11.50	-	Calculation Method

ENPRO Enviro Tech and Engineers Pvt. Ltd.(ETL)


CHECKED BY
Hiral Pavar


REVIEWED AND AUTHORISED BY
Chintan Desai (TM)

Note 1 : This Report is subject to terms & conditions mentioned overleaf.

Note 2 : Details about MU and Decision Rules are available with laboratory and same will be provided upon request.

*** End of Report ***

Page 1 of 1



ENPRO Enviro Tech and Engineers Pvt. Ltd.

Environmental Testing Laboratory

Plot No. D/29/16, Road No. 17, Hojiwala Industrial Estate, Gate No. 3,
Sachin-Palsana Road, Sachin, Surat - 394 230, Gujarat, INDIA.
Lab Ph. : +91-95128 74754 E-mail : lab@enpro.co.in



TC - 5885

Test Report

Format No : QR/7.8/01	Test Report No : TC588526000001562F	Issue Date : 21-02-2026
ULR No : TC588526000001562F	Discipline : Biological	Group : Environment & Pollution

Customer's Name & Address : **Phoenix Projects Pvt. Ltd.**
Nagarpalika Dharampur

Description of Sample	: STP Inlet	
Sampling By	: Sample Sent By Party	Qty / Nos of Sample : 2 L / 1 No.
Date of Sampling	: -	Packing / Seal : Sealed
Sample Received Date	: 18-02-2026	Protocol / Purpose : Waste Water Analysis
Date of Starting of Test	: 18-02-2026	Date of Completion : 21-02-2026
Sampling Method	: N.A	Sample ID : 0226/WW01562

RESULT TABLE

S.NO.	TEST PARAMETER	UNIT	RESULT	LIMIT	METHOD REFERENCE
1	Fecal Coliform	MPN/100 ml	90	-	IS:1622-1981(Reaffirmed 2019)

ENPRO Enviro Tech and Engineers Pvt. Ltd.(ETL)

Divya
CHECKED BY
Divya Gupta

Megha
REVIEWED AND AUTHORISED BY
Megha Gowda (Dy. TM)

Note 1 : This Report is subject to terms & conditions mentioned overleaf.

Note 2 : Details about MU and Decision Rules are available with laboratory and same will be provided upon request.

*** End of Report ***

Page 1 of 1





ENPRO
Environment,
Energy, Water
Project Consultant

ENPRO Enviro Tech and Engineers Pvt. Ltd.

Environmental Testing Laboratory

Plot No. D/29/16, Road No. 17, Hojiwala Industrial Estate, Gate No. 3,

Sachin-Palsana Road, Sachin, Surat - 394 230. Gujarat, INDIA.

Lab Ph. : +91-95128 74754 E-mail : lab@enpro.co.in



TC - 5885

Test Report


Format No : QR/7.8/01	Test Report No : TC58852600001562F	Issue Date : 21-02-2026
ULR No : TC58852600001562F	Discipline : Chemical	Group : Pollution & Environment

Customer's Name & Address : **Phoenix Projects Pvt. Ltd.**
Nagarpalika Dharampur


Description of Sample	: STP Inlet	
Sampling By	: Sample Sent By Party	Qty / Nos of Sample : 2 L / 1 No.
Date of Sampling	: -	Packing / Seal : Sealed
Sample Received Date	: 18-02-2026	Protocol / Purpose : Waste Water Analysis
Date of Starting of Test	: 18-02-2026	Date of Completion : 21-02-2026
Sampling Method	: N.A	Sample ID : 0226/WW01562

RESULT TABLE

S.NO.	TEST PARAMETER	UNIT	RESULT	LIMIT	METHOD REFERENCE
1	pH	-	7.76(at 25.2°C)	-	IS 3025 (Part-11):2022
2	Biochemical Oxygen Demand (3 Days at 27°C)	mg/L	251	-	IS 3025 (Part 44) : 2023
3	Chemical Oxygen Demand (COD)	mg/L	864	-	IS 3025 (Part 58) : 2023
4	Ammonical Nitrogen (as NH ₃ -N)	mg/L	20.6	-	IS 3025 (Part 34):1988 Clause 2
5	Total Suspended Solids	mg/L	232	-	IS 3025 (Part 17) : 2022
6	Chlorine Residual (as RFCI)	mg/L	2.8	-	IS 3025 (Part-26):2021 Clause 5
7	Phosphate (as PO ₄)	mg/L	24.6	-	IS 3025 (Part 31/Sec 1) : 2022 Clause 5


CHECKED BY
Hiral Pavar

ENPRO Enviro Tech and Engineers Pvt. Ltd.(ETL)


REVIEWED AND AUTHORISED BY
Chintan Desai (TM)

Note 1 : This Report is subject to terms & conditions mentioned overleaf.

Note 2 : Details about MU and Decision Rules are available with laboratory and same will be provided upon request.

*** End of Report ***

Page 1 of 1



•RECOGNIZED ENVIRONMENTAL TESTING LABORATORY UNDER EPA-1986, BY MoEF & CC (valid up to 24/06/2027) •CALIBRATION LABORATORY

•QCI-NABET ACCREDITED EIA CONSULTANT ORGANIZATION •GPCB APPROVED SCHEDULE II ENVIRONMENTAL AUDITOR

•ISO 9001 : 2015 •ISO 14001 : 2015 •ISO 45001 : 2018



ENPRO Enviro Tech and Engineers Pvt. Ltd.

Environmental Testing Laboratory

Plot No. D/29/16, Road No. 17, Hojiwala Industrial Estate, Gate No. 3,
Sachin-Palsana Road, Sachin, Surat - 394 230. Gujarat, INDIA.
Lab Ph. : +91-95128 74754 E-mail : lab@enpro.co.in

Test Report

Format No : QR/7.8/01	Test Report No : ETL/000682/26-	Issue Date : 21-02-2026
ULR No : N.A.	Discipline : Chemical	Group : Pollution & Environment


Customer's Name & Address : **Phoenix Projects Pvt. Ltd.**
Nagarpalika Dharampur


Description of Sample : STP Inlet	Qty / Nos of Sample : 2 L / 1 No.
Sampling By : Sample Sent By Party	Packing / Seal : Sealed
Date of Sampling : -	Protocol / Purpose : Waste Water Analysis
Sample Received Date : 18-02-2026	Date of Completion : 21-02-2026
Date of Starting of Test : 18-02-2026	Sample ID : 0226/WW01562
Sampling Method : N.A.	

RESULT TABLE

S.NO.	TEST PARAMETER	UNIT	RESULT	LIMIT	METHOD REFERENCE
1	Total Nitrogen	mg/L	40.00	-	Calculation Method

ENPRO Enviro Tech and Engineers Pvt. Ltd.(ETL)


CHECKED BY
Hiral Pavar


REVIEWED AND AUTHORISED BY
Chintan Desai (TM)

Note 1 : This Report is subject to terms & conditions mentioned overleaf.

Note 2 : Details about MU and Decision Rules are available with laboratory and same will be provided upon request.

*** End of Report ***

Page 1 of 1



ENPRO
Environment,
Energy, Water
Project Consultant

ENPRO Enviro Tech and Engineers Pvt. Ltd.

Environmental Testing Laboratory

Plot No. D/29/16, Road No. 17, Hojiwala Industrial Estate, Gate No. 3,
Sachin-Palsana Road, Sachin, Surat - 394 230. Gujarat, INDIA.
Lab Ph. : +91-95128 74754 E-mail : lab@enpro.co.in



TC - 5885

Test Report

Format No : QR/7.8/01	Test Report No : TC588526000001563F	Issue Date : 21-02-2026
ULR No : TC588526000001563F	Discipline : Biological	Group : Environment & Pollution

Customer's Name & Address : **Phoenix Projects Pvt. Ltd.**
Nagarpalika Dharampur

Description of Sample : STP Outlet	Qty / Nos of Sample : 2 L / 1 No.
Sampling By : Sample Sent By Party	Packing / Seal : Sealed
Date of Sampling : -	Protocol / Purpose : Waste Water Analysis
Sample Received Date : 18-02-2026	Date of Completion : 21-02-2026
Date of Starting of Test : 18-02-2026	Sample ID : 0226/WW01563
Sampling Method : N.A	

RESULT TABLE

S.NO.	TEST PARAMETER	UNIT	RESULT	LIMIT	METHOD REFERENCE
1	Fecal Coliform	MPN/100 ml	30	-	IS:1622-1981(Reaffirmed 2019)

ENPRO Enviro Tech and Engineers Pvt. Ltd.(ETL)

Divya
CHECKED BY
Divya Gupta

Megha
REVIEWED AND AUTHORISED BY
Megha Gowda (Dy. TM)

Note 1 : This Report is subject to terms & conditions mentioned overleaf.

Note 2 : Details about MU and Decision Rules are available with laboratory and same will be provided upon request.

*** End of Report ***

Page 1 of 1





ENPRO
Environment,
Energy, Water
Project Consultant

ENPRO Enviro Tech and Engineers Pvt. Ltd.

Environmental Testing Laboratory

Plot No. D/29/16, Road No. 17, Hojiwala Industrial Estate, Gate No. 3,
Sachin-Palsana Road, Sachin, Surat - 394 230. Gujarat, INDIA.
Lab Ph. : +91-95128 74754 E-mail : lab@enpro.co.in



TC - 5885

Test Report

Format No : QR/7.8/01	Test Report No : TC588526000001563F	Issue Date : 21-02-2026
ULR No : TC588526000001563F	Discipline : Chemical	Group : Pollution & Environment

Customer's Name & Address : **Phoenix Projects Pvt. Ltd.**
Nagarpalika Dharampur

Description of Sample : STP Outlet

Sampling By : Sample Sent By Party

Qty / Nos of Sample : 2 L / 1 No.

Date of Sampling : -

Packing / Seal : Sealed

Sample Received Date : 18-02-2026

Protocol / Purpose : Waste Water Analysis

Date of Starting of Test : 18-02-2026

Date of Completion : 21-02-2026

Sampling Method : N.A


Sample ID : 0226/WW01563


RESULT TABLE

S.NO.	TEST PARAMETER	UNIT	RESULT	LIMIT	METHOD REFERENCE
1	pH	--	7.14(at 25.2°C)	-	IS 3025 (Part-11):2022
2	Biochemical Oxygen Demand (3 Days at 27°C)	mg/L	14.5	-	IS 3025 (Part 44) : 2023
3	Chemical Oxygen Demand (COD)	mg/L	61.0	-	IS 3025 (Part 58) : 2023
4	Ammonical Nitrogen (as NH ₃ -N)	mg/L	7.6	-	IS 3025 (Part 34):1988 Clause 2
5	Total Suspended Solids	mg/L	14.0	-	IS 3025 (Part 17) : 2022
6	Chlorine Residual (as RfCl)	mg/L	BDL(<0.5)	-	IS 3025 (Part-26):2021 Clause 5
7	Phosphate (as PO ₄)	mg/L	4.2	-	IS 3025 (Part 31/Sec 1) : 2022 Clause 5

Note : BDL :- Below Detectable Limit

ENPRO Enviro Tech and Engineers Pvt. Ltd.(ETL)


CHECKED BY
Hiral Pavar


REVIEWED AND AUTHORISED BY
Chintan Desai (TM)

Note 1 : This Report is subject to terms & conditions mentioned overleaf.

Note 2 : Details about MU and Decision Rules are available with laboratory and same will be provided upon request.

*** End of Report ***

Page 1 of 1





ENPRO
Environment,
Energy, Water
Project Consultant

ENPRO Enviro Tech and Engineers Pvt. Ltd.

Environmental Testing Laboratory

Plot No. D/29/16, Road No. 17, Hojiwala Industrial Estate, Gate No. 3,

Sachin-Palsana Road, Sachin, Surat - 394 230. Gujarat, INDIA.

Lab Ph. : +91-95128 74754 E-mail : lab@enpro.co.in

Test Report


Format No : QR/7.8/01	Test Report No : ETL/000593/26-	Issue Date : 21-02-2026
ULR No : N.A.	Discipline : Chemical	Group : Pollution & Environment


Customer's Name & Address : Phoenix Projects Pvt. Ltd. Nagarpalika Dharampur		
Description of Sample : STP Outlet		
Sampling By : Sample Sent By Party	Qty / Nos of Sample : 2 L / 1 No.	
Date of Sampling : -	Packing / Seal : Sealed	
Sample Received Date : 18-02-2026	Protocol / Purpose : Waste Water Analysis	
Date of Starting of Test : 18-02-2026	Date of Completion : 21-02-2026	
Sampling Method : N.A	Sample ID : 0226/WW01563	

RESULT TABLE

S.NO.	TEST PARAMETER	UNIT	RESULT	LIMIT	METHOD REFERENCE
1	Total Nitrogen	mg/L	14.60	-	Calculation Method

ENPRO Enviro Tech and Engineers Pvt. Ltd.(ETL)


CHECKED BY
Hiral Pavar


REVIEWED AND AUTHORISED BY
Chintan Desai (TM)

Note 1 : This Report is subject to terms & conditions mentioned overleaf.

Note 2 : Details about MU and Decision Rules are available with laboratory and same will be provided upon request.

*** End of Report ***

Page 1 of 1



Test Report
Water Sample Analysis Report

Client's Name & Address GWSSB, Bharuch, Gujarat Construction, company Mahesana, AMOD 3.10 MLD STP	Report No: GLEPL/240601/2500 Issue Date: 12/02/2026
---	--

Lab ID Code	: GLEPL/230222/WL ₁		
Sample Description	: Waste Water (STP Inlet)	Purpose	: As per Client requirement
Date of Sampling	: Submitted by Client	Sample Collected/Submitted by	: Submitted by Client
Date of Sample Received	: 02/02/2026	Test Parameters	: As per Client requirement
Date of starting Analysis	: 03/02/2026	Quantity/No. of sample	: 2 Lit./01
Date of completion Analysis	: 09/02/2026	Packed/Seal	: Sealed

Result Table

Sr. No.	Test Parameters	Test Method	Unit	Results
1	pH @30 °C	IS 3025 (P-11) 1983 (Reaffirmed 2017)	pH Unit	10.45
2	Total Suspended Solids	IS 3025 (P-17) 1984 (Reaffirmed 2017)	mg/L	332.85
3	Chemical Oxygen Demand	IS 3025 (P-58) 2006 (Reaffirmed 2017)	mg/L	270.95
4	BOD (5 days at 20°C)	IS 3025 (P-44) 1993 (Reaffirmed 2019)	mg/L	148.36
5	Ammonical Nitrogen	IS 3025 (P-34) 1988 (Reaffirmed 2019)	mg/L	9.89
6	Total Phosphorus	IS 3025 (P-31) 1988 (Reaffirmed 2019)	mg/L	BDL
7	Total Kjeldahl Nitrogen	IS 3025 (P-34) 1988 (Reaffirmed 2019)	mg/L	32.41
8	Residual Chlorine	IS 3025 (P-26) 1986 (Reaffirmed 2019)	mg/L	ND
9	Total Coliform	APHA & AWWA 23 rd Ed. 9221 E (9-77)	MPN/100MI	380

Note: BDL: Below Detection Limit, ND: Not Detected.

WL₁: STP Inlet Water

N.A. Khant
Chemist

N.A. Khant
Authorized Signatory
KHANT NILESH

Notes: (1) The results pertain to tested items only.

(2) This report shall not be reproduced, except in full, without written approval of the laboratory.

(3) Authenticity of this Report could be validated with office copy at Greenleaf Envirotech Pvt. Ltd.

(4) Perishable samples will be destroyed after testing, others after 7 days from the date of issue of the report, unless otherwise agreed with the customer or as required by the applicable regulations.

Page No. 01 of 01

Recognized by MoEF, Govt. of India, EP Act 1986; NABL accredited; GPCB Schedule II Environment Auditor; OHSAS – 18001:2017 Certified Laboratory.

Greenleaf Envirotech Pvt. Ltd.

304, Kankavati Complex, Singanpor-Cauzway Road, Katargam, Surat – 395004, Tel: 0261-6430044

E-mail: lab@glepl.com | Web: www.glepl.com



Test Report
Water Sample Analysis Report

Client's Name & Address GWSSB, Bharuch, Gujarat Construction, company Mahesana, AMOD 3.10 MLD STP	Report No: GLEPL/240602/2501 Issue Date: 13/02/2026
---	--

Lab ID Code	: GLEPL/230222/WL ₂	Purpose	: As per Client requirement
Sample Description	: Waste Water (STP Outlet)	Sample Collected/Submitted by	: Submitted by Client
Date of Sampling	: Submitted by Client	Test Parameters	: As per Client requirement
Date of Sample Received	: 02/02/2026	Quantity/No. of sample	: 2 Lit./02
Date of starting Analysis	: 03/02/2026	Packed/Seal	: Sealed
Date of completion Analysis	: 09/02/2026		

Result Table

Sr. No.	Test Parameters	Test Method	Unit	Results	Permissible Limit
1	Ph @30 °C	IS 3025 (P-11) 1983 (Reaffirmed 2017)	Ph Unit	7.9	6.5-9.0
2	Total Suspended Solids	IS 3025 (P-17) 1984 (Reaffirmed 2017)	mg/L	7.6	<10
3	Chemical Oxygen Demand	IS 3025 (P-58) 2006 (Reaffirmed 2017)	mg/L	14.25	<50
4	BOD (5 days at 20°C)	IS 3025 (P-44) 1993 (Reaffirmed 2019)	mg/L	8.1	<10
5	Ammonical Nitrogen	IS 3025 (P-34) 1988 (Reaffirmed 2019)	mg/L	3.35	<5.0
6	Total Phosphorus	IS 3025 (P-31) 1988 (Reaffirmed 2019)	mg/L	BDL	<1.0
7	Total Nitrogen	IS 3025 (P-34) 1988 (Reaffirmed 2019)	mg/L	6.8	<10.0
8	Residual Chlorines	IS 3025 (P-26) 1986 (Reaffirmed 2019)	mg/L	0.7	0.5-1.0
9	Faecal Coliform	APHA & AWWA 23 rd Ed. 9221 E (9-77)	MPN/100MI	88	<230

MNote: BDL: Below Detection Limit.

WL₁: STP Outlet Water

N.A. Khant
Chemist

N.A. Khant
Authorized Signatory
KHANT NILESH

- Notes: (1) The results pertain to tested items only.
(2) This report shall not be reproduced, except in full, without written approval of the laboratory.
(3) Authenticity of this Report could be validated with office copy at Greenleaf Envirotech Pvt. Ltd.
(4) Perishable samples will be destroyed after testing, others after 7 days from the date of issue of the report, unless otherwise agreed with the customer or as required by the applicable regulations.

Recognized by MoEF, Govt. of India, EP Act 1986; NABL accredited; GPCB Schedule II Environment Auditor; OHSAS – 18001:2017 Certified Laboratory.

Greenleaf Envirotech Pvt. Ltd.

304, Kankavati Complex, Singanpor-Cauzway Road, Katargam, Surat – 395004, Tel: 0261-6430044

E-mail: lab@glepl.com | Web: www.glepl.com

Test Report
Water Sample Analysis Report

Client's Name & Address GWSSB, Bharuch, Gujarat Construction, company Mahesana, AMOD 3.10 MLD STP	Report No: GLEPL/240606/2506 Issue Date: 27/02/2026
---	--

Lab ID Code	: GLEPL/230222/WL ₁	Purpose	: As per Client requirement
Sample Description	: Waste Water (STP Outlet)	Sample Collected/Submitted by	: Submitted by Client
Date of Sampling	: Submitted by Client	Test Parameters	: As per Client requirement
Date of Sample Received	: 16/02/2026	Quantity/No. of sample	: 2 Lit./02
Date of starting Analysis	: 17/02/2026	Packed/Seal	: Sealed
Date of completion Analysis	: 24/02/2026		

Result Table

Sr. No.	Test Parameters	Test Method	Unit	Results	Permissible Limit
1	Ph @30 °C	IS 3025 (P-11) 1983 (Reaffirmed 2017)	Ph Unit	7.2	6.5-9.0
2	Total Suspended Solids	IS 3025 (P-17) 1984 (Reaffirmed 2017)	mg/L	6.9	<10
3	Chemical Oxygen Demand	IS 3025 (P-58) 2006 (Reaffirmed 2017)	mg/L	19.84	<50
4	BOD (5 days at 20°C)	IS 3025 (P-44) 1993 (Reaffirmed 2019)	mg/L	7.9	<10
5	Ammonical Nitrogen	IS 3025 (P-34) 1988 (Reaffirmed 2019)	mg/L	4.12	<5.0
6	Total Phosphorus	IS 3025 (P-31) 1988 (Reaffirmed 2019)	mg/L	BDL	<1.0
7	Total Nitrogen	IS 3025 (P-34) 1988 (Reaffirmed 2019)	mg/L	7.1	<10.0
8	Residual Chlorines	IS 3025 (P-26) 1986 (Reaffirmed 2019)	mg/L	0.7	0.5-1.0
9	Faecal Coliform	APHA & AWWA 23 rd Ed. 9221 E (9-77)	MPN/100MI	211	<230

INote: BDL: Below Detection Limit.

WL: STP Outlet Water

N.A. Khant

Chemist

N.A. Khant

Authorized Signatory
KHANT NILESH

Notes: (1) The results pertain to tested items only.

(2) This report shall not be reproduced, except in full, without written approval of the laboratory.

(3) Authenticity of this Report could be validated with office copy at Greenleaf Envirotech Pvt. Ltd.

(4) Perishable samples will be destroyed after testing, others after 7 days from the date of issue of the report, unless otherwise agreed with the customer or as required by the applicable regulations.

Recognized by MoEF, Govt. of India, EP Act 1986; NABL accredited; GPCB Schedule II Environment Auditor; OHSAS - 18001:2017 Certified Laboratory.

Greenleaf Envirotech Pvt. Ltd.

304, Kankavati Complex, Singanor-Cauway Road, Katargam, Surat - 395004, Tel: 0261-6430044

E-mail: lab@glepl.com | Web: www.glepl.com

N.A. Khant
CHIEF OFFICER
Amod Nagar Palika



Test Report
Water Sample Analysis Report

Client's Name & Address GWSSB, Bharuch, Gujarat Construction, company Mahesana, AMOD 3.10 MLD STP	Report No: GLEPL/240605/2505 Issue Date: 26/02/2026
---	--

Lab ID Code	: GLEPL/230222/WL1	Purpose	: As per Client requirement
Sample Description	: Waste Water (STP Inlet)	Sample Collected/Submitted by	: Submitted by Client
Date of Sampling	: Submitted by Client	Test Parameters	: As per Client requirement
Date of Sample Received	: 16/02/2026	Quantity/No. of sample	: 2 Lit./01
Date of starting Analysis	: 17/02/2026	Packed/Seal	: Sealed
Date of completion Analysis	: 24/02/2026		

Result Table

Sr. No.	Test Parameters	Test Method	Unit	Results
1	pH @30 °C	IS 3025 (P-11) 1983 (Reaffirmed 2017)	pH Unit	9.89
2	Total Suspended Solids	IS 3025 (P-17) 1984 (Reaffirmed 2017)	mg/L	364.85
3	Chemical Oxygen Demand	IS 3025 (P-58) 2006 (Reaffirmed 2017)	mg/L	275.24
4	BOD (5 days at 20°C)	IS 3025 (P-44) 1993 (Reaffirmed 2019)	mg/L	168.61
5	Ammonical Nitrogen	IS 3025 (P-34) 1988 (Reaffirmed 2019)	mg/L	8.75
6	Total Phosphorus	IS 3025 (P-31) 1988 (Reaffirmed 2019)	mg/L	BDL
7	Total Kjeldahl Nitrogen	IS 3025 (P-34) 1988 (Reaffirmed 2019)	mg/L	31.84
8	Residual Chlorine	IS 3025 (P-26) 1986 (Reaffirmed 2019)	mg/L	ND
9	Total Coliform	APHA & AWWA 23 rd Ed. 9221 E (9-77)	MPN/100MI	374

Note: BDL: Below Detection Limit, ND: Not Detected.

WL1: STP Inlet Water

N.A. Khant
Chemist

N.A. Khant
Authorized Signatory
KHANT NILESH

Notes: (1) The results pertain to tested items only.

(2) This report shall not be reproduced, except in full, without written approval of the laboratory.

(3) Authenticity of this Report could be validated with office copy at Greenleaf Envirotech Pvt. Ltd.

(4) Perishable samples will be destroyed after testing, others after 7 days from the date of issue of the report, unless otherwise agreed with the customer or as required by the applicable regulations.

Page No. 01 of 01

Recognized by MoEF, Govt. of India, EP Act 1986; NABL accredited; GPCB Schedule II Environment Auditor, OHSAS - 18001:2017 Certified Laboratory.

Greenleaf Envirotech Pvt. Ltd.
304, Kankavati Complex, Singapor-Cauzway Road, Katargam, Surat - 395004, Tel: 0261-6430044
E-mail: lab@glepl.com | Web: www.glepl.com

[Signature]
CHIEF OFFICER
Amod Nagar Palika



GEO DESIGNS & RESEARCH (P) LTD.

GEO TEST HOUSE
(A DIV. OF GEO DESIGNS & RESEARCH (P) LTD.)

TEST REPORT

Job No : 1152/316001
Sample No : 3160001

Report No : NV3/1152-316001/Water/3160001
Report Date : 15/02/2026

Client : G W S S B, Bilimora
Contractor : Maruti Trading Pvt Ltd
Consultant : Sia Engineering Projects India Pvt Ltd
Project Name : Design Supply Construction Installation Testing and Commissioning of Sewage Treatment Plant Gandevi (2.60 MLD)
Reference No : Letter Dated : 10/02/2026

Sample Description : Waste Water
Source of Sample : --
Sample ID : Water (Before Treatment)
Date sample received : 10/02/2026

Condition of Sample : Good
Quantity of Sample : 1 Ltr
Sample Submitted by : Contractor
Date Test Started : 10/02/2026
Date Test Completed : 15/02/2026

CHEMICAL PROPERTIES OF WATER

Sr. No.	Tests	Test Standard	Test Results
1	pH Value	IS 3025 (Part 11) : 2022	5.58
2	Biochemical Oxygen Demand (5 d at 20 °C as BOD), mg/l	APHA 23th Ed 5210 Method B : 2017	19.23
3	Chemical Oxygen Demand (COD), mg/l	APHA 23th Ed 5220 Method B&C : 2017	65.55
4	Total Suspended Solids, mg/l	IS 3025 (Part 15) : 2023	88.43
5	Total Nitrogen, mg/l	APHA 24th Ed 4500 NH3 Method, B & C : 2023	22.16
6	Ammonia (as Total ammonia - N), mg/l	APHA 23rd Ed 4500 NH3 C : 2017	18.59
7	Organic Matter, mg/l	IS 3025 (Part 18) : 2022	25.36

Tested By : GS



End of Report

[Signature]
Authorized Signatory

NOTE

1. This certificate or report may not be published for commercial purpose except in full unless permission for the publication of an approved abstract has been obtained from the Director, GEO TEST HOUSE, Vadodra.
2. This test certificate applies only to the samples received in the laboratory.

Page 1 of 1

Head Office :

B-10, Krishna Industrial Estate, Opp. B.I.D.C.
Gorwa Estate, Vadodra - 390 016, Gujarat, India
PH : +91-265-2290222 M : +91 93746 90024
E-mail : info@geogroup.in / lab@geogroup.in

Navsari Office :

Plot No - 486, New GIDC, Bardoli Road,
Kabilpore, Navsari, Gujarat- 396424
Office - M. 9374690023, 9313607313.
Email - navsari@geogroup.in, gmnavsari@gmail.com.

www.geogroup.in





**GEO DESIGNS &
RESEARCH (P) LTD.**

GEO TEST HOUSE
(A DIV. OF GEO DESIGNS & RESEARCH (P) LTD.)

TEST REPORT

Job No 1152/316001
Sample No 3160002

Report No NV3/1152-316001/Water/3160002
Report Date 15/02/2026

Client : G W S S B, Bilimora
Contractor : Maruti Trading Pvt Ltd
Consultant : Sia Engineering Projects India Pvt Ltd
Project Name : Design Supply Construction Installation Testing and Commissioning of Sewage Treatment Plant Gandevi (2.60 MLD)
Reference No : Letter Dated : 10/02/2026

Sample Description : Waste Water

Source of Sample : -

Sample ID : Water (After Treatment)

Date sample received : 10/02/2026

Condition of Sample : Good

Quantity of Sample : 1 Ltr.

Sample Submitted by : Contractor

Date Test Started : 10/02/2026

Date Test Completed : 15/02/2026

CHEMICAL PROPERTIES OF WATER

Sr. No.	Tests	Test Standard	Test Results
1	pH Value	IS 3025 (Part 11) : 2022	8.46
2	Biochemical Oxygen Demand (5 d at 20 °C as BOD), mg/l	APHA 23th Ed 5210 Method B : 2017	7.58
3	Chemical Oxygen Demand (COD), mg/l	APHA 23th Ed 5220 Method B&C : 2017	8.26
4	Total Suspended Solids, mg/l	IS 3025 (Part 15) : 2023	8.33
5	Ammonia (as Total ammonia - N), mg/l	APHA 23rd Ed 4500 NH3 C : 2017	7.59
6	Organic Matter, mg/l	IS 3025 (Part 18) : 2022	8.32
7	Total Nitrogen, mg/l	APHA 24th Ed 4500 NH3 Method, B & C : 2023	7.65
8	Total Residual Chlorine	APHA 24th Ed 4500 Cl Method B : 2023	0.98

Tested By : GS



[Signature]

Authorized Signatory

End of Report

NOTE:

- This certificate or report may not be published for commercial purposes without the full written permission for the publication of an approved abstract has been obtained from the Division, GEO TEST HOUSE, VRAHANE.
- This test certificate applies only to the samples received in the laboratory.

Page: 1 of 1

Head Office :
B-10, Krishna Industrial Estate, Opp. B.I.D.C.
Gorwa Estate, Vadodara - 390 016, Gujarat, India.
PH. : + 91-265-2290222 M : +91 93746 00024
E-mail : info@geogroup.in / test@geogroup.in
www.geogroup.in

Navsari Office :
Plot No - 486, New GIDC, Bardoli Road,
Kabilpore, Navsari, Gujarat- 396424
Office : M. 9374690023, 9313607313.
Email : navsari@geogroup.in, ghnavsari@gmail.com





57


TEST REPORT				
REPORT NUMBER : EI/WW/0226/080			DATE OF REPORT: 15-02-2026	
COMPANY NAME : GEO DESIGN & RESEARCH (P) LTD				
ADDRESS : PLOT NO 486, BARDOLI ROAD, NEW GIDC, KADIPORI, NAVSARI, GUJARAT - 396424				
SAMPLE DETAILS				
Laboratory ID	EI/WW/0226/080		Date of Sampling	-
Sample Type	WASTE WATER		Date of Sample Receipt	10-02-2026
Sample Description	STP INLET		Quantity/	Good
			Sample Condition	Adequate
Location of Sample	-		Analysis Start Date	10-02-2026
Monitoring Conducted By	Sample Received in Laboratory		Analysis End Date	15-02-2026
SL. NO.	PARAMETER	UNIT	TEST METHOD	RESULTS
01.	Total Coliform	MPN/100 ml	APHA:9222 23rd Edition	145
02.	Fecal Coliform	MPN/100 ml	APHA:9222 23rd Edition	114
		Authorized Signatory: Name: KHUSHBU S GAJJAR Designation: CEO		
* End of Report *				
1) The results relate only to the items tested. 2) This test report shall not be reproduced except in full, without approval of the laboratory can provide assurance that parts of a report are not taken out of context.				
F/7.8/01 Issue No.01/Issue Date: 01-10-2018/ Amend No.:00 / Amend Date:-- / Page 1 of 1				



58



ENVIRONMENT
INNOVATION

TEST REPORT				
REPORT NUMBER : EI/WW/0226/081			DATE OF REPORT: 15-02-2026	
COMPANY NAME : GEO DESIGN & RESEARCH (P) LTD				
ADDRESS : PLOT NO:486,BARDOLI ROAD,NEW GIDC,KABILPORE,NAVSARI,GUJARAT-396424				
SAMPLE DETAILS.				
Laboratory ID	: EI/WW/0226/081	Date of Sampling	: -	
Sample Type	: WASTE WATER	Date of Sample Receipt	: 10-02-2026	
Sample Description	: STP OUTLET	Quantity/	: Good/	
		Sample Condition	: Adequate	
Location of Sample	: --	Analysis Start Date	: 10-02-2026	
Monitoring Conducted By	: Sample Received in Laboratory	Analysis End Date	: 15-02-2026	
SL. NO.	PARAMETER	UNIT	TEST METHOD	RESULTS
01.	Total Coliform	MPN/100 ml	APHA-9222 23rd Edition	117
02.	Fecal Coliform	MPN/100 ml	APHA-9222 23rd Edition	95
				
 Authorized Signatory. Name: KHUSHBU S GAJJAR Designation: CEO				
* End of Report *				
1) The results relate only to the items tested. 2) This test report shall not be reproduced except in full, without approval of the laboratory can provide assurance that parts of a report are not taken out of context.				
F7.8/01/Issue No.01/Issue Date: 01-10-2018/ Amend No.:00 / Amend Date:-- / Page 1 of 1				



ENVIRONMENTAL AUDITOR & CONSULTANT
ANALYTICAL LABORATORY

401, SHREE RAM COMPLEX, PIPLOD, SURAT - 395007, GUJARAT, INDIA.
Phone: +91-7874231658
Email: info.eigroup@gmail.com

59



GEO DESIGNS & RESEARCH (P) LTD. TEST REPORT

GEO TEST HOUSE

(A DIV. OF GEO DESIGNS & RESEARCH (P) LTD.)

Job No : 1152-329001
Sample No : 3290001

Report No : NV3/1152-115002/Water/1150002
Report Date : 28-02-2026

Client : DEE., G.W.S.S.B, Bilimora
Contractor : Maruti Trading Pvt Ltd
Consultant : Sia Engineering Projects India Pvt.Ltd.
Project Name : Design Supply Construction Installation Testing and Commissioning of Sewage Treatment Plant Gandevi.
(2.60 MLD)
Reference No. : Letter Date :- 23/02/2026

Sample Description : Waste Water
Source of Sample : --
Sample ID. : Water (Before Treatment)
Date sample received : 23-02-2026

Condition of Sample : Good
Quantity of Sample : 1 Ltr.
Sample Submitted by : Contractor
Date Test Started : 23-02-2026
Date Test Completed : 28-02-2026

CHEMICAL PROPERTIES OF WATER

Sr. No.	Tests	Test Standard	Test Results
1	pH Value	IS 3025 (Part 11) : 2022	5.85
2	Biochemical Oxygen Demand (5 d at 20 °C as BOD), mg/l	APHA 23rd Ed 5210 Method B : 2017	18.52
3	Chemical Oxygen Demand (COD),mg/l	APHA 23rd Ed 5220 Method B&C : 2017	65.32
4	Total Suspended Solids, mg/l	IS 3025 (Part 15) : 1984	87.52
5	Total Nitrogen, mg/l	APHA 24rd Ed 4500 NH3 Method, B & C : 2023	22.15
6	Ammonia (as Total ammonia - N), mg/l	APHA 23rd Ed 4500 NH3 C : 2017	19.52
7	Organic Matter, mg/l	IS 3025 (Part 18) 2022	25.30

Tested By : GS



Checked By




Authorized Signatory

Page: 1 of 1

NOTE:

- This certificate or report may not be published for commercial purpose except in full unless permission for the publication of an approved abstract has been obtained from the Director, GEO TEST HOUSE, Vadodra.
- This Test Report applies only to the samples received in the laboratory.
B-10, Krishna Industrial Estate, Opp. B.I.D.C.
Gorwa Estate, Vadodra - 390 016, Gujarat, India.

Plot No - 486, New GIDC, Bardoli Road,
Kablpara, Navsari, Gujarat- 396424





GEO DESIGNS & RESEARCH (P) LTD. TEST REPORT

GEO TEST HOUSE
(A DIV. OF GEO DESIGNS & RESEARCH (P) LTD.)

Job No : 1152-329001
Sample No : 3290002

Report No : NV3/1152-115002/Water/1150002
Report Date : 28-02-2026

Client : DEE., G.W.S.S.B, Bilimora
Contractor : Maruti Trading Pvt Ltd
Consultant : Sia Engineering Projects India Pvt.Ltd.
Project Name : Design Supply Construction Installation Testing and Commissioning of Sewage Treatment Plant Gandevi.
(2.60 MLD)
Reference No. : Letter Date :- 23/02/2026

Sample Description : Waste Water
Source of Sample : --
Sample ID. : Water (After Treatment)
Date sample received : 23-02-2026

Condition of Sample : Good
Quantity of Sample : 1 Ltr.
Sample Submitted by : Contractor
Date Test Started : 23-02-2026
Date Test Completed : 28-02-2026

CHEMICAL PROPERTIES OF WATER

Sr. No.	Tests	Test Standard	Test Results
1	pH Value	IS 3025 (Part 11) : 2022	8.78
2	Biochemical Oxygen Demand (5 d at 20 °C as BOD), mg/l	APHA 23rd Ed 5210 Method B : 2017	7.66
3	Chemical Oxygen Demand (COD),mg/l	APHA 23rd Ed 5220 Method B&C : 2017	8.54
4	Total Suspended Solids, mg/l	IS 3025 (Part 15) : 1984	8.33
5	Ammonia (as Total ammonia - N), mg/l	APHA 23rd Ed 4500 NH3 C : 2017	7.95
6	Organic Matter, mg/l	IS 3025 (Part 18) 2022	8.21
7	Total Nitrogen, mg/l	APHA 24rd Ed 4500 NH3 Method, B & C : 2023	7.55
8	Total Residual Chlorine	APHA 24rd Ed 4500 Cl Method, B : 2023	0.98

Tested By : GS



Checked By



End of Report

Authorized Signatory

NOTE:

1. This certificate or report may not be published for commercial purpose except in full unless permission for the publication of an approved abstract has been obtained from the Director, GEO TEST HOUSE, Vadodara.
2. This certificate applies only to the samples received in the laboratory.
- Navsari Office :
Plot No - 486, New GIDC, Bardoli Road,
Kabilpore, Navsari, Gujarat- 396424
Office :- M. 9374690023, 9313607313.

Page: 1 of 1

B-10, Kristina Industrial Estate, Opp. B.I.D.C.
Gorwa Estate, Vadodara - 390 016. Gujarat, India.
PH. : +91-265-2290222 M : +91 93746 90024



TEST REPORT

REPORT NO: AEPL/26-02/0033 ISSUE DATE: 18-02-2026

NAME OF CLIENT: KHAMBHAT NAGARPALIKA

ADDRESS: Survey no. 987/1, In South Direction of Revenue Survey no. 9000, Khambhat – 388620,
Tal: Khambhat, Dist: Anand.

SAMPLE TYPE	: Wastewater
LOCATION OF SAMPLE	: 4.50 MLD
DESCRIPTION	: STP Inlet
SAMPLING PROTOCOL / STANDARD	: NA
TYPE OF SAMPLING	: Grab
SAMPLE COLLECTED BY/ RECEIVED IN	: Client / Plastic Carboy
QUANTITY	: 2.5 Liter
SAMPLE CONDITION	: Acceptable
SAMPLING DATE	: NA
SAMPLE RECEIPT DATE	: 11-02-2026
ANALYSIS START DATE	: 11-02-2026
ANALYSIS END DATE	: 18-02-2026
TEST CONDITIONS	Temperature (°C): 24.6 Relative Humidity (%):42

RESULTS

SR.NO	PARAMETERS	UNIT	RESULT	REFERENCE METHOD
1.	pH @ 25 °C	--	7.06	IS 3025 (Part-11) 2022
2.	Chemical Oxygen Demand	mg/L	487	IS 3025 (Part-58) 2023
3.	Bio Chemical Oxygen Demand (3 Days@ 27 °C)	mg/L	134	IS 3025 (Part-44) 2023
4.	Total Phosphate	mg/L	3.2	APHA 24 th Edition 2023 4500-PO ₄
5.	Total Suspended Solids	mg/L	151	APHA 24 th Edition 2023 2540 D
6.	Ammonical Nitrogen	mg/L	22	IS 3025 Part – 34: Sec 4: 2023
7.	Total Nitrogen	mg/L	40	IS 3025 Part – 34: Sec 4: 2023
8.	Fecal Coliform	MPN/100 ml	824	APHA 24 th Edition 2023 9221 B
9.	Total Coliform	MPN/100 ml	1520	APHA 24 th Edition 2023 9221 B

Disha
Authorized Signatory
Disha Chaudhary
Senior Chemist

* End of Report *

Information provided by the Customer: NA

Note:

1. This report shall not be reproduced in part or full without prior permission of Aagam Environment Pvt Ltd.
2. The results listed herewith are only for the items tested.
3. Sample shall be disposed after 15 days from the date of issue of the report unless agreed with the customer.
4. In case when laboratory is not involved in sampling, the results apply to the samples as received.
5. This report shall not be used for publicity or litigation.
6. Tests performed by External Provider shall be identified/marked by "" sign.
7. Any additions to, deviations or exclusions from the method shall be identified by "" sign

Shed - 92, Pushkar Industrial Hub - 4, GIDC Vatva, Opp. Machhunagar Torrent Compound,
Ahmedabad-382445, Gujarat.



GPCB Recognized Schedule – II Environmental Auditor & NABL Accredited Laboratory

TEST REPORT

REPORT NO: AEPL/26-02/0034

ISSUE DATE: 18-02-2026

NAME OF CLIENT: KHAMBHAT NAGARPALIKA

ADDRESS: Survey no. 987/1, In South Direction of Revenue Survey no. 9000, Khambhat – 388620,
Tal: Khambhat, Dist: Anand.

SAMPLE TYPE	: Wastewater
LOCATION OF SAMPLE	: 4.50 MLD
DESCRIPTION	: STP Outlet
SAMPLING PROTOCOL / STANDARD	: NA
TYPE OF SAMPLING	: Grab
SAMPLE COLLECTED BY/ RECEIVED IN	: Client / Plastic Carboy
QUANTITY	: 2.5 Liter
SAMPLE CONDITION	: Acceptable
SAMPLING DATE	: NA
SAMPLE RECIEPT DATE	: 11-02-2026
ANALYSIS START DATE	: 11-02-2026
ANALYSIS END DATE	: 18-02-2026
TEST CONDITIONS	Temperature (°C): 24.6 Relative Humidity (%):42

RESULTS

SR.NO	PARAMETERS	UNIT	RESULT	REFERENCE METHOD
1.	pH @ 25 °C	--	6.26	IS 3025 (Part-11) 2022
2.	Chemical Oxygen Demand	mg/L	28	IS 3025 (Part-58) 2023
3.	Bio Chemical Oxygen Demand (3 Days@ 27 °C)	mg/L	5.0	IS 3025 (Part-44) 2023
4.	Total Phosphate	mg/L	0.8	APHA 24 th Edition 2023 4500-PO ₄
5.	Residual Chlorine	mg/L	0.6	APHA 24 th Edition 2023 4500 Cl
6.	Total Suspended Solids	mg/L	4.8	APHA 24 th Edition 2023 2540 D
7.	Ammonical Nitrogen	mg/L	2.5	IS 3025 Part – 34: Sec 4: 2023
8.	Total Nitrogen	mg/L	5.3	IS 3025 Part – 34: Sec 4: 2023
9.	Fecal Coliform	MPN/100 ml	92	APHA 24 th Edition 2023 9221 B
10.	Total Coliform	MPN/100 ml	168	APHA 24 th Edition 2023 9221 B

Disha

Authorized Signatory
Disha Chaudhary
Senior Chemist

* End of Report *

Information provided by the Customer: NA

Note:

1. This report shall not be reproduced in part or full without prior permission of Aagam Environment Pvt Ltd.
2. The results listed herewith are only for the items tested.
3. Sample shall be disposed after 15 days from the date of issue of the report unless agreed with the customer.
4. In case when laboratory is not involved in sampling, the results apply to the samples as received.
5. This report shall not be used for publicity or litigation.
6. Tests performed by External Provider shall be identified/marked by **** sign.
7. Any additions to, deviations or exclusions from the method shall be identified by *** sign

Shed - 92, Pushkar Industrial Hub - 4, GIDC Vatva, Opp. Machhunagar Torrent Compound,
Ahmedabad-382445, Gujarat.



GPCB Recognized Schedule – II Environmental Auditor & NABL Accredited Laboratory

TEST REPORT

REPORT NO: AEPL/26-02/0035

ISSUE DATE: 18-02-2026

NAME OF CLIENT: KHAMBHAT NAGARPALIKA STP (6.80 MLD)

ADDRESS: Survey no. 987 paiki 1, In South Direction of Survey no. 1019, Khambhat – 388620,
Tal: Khambhat, Dist: Anand.

SAMPLE TYPE	: Wastewater
LOCATION OF SAMPLE	: 6.80 MLD
DESCRIPTION	: STP Inlet
SAMPLING PROTOCOL / STANDARD	: NA
TYPE OF SAMPLING	: Grab
SAMPLE COLLECTED BY/ RECEIVED IN	: Client / Plastic Carboy
QUANTITY	: 2.5 Liter
SAMPLE CONDITION	: Acceptable
SAMPLING DATE	: NA
SAMPLE RECIEPT DATE	: 11-02-2026
ANALYSIS START DATE	: 11-02-2026
ANALYSIS END DATE	: 18-02-2026
TEST CONDITIONS	Temperature (°C): 24.9 Relative Humidity (%):42

RESULTS

SR.NO	PARAMETERS	UNIT	RESULT	REFERENCE METHOD
1.	pH @ 25 °C	--	6.62	IS 3025 (Part-11) 2022
2.	Chemical Oxygen Demand	mg/L	432	IS 3025 (Part-58) 2023
3.	Bio Chemical Oxygen Demand (3 Days@ 27 °C)	mg/L	124	IS 3025 (Part-44) 2023
4.	Total Phosphate	mg/L	5.2	APHA 24 th Edition 2023 4500-PO ₄
5.	Total Suspended Solids	mg/L	228	APHA 24 th Edition 2023 2540 D
6.	Ammonical Nitrogen	mg/L	24	IS 3025 Part – 34: Sec 4: 2023
7.	Total Nitrogen	mg/L	32	IS 3025 Part – 34: Sec 4: 2023
8.	Fecal Coliform	MPN/100 ml	638	APHA 24 th Edition 2023 9221 B
9.	Total Coliform	MPN/100 ml	1620	APHA 24 th Edition 2023 9221 B

Disha

Authorized Signatory
Disha Chaudhary
Senior Chemist

* End of Report *

Information provided by the Customer: NA

Note:

1. This report shall not be reproduced in part or full without prior permission of Aagam Environment Pvt Ltd.
2. The results listed herewith are only for the items tested.
3. Sample shall be disposed after 15 days from the date of issue of the report unless agreed with the customer.
4. In case when laboratory is not involved in sampling, the results apply to the samples as received.
5. This report shall not be used for publicity or litigation.
6. Tests performed by External Provider shall be identified/marked by **** sign.
7. Any additions to, deviations or exclusions from the method shall be identified by *** sign

Shed - 92, Pushkar Industrial Hub - 4, GIDC Vatva, Opp. Machhunagar Torrent Compound,
Ahmedabad-382445, Gujarat.

+91 94270 66173 | +91 87806 38361 | chaxu@aagamenvironment.com | aagamenvironment@gmail.com

www.aagamenvironment.com



GPCB Recognized Schedule – II Environmental Auditor & NABL Accredited Laboratory

TEST REPORT

REPORT NO: AEPL/26-02/0036		ISSUE DATE: 18-02-2026
NAME OF CLIENT: KHAMBHAT NAGARPALIKA STP (6.80 MLD)		
ADDRESS: Survey no. 987 paiki 1, In South Direction of Survey no. 1019, Khambhat – 388620, Tal: Khambhat, Dist: Anand.		
SAMPLE TYPE	: Wastewater	
LOCATION OF SAMPLE	: 6.80 MLD	
DESCRIPTION	: STP Outlet	
SAMPLING PROTOCOL / STANDARD	: NA	
TYPE OF SAMPLING	: Grab	
SAMPLE COLLECTED BY/ RECEIVED IN	: Client / Plastic Carboy	
QUANTITY	: 2.5 Liter	
SAMPLE CONDITION	: Acceptable	
SAMPLING DATE	: NA	
SAMPLE RECIEPT DATE	: 11-02-2026	
ANALYSIS START DATE	: 11-02-2026	
ANALYSIS END DATE	: 18-02-2026	
TEST CONDITIONS	Temperature (°C): 24.9	Relative Humidity (%):40

RESULTS

SR.NO	PARAMETERS	UNIT	RESULT	REFERENCE METHOD
1.	pH @ 25 °C	--	7.29	IS 3025 (Part-11) 2022
2.	Chemical Oxygen Demand	mg/L	32	IS 3025 (Part-58) 2023
3.	Bio Chemical Oxygen Demand (3 Days@ 27 °C)	mg/L	5.0	IS 3025 (Part-44) 2023
4.	Total Phosphate	mg/L	0.5	APHA 24 th Edition 2023 4500-PO ₄
5.	Residual Chlorine	mg/L	0.6	APHA 24 th Edition 2023 4500 Cl
6.	Total Suspended Solids	mg/L	4.9	APHA 24 th Edition 2023 2540 D
7.	Ammonical Nitrogen	mg/L	2.3	IS 3025 Part – 34: Sec 4: 2023
8.	Total Nitrogen	mg/L	4.6	IS 3025 Part – 34: Sec 4: 2023
9.	Fecal Coliform	MPN/100 ml	88	APHA 24 th Edition 2023 9221 B
10.	Total Coliform	MPN/100 ml	159	APHA 24 th Edition 2023 9221 B

Disha
Authorized Signatory
 Disha Chaudhary
 Senior Chemist

* End of Report *

Information provided by the Customer: NA

Note:

1. This report shall not be reproduced in part or full without prior permission of Aagam Environment Pvt Ltd.
2. The results listed herewith are only for the items tested.
3. Sample shall be disposed after 15 days from the date of issue of the report unless agreed with the customer.
4. Incase when laboratory is not involved in sampling, the results apply to the samples as received.
5. This report shall not be used for publicity or litigation.
6. Tests performed by External Provider shall be identified/marked by **** sign.
7. Any additions to, deviations or exclusions from the method shall be identified by **** sign

Shed - 92, Pushkar Industrial Hub - 4, GIDC Vatva, Opp. Machhunagar Torrent Compound,
 Ahmedabad-382445, Gujarat.



ISO 9001:2015 and ISO 17025:2017 NABL certified

No.4, Versetile Industrial Estate, Nr. Kotak Bank, Gate No.5,
Kathwada Gidc, Ahmedabad - 382430.

+91 8469130040, +91 6357351655 naturemicrovision@gmail.com GSTIN : 24AAWFN4704G1Z4

Test Report

Report ID: NML/WW/25-26/1255

Date: 16/02/2026


Customer Name	P.DAS INFRASTRUCTURE PVT LTD		
Customer Address	13.70 MLD DAHOD		
Date & Time of Sampling	10/02/2026	Sampling Plan & Method	IS 3025(Part-1) RA 2019
Date of Receipt of Sample	11/02/2026		
Sample Collected by	Client	Sample Condition	SATISFACTORY
Analysis Starting Date	11/02/2026	Packing / Seal	SEALED
Analysis Completion Date	16/02/2026	Quantity / No. of Samples	Approx. 1 LIT. * 1NO.
Environmental Condition	Temperature: 25 °C ± 2	Relative Humidity (%)	Humidity ≤ 50 %

Sample No.	Sample ID	Sample Type	Location	Description
1.	25-26/1264	Waste Water	Inlet	Untreated Water

Analysis Results

Sr. No.	Parameters	Reference Method	Results	Regulatory Limit	Unit
1.	pH	IS 3025 (Part 11): 2022	7.12	6.5-7.0	--
2.	BIOLOGICAL OXYGEN DEMAND (3 days at 27°C)	IS 3025 (Part 44): 2023	223	<250	mg/L
3.	CHEMICAL OXYGEN DEMAND	IS 3025 (Part 58) : 2023	408.4	<425	mg/L
4.	TOTAL SUSPENDED SOLIDS	IS 3025 (Part 17): 1988 (RA 2022)	248.65	<375	mg/L
5.	TOTAL NITROGEN	IS 3025 (Part 34/sec- 1):2023	35	<50	mg/L
6.	TOTAL PHOSPHORUS	IS 3025 (Part 31) :Sec 1 : 2022	2.7	<7.1	mg/L
7.	TOTAL COLIFORM	APHA 24 th Edition 2023 9221 B	10 ⁷	10 ⁷ -10 ⁸	(MPN)/100
8.	FECAL COLIFORM	APHA 24 th Edition 2023 9221 E	845	10 ⁴ -10 ⁸	(MPN)/100

Checked by
Senior Chemist



Authorised by
Lab Manager/CEO

End of Test Report

Remarks:

- BDL: Below Detectable Limit.
- The report pertains only to the sample tested and does not apply to the bulk quantity.
- The test report may not be reproduced, wholly or partially, nor used for promotional or publicity purposes without written consent from the laboratory department.
- Samples will be retained for 15 days after the completion of analysis. A longer retention period can be arranged upon customer request.



ISO 9001:2015 and ISO 17025:2017 NABL certified

No.4, Versetile Industrial Estate, Nr. Kotak Bank, Gate No.5,
Kathwada Gidc, Ahmedabad - 382430.

+91 8469130040, +91 6357351655 naturemicrovision@gmail.com GSTIN : 24AAWFN4704G1Z4

Test Report

Report ID: NML/WW/25-26/1256

Date: 16/02/2026


Customer Name	P.DAS INFRASTRUCTURE PVT LTD		
Customer Address	13.70 MLD DAHOD		
Date & Time of Sampling	10/02/2026	Sampling Plan & Method	IS 3025(Part-1) RA 2019
Date of Receipt of Sample	11/02/2026		
Sample Collected by	Client	Sample Condition	SATISFACTORY
Analysis Starting Date	11/02/2026	Packing / Seal	SEALED
Analysis Completion Date	16/02/2026	Quantity / No. of Samples	Approx. 1 LIT. * 1NO.
Environmental Condition	Temperature: 25 °C ± 2	Relative Humidity (%)	Humidity ≤ 50 %

Sample No.	Sample ID	Sample Type	Location	Description
1.	25-26/1265	Waste Water	Outlet	Treated Water

Analysis Results

Sr. No.	Parameters	Reference Method	Results	Regulatory Limit	Unit
1.	pH	IS 3025 (Part 11): 2022	7.55	6.5-9.0	--
2.	BIOLOGICAL OXYGEN DEMAND (3 days at 27°C)	IS 3025 (Part 44): 2023	8.1	<10	mg/L
3.	CHEMICAL OXYGEN DEMAND	IS 3025 (Part 58) : 2023	39	<50	mg/L
4.	TOTAL SUSPENDED SOLIDS	IS 3025 (Part 17): 1988 (RA 2022)	8.23	<10	mg/L
5.	AMMONICAL NITROGEN	IS 3025 (Part 34/sec-1):2023	1.9	<5	mg/L
6.	TOTAL NITROGEN	IS 3025 (Part 34/sec-1):2023	6.8	<10	mg/L
7.	TOTAL PHOSPHORUS	IS 3025 (Part 31) :Sec 1 : 2022	0.70	1	mg/L
8.	FECAL COLIFORM	APHA 24 th Edition 2023 9221 E	125	<230	(MPN)/100
9.	RESIDUAL CHLORINE	IS 3025 (Part 31) : Sec 1 : 2022	0.64	0.5-1.0	mg/L
10.	TOTAL COLIFORM	APHA 24 th Edition 2023 9221 B	225	<230	(MPN)/100

Checked by
Senior Chemist



End of Test Report

Authorised by
Lab Manager/CEO

Remarks:

- BDL: Below Detectable Limit.
- The report pertains only to the sample tested and does not apply to the bulk quantity.
- The test report may not be reproduced, wholly or partially, nor used for promotional or publicity purposes without written consent from the laboratory department.
- Samples will be retained for 15 days after the completion of analysis. A longer retention period can be arranged upon customer request.



ISO 9001:2015 and ISO 17025:2017 NABL certified

No.4, Versetile Industrial Estate, Nr. Kotak Bank, Gate No.5,
Kathwada Gidc, Ahmedabad - 382430.

+91 8469130040, +91 6357351655 naturemicrovision@gmail.com GSTIN : 24AAWFN4704G1Z4

Test Report

Report ID: NML/WW/25-26/1270


Date: 21/02/2026

Customer Name	P.DAS INFRASTRUCTURE PVT LTD		
Customer Address	5.60 MLD LUNAWADA		
Date & Time of Sampling	16/02/2026	Sampling Plan & Method	IS 3025(Part-1) RA 2019
Date of Receipt of Sample	17/02/2026		
Sample Collected by	Client	Sample Condition	SATISFACTORY
Analysis Starting Date	17/02/2026	Packing / Seal	SEALED
Analysis Completion Date	21/02/2026	Quantity / No. of Samples	Approx. 1 LIT. * 1NO.
Environmental Condition	Temperature: 25 °C ± 2	Relative Humidity (%)	Humidity ≤ 50 %

Sample No.	Sample ID	Sample Type	Location	Description
1.	25-26/1279	Waste Water	Inlet	Untreated Water

Analysis Results

Sr. No.	Parameters	Reference Method	Results	Regulatory Limit	Unit
1.	pH	IS 3025 (Part 11): 2022	7.72	6.5-7.0	--
2.	BIOLOGICAL OXYGEN DEMAND (3 days at 27°C)	IS 3025 (Part 44): 2023	216.2	<250	mg/L
3.	CHEMICAL OXYGEN DEMAND	IS 3025 (Part 58) : 2023	399	<425	mg/L
4.	TOTAL SUSPENDED SOLIDS	IS 3025 (Part 17): 1988 (RA 2022)	254.19	<375	mg/L
5.	TOTAL NITROGEN	IS 3025 (Part 34/sec- 1):2023	36	<50	mg/L
6.	TOTAL PHOSPHORUS	IS 3025 (Part 31) :Sec 1 : 2022	3.7	<7.1	mg/L
7.	TOTAL COLIFORM	APHA 24th Edition, 2023 9221 B	10 ⁸	10 ⁶ -10 ⁸	(MPN)/100
8.	FECAL COLIFORM	APHA 24th Edition 2023 9221 E	10 ³	10 ⁴ -10 ⁸	(MPN)/100


Checked by
Senior Chemist




Authorised by
Lab Manager/CEO

End of Test Report

Remarks:

- BDL: Below Detectable Limit.
- The report pertains only to the sample tested and does not apply to the bulk quantity.
- The test report may not be reproduced, wholly or partially, nor used for promotional or publicity purposes without written consent from the laboratory department.
- Samples will be retained for 15 days after the completion of analysis. A longer retention period can be arranged upon customer request.



ISO 9001:2015 and ISO 17025:2017 NABL certified

No.4, Versetile Industrial Estate, Nr. Kotak Bank, Gate No.5,
Kathwada Gidc, Ahmedabad - 382430.

+91 8469130040, +91 6357351655 naturemicrovision@gmail.com GSTIN : 24AAWFN4704G1Z4

Test Report

Report ID: NML/WW/25-26/1276

Date: 21/02/2026


Customer Name	P.DAS INFRASTRUCTURE PVT LTD		
Customer Address	5.60 MLD LUNAWADA		
Date & Time of Sampling	16/02/2026	Sampling Plan & Method	IS 3025(Part-1) RA 2019
Date of Receipt of Sample	17/02/2026		
Sample Collected by	Client	Sample Condition	SATISFACTORY
Analysis Starting Date	17/02/2026	Packing / Seal	SEALED
Analysis Completion Date	21/02/2026	Quantity / No. of Samples	Approx. 1 LIT. * 1NO.
Environmental Condition	Temperature: 25 °C ± 2	Relative Humidity (%)	Humidity ≤ 50 %

Sample No.	Sample ID	Sample Type	Location	Description
1.	25-26/1285	Waste Water	Outlet	Treated Water

Analysis Results

Sr. No.	Parameters	Reference Method	Results	Regulatory Limit	Unit
1.	pH	IS 3025 (Part 11): 2022	7.52	6.5-9.0	--
2.	BIOLOGICAL OXYGEN DEMAND (3 days at 27°C)	IS 3025 (Part 44): 2023	7.8	<10	mg/L
3.	CHEMICAL OXYGEN DEMAND	IS 3025 (Part 58) : 2023	38	<50	mg/L
4.	TOTAL SUSPENDED SOLIDS	IS 3025 (Part 17): 1988 (RA 2022)	8.0	<10	mg/L
5.	AMMONICAL NITROGEN	IS 3025 (Part 34/sec-1):2023	2.3	<5	mg/L
6.	TOTAL NITROGEN	IS 3025 (Part 34/sec- 1):2023	7.3	<10	mg/L
7.	TOTAL PHOSPHORUS	IS 3025 (Part 31) :Sec 1 : 2022	0.75	1	mg/L
8.	FECAL COLIFORM	APHA 24th Edition 2023 9221 E	140	<230	(MPN)/100
9.	RESIDUAL CHLORINE	IS 3025 (Part 31) : Sec 1 : 2022	0.61	0.5-1.0	mg/L
10.	TOTAL COLIFORM	APHA 24th Edition 2023 9221 B	190	<230	(MPN)/100

Checked by
Senior Chemist



Authorised by
Lab Manager/CEO

Remarks:

- BDL: Below Detectable Limit.
- The report pertains only to the sample tested and does not apply to the bulk quantity.
- The test report may not be reproduced, wholly or partially, nor used for promotional or publicity purposes without written consent from the laboratory department.
- Samples will be retained for 15 days after the completion of analysis. A longer retention period can be arranged upon customer request.



TEST REPORT

REPORT NO: AEPL/02-26/0072

ISSUE DATE: 18-02-2026


NAME OF CLIENT: SEWAGE TREATMENT PLANT (27.6 MLD)

ADDRESS: Godhra, Dist. Panchmahal, Gujarat

SAMPLE TYPE	: Wastewater
LOCATION OF SAMPLE	: STP
DESCRIPTION	: Inlet
SAMPLING PROTOCOL / STANDARD	: NA
TYPE OF SAMPLING	: NA
SAMPLE COLLECTED/ RECEIVED IN	: Plastic Carboy
QUANTITY	: 2.0 Ltrs
SAMPLE CONDITION	: Acceptable
SAMPLING DATE	: NA
SAMPLE RECIEPT DATE	: 11-02-2026
ANALYSIS START DATE	: 11-02-2026
ANALYSIS END DATE	: 18-02-2026
TEST CONDITIONS	Temperature (°C): 25.2 Relative Humidity (%): 46

RESULTS

SR.NO	PARAMETERS	UNIT	INLET	REFERENCE METHOD
1.	pH @ 25 °C	-	7.80	IS 3025 (Part-11) 2017
2.	Total Suspended Solids	mg/L	370	APHA 23rd Edition 2017 2540-D
3.	Chemical Oxygen Demand	mg/L	520	IS 3025 (Part-58) 2017
4.	BOD (3 Days@ 27 °C)	mg/L	230	IS 3025 (Part-44) 2017
5.	Ammonical Nitrogen	mg/L	42	APHA 23 rd Edition 2017 4500 NH ₃ , B, C
6.	Total Nitrogen	mg/L	57	APHA 23 rd Edition 2017 4500 NH ₃ , N _(org) C
7.	Total Phosphorus	mg/L	7.5	APHA 23 rd Edition 2017 4500 P C
8.	Total Coliform	MPN/100 ml	> 1100	APHA 23rd Edition 2017 9221 B
9.	Fecal Coliform	MPN/100 ml	> 1100	APHA 23rd Edition 2017 9221 D


 Authorized Signatory
 Hardik Pathak
 Quality Manager

* End of Report *

Information provided by the Customer: N.A.

Note:

1. This report shall not be reproduced in part or full without prior permission of Aagam Environment Pvt Ltd.
2. The results listed herewith are only for the items tested.
3. Sample shall be disposed after 15 days from the date of issue of the report unless agreed with the customer.
4. Incase when laboratory is not involved in sampling, the results apply to the samples as received.
5. This report shall not be used for publicity or litigation.
6. Tests performed by External Provider shall be identified/marked by ""*"" sign.
7. Any additions to, deviations or exclusions from the method shall be identified by ""*"" sign.

Shed - 92, Pushkar Industrial Hub - 4, GIDC Vatva, Opp. Machhunagar Torrent Compound,
 Ahmedabad-382445, Gujarat.



TEST REPORT

REPORT NO: AEPL/02-26/0073

ISSUE DATE: 18-02-2026

NAME OF CLIENT: SEWAGE TREATMENT PLANT (27.6 MLD)

ADDRESS: Godhra, Dist. Panchmahal, Gujarat

SAMPLE TYPE	: Wastewater
LOCATION OF SAMPLE	: STP
DESCRIPTION	: Outlet
SAMPLING PROTOCOL / STANDARD	: NA
TYPE OF SAMPLING	: NA
SAMPLE COLLECTED/ RECEIVED IN	: Plastic Carboy
QUANTITY	: 2.5 Ltrs
SAMPLE CONDITION	: Acceptable
SAMPLING DATE	: NA
SAMPLE RECEIPT DATE	: 11-02-2026
ANALYSIS START DATE	: 11-02-2026
ANALYSIS END DATE	: 18-02-2026
TEST CONDITIONS	Temperature (°C): 25.2 Relative Humidity (%): 46

RESULTS

SR.NO	PARAMETERS	UNIT	OUTLET	REFERENCE METHOD
1.	pH @ 25 °C	-	7.39	IS 3025 (Part-11) 2017
2.	Total Suspended Solids	mg/L	11	APHA 23rd Edition 2017 2540-D
3.	Chemical Oxygen Demand	mg/L	38	IS 3025 (Part-58) 2017
4.	BOD (3 Days@ 27 °C)	mg/L	9.4	IS 3025 (Part-44) 2017
5.	Ammonical Nitrogen	mg/L	3.1	APHA 23rd Edition 2017 4500 NH ₃ , B, C
6.	Total Nitrogen	mg/L	5.5	APHA 23rd Edition 2017 4500 NH ₃ , N _(org) , C
7.	Total Phosphorus	mg/L	0.8	APHA 23rd Edition 2017 4500 P C
8.	Residual Chlorine	mg/L	1.0	APHA 23rd Edition 2017 4500 Cl- B
9.	Total Coliform	MPN/100 ml	220	APHA 23rd Edition 2017 9221 B
10.	Fecal Coliform	MPN/100 ml	59	APHA 23rd Edition 2017 9221 D


 Authorized Signatory
 Hardik Pathak
 Quality Manager

* End of Report *

Information provided by the Customer: N.A.

Note:

1. This report shall not be reproduced in part or full without prior permission of Aagam Environment Pvt Ltd.
2. The results listed herewith are only for the items tested.
3. Sample shall be disposed after 15 days from the date of issue of the report unless agreed with the customer.
4. In case when laboratory is not involved in sampling, the results apply to the samples as received.
5. This report shall not be used for publicity or litigation.
6. Tests performed by External Provider shall be identified/ marked by *** sign.
7. Any additions, deviations or exclusions from the method shall be identified by *** sign.

Shed - 92, Pushkar Industrial Hub - 4, GIDC Vatva, Opp. Machhunagar Torrent Compound,
 Ahmedabad-382445, Gujarat.



ISO 9001:2015 and ISO 17025:2017 NABL certified

No.4, Versetile Industrial Estate, Nr. Kotak Bank, Gate No.5,
Kathwada Gidc, Ahmedabad - 382430.

+91 8469130040, +91 6357351655 naturemicrovision@gmail.com GSTIN : 24AAWFN4704G1Z4

Test Report

Report ID: NML/WW/25-26/1199

Date: 07/02/2026

Customer Name	P.DAS INFRASTRUCTURE PVT LTD		
Customer Address	9.80 MLD BORSAD		
Date & Time of Sampling	02/02/2026	Sampling Plan & Method	IS 3025(Part-1) RA 2019
Date of Receipt of Sample	03/02/2026		
Sample Collected by	Client	Sample Condition	SATISFACTORY
Analysis Starting Date	03/02/2026	Packing / Seal	SEALED
Analysis Completion Date	06/02/2026	Quantity / No. of Samples	Approx. 1 LIT. * 1NO.
Environmental Condition	Temperature: 25 °C ± 2	Relative Humidity (%)	Humidity ≤ 50 %

Sample No.	Sample ID	Sample Type	Location	Description
1.	25-26/1208	Waste Water	Inlet	Untreated Water

Analysis Results

Sr. No.	Parameters	Reference Method	Results	Regulatory Limit	Unit
1.	pH	IS 3025 (Part 11): 2022	7.52	6.5-7.0	--
2.	BIOLOGICAL OXYGEN DEMAND (3 days at 27°C)	IS 3025 (Part 44): 2023	241.5	<250	mg/L
3.	CHEMICAL OXYGEN DEMAND	IS 3025 (Part 58) : 2023	401	<425	mg/L
4.	TOTAL SUSPENDED SOLIDS	IS 3025 (Part 17): 1988 (RA 2022)	256.21	<375	mg/L
5.	TOTAL NITROGEN	IS 3025 (Part 34/sec- 1):2023	33	<50	mg/L
6.	TOTAL PHOSPHORUS	IS 3025 (Part 31) :Sec 1 : 2022	2.9	<7.1	mg/L
7.	TOTAL COLIFORM	APHA 24th Edition 2023 9221 B	10 ⁷	10 ⁷ -10 ⁸	(MPN)/100
8.	FECAL COLIFORM	APHA 24th Edition 2023 9221 E	1011	10 ⁴ -10 ⁸	(MPN)/100


Checked by
Senior Chemist




Authorised by
Lab Manager/CEO

End of Test Report

Remarks:

- BDL: Below Detectable Limit.
- The report pertains only to the sample tested and does not apply to the bulk quantity.
- The test report may not be reproduced, wholly or partially, nor used for promotional or publicity purposes without written consent from the laboratory department.
- Samples will be retained for 15 days after the completion of analysis. A longer retention period can be arranged upon customer request.



ISO 9001:2015 and ISO 17025:2017 NABL certified

No.4, Versetile Industrial Estate, Nr. Kotak Bank, Gate No.5, Kathwada Gidc, Ahmedabad - 382430.

+91 8469130040, +91 6357351655 naturemicrovision@gmail.com GSTIN : 24AAWFN4704G1Z4

Test Report

Report ID: NML/WW/25-26/1200

Date: 07/02/2026

Customer Name	P.DAS INFRASTRUCTURE PVT LTD		
Customer Address	9.80 MLD BORSAD		
Date & Time of Sampling	02/02/2026	Sampling Plan & Method	IS 3025(Part-1) RA 2019
Date of Receipt of Sample	03/02/2026		
Sample Collected by	Client	Sample Condition	SATISFACTORY
Analysis Starting Date	03/02/2026	Packing / Seal	SEALED
Analysis Completion Date	06/02/2026	Quantity / No. of Samples	Approx. 1 LIT. * 1NO.
Environmental Condition	Temperature: 25 °C ± 2	Relative Humidity (%)	Humidity ≤ 50 %

Sample No.	Sample ID	Sample Type	Location	Description
1.	25-26/1209	Waste Water	Outlet	Treated Water

Analysis Results

Sr. No.	Parameters	Reference Method	Results	Regulatory Limit	Unit
1.	pH	IS 3025 (Part 11): 2022	7.62	6.5-9.0	--
2.	BIOLOGICAL OXYGEN DEMAND (3 days at 27°C)	IS 3025 (Part 44): 2023	8.6	<10	mg/L
3.	CHEMICAL OXYGEN DEMAND	IS 3025 (Part 58) : 2023	41	<50	mg/L
4.	TOTAL SUSPENDED SOLIDS	IS 3025 (Part 17): 1988 (RA 2022)	8.6	<10	mg/L
5.	AMMONICAL NITROGEN	IS 3025 (Part 34/sec-1):2023	2.7	<5	mg/L
6.	TOTAL NITROGEN	IS 3025 (Part 34/sec- 1):2023	7.9	<10	mg/L
7.	TOTAL PHOSPHORUS	IS 3025 (Part 31) :Sec 1 : 2022	0.69	1	mg/L
8.	FECAL COLIFORM	APHA 24th Edition 2023 9221 E	128	<230	(MPN)/100
9.	RESIDUAL CHLORINE	IS 3025 (Part 31) : Sec 1 : 2022	0.73	0.5-1.0	mg/L
10.	TOTAL COLIFORM	APHA 24th Edition 2023 9221 B	450	<230	(MPN)/100

Checked by Senior Chemist



Authorised by Lab Manager/CEO

End of Test Report

Remarks:

- BDL: Below Detectable Limit.
- The report pertains only to the sample tested and does not apply to the bulk quantity.
- The test report may not be reproduced, wholly or partially, nor used for promotional or publicity purposes without written consent from the laboratory department.
- Samples will be retained for 15 days after the completion of analysis. A longer retention period can be arranged upon customer request.

Test Report
Water Sample Analysis Report

Client's Name & Address: GWSSB, Anand, Petlad 10.37 MLD STP	Report No: GLEPL/230225/348 Issue Date: 20/01/2026
--	---

Lab ID Code	:	GLEPL/230222/WL ₁
Sample Description	:	Waste Water (STP Inlet) Purpose : As per Client requirement
Date of Sampling	:	Submitted by Client Sample Collected/Submitted by : Submitted by Client
Date of Sample Received	:	11/01/2026 Test Parameters : As per Client requirement
Date of starting Analysis	:	12/01/2026 Quantity/No. of sample : 2 Lit./01
Date of completion Analysis	:	18/01/2026 Packed/Seal : Sealed

Result Table

Sr. No.	Test Parameters	Test Method	Unit	Results
1	pH @30 °C	IS 3025 (P-11) 1983 (Reaffirmed 2017)	pH Unit	6.91
2	Total Suspended Solids	IS 3025 (P-17) 1984 (Reaffirmed 2017)	mg/L	108
3	Chemical Oxygen Demand	IS 3025 (P-58) 2006 (Reaffirmed 2017)	mg/L	276.2
4	BOD (5 days at 20°C)	IS 3025 (P-44) 1993 (Reaffirmed 2019)	mg/L	125.7
5	Ammonical Nitrogen	IS 3025 (P-34) 1988 (Reaffirmed 2019)	mg/L	-
6	Total Phosphorus	IS 3025 (P-31) 1988 (Reaffirmed 2019)	mg/L	4.48
7	Total Kjeldahl Nitrogen	IS 3025 (P-34) 1988 (Reaffirmed 2019)	mg/L	16.8
8	Residual Chlorine	IS 3025 (P-26) 1986 (Reaffirmed 2019)	mg/L	ND
9	Total Coliform	APHA & AWWA 23 rd Ed. 9221 E (9-77)	MPN/100mL	1.8x10 ³
10	Fecal Coliform	APHA & AWWA 23 rd Ed. 9221 E (9-77)	MPN/100mL	1x10 ⁵

Note: BDL: Below Detection Limit, **ND:** Not Detected.

WL₁: STP Inlet Water



Chemist



Authorized Signatory
Rekha Dare

- Notes: (1) The results pertain to tested items only.
(2) This report shall not be reproduced, except in full, without written approval of the laboratory.
(3) Authenticity of this Report could be validated with office copy at Greenleaf Envirotech Pvt. Ltd.
(4) Perishable samples will be destroyed after testing, others after 7 days from the date of issue of the report, unless otherwise agreed with the customer or as required by the applicable regulations.

Test Report
Water Sample Analysis Report


Client's Name & Address: GWSSB, Anand, Petlad 10.37 MLD STP	Report No: GLEPL/230225/349 Issue Date: 20/01/2026
--	---

Lab ID Code	:	GLEPL/230222/WL ₂	
Sample Description	:	Waste Water (STP Outlet)	Purpose : As per Client requirement
Date of Sampling	:	Submitted by Client	Sample Collected/Submitted by : Submitted by Client
Date of Sample Received	:	11/01/2026	Test Parameters : As per Client requirement
Date of starting Analysis	:	12/01/2026	Quantity/No. of sample : 2 Lit./02
Date of completion Analysis	:	18/01/2026	Packed/Seal : Sealed

Result Table

Sr. No.	Test Parameters	Test Method	Unit	Results	Permissible Limit
1	pH @30 °C	IS 3025 (P-11) 1983 (Reaffirmed 2017)	pH Unit	7.18	6.5-9.0
2	Total Suspended Solids	IS 3025 (P-17) 1984 (Reaffirmed 2017)	mg/L	20.3	<10
3	Chemical Oxygen Demand	IS 3025 (P-58) 2006 (Reaffirmed 2017)	mg/L	12.86	<50
4	BOD (5 days at 20°C)	IS 3025 (P-44) 1993 (Reaffirmed 2019)	mg/L	3.302	<10
5	Ammonical Nitrogen	IS 3025 (P-34) 1988 (Reaffirmed 2019)	mg/L	-	<5.0
6	Total Phosphorus	IS 3025 (P-31) 1988 (Reaffirmed 2019)	mg/L	0.85	<1.0
7	Total Nitrogen	IS 3025 (P-34) 1988 (Reaffirmed 2019)	mg/L	14.5	<10.0
8	Residual Chlorines	IS 3025 (P-26) 1986 (Reaffirmed 2019)	mg/L	ND	0.5-1.0
9	Fecal Coliform	APHA & AWWA 23 rd Ed. 9221 E (9-77)	MPN/100mL	362	<230
10	Total Coliform	APHA & AWWA 23 rd Ed. 9221 E (9-77)	MPN/100mL	172	

Note: BDL: Below Detection Limit.
WL₁: STP Outlet Water



Chemist



Authorized Signatory
Rekha Dare

Notes: (1) The results pertain to tested items only.
(2) This report shall not be reproduced, except in full, without written approval of the laboratory.
(3) Authenticity of this Report could be validated with office copy at Greenleaf Envirotech Pvt. Ltd.
(4) Perishable samples will be destroyed after testing, others after 7 days from the date of issue of the report, unless otherwise agreed with the customer or as required by the applicable regulations.
Recognized by **MoEF**, Govt. of India, EP Act 1986; **NABL** accredited; **GPCB** Schedule II Environment Auditor; **OHSAS** – 18001:2017 Certified Laboratory.



NATURE MICROVISION LLP

808

ISO 9001:2015 and ISO 17025:2017 NABL certified

No.4, Versetile Industrial Estate, Nr. Kotak Bank, Gate No.5,
Kathwada Gidc, Ahmedabad - 382430.

+91 8469130040, +91 6357351655 naturemicrovision@gmail.com GSTIN : 24AAWFN4704G1Z4

Test Report

Report ID: NML/WW/25-26/1288

Date: 25/02/2026


Customer Name		Nagarpalika Chhotaudaipur		
Customer Address		5 MLD Chhota Udaipur		
Date & Time of Sampling	20/02/2026	Sampling Plan & Method	IS 3025(Part-1) RA 2019	
Date of Receipt of Sample	21/02/2026			
Sample Collected by	Client	Sample Condition	SATISFACTORY	
Analysis Starting Date	21/02/2026	Packing / Seal	SEALED	
Analysis Completion Date	24/02/2026	Quantity / No. of Samples	Approx. 1 LIT. * 1NO.	
Environmental Condition	Temperature: 25 °C ± 2	Relative Humidity (%)	Humidity ≤ 50 %	
Sample No.	Sample ID	Sample Type	Location	Description
1.	25-26/1297	Waste Water	Inlet	Untreated Water

Analysis Results

Sr. No.	Parameters	Reference Method	Results	Unit
1.	pH	IS 3025 (Part 11): 2022	7.24	--
2.	BIOLOGICAL OXYGEN DEMAND (3 days at 27°C)	IS 3025 (Part 44): 2023	210.2	mg/L
3.	CHEMICAL OXYGEN DEMAND	IS 3025 (Part 58) : 2023	398.8	mg/L
4.	TOTAL SUSPENDED SOLIDS	IS 3025 (Part 17): 1988 (RA 2022)	302.29	mg/L
5.	TOTAL NITROGEN	IS 3025 (Part 34/sec- 1):2023	32	mg/L
6.	TOTAL PHOSPHORUS	IS 3025 (Part 31) :Sec 1 : 2022	2.8	mg/L
7.	FECAL COLIFORM	APHA 24th Edition 2023 9221 E	1.1 × 10 ²	(MPN)/100
8.	TOTAL COLIFORM	APHA 24th Edition 2023 9221 B	Present	(MPN)/100


Checked by
Senior Chemist




Authorised by
Lab Manager/CEO

End of Test Report

Remarks:

- BDL: Below Detectable Limit.
- The report pertains only to the sample tested and does not apply to the bulk quantity.
- The test report may not be reproduced, wholly or partially, nor used for promotional or publicity purposes without written consent from the laboratory department.
- Samples will be retained for 15 days after the completion of analysis. A longer retention period can be arranged upon customer request.



ISO 9001:2015 and ISO 17025:2017 NABL certified

No.4, Versetile Industrial Estate, Nr. Kotak Bank, Gate No.5,
Kathwada Gidc, Ahmedabad - 382430.

+91 8469130040, +91 6357351655 naturemicrovision@gmail.com GSTIN : 24AAWFN4704G1Z4

Test Report

Report ID: NML/WW/25-26/1289

Date: 25/02/2026

Customer Name		Nagarpalika Chhotaudaipur		
Customer Address		5 MLD Chhota Udaipur		
Date & Time of Sampling		20/02/2026	Sampling Plan & Method	IS 3025(Part-1) RA 2019
Date of Receipt of Sample		21/02/2026		
Sample Collected by		Client	Sample Condition	SATISFACTORY
Analysis Starting Date		21/02/2026	Packing / Seal	SEALED
Analysis Completion Date		24/02/2026	Quantity / No. of Samples	Approx. 1 LIT. * 1NO.
Environmental Condition		Temperature: 25 °C ± 2	Relative Humidity (%)	Humidity ≤ 50 %
Sample No.	Sample ID	Sample Type	Location	Description
1.	25-26/1298	Waste Water	Outlet	Treated Water

Analysis Results

Sr. No.	Parameters	Reference Method	Results	Regulatory Limit	Unit
1.	pH	IS 3025 (Part 11): 2022	7.48	6.5-9.0	--
2.	BIOLOGICAL OXYGEN DEMAND (3 days at 27°C)	IS 3025 (Part 44): 2023	7.5	<10	mg/L
3.	CHEMICAL OXYGEN DEMAND	IS 3025 (Part 58) : 2023	37	<50	mg/L
4.	TOTAL SUSPENDED SOLIDS	IS 3025 (Part 17): 1988 (RA 2022)	7.19	<10	mg/L
5.	AMMONICAL NITROGEN	IS 3025 (Part 34/sec-1):2023	2.7	<5	mg/L
6.	TOTAL NITROGEN	IS 3025 (Part 34/sec- 1):2023	6.8	<10	mg/L
7.	TOTAL PHOSPHORUS	IS 3025 (Part 31) :Sec 1 : 2022	0.67	<2	mg/L
8.	FECAL COLIFORM	APHA 24th Edition 2023 9221 E	80	<230	(MPN)/100
9.	TOTAL COLIFORM	APHA 24th Edition 2023 9221 B	114	<230	(MPN)/100
10.	RESIDUAL CHLORINE	IS 3025 (Part 31) : Sec 1 : 2022	0.62	0.5-1.0	mg/L

Checked by
Senior Chemist



End of Test Report

Authorised by
Lab Manager/CEO

Remarks:

- BDL: Below Detectable Limit.
- The report pertains only to the sample tested and does not apply to the bulk quantity.
- The test report may not be reproduced, wholly or partially, nor used for promotional or publicity purposes without written consent from the laboratory department.
- Samples will be retained for 15 days after the completion of analysis. A longer retention period can be arranged upon customer request.

Test Report

Water/Waste Water Analysis			Issue No. 06	Doc. No. F/LMS/67 Page No. : 1 of 1
Report No:-EAC/WAT/912602A ULR ID :- TC172362600000446F		Issue Date:- 25/02/2026		
CUSTOMER NAME: - M/s. Balasinor Water Recycling Pvt. Ltd ADDRESS: - Near Indira nagar Handiya – 388255, Balasinor, Dist : Mahisagar				
Sample Details				
Sample ID	EAC/WAT/91	Sampling Date	-	
Source of Sample	STP Inlet	Sample Received Date	19/02/2026	
Sample Description	Untreated Waste Water	Analysis Start Date	19/02/2026	
Sample Quantity	2 Liter	Analysis Completion Date	25/02/2026	
Sample Collected By	Client	Report sent to (Name & Address)	M/s. Balasinor Water Recycling Pvt. Ltd	
Environmental conditions during sampling	NA	Packed/Seal	Packed	
		Sampling Plan & Procedure	QP/23.0	
Analysis Result				
Sr. No.	Parameter	Result	Unit	Test Method
1	pH at 25 °C	6.89	-	IS 3025 (Part 11)- 2022
2	Total Suspended Solids	226.8	mg/L	APHA 24 th Edition 2540 D: 2023
3	Chemical Oxygen Demand	388.00	mg/L	APHA 24 th Edition 5220 B: 2023
4	Biochemical Oxygen Demand (5 days at 20 °C)	122.45	mg/L	IS 3025 (Part 44):1993
Opinion & Interpretation:		Not Practiced		
		 Authorized Signatory (Ms. Nirali Trivedi) Quality Manager		

----- (End of the Report) -----

DISCLAIMERS:

- 1) A statement to the effect that the result relates only to the items tested, calibrated or sampled.
- 2) Additions to, deviations, or exclusions from the method is not practiced if not mentioned.
- 3) Results are from external providers are not used if not specified.
- 4) NA=Not Analysis, BDL=Below Detection Limit, ND- Not Detectable

Test Report

Water/Waste Water Analysis		Issue No. 06	Doc .No. F/LMS/67 Page No. : 1 of 1	
Report No:-EAC/WAT/912602B		Issue Date:- 25/02/2026		
CUSTOMER NAME: - M/s. Balasinor Water Recycling Pvt. Ltd				
ADDRESS: - Near Indira nagar Handiya – 388255, Balasinor, Dist : Mahisagar				
Sample Details				
Sample ID	EAC/WAT/91	Sampling Date	-	
Source of Sample	STP Inlet	Sample Received Date	19/02/2026	
Sample Description	Untreated Waste Water	Analysis Start Date	19/02/2026	
Sample Quantity	2 Liter	Analysis Completion Date	25/02/2026	
Sample Collected By	Client	Report sent to (Name & Address)	M/s. Balasinor Water Recycling Pvt. Ltd	
Environmental conditions during sampling	NA	Packed/Seal	Packed	
		Sampling Plan & Procedure	QP/23.0	
Analysis Result				
Sr. No.	Parameter	Result	Unit	Test Method
1	Total Nitrogen	18.00	mg/L	IS 3025 (Part 34):1988, Rea.:2019
2	Total Coliform	400.00	CFU/100 ml	APHA 24 th Edition. 9221 B;2023
3	Total Phosphorus	1.50	mg/L	APHA 24 th Edition 4500 P B: 2023
4	Fecal Coliform	47.00	CFU/100 ml	APHA 24 th Edition. 9221 E;2023
Opinion & Interpretation:		Not Practiced		
				 Authorized Signatory (Ms. Nirali Trivedi) Quality Manager

----- (End of the Report) -----

DISCLAIMERS:

- 1) A statement to the effect that the result relates only to the items tested, calibrated or sampled.
- 2) Additions to, deviations, or exclusions from the method is not practiced if not mentioned.
- 3) Results are from external providers are not used if not specified.
- 4) NA=Not Analysis, BDL=Below Detection Limit, ND- Not Detectable

Test Report

Water/Waste Water Analysis			Issue No. 06	Doc .No. F/LMS/67 Page No. : 1 of 1
Report No:-EAC/WAT/922602A ULR ID :- TC172362600000447F		Issue Date:- 25/02/2026		
CUSTOMER NAME: - M/s. Balasinor Water Recycling Pvt. Ltd ADDRESS: - Near Indira nagar Handiya – 388255, Balasinor, Dist : Mahisagar				
Sample Details				
Sample ID	EAC/WAT/92	Sampling Date	-	
Source of Sample	STP Outlet	Sample Received Date	19/02/2026	
Sample Description	Treated Waste Water	Analysis Start Date	19/02/2026	
Sample Quantity	2 Liter	Analysis Completion Date	25/02/2026	
Sample Collected By	Client	Report sent to (Name & Address)	M/s. Balasinor Water Recycling Pvt. Ltd	
Environmental conditions during sampling	NA	Packed/Seal	Packed	
		Sampling Plan & Procedure	QP/23.0	
Analysis Result				
Sr. No.	Parameter	Result	Unit	Test Method
1	pH at 25 °C	7.02	-	IS 3025 (Part 11)- 2022
2	Total Suspended Solids	BDL<10	mg/L	APHA 24 th Edition 2540 D: 2023
3	Chemical Oxygen Demand	12.00	mg/L	APHA 24 th Edition 5220 B: 2023
4	Biochemical Oxygen Demand (5 days at 20 °C)	BDL<10	mg/L	IS 3025 (Part 44):1993
5	Ammonical Nitrogen	1.12	mg/L	APHA 24 th Edition 4500 NH ₃ : 2023
Opinion & Interpretation:		Not Practiced		
		 Authorized Signatory (Ms. Nirali Trivedi) Quality Manager		

----- (End of the Report) -----

DISCLAIMERS:

- 1) A statement to the effect that the result relates only to the items tested, calibrated or sampled.
- 2) Additions to, deviations, or exclusions from the method is not practiced if not mentioned.
- 3) Results are from external providers are not used if not specified.
- 4) NA=Not Analysis, BDL=Below Detection Limit, ND- Not Detectable

Test Report

Water/Waste Water Analysis		Issue No. 06	Doc.No. F/LMS/67 Page No. : 1 of 1	
Report No:- EAC/WAT/922602B		Issue Date:- 25/02/2026		
CUSTOMER NAME: - M/s. Balasinor Water Recycling Pvt. Ltd				
ADDRESS: - Near Indira nagar Handiya – 388255, Balasinor, Dist : Mahisagar				
Sample Details				
Sample ID	EAC/WAT/92	Sampling Date	-	
Source of Sample	STP Outlet	Sample Received Date	19/02/2026	
Sample Description	Treated Waste Water	Analysis Start Date	19/02/2026	
Sample Quantity	2 Liter	Analysis Completion Date	25/02/2026	
Sample Collected By	Client	Report sent to (Name & Address)	M/s. Balasinor Water Recycling Pvt. Ltd	
Environmental conditions during sampling	NA	Packed/Seal	Packed	
		Sampling Plan & Procedure	QP/23.0	
Analysis Result				
Sr. No.	Parameter	Result	Unit	Test Method
1	Total Nitrogen	1.85	mg/L	IS 3025 (Part 34):1988, Rea.:2019
2	Fecal Coliform	Absent	CFU/100 ml	APHA 24 th Edition. 9221 E;2023
3	Total Phosphorus	BDL	mg/L	APHA 24 th Edition 4500 P B: 2023
4	Total Coliform	Absent	CFU/100 ml	APHA 24 th Edition. 9221 B;2023
5	Residual Free Chlorine	1.00	mg/L	APHA 24 th Edition 4500 Cl ⁻ B:2023
Opinion & Interpretation:		Not Practiced		
				 Authorized Signatory (Ms. Nirali Trivedi) Quality Manager

----- (End of the Report) -----

DISCLAIMERS:

- 1) A statement to the effect that the result relates only to the items tested, calibrated or sampled.
- 2) Additions to, deviations, or exclusions from the method is not practiced if not mentioned.
- 3) Results are from external providers are not used if not specified.
- 4) NA=Not Analysis, BDL=Below Detection Limit, ND- Not Detectable

Test Report
Water Sample Analysis Report

Client's Name & Address: GWSSB,Panchmahal Halol 12.35 MLD STP	Report No: GLEPL/230225/348 Issue Date: 28/02/2026
--	---

Lab ID Code	:	GLEPL/230222/WL ₁
Sample Description	:	Waste Water (STP Inlet) Purpose : As per Client requirement
Date of Sampling	:	Submitted by Client Sample Collected/Submitted by : Submitted by Client
Date of Sample Received	:	19/02/2026 Test Parameters : As per Client requirement
Date of starting Analysis	:	20/02/2026 Quantity/No. of sample : 2 Lit./01
Date of completion Analysis	:	26/02/2026 Packed/Seal : Sealed

Result Table

Sr. No.	Test Parameters	Test Method	Unit	Results
1	pH @30 °C	IS 3025 (P-11) 1983 (Reaffirmed 2017)	pH Unit	7.1
2	Total Suspended Solids	IS 3025 (P-17) 1984 (Reaffirmed 2017)	mg/L	197
3	Chemical Oxygen Demand	IS 3025 (P-58) 2006 (Reaffirmed 2017)	mg/L	179
4	BOD (5 days at 20°C)	IS 3025 (P-44) 1993 (Reaffirmed 2019)	mg/L	117
5	Ammonical Nitrogen	IS 3025 (P-34) 1988 (Reaffirmed 2019)	mg/L	-
6	Total Phosphorus	IS 3025 (P-31) 1988 (Reaffirmed 2019)	mg/L	2.7
7	Total Kjeldahl Nitrogen	IS 3025 (P-34) 1988 (Reaffirmed 2019)	mg/L	16
8	Residual Chlorine	IS 3025 (P-26) 1986 (Reaffirmed 2019)	mg/L	ND
9	Total Coliform	APHA & AWWA 23 rd Ed. 9221 E (9-77)	MPN/100mL	1.6x10 ³
10	Fecal Coliform	APHA & AWWA 23 rd Ed. 9221 E (9-77)	MPN/100mL	405

Note: BDL: Below Detection Limit, ND: Not Detected.

WL₁: STP Inlet Water



Chemist



Authorized Signatory
Rekha Dare

- Notes: (1) The results pertain to tested items only.
(2) This report shall not be reproduced, except in full, without written approval of the laboratory.
(3) Authenticity of this Report could be validated with office copy at Greenleaf Envirotech Pvt. Ltd.
(4) Perishable samples will be destroyed after testing, others after 7 days from the date of issue of the report, unless otherwise agreed with the customer or as required by the applicable regulations.

Test Report
Water Sample Analysis Report

Client's Name & Address: GWSSB,Panchmahal Halol 12.35 MLD STP	Report No: GLEPL/230225/349 Issue Date: 28/02/2026
--	---

Lab ID Code	:	GLEPL/230222/WL ₂	
Sample Description	:	Waste Water (STP Outlet)	Purpose : As per Client requirement
Date of Sampling	:	Submitted by Client	Sample Collected/Submitted by : Submitted by Client
Date of Sample Received	:	19/02/2026	Test Parameters : As per Client requirement
Date of starting Analysis	:	20/02/2026	Quantity/No. of sample : 2 Lit./02
Date of completion Analysis	:	26/02/2026	Packed/Seal : Sealed

Result Table

Sr. No.	Test Parameters	Test Method	Unit	Results	Permissible Limit
1	pH @30 °C	IS 3025 (P-11) 1983 (Reaffirmed 2017)	pH Unit	7.2	6.5-9.0
2	Total Suspended Solids	IS 3025 (P-17) 1984 (Reaffirmed 2017)	mg/L	4	<10
3	Chemical Oxygen Demand	IS 3025 (P-58) 2006 (Reaffirmed 2017)	mg/L	36	<50
4	BOD (5 days at 20°C)	IS 3025 (P-44) 1993 (Reaffirmed 2019)	mg/L	7	<10
5	Ammonical Nitrogen	IS 3025 (P-34) 1988 (Reaffirmed 2019)	mg/L	-	<5.0
6	Total Phosphorus	IS 3025 (P-31) 1988 (Reaffirmed 2019)	mg/L	0.5	<1.0
7	Total Nitrogen	IS 3025 (P-34) 1988 (Reaffirmed 2019)	mg/L	4.5	<10.0
8	Residual Chlorines	IS 3025 (P-26) 1986 (Reaffirmed 2019)	mg/L	ND	0.5-1.0
9	Fecal Coliform	APHA & AWWA 23 rd Ed. 9221 E (9-77)	MPN/100mL	139	<230
10	Total Coliform	APHA & AWWA 23 rd Ed. 9221 E (9-77)	MPN/100mL	172	

Note: BDL: Below Detection Limit.
WL₁: STP Outlet Water



Chemist



Authorized Signatory
Rekha Dare

Notes: (1) The results pertain to tested items only.
(2) This report shall not be reproduced, except in full, without written approval of the laboratory.
(3) Authenticity of this Report could be validated with office copy at Greenleaf Envirotech Pvt. Ltd.
(4) Perishable samples will be destroyed after testing, others after 7 days from the date of issue of the report, unless otherwise agreed with the customer or as required by the applicable regulations.
Recognized by **MoEF**, Govt. of India, EP Act 1986; **NABL** accredited; **GPCB** Schedule II Environment Auditor; **OHSAS** – 18001:2017 Certified Laboratory.

Test Report
Water Sample Analysis Report

Client's Name & Address: GWSSB, Panchmahal Dabhoi 9 MLD STP	Report No: GLEPL/230225/348 Issue Date: 10/02/2026
--	---

Lab ID Code	: GLEPL/230222/WL ₁
Sample Description	: Waste Water (STP Inlet) Purpose : As per Client requirement
Date of Sampling	: Submitted by Client Sample Collected/Submitted by : Submitted by Client
Date of Sample Received	: 1/02/2026 Test Parameters : As per Client requirement
Date of starting Analysis	: 2/02/2026 Quantity/No. of sample : 2 Lit./01
Date of completion Analysis	: 8/02/2026 Packed/Seal : Sealed

Result Table

Sr. No.	Test Parameters	Test Method	Unit	Results
1	pH @30 °C	IS 3025 (P-11) 1983 (Reaffirmed 2017)	pH Unit	7.8
2	Total Suspended Solids	IS 3025 (P-17) 1984 (Reaffirmed 2017)	mg/L	106.5
3	Chemical Oxygen Demand	IS 3025 (P-58) 2006 (Reaffirmed 2017)	mg/L	174
4	BOD (5 days at 20°C)	IS 3025 (P-44) 1993 (Reaffirmed 2019)	mg/L	56.12
5	Ammonical Nitrogen	IS 3025 (P-34) 1988 (Reaffirmed 2019)	mg/L	BDL
6	Total Phosphorus	IS 3025 (P-31) 1988 (Reaffirmed 2019)	mg/L	2.1
7	Total Kjeldahl Nitrogen	IS 3025 (P-34) 1988 (Reaffirmed 2019)	mg/L	11
8	Residual Chlorine	IS 3025 (P-26) 1986 (Reaffirmed 2019)	mg/L	ND
9	Total Coliform	APHA & AWWA 23 rd Ed. 9221 E (9-77)	MPN/100mL	>1100
10	Fecal Coliform	APHA & AWWA 23 rd Ed. 9221 E (9-77)	MPN/100mL	375

Note: BDL: Below Detection Limit, ND: Not Detected.

WL₁: STP Inlet Water



Chemist



Authorized Signatory
Rekha Dare

- Notes: (1) The results pertain to tested items only.
(2) This report shall not be reproduced, except in full, without written approval of the laboratory.
(3) Authenticity of this Report could be validated with office copy at Greenleaf Envirotech Pvt. Ltd.
(4) Perishable samples will be destroyed after testing, others after 7 days from the date of issue of the report, unless otherwise agreed with the customer or as required by the applicable regulations.

Test Report
Water Sample Analysis Report


Client's Name & Address: GWSSB, Panchmahal Dabhoi 9 MLD STP	Report No: GLEPL/230225/349 Issue Date: 10/02/2026
--	---

Lab ID Code	:	GLEPL/230222/WL ₂	
Sample Description	:	Waste Water (STP Outlet)	Purpose : As per Client requirement
Date of Sampling	:	Submitted by Client	Sample Collected/Submitted by : Submitted by Client
Date of Sample Received	:	1/02/2026	Test Parameters : As per Client requirement
Date of starting Analysis	:	2/02/2026	Quantity/No. of sample : 2 Lit./02
Date of completion Analysis	:	8/02/2026	Packed/Seal : Sealed

Result Table

Sr. No.	Test Parameters	Test Method	Unit	Results	Permissible Limit
1	pH @30 °C	IS 3025 (P-11) 1983 (Reaffirmed 2017)	pH Unit	6.85	6.5-9.0
2	Total Suspended Solids	IS 3025 (P-17) 1984 (Reaffirmed 2017)	mg/L	9.5	<10
3	Chemical Oxygen Demand	IS 3025 (P-58) 2006 (Reaffirmed 2017)	mg/L	32	<50
4	BOD (5 days at 20°C)	IS 3025 (P-44) 1993 (Reaffirmed 2019)	mg/L	BDL<10	<10
5	Ammonical Nitrogen	IS 3025 (P-34) 1988 (Reaffirmed 2019)	mg/L	BDL	<5.0
6	Total Phosphorus	IS 3025 (P-31) 1988 (Reaffirmed 2019)	mg/L	BDL	<1.0
7	Total Nitrogen	IS 3025 (P-34) 1988 (Reaffirmed 2019)	mg/L	BDL	<10.0
8	Residual Chlorines	IS 3025 (P-26) 1986 (Reaffirmed 2019)	mg/L	ND	0.5-1.0
9	Fecal Coliform	APHA & AWWA 23 rd Ed. 9221 E (9-77)	MPN/100mL	150	<230
10	Total Coliform	APHA & AWWA 23 rd Ed. 9221 E (9-77)	MPN/100mL	225	

Note: BDL: Below Detection Limit.
WL₁: STP Outlet Water



Chemist



Authorized Signatory
Rekha Dare

Notes: (1) The results pertain to tested items only.
(2) This report shall not be reproduced, except in full, without written approval of the laboratory.
(3) Authenticity of this Report could be validated with office copy at Greenleaf Envirotech Pvt. Ltd.
(4) Perishable samples will be destroyed after testing, others after 7 days from the date of issue of the report, unless otherwise agreed with the customer or as required by the applicable regulations.
Recognized by MoEF, Govt. of India, EP Act 1986; NABL accredited; GPCB Schedule II Environment Auditor; OHSAS – 18001:2017 Certified Laboratory.



ISO 9001:2015 and ISO 17025:2017 NABL certified

No.4, Versetile Industrial Estate, Nr. Kotak Bank, Gate No.5,
Kathwada Gidc, Ahmedabad - 382430.

+91 8469130040, +91 6357351655 naturemicrovision@gmail.com GSTIN : 24AAWFN4704G1Z4

Test Report

Report ID: NML/WW/25-26/1172

Date: 21/02/2026

Customer Name	P.DAS INFRASTRUCTURE PVT LTD		
Customer Address	5.60 MLD PADRA		
Date & Time of Sampling	16/02/2026	Sampling Plan & Method	IS 3025(Part-1) RA 2019
Date of Receipt of Sample	17/02/2026		
Sample Collected by	Client	Sample Condition	SATISFACTORY
Analysis Starting Date	17/02/2026	Packing / Seal	SEALED
Analysis Completion Date	21/02/2026	Quantity / No. of Samples	Approx. 1 LIT. * 1NO.
Environmental Condition	Temperature: 25 °C ± 2	Relative Humidity (%)	Humidity ≤ 50 %

Sample No.	Sample ID	Sample Type	Location	Description
1.	25-26/1181	Waste Water	Inlet	Untreated Water

Analysis Results

Sr. No.	Parameters	Reference Method	Results	Regulatory Limit	Unit
1.	pH	IS 3025 (Part 11): 2022	7.72	6.5-7.0	--
2.	BIOLOGICAL OXYGEN DEMAND (3 days at 27°C)	IS 3025 (Part 44): 2023	156.5	<250	mg/L
3.	CHEMICAL OXYGEN DEMAND	IS 3025 (Part 58) : 2023	342	<425	mg/L
4.	TOTAL SUSPENDED SOLIDS	IS 3025 (Part 17): 1988 (RA 2022)	198.24	<375	mg/L
5.	TOTAL NITROGEN	IS 3025 (Part 34/sec- 1):2023	41	<50	mg/L
6.	TOTAL PHOSPHORUS	IS 3025 (Part 31) :Sec 1 : 2022	3.1	<7.1	mg/L
7.	TOTAL COLIFORM	APHA 24th Edition 2023 9221 B	10 ⁶	10 ⁶ - 10 ⁸	(MPN)/100
8.	FECAL COLIFORM	APHA 24th Edition 2023 9221 E	7.5 × 10 ²	10 ⁴ - 10 ⁸	(MPN)/100

Checked by
Senior Chemist



Authorised by
Lab Manager/CEO

End of Test Report

Remarks:

- BDL: Below Detectable Limit.
- The report pertains only to the sample tested and does not apply to the bulk quantity.
- The test report may not be reproduced, wholly or partially, nor used for promotional or publicity purposes without written consent from the laboratory department.
- Samples will be retained for 15 days after the completion of analysis. A longer retention period can be arranged upon customer request.



ISO 9001:2015 and ISO 17025:2017 NABL certified

No.4, Versetile Industrial Estate, Nr. Kotak Bank, Gate No.5,
Kathwada Gidc, Ahmedabad - 382430.

+91 8469130040, +91 6357351655 naturemicrovision@gmail.com GSTIN : 24AAWFN4704G1Z4

Test Report

Report ID: NML/WW/25-26/1273

Date: 21/02/2026

Customer Name	P.DAS INFRASTRUCTURE PVT LTD		
Customer Address	5.60 MLD PADRA		
Date & Time of Sampling	16/02/2026	Sampling Plan & Method	IS 3025(Part-1) RA 2019
Date of Receipt of Sample	17/02/2026		
Sample Collected by	Client	Sample Condition	SATISFACTORY
Analysis Starting Date	17/02/2026	Packing / Seal	SEALED
Analysis Completion Date	21/02/2026	Quantity / No. of Samples	Approx. 1 LIT. * 1NO.
Environmental Condition	Temperature: 25 °C ± 2	Relative Humidity (%)	Humidity ≤ 50 %

Sample No.	Sample ID	Sample Type	Location	Description
1.	25-26/1282	Waste Water	Outlet	Treated Water

Analysis Results

Sr. No.	Parameters	Reference Method	Results	Regulatory Limit	Unit
1.	pH	IS 3025 (Part 11): 2022	7.55	6.5-9.0	--
2.	BIOLOGICAL OXYGEN DEMAND (3 days at 27°C)	IS 3025 (Part 44): 2023	7.9	<10	mg/L
3.	CHEMICAL OXYGEN DEMAND	IS 3025 (Part 58) : 2023	39	<50	mg/L
4.	TOTAL SUSPENDED SOLIDS	IS 3025 (Part 17): 1988 (RA 2022)	7.49	<10	mg/L
5.	TOTAL NITROGEN	IS 3025 (Part 34/sec- 1):2023	7.3	<10	mg/L
6.	FECAL COLIFORM	APHA 24th Edition 2023 9221 E	148	<230	(MPN)/100
7.	TOTAL COLIFORM	APHA 24th Edition 2023 9221 B	180	<230	(MPN)/100


Checked by
Senior Chemist




Authorised by
Lab Manager/CEO

End of Test Report

Remarks:

- BDL: Below Detectable Limit.
- The report pertains only to the sample tested and does not apply to the bulk quantity.
- The test report may not be reproduced, wholly or partially, nor used for promotional or publicity purposes without written consent from the laboratory department.
- Samples will be retained for 15 days after the completion of analysis. A longer retention period can be arranged upon customer request.



LABORATORY TESTING REPORT

Report No.: VBPL/WW/202602/0041		Date: 03/03/2026	
URL No.: -- TC158532500001973F			
Customer Name & Address	M/s. UMRETH NAGAR SEVA SADAN Nagar Seva Sadan, Court Compound, Umreth-388220 Dist. Anand, Gujarat		
Contact Person	Mr. Priyank Patel		
Date of Sample Collection	: NA	Sampling Type	: Grab
Date of Sample Received	: 28/02/2026	Sample ID	: WW/202602/0041
Sampling Location	: STP Inlet	Sample Description	: Waste Water
Sample Collected / Submitted by	: VBPL Team	Protocol used for Sampling	: APHA 24 th Edition
Quantity / No. of Sample	: 1L + 1L + 500 ml sterile Bottle / 3 Nos.	Analysis Started On	: 28/02/2026
Packing / Seal	: Cap Seal	Analysis Completed On	: 03/03/2026
Type of Container	: Plastic Container	Format No.	: 7.8 F-01
Environmental Condition during the test	25°C ± 3 °C		

Waste Water Analysis Results

Sr. No.	Parameter	Unit	Result	Protocol used for Analysis
1.	pH	-	6.52	APHA 24th Edition 4500 H + B
2.	Total Suspended Solid	mg/L	356.8	APHA 24th Edition 2540 D: 2023
3.	Total kjeldahl Nitrogen	mg/L	12.45	APHA 24th Edition 4500-Norg -B (Macro-Kjeldahl Method)
4.	Biochemical Oxygen Demand	mg/L	254	IS 3025 (Part-44)
5.	Chemical Oxygen Demand	mg/L	420	IS 3025 (Part-58)
6.	Total Coliform	MPN/100mL	7x10 ⁴	9221 B, APHA 24th Edition
7.	Fecal Coliform	MPN/100mL	685	9221 E, APHA 24th Edition

-----End Report-----

This Report is issued under the following terms & Condition:

1. Samples are not drawn by Vasundhara Biosustain Pvt. Ltd., unless otherwise mentioned. The results are applicable only to the submitted sample. Endorsement of the product is neither inferred nor implemented.
2. The test report in full or part shall not be used for promotional or publicity purposes without the written consent of Vasundhara Biosustain Pvt. Ltd.
3. Samples shall be stored for the period of 15 days after the date of issue of Report.

Verified By

Authorized Signatory

Formerly known as "VASUNDHARA ENTERPRISE"

Office :
Plot No.7313/1/A,
GIDC Ankleshwar - 393002.

Contact:
Mo.: +91-93136 16978 / 93136 16730
E-mail : info@vasundharaenterprise.in
Website : www.vasundharaenterprise.in



LABORATORY TESTING REPORT

Report No.: VBPL/WW/202602/0041/1		Date: 03/03/2026	
URL No.: --			
Customer Name & Address	M/s. UMRETH NAGAR SEVA SADAN : Nagar Seva Sadan, Court Compound, Umreth-388220 Dist. Anand, Gujarat		
Contact Person	: Mr. Priyank Patel		
Date of Sample Collection	: NA	Sampling Type	: Grab
Date of Sample Received	: 28/02/2026	Sample ID	: WW/202602/0041
Sampling Location	: STP Inlet	Sample Description	: Waste Water
Sample Collected / Submitted by	: VBPL Team	Protocol used for Sampling	: APHA 24 th Edition
Quantity / No. of Sample	: 1L + 1L + 500 ml sterile Bottle / 3 Nos.	Analysis Started On	: 28/02/2026
Packing / Seal	: Cap Seal	Analysis Completed On	: 03/03/2026
Type of Container	: Plastic Container	Format No.	: 7.8 F-01
Environmental Condition during the test		25°C ±3 °C	

Waste Water Analysis Results

Sr. No.	Parameter	Unit	Result	Protocol used for Analysis
1.	Total Phosphorous	mg/L	5.89	APHA 24th Edition 4500-P, D

-----End Report-----

This Report is issued under the following terms & Condition:

1. Samples are not drawn by Vasundhara Biosustain Pvt. Ltd., unless otherwise mentioned. The results are applicable only to the submitted sample. Endorsement of the product is neither inferred nor implemented.
2. The test report in full or part shall not be used for promotional or publicity purposes without the written consent of Vasundhara Biosustain Pvt. Ltd.
3. Samples shall be stored for the period of 15 days after the date of issue of Report.

Verified By

Authorized Signatory

Formerly known as "VASUNDHARA ENTERPRISE"

Office :
Plot No.7313/1/A,
GIDC Ankleshwar - 393002.

Contact:
Mo.: +91-93136 16978 / 93136 16730
E-mail : info@vasundharaenterprise.in
Website : www.vasundharaenterprise.in



LABORATORY TESTING REPORT

Report No.: VBPL/WW/202602/0042		Date: 03/03/2026	
URL No.: -- TC158532500001974F			
Customer Name & Address	M/s. UMRETH NAGAR SEVA SADAN Nagar Seva Sadan, Court Compound, Umreth-388220 Dist. Anand, Gujarat		
Contact Person	Mr. Priyank Patel		
Date of Sample Collection	: NA	Sampling Type	: Grab
Date of Sample Received	: 28/02/2026	Sample ID	: WW/202602/0042
Sampling Location	: STP Outlet	Sample Description	: Waste Water
Sample Collected / Submitted by	: VBPL Team	Protocol used for Sampling	: APHA 24 th Edition
Quantity / No. of Sample	: 1L + 1L + 500 ml sterile Bottle / 3 Nos.	Analysis Started On	: 28/02/2026
Packing / Seal	: Cap Seal	Analysis Completed On	: 03/03/2026
Type of Container	: Plastic Container	Format No.	: 7.8 F-01
Environmental Condition during the test	25°C ±3 °C		

Waste Water Analysis Results

Sr. No.	Parameter	Unit	Result	permissible limit	Protocol used for Analysis
1.	pH	-	7.18	6.5-9	APHA 24th Edition 4500 H + B
2.	Total Suspended Solid	mg/L	5.92	<10	APHA 24th Edition 2540 D: 2023
3.	Chemical Oxygen Demand	mg/L	42	<50	IS 3025 (Part-58)
4.	Biochemical Oxygen Demand	mg/L	8.4	<10	IS 3025 (Part-44)
5.	Ammonical Nitrogen	mg/L	1.2	<5	APHA 24th Edition 4500- NH3 B& C
6.	Fecal Coliform	MPN/100mL	38	<230	9221 E, APHA 24th Edition
7.	Total Coliform	MPN/100mL	70	<230	9221 B, APHA 24th Edition
8.	Residual Chlorine	mg/L	0.62	0.5-1.0	APHA 24th Edition 4500-Cl B

-----End Report-----

This Report is issued under the following terms & Condition:

1. Samples are not drawn by Vasundhara Biosustain Pvt. Ltd., unless otherwise mentioned. The results are applicable only to the submitted sample. Endorsement of the product is neither inferred nor implemented.
2. The test report in full or part shall not be used for promotional or publicity purposes without the written consent of Vasundhara Biosustain Pvt. Ltd.
3. Samples shall be stored for the period of 15 days after the date of issue of Report.

Verified By

Authorized Signatory

Formerly known as "VASUNDHARA ENTERPRISE"

Office :
Plot No.7313/1/A,
GIDC Ankleshwar - 393002.

Contact:
Mo.: +91-93136 16978 / 93136 16730
E-mail : info@vasundharaenterprise.in
Website : www.vasundharaenterprise.in



LABORATORY TESTING REPORT

Report No.: VBPL/WW/202602/0042/1		Date: 03/03/2026	
URL No.: --			
Customer Name & Address	M/s. UMRETH NAGAR SEVA SADAN : Nagar Seva Sadan, Court Compound, Umreth-388220 Dist. Anand, Gujarat		
Contact Person	: Mr. Priyank Patel		
Date of Sample Collection	: NA	Sampling Type	: Grab
Date of Sample Received	: 28/02/2026	Sample ID	: WW/202602/0042
Sampling Location	: STP Outlet	Sample Description	: Waste Water
Sample Collected / Submitted by	: VBPL Team	Protocol used for Sampling	: APHA 24 th Edition
Quantity / No. of Sample	: 1L + 1L + 500 ml sterile Bottle / 3 Nos.	Analysis Started On	: 28/02/2026
Packing / Seal	: Cap Seal	Analysis Completed On	: 03/03/2026
Type of Container	: Plastic Container	Format No.	: 7.8 F-01
Environmental Condition during the test		25°C ±3 °C	

Waste Water Analysis Results

Sr. No.	Parameter	Unit	Result	permissible limit	Protocol used for Analysis
1.	Total Phosphorous	mg/L	0.68	<2	APHA 24th Edition 4500-P, D
2.	Total Nitrogen	mg/L	6.82	<10	IS 10158

-----End Report-----

This Report is issued under the following terms & Condition:

1. Samples are not drawn by Vasundhara Biosustain Pvt. Ltd., unless otherwise mentioned. The results are applicable only to the submitted sample. Endorsement of the product is neither inferred nor implemented.
2. The test report in full or part shall not be used for promotional or publicity purposes without the written consent of Vasundhara Biosustain Pvt. Ltd.
3. Samples shall be stored for the period of 15 days after the date of issue of Report.



Verified By


Authorized Signatory

Formerly known as "VASUNDHARA ENTERPRISE"



Office :
Plot No.7313/1/A,
GIDC Ankleshwar - 393002.


Contact:
Mo.: +91-93136 16978 / 93136 16730
E-mail : info@vasundharaenterprise.in
Website : www.vasundharaenterprise.in

TEST REPORT						
Water/Wastewater Quality Sampling & Analysis						
Company Name	Jay Corporation - Shivam Builders, JV	Sample ID	WQ/294/26			
Company Contact Number	7874886393	Condition of sample	Satisfactory			
Address	71 first floor, Someshwar mall, Modhera Road, Mahsana, 384002	Sample Drawn By	Customer			
		Quantity of Sample	1 L			
		Sampling Method	APHA/IS MODE: (GRAB/ COMPOSITE)			
Date & Time of Sampling	18-02-2026	Date of Sample Received	18-02-2026			
Analysis Starts Date	18-02-2026	Analysis Completion Date	24-02-2026			
Sample Description	STP Outlet- Anklav 3.6 MLD	Temperature/ Humidity during testing	Temp.- 25-29 deg C / Humidity <50 %			
Report Code:	SWA/LAB/18/02/2026/WQ/294	Report Date:	24-02-2026			
S.No.	PARAMETERS	UNIT	RESULTS	Regulatory Limit	Remarks	Testing Method/ Standard
1	pH @27 deg.	-	7.53	6.5-9	/	APHA 24th Edition 4500 B: 2023
2	Total Suspended Solids	mg/l	6.12	<10		APHA 24th Edition 2540 D: 2023
3	Ammonical Nitrogen	mg/l	2.61	<5		APHA 24th Edition 4500 NH3 C: 2023
4	Residual Chlorine	mg/l	0.69	0.5-1		APHA 24th Edition 4500 CL B: 2023
5	Chemical Oxygen Demand	mg/l	30.16	<50		IS 3025 - Part 58 : 2023
6	Total Nitrogen	mg/l	7.56	<10		APHA 24th Edition 4500 NH3 C/Norg B/N03 B/N02 B: 2023
7	Total Phosphorous	mg/l	0.54	<1		APHA 24th Edition 4500 P D: 2023
8	Biochemical Oxygen Demand	mg/l	6.50	<10		IS 3025 - Part 44 : 2023
9	Faecal Coliform	MPN/100 ml	40.00	<230		IS 1622 - Rea. 1981
10	Total Coliform	MPN/100 ml	50.00	<230		IS 1622 - Rea. 1981
Supervised By :		Harshad Salvi		Authorized Signatory :		Pankaj Gothi
Signature :				Signature :		
Designation :		Technical Manager/COO Lab		Designation :		Quality Manager/CEO
Notes:						
1. The report shall not be reproduced except in full without approval of the laboratory can provide assurance that parts of a report are not taken out of context.						
2. The results relate only to the items tested and sampled						
3. Additions to, deviations, or exclusions from the method- NA						
4. Results which were outsourced to external providers are marked with ** and results which are performed and not in NABL accreditation scope are marked with * in parameter column						
5. Disclaimer: When the information is supplied by the customer and can affect the validity of results						
6. Disclaimer: The report that the results apply to the sample as received in case of the sample has been supplied by customer						
7. Disclaimer: The laboratory shall be responsible for all the information provided in the report, except when information is provided by the customer						
8. Regulatory limit reference if any:- NA						
9. Opinion, Interpretation & Statement of Conformity if provided can be referred in the remarks section as "Permissible" "Below acceptable" or whatever is applicable as per the rule						
10. BDL : Below Detection Limit R1:- Revised report and the number of that times revised						
----- End of the Test Report -----						



WASTEWATER TREATMENT | ENVIRONMENTAL TESTING | FOOD TESTING

TEST REPORT						
Water/Wastewater Quality Sampling & Analysis						
Company Name	Jay Corporation - Shivam Builders, JV	Sample ID	WQ/293/26			
Company Contact Number	7874886393	Condition of sample	Satisfactory			
Address	71 first floor, Someshwar mall, Modhera Road, Mahsana, 384002	Sample Drawn By	Customer			
		Quantity of Sample	1 L			
		Sampling Method	APHA/IS MODE: (GRAB/ COMPOSITE)			
Date & Time of Sampling	18-02-2026	Date of Sample Received	18-02-2026			
Analysis Starts Date	18-02-2026	Analysis Completion Date	24-02-2026			
Sample Description	STP Inlet- Anklav 3.6 MLD	Temperature/ Humidity during testing	Temp.- 25-29 deg C / Humidity <50 %			
Report Code:	SWA/LAB/18/02/2026/WQ/293	Report Date:	24-02-2026			
S.No.	PARAMETERS	UNIT	RESULTS	Regulatory Limit	Remarks	Testing Method/ Standard
1	pH @27 deg.	-	7.43			APHA 24th Edition 4500 B: 2023
2	Total Suspended Solids	mg/l	158.13			APHA 24th Edition 2540 D: 2023
3	Total Kjeldahl Nitrogen	mg/l	24.81			APHA 24th Edition 4500 NH3 C/Norg B: 2023
4	Total Phosphorous	mg/l	6.72			APHA 24th Edition 4500 P D: 2023
5	Chemical Oxygen Demand	mg/l	176.34			IS 3025 - Part 58 : 2023
6	Biochemical Oxygen Demand	mg/l	66.25			IS 3025 - Part 44 : 2023
7	Faecal Coliform	MPN/100 ml	6 X 10 ⁴			IS 1622 - Rea. 1981
8	Total Coliform	MPN/100 ml	8 X 10 ⁴			IS 1622 - Rea. 1981
Supervised By :		Harshad Salvi		Authorized Signatory :		Pankaj Gothi
Signature :				Signature :		
Designation :		Technical Manager/COO Lab		Designation :		Quality Manager/CEO
Notes:						
1. The report shall not be reproduced except in full without approval of the laboratory can provide assurance that parts of a report are not taken out of context.						
2. The results relate only to the items tested and sampled						
3. Additions to, deviations, or exclusions from the method- NA						
4. Results which were outsourced to external providers are marked with ** and results which are performed and not in NABL accreditation scope are marked with * in parameter column						
5. Disclaimer: When the information is supplied by the customer and can affect the validity of results						
6. Disclaimer: The report that the results apply to the sample as received in case of the sample has been supplied by customer						
7. Disclaimer: The laboratory shall be responsible for all the information provided in the report, except when information is provided by the customer						
8. Regulatory limit reference if any:- NA						
9. Opinion, Interpretation & Statement of Conformity if provided can be referred in the remarks section as "Permissible" "Below acceptable" or whatever is applicable as per the limit						
10. BDL : Below Detection Limit R1 : Revised report and the number of that times revised						
----- End of the Test Report -----						



WASTEWATER TREATMENT | ENVIRONMENTAL TESTING | FOOD TESTING

-  Head Office : Survey No. 645, Miroli Kamod Circle, Ahmedabad-Dholka Road, Ahmedabad-382425
-  Branch Office : Jaipur, Surat, Delhi, Bengaluru
-  +91 9227988980 / 9265491610  swa@swaenviro.com / lab@swaenviro.com  www.swaenviro.com

Test Report
Water Sample Analysis Report

Client's Name & Address: GWSSB, Anand, Vraj Construction, Amreli, ODE 2.5 MLD STP	Report No: GLEPL/230225/348 Issue Date: 18/01/2026
---	---

Lab ID Code	:	GLEPL/230222/WL ₁
Sample Description	:	Waste Water (STP Inlet) Purpose : As per Client requirement
Date of Sampling	:	Submitted by Client Sample Collected/Submitted by : Submitted by Client
Date of Sample Received	:	10/01/2026 Test Parameters : As per Client requirement
Date of starting Analysis	:	11/01/2026 Quantity/No. of sample : 2 Lit./01
Date of completion Analysis	:	17/01/2026 Packed/Seal : Sealed

Result Table

Sr. No.	Test Parameters	Test Method	Unit	Results
1	pH @30 °C	IS 3025 (P-11) 1983 (Reaffirmed 2017)	pH Unit	8.50
2	Total Suspended Solids	IS 3025 (P-17) 1984 (Reaffirmed 2017)	mg/L	290.20
3	Chemical Oxygen Demand	IS 3025 (P-58) 2006 (Reaffirmed 2017)	mg/L	200.55
4	BOD (5 days at 20°C)	IS 3025 (P-44) 1993 (Reaffirmed 2019)	mg/L	90.17
5	Ammonical Nitrogen	IS 3025 (P-34) 1988 (Reaffirmed 2019)	mg/L	15.25
6	Total Phosphorus	IS 3025 (P-31) 1988 (Reaffirmed 2019)	mg/L	BDL
7	Total Kjeldahl Nitrogen	IS 3025 (P-34) 1988 (Reaffirmed 2019)	mg/L	15.58
8	Residual Chlorine	IS 3025 (P-26) 1986 (Reaffirmed 2019)	mg/L	ND
9	Total Coliform	APHA & AWWA 23 rd Ed. 9221 E (9-77)	MPN/100mL	575
10	Fecal Coliform	APHA & AWWA 23 rd Ed. 9221 E (9-77)	MPN/100mL	250

Note: BDL: Below Detection Limit, ND: Not Detected.

WL₁: STP Inlet Water



Chemist



Authorized Signatory
Rekha Dare

- Notes: (1) The results pertain to tested items only.
(2) This report shall not be reproduced, except in full, without written approval of the laboratory.
(3) Authenticity of this Report could be validated with office copy at Greenleaf Envirotech Pvt. Ltd.
(4) Perishable samples will be destroyed after testing, others after 7 days from the date of issue of the report, unless otherwise agreed with the customer or as required by the applicable regulations.

Test Report
Water Sample Analysis Report

Client's Name & Address: GWSSB, Anand, Vraj Construction, Amreli, ODE 2.5 MLD STP	Report No: GLEPL/230225/349 Issue Date: 18/01/2026
---	---

Lab ID Code	:	GLEPL/230222/WL ₂	
Sample Description	:	Waste Water (STP Outlet)	Purpose : As per Client requirement
Date of Sampling	:	Submitted by Client	Sample Collected/Submitted by : Submitted by Client
Date of Sample Received	:	10/01/2026	Test Parameters : As per Client requirement
Date of starting Analysis	:	11/01/2026	Quantity/No. of sample : 2 Lit./02
Date of completion Analysis	:	17/01/2026	Packed/Seal : Sealed

Result Table

Sr. No.	Test Parameters	Test Method	Unit	Results	Permissible Limit
1	pH @30 °C	IS 3025 (P-11) 1983 (Reaffirmed 2017)	pH Unit	8.20	6.5-9.0
2	Total Suspended Solids	IS 3025 (P-17) 1984 (Reaffirmed 2017)	mg/L	7.30	<10
3	Chemical Oxygen Demand	IS 3025 (P-58) 2006 (Reaffirmed 2017)	mg/L	15.30	<50
4	BOD (5 days at 20°C)	IS 3025 (P-44) 1993 (Reaffirmed 2019)	mg/L	7.50	<10
5	Ammonical Nitrogen	IS 3025 (P-34) 1988 (Reaffirmed 2019)	mg/L	3.50	<5.0
6	Total Phosphorus	IS 3025 (P-31) 1988 (Reaffirmed 2019)	mg/L	BDL	<1.0
7	Total Nitrogen	IS 3025 (P-34) 1988 (Reaffirmed 2019)	mg/L	6.40	<10.0
8	Residual Chlorines	IS 3025 (P-26) 1986 (Reaffirmed 2019)	mg/L	0.60	0.5-1.0
9	Fecal Coliform	APHA & AWWA 23 rd Ed. 9221 E (9-77)	MPN/100mL	80	<230
10	Total Coliform	APHA & AWWA 23 rd Ed. 9221 E (9-77)	MPN/100mL	125	

Note: BDL: Below Detection Limit.
WL₁: STP Outlet Water



Chemist



Authorized Signatory
Rekha Dare

Notes: (1) The results pertain to tested items only.
(2) This report shall not be reproduced, except in full, without written approval of the laboratory.
(3) Authenticity of this Report could be validated with office copy at Greenleaf Envirotech Pvt. Ltd.
(4) Perishable samples will be destroyed after testing, others after 7 days from the date of issue of the report, unless otherwise agreed with the customer or as required by the applicable regulations.
Recognized by **MoEF**, Govt. of India, EP Act 1986; **NABL** accredited; **GPCB** Schedule II Environment Auditor; **OHSAS** – 18001:2017 Certified Laboratory.

Test Report
Water Sample Analysis Report

Client's Name & Address: GWSSB, Anand, Shivam builders, ahmedabad, boriyavi 3.3 MLD STP	Report No: GLEPL/230224/2557 Issue Date: 18/02/2026
--	--

Lab ID Code	:	GLEPL/230222/WL ₁
Sample Description	:	Waste Water (STP Inlet) Purpose : As per Client requirement
Date of Sampling	:	Submitted by Client Sample Collected/Submitted by : Submitted by Client
Date of Sample Received	:	10/02/2026 Test Parameters : As per Client requirement
Date of starting Analysis	:	11/02/2026 Quantity/No. of sample : 2 Lit./01
Date of completion Analysis	:	17/02/2026 Packed/Seal : Sealed

Result Table

Sr. No.	Test Parameters	Test Method	Unit	Results
1	pH @30 °C	IS 3025 (P-11) 1983 (Reaffirmed 2017)	pH Unit	7.50
2	Total Suspended Solids	IS 3025 (P-17) 1984 (Reaffirmed 2017)	mg/L	350.10
3	Chemical Oxygen Demand	IS 3025 (P-58) 2006 (Reaffirmed 2017)	mg/L	150.44
4	BOD (5 days at 20°C)	IS 3025 (P-44) 1993 (Reaffirmed 2019)	mg/L	90.10
5	Ammonical Nitrogen	IS 3025 (P-34) 1988 (Reaffirmed 2019)	mg/L	20.10
6	Total Phosphorus	IS 3025 (P-31) 1988 (Reaffirmed 2019)	mg/L	BDL
7	Total Kjeldahl Nitrogen	IS 3025 (P-34) 1988 (Reaffirmed 2019)	mg/L	16.20
8	Residual Chlorine	IS 3025 (P-26) 1986 (Reaffirmed 2019)	mg/L	ND
9	Total Coliform	APHA & AWWA 23 rd Ed. 9221 E (9-77)	MPN/100MI	300

Note: BDL: Below Detection Limit, ND: Not Detected.

WL₁: STP Inlet Water

N.A. Khunt

Chemist

N.A. Khunt

**Authorized Signatory
Khant Nilesh**

- Notes: (1) The results pertain to tested items only.
(2) This report shall not be reproduced, except in full, without written approval of the laboratory.
(3) Authenticity of this Report could be validated with office copy at Greenleaf Envirotech Pvt. Ltd.
(4) Perishable samples will be destroyed after testing, others after 7 days from the date of issue of the report, unless otherwise agreed with the customer or as required by the applicable regulations.

Page No. 01 of 01

Recognized by **MoEF**, Govt. of India, EP Act 1986; **NABL** accredited; **GPCB** Schedule II Environment Auditor; **OHSAS** – 18001:2017 Certified Laboratory.

Greenleaf Envirotech Pvt. Ltd.

304, Kankavati Complex, Singanpor-Cauzway Road, Katargam, Surat – 395004, Tel: 0261-6430044

E-mail: lab@glepl.com | Web: www.glepl.com

Test Report
Water Sample Analysis Report

Client's Name & Address: GWSSB, Anand, Shivam builders, ahmedabad, boriyavi 3.3 MLD STP	Report No: GLEPL/230224/2558 Issue Date: 18/02/2026
--	--


Lab ID Code	:	GLEPL/230222/WL ₂	
Sample Description	:	Waste Water (STP Outlet)	Purpose : As per Client requirement
Date of Sampling	:	Submitted by Client	Sample Collected/Submitted by : Submitted by Client
Date of Sample Received	:	10/02/2026	Test Parameters : As per Client requirement
Date of starting Analysis	:	11/02/2026	Quantity/No. of sample : 2 Lit./02
Date of completion Analysis	:	17/02/2026	Packed/Seal : Sealed


Result Table

Sr. No.	Test Parameters	Test Method	Unit	Results	Permissible Limit
1	pH @30 °C	IS 3025 (P-11) 1983 (Reaffirmed 2017)	pH Unit	7.50	6.5-9.0
2	Total Suspended Solids	IS 3025 (P-17) 1984 (Reaffirmed 2017)	mg/L	6.50	<10
3	Chemical Oxygen Demand	IS 3025 (P-58) 2006 (Reaffirmed 2017)	mg/L	16.50	<50
4	BOD (5 days at 20°C)	IS 3025 (P-44) 1993 (Reaffirmed 2019)	mg/L	6.90	<10
5	Ammonical Nitrogen	IS 3025 (P-34) 1988 (Reaffirmed 2019)	mg/L	3.60	<5.0
6	Total Phosphorus	IS 3025 (P-31) 1988 (Reaffirmed 2019)	mg/L	BDL	<1.0
7	Total Nitrogen	IS 3025 (P-34) 1988 (Reaffirmed 2019)	mg/L	6.10	<10.0
8	Residual Chlorines	IS 3025 (P-26) 1986 (Reaffirmed 2019)	mg/L	0.30	0.5-1.0
9	Faecal Coliform	APHA & AWWA 23 rd Ed. 9221 E (9-77)	MPN/100mL	100	<230

Note: BDL: Below Detection Limit.

WL₁: STP Outlet Water


Chemist


Authorized Signatory
Khant Nilesh

- Notes: (1) The results pertain to tested items only.
(2) This report shall not be reproduced, except in full, without written approval of the laboratory.
(3) Authenticity of this Report could be validated with office copy at Greenleaf Envirotech Pvt. Ltd.
(4) Perishable samples will be destroyed after testing, others after 7 days from the date of issue of the report, unless otherwise agreed with the customer or as required by the applicable regulations.

Recognized by **MoEF**, Govt. of India, EP Act 1986; **NABL** accredited; **GPCB** Schedule II Environment Auditor; **OHSAS** – 18001:2017 Certified Laboratory.

Greenleaf Envirotech Pvt. Ltd.

304, Kankavati Complex, Singanpor-Cauzway Road, Katargam, Surat – 395004, Tel: 0261-6430044

E-mail: lab@glepl.com | Web: www.glepl.com

Test Report
Water Sample Analysis Report

Client's Name & Address: GWSSB, Panchmahal Zalod 4.6 MLD STP	Report No: GLEPL/230225/348 Issue Date: 20/02/2026
---	---

Lab ID Code	:	GLEPL/230222/WL ₁		
Sample Description	:	Waste Water (STP Inlet)	Purpose	: As per Client requirement
Date of Sampling	:	Submitted by Client	Sample Collected/Submitted by	: Submitted by Client
Date of Sample Received	:	10/02/2026	Test Parameters	: As per Client requirement
Date of starting Analysis	:	11/02/2026	Quantity/No. of sample	: 2 Lit./01
Date of completion Analysis	:	17/02/2026	Packed/Seal	: Sealed

Result Table

Sr. No.	Test Parameters	Test Method	Unit	Results
1	pH @30 °C	IS 3025 (P-11) 1983 (Reaffirmed 2017)	pH Unit	7.18
2	Total Suspended Solids	IS 3025 (P-17) 1984 (Reaffirmed 2017)	mg/L	298.76
3	Chemical Oxygen Demand	IS 3025 (P-58) 2006 (Reaffirmed 2017)	mg/L	406
4	BOD (5 days at 20°C)	IS 3025 (P-44) 1993 (Reaffirmed 2019)	mg/L	218.5
5	Ammonical Nitrogen	IS 3025 (P-34) 1988 (Reaffirmed 2019)	mg/L	BDL
6	Total Phosphorus	IS 3025 (P-31) 1988 (Reaffirmed 2019)	mg/L	2.8
7	Total Kjeldahl Nitrogen	IS 3025 (P-34) 1988 (Reaffirmed 2019)	mg/L	35
8	Residual Chlorine	IS 3025 (P-26) 1986 (Reaffirmed 2019)	mg/L	ND
9	Total Coliform	APHA & AWWA 23 rd Ed. 9221 E (9-77)	MPN/100mL	>1100
10	Fecal Coliform	APHA & AWWA 23 rd Ed. 9221 E (9-77)	MPN/100mL	855

Note: BDL: Below Detection Limit, ND: Not Detected.

WL₁: STP Inlet Water



Chemist



Authorized Signatory
Rekha Dare

- Notes: (1) The results pertain to tested items only.
(2) This report shall not be reproduced, except in full, without written approval of the laboratory.
(3) Authenticity of this Report could be validated with office copy at Greenleaf Envirotech Pvt. Ltd.
(4) Perishable samples will be destroyed after testing, others after 7 days from the date of issue of the report, unless otherwise agreed with the customer or as required by the applicable regulations.

Test Report
Water Sample Analysis Report

Client's Name & Address: GWSSB,Panchmahal Zalod 4.6 MLD STP	Report No: GLEPL/230225/349 Issue Date: 20/02/2026
--	---

Lab ID Code	:	GLEPL/230222/WL ₂			
Sample Description	:	Waste Water (STP Outlet)	Purpose	:	As per Client requirement
Date of Sampling	:	Submitted by Client	Sample Collected/Submitted by	:	Submitted by Client
Date of Sample Received	:	10/02/2026	Test Parameters	:	As per Client requirement
Date of starting Analysis	:	11/02/2026	Quantity/No. of sample	:	2 Lit./02
Date of completion Analysis	:	17/02/2026	Packed/Seal	:	Sealed

Result Table

Sr. No.	Test Parameters	Test Method	Unit	Results	Permissible Limit
1	pH @30 °C	IS 3025 (P-11) 1983 (Reaffirmed 2017)	pH Unit	7.48	6.5-9.0
2	Total Suspended Solids	IS 3025 (P-17) 1984 (Reaffirmed 2017)	mg/L	7.8	<10
3	Chemical Oxygen Demand	IS 3025 (P-58) 2006 (Reaffirmed 2017)	mg/L	37	<50
4	BOD (5 days at 20°C)	IS 3025 (P-44) 1993 (Reaffirmed 2019)	mg/L	7.9	<10
5	Ammonical Nitrogen	IS 3025 (P-34) 1988 (Reaffirmed 2019)	mg/L	1.5	<5.0
6	Total Phosphorus	IS 3025 (P-31) 1988 (Reaffirmed 2019)	mg/L	0.63	<1.0
7	Total Nitrogen	IS 3025 (P-34) 1988 (Reaffirmed 2019)	mg/L	6.2	<10.0
8	Residual Chlorines	IS 3025 (P-26) 1986 (Reaffirmed 2019)	mg/L	ND	0.5-1.0
9	Fecal Coliform	APHA & AWWA 23 rd Ed. 9221 E (9-77)	MPN/100mL	85	<230
10	Total Coliform	APHA & AWWA 23 rd Ed. 9221 E (9-77)	MPN/100mL	210	

Note: BDL: Below Detection Limit.
WL₁: STP Outlet Water



Chemist



Authorized Signatory
Rekha Dare

Notes: (1) The results pertain to tested items only.
(2) This report shall not be reproduced, except in full, without written approval of the laboratory.
(3) Authenticity of this Report could be validated with office copy at Greenleaf Envirotech Pvt. Ltd.
(4) Perishable samples will be destroyed after testing, others after 7 days from the date of issue of the report, unless otherwise agreed with the customer or as required by the applicable regulations.
Recognized by MoEF, Govt. of India, EP Act 1986; NABL accredited; GPCB Schedule II Environment Auditor; OHSAS – 18001:2017 Certified Laboratory.



LAB FOR CIVIL ENGINEERING MATERIAL & SOIL TESTING

TEST REPORT

APEX/WTRI/ 2507899		Report Date:- 19-02-2026	
Name of work.	3.8 MLD STP Devgadhi Baria		
Details of sample.	STP Inlet of 3.8 MLD STP Devgadhi Baria		
Report Submitted To,	GWSSB Dahod		
Name of the Client	Rajkamal Builder's		
PMC	Mars Ahmedabad		
Reference No.	Letter Date:08/02/2026		
Date of Receipt of Sample	08-02-2026		
Condition of sample during receipt	Sealed		
Source	Grab Sample (Inlet)		
Job No.	2507899		
Lab No.	250812/10		
Starting Date of Test	08-02-2026	Completion Date of Test	19-02-2026

Sr.No	Test	Test Perform As per IS	Results obtained	Unit
1	2	3	4	5
1	PH	IS: 3025 : 1983 (Part-11) (RA-2017)	7.99	---
2	Total Suspended Soild	IS: 3025 : 1986 (Part-16) (RA-2019)	7	mg/l
3	Chemical Oxygen Demand	IS: 3025 : 1988 (Part-58) (RA-2017)	57	mg/l
4	Bio-chemical Oxygen Demand (27°C @ 3 Days)	IS: 3025 : 1984 (Part-44) (RA-2021)	5.6	mg/l
5	Total Nitrogen	IS: 3025 : 1988 (Part-34) (RA-2023)	7.3	mg/l
6	Total Phosorus	IS: 3025 : 1993 (Part-45) (RA-2019)	0.94	mg/l
7	Total Coliform	IS: 15185:2016	280	(MNP)/100

Note:- [1] Test results are related to sample collected by supplier. [2] Results/Reports are issued with specific understanding the APEX will not in any case be involved in action following the interpretation of test results. [3] The Reports/Results are not supposed to be used for publicity.[4]Test report shall not be reproduced except in full without written approval of APEX.

For, Apex Geo Tech & Consultancy
 Authorized Signatory
 Technical Manager/ Quality Manager

.....End of Report.....



LAB FOR CIVIL ENGINEERING MATERIAL & SOIL TESTING

TEST REPORT

APEX/WTR/ 2507899		Report Date:- 19-02-2026
Name of work.	3.8 MLD STP Devgadh Baria	
Details of sample.	STP Outlet of 3.8 MLD STP Devgadh Baria	
Report Submitted To,	GWSSB Dahod	
Name of the Client	Rajkamal Builder's	
PMC	Mars Ahmedabad	
Reference No.	Letter Date:08/02/2026	
Date of Receipt of Sample	08-02-2026	
Condition of sample during receipt	Sealed	
Source	Grab Sample (Outlet)	
Job No.	250899	
Lab No.	250812/10	
Starting Date of Test	08-02-2026	Completion Date of Test 19-02-2026

Sr.No	Test	Test Perform As per IS	Results obtained	Unit
1	2	3	4	5
1	PH	IS: 3025 : 1983 (Part-11) (RA-2017)	7.02	---
2	Total Suspended Soild	IS: 3025 : 1986 (Part-16) (RA-2019)	7.9	mg/l
3	Chemical Oxygen Demand	IS: 3025 : 1988 (Part-58) (RA-2017)	43	mg/l
4	Bio-chemical Oxygen Demand (27°C @ 3 Days)	IS: 3025 : 1984 (Part-44) (RA-2021)	6	mg/l
5	Ammonical Nitrogen	IS: 3025 : 1984 (Part-34) (RA-2019)	3.0	mg/l
6	Total Nitrogen	IS: 3025 : 1988 (Part-34) (RA-2023)	6.7	mg/l
7	Total Phoshorus	IS: 3025 : 1993 (Part-45) (RA-2019)	0.67	mg/l
8	Faecal Coliform	IS: 15185:2016	131	(MNP)/100
9	Total Coliform	IS: 15185:2016	230	(MNP)/100
10	Residual Chlorine	IS: 3025 : 2001 (Part-31) (RA-2022)	0.90	mg/l

Note:- [1] Test results are related to sample collected by supplier. [2] Results/Reports are issued with specific understanding the APEX will not in any case be involved in action following the interpretation of test results. [3] The Reports/Results are not supposed to be used for publicity.[4]Test report shall not be reproduced except in full without written approval of APEX.

For, Apex Geo Tech & Consultancy

 Authorized Signatory
 Technical Manager/Quality Manager

End of Report



TEST REPORT

REPORT NO: AEPL/26-02/0053	ISSUE DATE: 21-02-2026
NAME OF CLIENT: M/s. SANTRAMPUR NAGARPALIKA STP	
ADDRESS: Survey no. 198/1, At: Santrampur, Ta: Santrampur, Dist: Mahisagar-389 260.	
SAMPLE TYPE	: Wastewater
LOCATION OF SAMPLE	: STP
DESCRIPTION	: Inlet
SAMPLING PROTOCOL / STANDARD	: NA
TYPE OF SAMPLING	: NA
SAMPLE COLLECTED/ RECEIVED IN	: Client/ Plastic Carboy
QUANTITY	: 2.0 Ltrs
SAMPLE CONDITION	: Acceptable
SAMPLING DATE	: NA
SAMPLE RECIEPT DATE	: 14-02-2026
ANALYSIS START DATE	: 14-02-2026
ANALYSIS END DATE	: 21-02-2026
TEST CONDITIONS	Temperature (°C): 25.0 Relative Humidity (%): 40

RESULTS

SR.NO	PARAMETERS	UNIT	INLET	REFERENCE METHOD
1.	pH @ 25 °C	-	7.28	IS 3025 (Part-11) 2022
2.	Total Suspended Solids	mg/L	158	APHA 24th Edition 2023 2540-D
3.	Chemical Oxygen Demand	mg/L	286	IS 3025 (Part-58) 2023
4.	BOD (3 Days@ 27 °C)	mg/L	68	IS 3025 (Part-44) 2023
5.	Ammonical Nitrogen	mg/L	22	IS 3025 Part – 34: Sec 4: 2023
6.	Total Nitrogen	mg/L	30	IS 3025 Part – 34: Sec 4: 2023
7.	Total Phosphorus	mg/L	4.8	APHA 24th Edition 2023 4500 P C
8.	Fecal Coliform	MPN/100 ml	584	APHA 24th Edition 2023 9221 B
9.	Total Coliform	MPN/100 ml	1270	APHA 24th Edition 2023 9221 B

Remark: NA

Disha
Authorized Signatory
 Disha Chaudhary
 Senior Chemist

* End of Report *

Information provided by the Customer: N.A.

Note:

1. This report shall not be reproduced in part or full without prior permission of Aagam Environment Pvt Ltd.
2. The results listed herewith are only for the items tested.
3. Sample shall be disposed after 15 days from the date of issue of the report unless agreed with the customer.
4. Incase when laboratory is not involved in sampling, the results apply to the samples as received.
5. This report shall not be used for publicity or litigation.
6. Tests performed by External Provider shall be identified/marked by **** sign.
7. Any additions to, deviations or exclusions from the method shall be identified by *** sign.

Shed - 92, Pushkar Industrial Hub - 4, GIDC Vatva, Opp. Machhunagar Torrent Compound, Ahmedabad-382445, Gujarat.



TEST REPORT

REPORT NO: AEPL/26-02/0054	ISSUE DATE: 21-02-2026
NAME OF CLIENT: M/s. SANTRAMPUR NAGARPALIKA STP	
ADDRESS: Survey no. 198/1, At: Santrampur, Ta: Santrampur, Dist: Mahisagar-389 260.	
SAMPLE TYPE	: Wastewater
LOCATION OF SAMPLE	: STP
DESCRIPTION	: Outlet
SAMPLING PROTOCOL / STANDARD	: NA
TYPE OF SAMPLING	: NA
SAMPLE COLLECTED/ RECEIVED IN	: Client/ Plastic Carboy
QUANTITY	: 2.0 Ltrs
SAMPLE CONDITION	: Acceptable
SAMPLING DATE	: NA
SAMPLE RECEIPT DATE	: 14-02-2026
ANALYSIS START DATE	: 14-02-2026
ANALYSIS END DATE	: 21-02-2026
TEST CONDITIONS	Temperature (°C): 25.0 Relative Humidity (%): 40

RESULTS

SR.NO	PARAMETERS	UNIT	OUTLET	REFERENCE METHOD
1.	pH @ 25 °C	-	6.59	IS 3025 (Part-11) 2022
2.	Total Suspended Solids	mg/L	7.3	APHA 24th Edition 2023 2540-D
3.	Chemical Oxygen Demand	mg/L	28	IS 3025 (Part-58) 2023
4.	BOD (3 Days@ 27 °C)	mg/L	5.9	IS 3025 (Part-44) 2023
5.	Ammonical Nitrogen	mg/L	2.7	IS 3025 Part – 34: Sec 4: 2023
6.	Total Nitrogen	mg/L	5.8	IS 3025 Part – 34: Sec 4: 2023
7.	Total Phosphorus	mg/L	0.8	APHA 24th Edition 2023 4500 P C
8.	Residual Chlorine	mg/L	0.6	APHA 24 th Edition 2023 4500 Cl- B
9.	Fecal Coliform	MPN/100 ml	56	APHA 24th Edition 2023 9221 B
10.	Total Coliform	MPN/100 ml	182	APHA 24th Edition 2023 9221 B

Remark: NA

Disha

Authorized Signatory
Disha Chaudhary
Senior Chemist

* End of Report *

Information provided by the Customer: N.A.

Note:

- This report shall not be reproduced in part or full without prior permission of Aagam Environment Pvt Ltd.
- The results listed herewith are only for the items tested.
- Sample shall be disposed after 15 days from the date of issue of the report unless agreed with the customer.
- In case when laboratory is not involved in sampling, the results apply to the samples as received.
- This report shall not be used for publicity or litigation.
- Tests performed by External Provider shall be identified/ marked by "****" sign.
- Any addition to, deviation or exclusion from the method shall be identified/ marked by "****" sign.

Shed 92, Pushkar Industrial Hub 4, BHE Walva, Opp. Machhunagar Torrent Compound, Ahmedabad-382445, Gujarat.



TEST REPORT

REPORT NO: AEPL/02-26/0042

ISSUE DATE: 14-02-2026

NAME OF CLIENT: SEWAGE TREATMENT PLANT (4.80 MLD)

CONTRACTOR: M/s ANKITA CONSTRUCTION, AHMEDABAD.

ADDRESS: Kaalol Nagarpalika, Dist- Panchmahal, Gujarat.

SAMPLE TYPE	: Wastewater
LOCATION OF SAMPLE	: STP
DESCRIPTION	: Inlet
SAMPLING PROTOCOL / STANDARD	: NA
TYPE OF SAMPLING	: Grab
SAMPLE COLLECTED BY / RECEIVED IN	: Client / Plastic Carboy
QUANTITY	: 2.0 Ltr
SAMPLE CONDITION	: Acceptable
SAMPLING DATE	: NA
SAMPLE RECIEPT DATE	: 07-02-2026
ANALYSIS START DATE	: 07-02-2026
ANALYSIS END DATE	: 14-02-2026
TEST CONDITIONS	Temperature (°C): 24.2 Relative Humidity (%): 45

RESULTS

SR.NO	PARAMETERS	UNIT	INLET	REFERENCE METHOD
1.	pH @ 25 °C	-	7.68	IS 3025 (Part-11) 2022
2.	Total Suspended Solids	mg/L	259	APHA 24 th Edition 2023 2540-D
3.	Chemical Oxygen Demand	mg/L	442	IS 3025 (Part-58) 2023
4.	BOD (5 Days@ 20 °C)	mg/L	228	IS 3025 (Part-44) 2023
5.	Total Kjeldahl Nitrogen	mg/L	192	IS 3025 Part – 34: Sec 4: 2023
6.	Total Phosphorus	mg/L	6.8	APHA 24 th Edition 2023 4500 P C
7.	Fecal Coliform	MPN/100 mL	846	APHA 24 th Edition 2023 9221 B
8.	Total Coliform	MPN/100 mL	> 2200	APHA 24 th Edition 2023 9221 B

Remark: NA

Authorized Signatory
Hardik Pathak
Quality Manager

* End of Report *

Information provided by the Customer: N.A.

Note:

1. This report shall not be reproduced in part or full without prior permission of Aagam Environment Private Limited.
2. The results listed herewith are only for the items tested.
3. Sample shall be disposed after 15 days from the date of issue of the report unless agreed with the customer.
4. In case when laboratory is not involved in sampling, the results apply to the samples as received.
5. This report shall not be used for publicity or litigation.
6. Tests performed by External Provider shall be identified/marked by "***" sign.
7. Any additions to, deviations or exclusions from the method shall be identified by "*" sign.



TEST REPORT

REPORT NO: AEPL/02-26/0043

ISSUE DATE: 14-02-2026

NAME OF CLIENT: SEWAGE TREATMENT PLANT (4.80 MLD)

CONTRACTOR: M/s ANKITA CONSTRUCTION, AHMEDABAD.

ADDRESS: Kaalol Nagarpalika, Dist- Panchmahal, Gujarat.

SAMPLE TYPE	: Wastewater
LOCATION OF SAMPLE	: STP
DESCRIPTION	: Outlet
SAMPLING PROTOCOL / STANDARD	: NA
TYPE OF SAMPLING	: Grab
SAMPLE COLLECTED BY / RECEIVED IN	: Client / Plastic Carboy
QUANTITY	: 2.0 Ltr
SAMPLE CONDITION	: Acceptable
SAMPLING DATE	: NA
SAMPLE RECEIPT DATE	: 07-02-2026
ANALYSIS START DATE	: 07-02-2026
ANALYSIS END DATE	: 14-02-2026
TEST CONDITIONS	Temperature (°C): 24.2 Relative Humidity (%): 45

RESULTS

SR.NO	PARAMETERS	UNIT	RESULT	PERMISSIBLE LIMIT	REFERENCE METHOD
1.	pH @ 25 °C	-	7.30	6.5 to 9.0	IS 3025 (Part-11) 2022
2.	Total Suspended Solids	mg/L	5.2	< 10	APHA 24 th Edition 2023 2540-D
3.	Chemical Oxygen Demand	mg/L	32	< 50	IS 3025 (Part-58) 2023
4.	BOD (5 Days@ 20 °C)	mg/L	6.0	< 10	IS 3025 (Part-44) 2023
5.	Ammonical Nitrogen	mg/L	4.6	< 5.0	IS 3025 Part – 34: Sec 4: 2023
6.	Residual Chlorine	mg/L	0.9	--	APHA 24 th Edition 2023 4500 Cl
7.	Total Nitrogen	mg/L	7.2	< 10	IS 3025 Part – 34: Sec 4: 2023
8.	Total Phosphorus	mg/L	0.6	< 2.0	APHA 24 th Edition 2023 4500 P C
9.	Total Coliform	MPN/100 mL	169	< 230	APHA 24 th Edition 2023 9221 B
10.	Fecal Coliform	MPN/100 ml	32	< 100	APHA 24 th Edition 2023 9221 B

Remark: NA


Authorized Signatory
Hardik Pathak
Quality Manager

* End of Report *

Information provided by the Customer: N.A.

Note:

1. This report shall not be reproduced in part or full without prior permission of Aagam Environment Private Limited.
2. The results listed herewith are only for the items tested.
3. Sample shall be disposed after 15 days from the date of issue of the report unless agreed with the customer.
4. In case when laboratory is not involved in sampling, the results apply to the samples as received.
5. This report shall not be used for publicity or litigation.
6. Tests performed by External Provider shall be identified/marked by "***" sign.
7. Any additions to, deviations or exclusions from the method shall be identified by "*" sign.



ISO 9001:2015 and ISO 17025:2017 NABL certified

No.4, Versetile Industrial Estate, Nr. Kotak Bank, Gate No.5,
Kathwada Gidc, Ahmedabad - 382430.

+91 8469130040, +91 6357351655 naturemicrovision@gmail.com GSTIN : 24AAWFN4704G1Z4

Test Report

Report ID: NML/WW/25-26/1295

Date: 24/02/2026

Customer Name	Rajkamal Builders Infrastructure Private Limited		
Customer Address	2.08 MLD Shehara		
Date & Time of Sampling	20/02/2026	Sampling Plan & Method	IS 3025(Part-1) RA 2019
Date of Receipt of Sample	21/02/2026		
Sample Collected by	Client	Sample Condition	SATISFACTORY
Analysis Starting Date	21/02/2026	Packing / Seal	SEALED
Analysis Completion Date	24/02/2026	Quantity / No. of Samples	Approx. 1 LIT. * 1NO.
Environmental Condition	Temperature: 25 °C ± 2	Relative Humidity (%)	Humidity ≤ 50 %

Sample No.	Sample ID	Sample Type	Location	Description
1.	25-26/1304	Waste Water	Outlet	Treated Water

Analysis Results

Sr. No.	Parameters	Reference Method	Results	Regulatory Limit	Unit
1.	pH	IS 3025 (Part 11): 2022	7.49	6.5-9.0	--
2.	BIOLOGICAL OXYGEN DEMAND (3 days at 27°C)	IS 3025 (Part 44): 2023	6.8	<10	mg/L
3.	CHEMICAL OXYGEN DEMAND	IS 3025 (Part 58) : 2023	35	<50	mg/L
4.	TOTAL SUSPENDED SOLIDS	IS 3025 (Part 17): 1988 (RA 2022)	5.5	<10	mg/L
5.	AMMONICAL NITROGEN	IS 3025 (Part 34/sec-1):2023	1.4	<5	mg/L
6.	TOTAL NITROGEN	IS 3025 (Part 34/sec- 1):2023	4.2	<10	mg/L
7.	TOTAL PHOSPHORUS	IS 3025 (Part 31) :Sec 1 : 2022	0.56	<2	mg/L
8.	FECAL COLIFORM	APHA 24 th Edition 2023 9221 E	98	<230	(MPN)/100
9.	RESIDUAL CHLORINE	IS 3025 (Part 31) : Sec 1 : 2022	0.53	0.5-1.0	mg/L
10.	TOTAL COLIFORM	APHA 24 th Edition 2023 9221 B	170	<230	(MPN)/100

Checked by
Senior Chemist



Authorised by
Lab Manager/CEO

Remarks:

- BDL: Below Detectable Limit.
- The report pertains only to the sample tested and does not apply to the bulk quantity.
- The test report may not be reproduced, wholly or partially, nor used for promotional or publicity purposes without written consent from the laboratory department.
- Samples will be retained for 15 days after the completion of analysis. A longer retention period can be arranged upon customer request.



ISO 9001:2015 and ISO 17025:2017 NABL certified

No.4, Versetile Industrial Estate, Nr. Kotak Bank, Gate No.5,
Kathwada Gidc, Ahmedabad - 382430.

+91 8469130040, +91 6357351655 naturemicrovision@gmail.com GSTIN : 24AAWFN4704G1Z4

Test Report

Report ID: NML/WW/25-26/1294


Date: 24/02/2026

Customer Name	Rajkamal Builders Infrastructure Private Limited			
Customer Address	2.08 MLD Shehara			
Date & Time of Sampling	20/02/2026	Sampling Plan & Method	IS 3025(Part-1) RA 2019	
Date of Receipt of Sample	21/02/2026			
Sample Collected by	Client	Sample Condition	SATISFACTORY	
Analysis Starting Date	21/02/2026	Packing / Seal	SEALED	
Analysis Completion Date	24/02/2026	Quantity / No. of Samples	Approx. 1 LIT. * 1NO.	
Environmental Condition	Temperature: 25 °C ± 2	Relative Humidity (%)	Humidity ≤ 50 %	
Sample No.	Sample ID	Sample Type	Location	Description
1.	25-26/1303	Waste Water	Inlet	Untreated Water

Analysis Results

Sr. No.	Parameters	Reference Method	Results	Unit
1.	pH	IS 3025 (Part 11): 2022	7.12	--
2.	BIOLOGICAL OXYGEN DEMAND (3 days at 27°C)	IS 3025 (Part 44): 2023	225	mg/L
3.	CHEMICAL OXYGEN DEMAND	IS 3025 (Part 58) : 2023	363.5	mg/L
4.	TOTAL SUSPENDED SOLIDS	IS 3025 (Part 17): 1988 (RA 2022)	291.27	mg/L
5.	TOTAL NITROGEN	IS 3025 (Part 34/sec- 1):2023	33	mg/L
6.	TOTAL PHOSPHORUS	IS 3025 (Part 31) :Sec 1 : 2022	2.9	mg/L
7.	TOTAL COLIFORM	APHA 24 th Edition 2023 9221 B	10 ⁶	(MPN)/100
8.	FECAL COLIFORM	APHA 24 th Edition 2023 9221 E	1.8 × 10 ²	(MPN)/100

Checked by
Senior Chemist



Authorised by
Lab Manager/CEO

*End of Test Report

Remarks:

- BDL: Below Detectable Limit.
- The report pertains only to the sample tested and does not apply to the bulk quantity.
- The test report may not be reproduced, wholly or partially, nor used for promotional or publicity purposes without written consent from the laboratory department.
- Samples will be retained for 15 days after the completion of analysis. A longer retention period can be arranged upon customer request.

Test Report
Water Sample Analysis Report

Client's Name & Address: GWSSB, Karjan 5.2 MLD STP	Report No: GLEPL/230225/348 Issue Date: 4/03/2026
---	--

Lab ID Code	: GLEPL/230222/WL ₁
Sample Description	: Waste Water (STP Inlet) Purpose : As per Client requirement
Date of Sampling	: Submitted by Client Sample Collected/Submitted by : Submitted by Client
Date of Sample Received	: 23/02/2026 Test Parameters : As per Client requirement
Date of starting Analysis	: 24/02/2026 Quantity/No. of sample : 2 Lit./01
Date of completion Analysis	: 2/03/2026 Packed/Seal : Sealed

Result Table

Sr. No.	Test Parameters	Test Method	Unit	Results
1	pH @30 °C	IS 3025 (P-11) 1983 (Reaffirmed 2017)	pH Unit	7.25
2	Total Suspended Solids	IS 3025 (P-17) 1984 (Reaffirmed 2017)	mg/L	285.15
3	Chemical Oxygen Demand	IS 3025 (P-58) 2006 (Reaffirmed 2017)	mg/L	395
4	BOD (5 days at 20°C)	IS 3025 (P-44) 1993 (Reaffirmed 2019)	mg/L	205
5	Ammonical Nitrogen	IS 3025 (P-34) 1988 (Reaffirmed 2019)	mg/L	BDL
6	Total Phosphorus	IS 3025 (P-31) 1988 (Reaffirmed 2019)	mg/L	2.5
7	Total Kjeldahl Nitrogen	IS 3025 (P-34) 1988 (Reaffirmed 2019)	mg/L	32
8	Residual Chlorine	IS 3025 (P-26) 1986 (Reaffirmed 2019)	mg/L	ND
9	Total Coliform	APHA & AWWA 23 rd Ed. 9221 E (9-77)	MPN/100mL	10 ⁶
10	Fecal Coliform	APHA & AWWA 23 rd Ed. 9221 E (9-77)	MPN/100mL	870

Note: BDL: Below Detection Limit, ND: Not Detected.

WL₁: STP Inlet Water



Chemist



Authorized Signatory
Rekha Dare

- Notes: (1) The results pertain to tested items only.
(2) This report shall not be reproduced, except in full, without written approval of the laboratory.
(3) Authenticity of this Report could be validated with office copy at Greenleaf Envirotech Pvt. Ltd.
(4) Perishable samples will be destroyed after testing, others after 7 days from the date of issue of the report, unless otherwise agreed with the customer or as required by the applicable regulations.

Test Report
Water Sample Analysis Report


Client's Name & Address: GWSSB, Karjan 5.2 MLD STP	Report No: GLEPL/230225/349 Issue Date: 4/03/2026
---	--

Lab ID Code	:	GLEPL/230222/WL ₂	
Sample Description	:	Waste Water (STP Outlet)	Purpose : As per Client requirement
Date of Sampling	:	Submitted by Client	Sample Collected/Submitted by : Submitted by Client
Date of Sample Received	:	23/02/2026	Test Parameters : As per Client requirement
Date of starting Analysis	:	24/02/2026	Quantity/No. of sample : 2 Lit./02
Date of completion Analysis	:	2/03/2026	Packed/Seal : Sealed

Result Table

Sr. No.	Test Parameters	Test Method	Unit	Results	Permissible Limit
1	pH @30 °C	IS 3025 (P-11) 1983 (Reaffirmed 2017)	pH Unit	7.42	6.5-9.0
2	Total Suspended Solids	IS 3025 (P-17) 1984 (Reaffirmed 2017)	mg/L	9.1	<10
3	Chemical Oxygen Demand	IS 3025 (P-58) 2006 (Reaffirmed 2017)	mg/L	47	<50
4	BOD (5 days at 20°C)	IS 3025 (P-44) 1993 (Reaffirmed 2019)	mg/L	9	<10
5	Ammonical Nitrogen	IS 3025 (P-34) 1988 (Reaffirmed 2019)	mg/L	1.5	<5.0
6	Total Phosphorus	IS 3025 (P-31) 1988 (Reaffirmed 2019)	mg/L	BDL	<1.0
7	Total Nitrogen	IS 3025 (P-34) 1988 (Reaffirmed 2019)	mg/L	9	<10.0
8	Residual Chlorines	IS 3025 (P-26) 1986 (Reaffirmed 2019)	mg/L	ND	0.5-1.0
9	Fecal Coliform	APHA & AWWA 23 rd Ed. 9221 E (9-77)	MPN/100mL	55	<230
10	Total Coliform	APHA & AWWA 23 rd Ed. 9221 E (9-77)	MPN/100mL	165	

Note: BDL: Below Detection Limit.
WL₁: STP Outlet Water



Chemist



Authorized Signatory
Rekha Dare

Notes: (1) The results pertain to tested items only.
(2) This report shall not be reproduced, except in full, without written approval of the laboratory.
(3) Authenticity of this Report could be validated with office copy at Greenleaf Envirotech Pvt. Ltd.
(4) Perishable samples will be destroyed after testing, others after 7 days from the date of issue of the report, unless otherwise agreed with the customer or as required by the applicable regulations.
Recognized by MoEF, Govt. of India, EP Act 1986; NABL accredited; GPCB Schedule II Environment Auditor; OHSAS – 18001:2017 Certified Laboratory.

Annexure – III - Ring Fence Account					
Sr No	Amount Disbursement to Authority	Amount Allocated (In Cr)	Amount Disbursed (in Cr)	Amount Utilised (In Cr)	Plan for Utilisation
1.	Ahmedabad Municipal Corporation	80	80	58.31	Fund will be utilized till December 2026
2.	Bhavnagar Municipal Corporation	50	50	36.31	Fund will be utilised upto Rs.45 cr. Till March 2027
3.	Gandhinagar Municipal Corporation	46	46	24.99	The remaining expenditure RS.21,00,61,223/- shall be booked from 3 MLD STP at Raysan project and another ongoing drainage projects and it will be completed by Sept 2026.
4.	Jamnagar Municipal Corporation	20	20	5.96	The remaining Fund will be utilise under Project of 10MLD STP at Naghedi, Jamnagar and at present work is Under Construction and will be completed by Sept 2026.
5.	Junagadh Municipal Corporation	64	64	24.17	The work of the Underground Sewer Phase-2 project is currently work in Progress, in which these funds will be utilized and tentatively completed by Sept 2026.
6.	Surat Municipal Corporation	144	144	135.75	The remaining Fund of Rs. 82495000/- will be utilise under Project of Variav Kosad STP
7	Gujarat Urban Development Company Ltd.	500	500	414.56	The ULB-wise planning for the projects under implementation by GUDCL is attached herewith.
8.	Gujarat Water Supply and Sewerage and board	600	600	423.93	Under SJMMSVY Scheme
					(1) Junagadh, Sanand ugd Part-2 and Halol UGD Physical Work have been Completed. The Operation & Maintenance of these works are currently under progress.
					(2) 9 STP Physical and Operation & Maintenance Work have been Completed.
					(3) 91 STP Physical Work have been Completed. The Operation & Maintenance of these works are currently under progress.
					(4) 10 STP Work is under Progress.
					Under Amrut Scheme
					(1) Dwarka UGD Part-2, Jetpur UGD Part-2 & Bhuj UGD Physical Work have been Completed. The Operation & Maintenance of these works are currently under progress.
					(2) Dwarka STP Physical and Operation & Maintenance Work has been Completed.
(3) 6 STP Physical Work have been Completed. The Operation &					

					Maintenance of these work is currently under progress.
9.	Swacch Bharat Mission	90	90	90.00	As per annexure attached in solid waste management compliances.
10.	SJMMSVY	500	300	0.00	Amount Disbursed to GUDCL for the projects STP at Gadhada, Kathlal Patdi, Thasra, Virangam, Savarkundla, Vanthali, Bayad, Modasa, Siddhpur, Jamraval, Upleta, Pardi, Tarsadi, Sojitra, Vvnagar & UGD at Bavla, Dholka, Dhrangadhra, Kapadwanj, Kathlal, Patdi, Thasra, Balasinor, Boriyavi, Borsad, Chhota Udepur, Dabhoi, Godhra, Halol, Karjan, Khambhat, Ode, Padra, Petlad, Savli, Umreth, Bayad, Chanasma, Dhanera, Harij, Idar, Modasa, Radhanpur, Tharad, Unjha, Vadali, Vijapur, Visnagar, Anjar, Bhachau, Khambhaliya, Morbi, Mundra Baroi, Rapar, Salaya, Upleta, Gariyadhar, Jafarabad, Kodinar, Mangrol J, Palitana, Rajula, Savarkundla, Sihor, Talala, Una G, Vallabhipur, Vanthali, Veraval, Amod, Ankleshwar, Dharampur, Jambusar, Mandvi S, Pardi, Songadh, Tarsadi, Vapi, Vyara, Vadnagar Heritage, Virangam, Dhoraji, Bharuch, Gandhidham, Amreli, Anand, Bardoli, Bilimora, Kaalol, Kadi, Kalol, Kanakpur Kansad, Mahuva II, Mehsana, Rajpipla, Rajpipla II, Wadhvan
11.	Municipal Corporation	6	0	0.00	
12.	Total Amount (in Cr)	2100	1894	1213.98	

Annexure-Expenditure Details of GWSSB					
					Up to Date: 28/02/2026
Sr.No.	Name of Municipality	Name of Work	Total amount of Project (Rs. in lakh)	Tentative Date of Completion	Expenditure (Rs. in lakh)
1	Chhotaudepur	Chhotaudepur (5 MLD)	836.16	Physical and O & M work completed	173.01
2	Dahod	Dahod (13.7 MLD)	1739.79	Physical work completed, O&M on going	208.71
3	Zalod	Zalod (4.6 MLD)	783.42	Physical work completed, O&M on going	262.33
4	Devgadhbaria	Devgadhbaria (3.8 MLD)	710.53	Physical work completed, O&M on going	186.55
5	Santarampur	Santarampur (3 MLD)	1053.06	Physical work completed, O&M on going	136.55
6	Karjan	Karjan (5.2 MLD)	1097.96	Physical work completed, O&M on going	297.6
7	Kalol (P)	Kalol (P) (4.8 MLD)	1048.4	Physical work completed, O&M on going	209.44
8	Shahera	Shahera (2.8 MLD)	600.35	Physical work completed, O&M on going	219.88
9	Lunawada	Lunawada (5.6 MLD)	1352.69	Physical work completed, O&M on going	345.78
10	Balasinor	Balasinor (6.5 MLD)	1667.34	Physical work completed, O&M on going	316.99
11	Halol	Halol (12.35 MLD)	2567.01	Physical work completed, O&M on going	990.35
12	Dabhoi	Dabhoi (9.00 MLD)	2005.95	Physical work completed, O&M on going	435.64

Annexure-Expenditure Details of GWSSB					
					Up to Date: 28/02/2026
13	Padra	Padra (5.6 MLD)	1247.12	Physical work completed, O&M on going	171.02
14	Borsad	Borsad (9.8 MLD)	1422.22	Physical work completed, O&M on going	235.57
15	Umreth	Umreth STP & EW (6.1 MLD)	1311.22	Physical work completed, O&M on going	213.2
16	Anklav	Anklav STP & EW (3.6 MLD)	1061.39	Physical work completed, O&M on going	209.87
17	Ode	Ode (2.5 MLD)	824.26	Physical work completed, O&M on going	130.9
18	Boriyavi	Boriyavi (3.3 MLD)	951.23	Physical work completed, O&M on going	241.29
19	Khambhat	Khambhat -1 (6.8 MLD)	2812.69	Physical work completed, O&M on going	699.24
20	Khambhat	Khambhat -2 (4.5 MLD)		Physical work completed, O&M on going	
21	Karamsad	Karamsad (7 MLD)	1474.23	Physical work completed, O&M on going	187.96
22	Kanjari	Kanjari (3.3 MLD)	953.78	Physical work completed, O&M on going	125.41
23	Kapadwanj	Kapadwanj (6.2 MLD)	1307.00	Physical work completed, O&M on going	199.12
24	Mahemdavad	Mahemdavad (5.6 MLD)	2726.19	Physical work completed, O&M on going	141.39
25	Kheda	Kheda (5.2 MLD)		Physical work completed, O&M on going	137.02
26	Dhandhuka	Dhandhuka (7.5 MLD)	1103.87	Physical work completed, O&M on going	179.37

Annexure-Expenditure Details of GWSSB					
					Up to Date: 28/02/2026
27	Bareja	Bareja (3.1 MLD)	537.71	Physical work completed, O&M on going	107.58
28	Bavla	Bavla (5.8 MLD)	1270.86	Physical work completed, O&M on going	205.41
29	Virangam	Virangam (4.5 MLD)	828.67	Physical work completed, O&M on going	190.26
30	Botad	Botad (32 MLD)	4271.80	Physical work completed, O&M on going	2745
31	Barwala	Barwala (2.9 MLD)	882.02	Physical work completed, O&M on going	631.93
32	Chotila	Chotila-1 (2.3 MLD)	880.62	Physical work completed, O&M on going	332.88
33	Chotila	Chotila-2 (1.7 MLD)		Physical work completed, O&M on going	
34	Thangadh	Thangadh (9 MLD)	1737.99	Physical work completed, O&M on going	286.05
35	Dhrangadhra	Dhrangadhra (11.6 MLD)	1503.54	Physical work completed, O&M on going	223.56
36	Visnagar	Visnagar-1 (12 MLD)	2347.91	Physical and O & M work completed	400.03
37	Visnagar	Visnagar-2 (5.3 MLD)			
38	Unjha	Unjha (11.6 MLD)	1701.2	Physical work completed, O&M on going	297.77
39	Vijapur	Vijapur (4.1 MLD)	1851.27	Physical work completed, O&M on going	261.58
40	Kheralu	Kheralu (2.9 MLD)		Physical and O & M work completed	
41	Kadi	Kadi (12.8 MLD)	1914.65	Physical work completed, O&M on going	368.57

Annexure-Expenditure Details of GWSSB					
					Up to Date: 28/02/2026
42	Dhanera	Dhanera (4 MLD)	2970.16	Physical work completed, O&M on going	121.7
43	Thara	Thara (3.3 MLD)		Physical work completed, O&M on going	69.17
44	Bhabhar	Bhabhar (3.5 MLD)		Physical work completed, O&M on going	104.72
45	Tharad	Tharad (4.8 MLD)	834.73	Physical and O & M work completed	140.59
46	Radhanpur	Radhanpur (6 MLD)	1249.93	Physical work completed, O&M on going	297.55
47	Harij	Harij (3 MLD)	1722.8	Physical work completed, O&M on going	407.33
48	Chanasama	Chanasama (2.5 MLD)		Physical work completed, O&M on going	
49	Idar	Idar (7.4 MLD)	1169.52	Physical and O & M work completed	183.99
50	Prantij	Prantij (3.7 MLD)	678.92	Physical and O & M work completed	110.64
51	Khedbhrhma	Khedbhrhma (5.8 MLD)	929.95	Physical work completed, O&M on going	151.02
52	Talod	Talod (3.6 MLD)	1899.45	Physical work completed, O&M on going	461.46
53	Vadali	Vadali (3.8 MLD)		Physical work completed, O&M on going	
54	Dehgam	Dehgam (7.6 MLD)	1075.08	Physical and O & M work completed	188.01
55	Mansa	Mansa (5 MLD)	1129.49	Physical work completed, O&M on going	200.47

Annexure-Expenditure Details of GWSSB					
					Up to Date: 28/02/2026
56	Gondal	Gondal (16.5 MLD)	2624.62	Physical work completed, O&M on going	602.46
57	Jasdan	Jasdan (8.30 MLD)	1738.09	Physical work completed, O&M on going	64.14
58	Jetpur	Jetpur (23.5 MLD)	3311.41	Physical work completed, O&M on going	351.01
59	Dhoraji	Dhoraji (12.9 MLD)	2218.93	Physical work completed, O&M on going	339.57
60	Bhayavadar	Bhayavadar (3.10 MLD)	1015.82	Physical work completed, O&M on going	417.16
61	Morbi	Morbi-1 (28.8 MLD)	4094.10	Physical work completed, O&M on going	906.29
62	Morbi	Morbi-2 (9.3 MLD)	1808.24	Physical work completed, O&M on going	287.48
63	Halvad	Halvad STP (6.7 MLD)	1447.80	Physical work completed, O&M on going	654.96
64	Wankaner	Wankaner STP (5.8 MLD)	1334.79	Physical work completed, O&M on going	501.87
65	Maliya	Maliya STP (2.5 MLD)	865.00	Physical work completed, O&M on going	644.97
66	Sikka	Sikka (2.9 MLD)	1218.28	Physical work completed, O&M on going	899.18
67	Kalavad	Kalavad (4.5 MLD)	1146.18	Physical work completed, O&M on going	250.31
68	Dhrol	Dhrol (5.3 MLD)	1309.16	Physical work completed, O&M on going	227.52
69	Jamjodhpur	Jamjodhpur (3.6 MLD)	1104.69	Physical work completed, O&M on going	131.897

Annexure-Expenditure Details of GWSSB					
					Up to Date: 28/02/2026
70	Dwarka	Dwarka (7.4 MLD)	1579.41	Physical and O & M work completed	127.20
71	Okha	Okha (10.1 MLD)	1887.02	Physical work completed, O&M on going	365.25
72	Salaya	Salaya (6.2 MLD)	1424.42	Physical work completed, O&M on going	365.25
73	Bhuj	Bhuj (23.7 MLD)	3587.18	Physical work completed, O&M on going	222.79
74	Bhachau	Bhachau (5.5 MLD)	1398.94	Physical work completed, O&M on going	149.92
75	Rapar	Rapar (5.2 MLD)	1296.78	Physical work completed, O&M on going	214.47
76	Chalala	Chalala (2.8 MLD)	556.36	Physical work completed, O&M on going	140.93
77	Babra	Babra (4 MLD)	1180.17	Physical work completed, O&M on going	760.25
78	Bagasara	Bagasara (5.9 MLD)	1257.53	Physical work completed, O&M on going	221.79
79	Rajula	Rajula (5.7 MLD)	1153.60	Physical work completed, O&M on going	311.23
80	Palitana	Palitana (12 MLD)	2132.98	Physical work completed, O&M on going	873.91
81	Gariyadhar	Gariyadhar (7.1 MLD)	1454.96	Physical work completed, O&M on going	274.84
82	Vallabhipur	Vallabhipur (2.3 MLD)	838.80	Physical work completed, O&M on going	350.88
83	Talaja	Talaja (5.8 MLD)	868.08	Physical work completed, O&M on going	291.7

Annexure-Expenditure Details of GWSSB					
					Up to Date: 28/02/2026
84	Mahuva	Mahuva (16.3 MLD)	1985.69	Physical and O & M work completed	398.64
85	Sihor	Sihor (8.9 MLD)	1695.92	Physical work completed, O&M on going	320.93
86	Kodinar	Kodinar (5.6 MLD)	1450.12	Physical work completed, O&M on going	417.46
87	Una	Una (11.7 MLD)	1723.67	Physical work completed, O&M on going	348.72
88	Sutrapada	Sutrapada (4 MLD)	1205.03	Physical work completed, O&M on going	259.88
89	Talala	Talala (3.8 MLD)	1017.14	Physical work completed, O&M on going	274.00
90	Kutiyana	Kutiyana (2.9 MLD)	1033.85	Physical work completed, O&M on going	219.24
91	Visavadar	Visavadar (3.4 MLD)	970.75	Physical work completed, O&M on going	202.45
92	Manavadar	Manavadar (4.9 MLD)	1174.2	Physical work completed, O&M on going	242.6
93	Bantwa	Bantwa (2.6 MLD)	533.22	Physical work completed, O&M on going	126.08
94	Chorwad	Chorwad (3.7 MLD)	1086.63	Physical work completed, O&M on going	209.3
95	Keshod	Keshod (13.3 MLD)	1869.68	Physical work completed, O&M on going	580.2
96	Mandvi-Surat	Mandvi-Surat (3.5 MLD)	1043.13	Physical work completed, O&M on going	420.45
97	Bardoli	Bardoli (11.3 MLD)	1634.95	Physical work completed, O&M on going	70.00

Annexure-Expenditure Details of GWSSB					
					Up to Date: 28/02/2026
98	Jambusar	Jambusar (5.9 MLD)	2386.29	Physical work completed, O&M on going	184.87
99	Amod	Amod (3.1 MLD)		Physical work completed, O&M on going	127.77
100	Dharmpur	Dharmpur (4.1 MLD)	796.14	Physical work completed, O&M on going	152.93
101	Bilimora	Bilimora (8.3 MLD)	1205.7	Physical work completed, O&M on going	269.41
102	Gandevi	Gandevi (2.6 MLD)	778.89	Physical work completed, O&M on going	186.61
103	Rajpipla	Rajpipla (5.5 MLD)	1260.89	Physical work completed, O&M on going	823.2
104	Vyara	Vyara (6.5 MLD)	1016.85	Physical work completed, O&M on going	143.36
105	Songadh	Songadh (4.5 MLD)	1115.17	Physical work completed, O&M on going	993.03
106	Khambhaliya	Khambhaliya (5.5 MLD)	1330.01	Physical work completed, O&M on going	265.48
107	Bhanvad	Bhanvad (3 MLD)	1017.58	Physical work completed, O&M on going	180.45
108	Chaklasi	Chaklasi (4.9 MLD)	786.67	30.06.2026	638.03
109	Beyt, Okha	Beyt, Okha (1 MLD)	520.26	30/06/2026	146.35
110	Mandvi	Mandvi (GT Ground) (5.3 MLD)	2484.63	31.03.2026	1313.29
111	Mandvi	Mandvi (Salaya) (3.2 MLD)			
112	Porbandar	Chhaya (Porbandar) (13.1 MLD)	2231.43	-	0.00
113	Lathi	Lathi (3.8 MLD)	1768.38	31/03/2026	1248.25
114	Damnagar	Damnagar (2.8 MLD)			
115	Jafrabad	Jafrabad (5.4 MLD)	1595.93	31/03/2027	15.59

Annexure-Expenditure Details of GWSSB					
					Up to Date: 28/02/2026
116	Ankleshwar	Ankleshwar (14 MLD)	2641.33	31.07.2026	1225.20
117	Umargam	Umargam (6.5 MLD)	1641.29	31.09.2026	167.78
				Total	38262.24
1	Junagadh	Junagadh UGD	25344.79	Physical work completed, O&M on going	109.49
2	Sanand	Sanand UGD Part-2	1133.79	Physical work completed, O&M on going	451.13
3	Halol	Halol UGD	6213.62	Physical work completed, O&M on going	1291.07
4	Dwarka	Dwarka UGD Part-2	694.41	Physical work completed, O&M on going	182.89
5	Jetpur	Jetpur UGD Part-2	304.77	Physical work completed, O&M on going	1.85
6	Bhuj	Bhuj UGD	3522.73	Physical work completed, O&M on going	752.69
7	Botad	Botad UGD-2	3807.43	Physical and O & M work completed	118.19
8	Vijapur	Vijapur UGD	935.97	Physical and O & M work completed	926.41
9	Gondal	Gondal UGD-1&2	11497.19	Physical and O & M work completed	55.80
10	Kheda	Mahudha UGD	842.06	Physical and O & M work completed	241.65
				Total	4131.17
				Grand Total	42393.41

Expenditure from NGT Fund in the Project of GUDCL Part - I					
Sr. No	Name of Municipality	Name of Work	Total Amount of Project In Lakh	Tentative Date of Completion	Expenditure from NGT Ring Fenced Grant in lakhs
1	Gadhada	Gadhada STP	1786.69	17/04/2026	654.37
2	Kathlal	Kathlal STP	1143.32	31/03/2026	4.28
3	Patdi	Patdi STP	850.56	20/12/2025	9.38
4	Thasra	Thasra STP	929.95	30/06/2026	30.91
5	Savarkundla	Savarkundla STP	2008.66	31/12/2025	471.1
6	Bayad	Bayad STP	1383.93	31/12/2025	264.96
7	Modasa	Modasa STP	2391.92	04/09/2026	21.08
8	Siddhpur	Siddhpur STP	4184.28	30/04/2026	1751.45
9	Jamraval	Jamraval STP	1099.38	23/03/2027	14.48
10	Pardi	Pardi STP	1312.77	20/12/2026	71.31
11	Tarsadi	Tarsadi STP	1088.09	28/10/2026	9.17
12	Sojitra	Sojitra STP	975.65	30/06/2026	0.89
13	VVnagar	Vvnagar STP	2820.93	01/08/2026	723.45
14	Bavla	Bavla UGD	7347.41	23/01/2028	116.98
15	Dholka	Dholka UGD	4837.65	30/12/2027	1202.26
16	Dhrangadhra	Dhrangadhra UGD	2095.98	15/08/2026	23.43
17	Kathlal	Kathlal UGD	2462.83	26/05/2026	15.34
18	Chhota Udepur	Chhota Udepur UGD	1774.4	09/02/2028	11.94
19	Godhra-II	Godhra UGD	7429.43	17/06/2027	43.07
20	Petlad	Petlad UGD	2762.48	29/05/2027	17.94
21	Modasa	Modasa UGD	6007.79	30/06/2026	2047.08
22	Unjha	Unjha UGD	4632.8	25/05/2027	84.95
23	Visnagar-II	Visnagar UGD	7990.95	26/08/2026	140.82
24	Bhachau-II	Bhachau UGD	1079.4	03/04/2027	217.69
25	Morbi	Morbi UGD	1767.3	31/12/2025	746.78
26	Mundra baroi	Mundra baroi UGD	5110.27	04/02/2026	199.09
27	Upleta	Upleta UGD	4378.15	31/08/2026	308.56
28	Mangrol_J	Mangrol_J UGD	6641.6	20/06/2027	12.27
29	Palitana-II	Palitana UGD	1659.94	02-02-026	611.23
30	Palitana-III	Palitana UGD	1595.3	31/03/2021	5.16
31	Savarkundla	Savarkundla UGD	3182.99	04/12/2026	21.6
32	Ankleshwer	Ankleshwer UGD	1158.06	25/05/2026	15.73
33	Dharampur	Dharampur UGD	1090.46	26/12/2025	363.66
34	Pardi-II	Pardi UGD	947.43	28/05/2026	331.91
35	Vyara	Vyara UGD	1032.52	08/09/2026	10.66

Expenditure from NGT Fund in the Project of GUDCL Part - I					
Sr. No	Name of Municipality	Name of Work	Total Amount of Project In Lakh	Tentative Date of Completion	Expenditure from NGT Ring Fenced Grant in lakhs
36	Vadnagar	STP	740	30/11/2020	17.5
37	Vadnagar-III	UGD	698.42	31/01/2025	712.86
38	Mehsana	STP	5134	31/01/2023	349.85
39	Viramgam-III	Viramgam UGD	1747.32	31/03/2025	1613.22
40	Dhoraji	Dhoraji SEW	1612.89	26/12/2025	310.74
41	Bharuch-1	Bharuch-ugd	1031.53	30/11/2021	35
42	Gandhidham	Gandhidham-UGD	4595.57	22/03/2024	3082.86
43	Amreli	Amreli-UGD	1233.55	31/10/2020	4.06
44	Anand	Anand-UGD	8667.27	30/08/2019	18.75
45	Bardoli-II	Bardoli-UGD	492.99	21/10/2023	84.15
46	Bilimora	Bilimora-UGD	2135.3	31/05/2016	18.48
47	Kaalol	Kaalol-UGD	2298.88	30/06/2021	12.5
48	Kadi-IV	kadi IV UGD	409.62	31/12/2021	3.81
49	Kalol	Kalol-UGD	2806.17	30/09/2017	6.36
50	Kanakpur-Kansad	Kanakpur-Kansad UGD	2081.63	31/12/2016	1.66
51	Mahuva-II	Mahuva-II UGD	3228.94	30/06/2017	42.08
52	Mehsana	Mehsana-UGD	4996.13	31/07/2015	12.77
53	Rajpipla	Rajpipla UGD	1777.19	30/11/2022	0.45
54	Rajpipla-II	Rajpipla II UGD	824.77	30/08/2019	66.91
55	Wadhvan	Wadhvan-UGD	4241.36	30/11/2016	40
56	Dhrangadhra	Dhrangadhra SEW	2095.98	15/08/2026	89.52
				Total	17098.51

Expenditure from NGT Fund in the Project of GUDCL Part - II					
Sr. No	Name of Municipality	Name of Work	Total Amount of Project In Lakh	Tentative Date of Completion	Expenditure from NGT Ring Fenced Grant in Lakhs
1	Gadhada	Gadhada STP	1786.69	01/11/2025	135.27
2	Kathlal	Kathlal STP	1143.32	31/03/2026	174.91
3	Patdi	Patdi STP	850.56	20/12/2025	263.21
5	Viramgam	Viramgam STP	1275.87	20/04/2026	347.43
6	Savarkundla	Savarkundla STP	2008.66	31/12/2025	702.18
8	Bayad	Bayad STP	1383.93	31/12/2025	422.96
9	Modasa	Modasa STP	2391.92	04/09/2026	483.15
10	Siddhpur	Siddhpur STP	4184.28	30/04/2026	1348.84
12	Upleta	Upleta STP	1304.35	31/08/2026	122.55
13	Pardi	Pardi STP	1312.77	20/12/2026	117.02
15	Sojitra	Sojitra STP	975.65	30/06/2026	83.44
16	VVnagar	Vvnagar STP	2820.93	01/08/2026	481.98
17	Bavla	Bavla UGD	7347.41	23/01/2028	536.26
19	Dhrangadhra	Dhrangadhra UGD	2095.98	16/09/2025	56.06
20	Kapadwanj	Kapadwanj UGD	1623.65	22/12/2026	349.59
21	Kathlal	Kathlal UGD	2462.83	26/05/2026	1233.66
23	Thasra	Thasra UGD	612.08	29/11/2025	220.36
26	Borsad	Borsad UGD	1616.2	24/05/2026	389.9
29	Godhra	Godhra UGD	7429.43	17/06/2027	695.55
31	Karjan	Karjan UGD	1135.83	12/09/2025	471.7
39	Chanasma	Chanasma UGD	1548.25	25/05/2027	184.87
41	Harij	Harij UGD	1792.67	25/05/2027	129.7
42	Idar	Idar UGD	3014.69	25/05/2027	452.1
43	Modasa	Modasa UGD	6007.79	30/06/2026	381.29
44	Radhanpur	Radhanpur UGD	6349.72	22/08/2026	1846.68
46	Unjha	Unjha UGD	4632.8	25/05/2027	468.01
48	Vijapur	Vijapur UGD	700.8	27/02/2026	150.4
49	Visnagar	Visnagar UGD	7604.46	26/08/2026	2497.53
50	Anjar	Anjar UGD	1140.48	26/02/2026	528.56
53	Morbi	Morbi UGD	1767.3	31/12/2025	1.01
54	Mundra baroi	Mundra baroi UGD	5110.27	04/02/2026	1079.86
57	Upleta	Upleta UGD	4378.15	31/08/2026	1737.96
58	Gariyadhar	Gariyadhar UGD	882.93	26/11/2026	73.13
59	Jafarabad	Jafarabad UGD	853.55	26/11/2026	86.05
62	Palitana	Palitana UGD	1659.94	12/09/2025	152.09
64	Savarkundla	Savarkundla UGD	3182.99	04/12/2026	789.2
65	Sihor	Sihor UGD	1961.92	20/08/2026	432.45
67	Una_G	Una_G UGD	2826.37	26/11/2026	
68	Vallabhipur	Vallabhipur UGD	715.3	26/11/2026	49.4
70	Veraval	Veraval UGD	2255.34	29/01/2027	165.37
71	Veraval (Somnath Trust)	Veraval UGD	3072.63	19/09/2026	855.41
72	Amod	Amod UGD	584.64	25/11/2025	446.37
73	Ankleshwer	Ankleshwer UGD	974.48	25/05/2026	540.37
74	Dharampur	Dharampur UGD	1090.46	26/12/2025	434.52
76	Mandvi_S	Mandvi_S UGD	995.29	09/12/2026	230.96

Expenditure from NGT Fund in the Project of GUDCL Part - II					
Sr. No	Name of Municipality	Name of Work	Total Amount of Project In Lakh	Tentative Date of Completion	Expenditure from NGT Ring Fenced Grant in Lakhs
79	Tarsadi	Tarsadi UGD	2214.2	28/10/2026	393.18
80	Vapi	Vapi UGD	2189.72	08/09/2026	246.42
81	Vyara	Vyara UGD	1032.52	08/09/2026	
82	Vadnagar	vadnagar Heritage	4210.45	05/12/2026	308.15
83	Mehsana	STP	5134	31/01/2023	152.8
84	Virangam	Virangam UGD	1747.32	31/03/2025	102.36
85	Dhoraji	Dhoraji UGD	1612.89	26/12/2025	200.49
86	Bharuch-1	Bharuch-ugd	1031.53	30/11/2021	35
87	Gandhidham	Gandhidham-UGD	4595.57	22/03/2024	668.14
				Total	24455.85

Annex IV CTE CCA Status					
#	Name of STP	CCA Available?	if No CCA Applied?	CTE Available?	If No CTE Applied?
		details	details	details	details
1	Old Pirana	Yes	NA	Yes	NA
2	Old Pirana	Yes	NA	Yes	NA
3	New pirana	Yes	NA	Yes	NA
4	Vinzol	Yes	NA	Yes	NA
5	Vinzol	Yes	NA	Yes	NA
6	Lambha	Yes	NA	Yes	NA
7	Shankarbhuvan	Yes	NA	Yes	NA
8	New pirana	Yes	NA	Yes	NA
9	Vinzol	Yes	NA	Yes	NA
10	Maleksaban	Yes	NA	Yes	NA
11	Kotarpur	Yes	NA	Yes	NA
12	Dafnala	Yes	NA	Yes	NA
13	Saijpur	Yes	NA	Yes	NA
14	Vasna	Yes	NA	Yes	NA
15	Vasna	Yes	NA	Yes	NA
16	Vasna	Yes	NA	Yes	NA
17	Vasna	Yes	NA	Yes	NA
18	Jalvihar	Yes	NA	Yes	NA
19	Bhavnagar Nari road,	No	NA	Yes	NA
20	Bhavnagar Behind Excel	Yes	NA	Yes	NA
21	Bhavnagar Excel Industries	Yes	NA	Yes	NA
22	Bhavnagar Akwada	Yes	NA	Yes	NA
23	Jaspur R & B	Yes	NA	No	NA
24	Jaspur GUDA	No	Yes	Yes	NA
25	Sargasan R & B	Yes	NA	Yes	NA
26	Basan R & B	Yes	NA	Yes	NA
27	Bhat	No	Yes	Yes	NA
28	Kolavda	As per Remarks		Yes	
29	Bilkha Road STP	Yes	NA	Yes	NA
30	Zanzarda Zone STP	Yes	NA	Yes	NA
31	Kalva Zone STP	Yes	NA	Yes	NA
32	Sonrakh Zone STP	Yes	NA	Yes	NA
33	In Situ Remediation Plant	NA	NA	Yes	
34	kothariya 15 MLD NEW -NH	Yes	NA	Yes	NA

Annex IV CTE CCA Status					
#	Name of STP	CCA Available?	if No CCA Applied?	CTE Available?	If No CTE Applied?
		details	details	details	details
35	kothariya 15 MLD RUDA	Yes	NA	Yes	NA
36	Raiyadhar 56 MLD	Yes	NA	Yes	NA
37	Raiya 51 MLD	Yes	NA	Yes	NA
38	Gavaridad 70 MLD	Yes	NA	Yes	NA
39	Madhapar 44.5 MLD	Yes	NA	Yes	NA
40	Madhapar 80 MLD	No	Yes	Yes	NA
41	Bhesan	Yes	NA	Yes	NA
42	Gavier	Yes	NA	Yes	NA
43	Karanj	Yes	NA	Yes	NA
44	Asarma	Yes	NA	Yes	NA
45	Anjana	Yes	NA	Yes	NA
46	Dindoli	Yes	NA	Yes	NA
47	Bamroli	Yes	NA	Yes	NA
48	Singapore	Yes	NA	Yes	NA
49	Bhatar	Yes	NA	Yes	NA
50	Khajod	Yes	NA	Yes	NA
51	Variav Kosad	Yes	NA	Yes	NA
52	Dungara	Yes	NA	Yes	NA
53	Kholeshwar	Yes	NA	Yes	NA
54	Koli Bharthana	Yes	NA	Yes	NA
55	Kamrej	Yes	NA	Yes	NA
56	Pasodara	Yes	NA	Yes	NA
57	Karjan	Yes	NA	Yes	NA
58	Dhoran Pardi	Yes	NA	Yes	NA
59	Kathor	Yes	NA	Yes	NA
60	Bharthana	Yes	NA	Yes	NA
61	Valak	Yes	NA	Yes	NA
62	Tarsali	Yes	NA	Yes	NA
63	Gajarawadi	Yes	NA	Yes	NA
64	Kapurai	Yes	NA	Yes	NA
65	Rajivnagar	Yes	NA	Yes	NA
66	Sayajigarden	Yes	NA	Yes	NA
67	Channi (Old)	Yes	NA	Yes	NA
68	Atladara (Old)	Yes	NA	Yes	NA
69	Atladara (New)	Yes	NA	Yes	NA
70	Kapurai (New)	Yes	NA	Yes	NA

Annex IV CTE CCA Status					
#	Name of STP	CCA Available?	if No CCA Applied?	CTE Available?	If No CTE Applied?
		details	details	details	details
71	Chhani (New)	Yes	NA	Yes	NA
72	Bhayli	Yes	NA	Yes	NA
73	Vemali	Yes	NA	Yes	NA
74	Atladara	Yes	NA	Yes	NA
75	Undera	No	Yes	Yes	NA
76	Nadiad	Yes	NA	Yes	NA
77	Surendranagar	Yes	NA	Yes	NA
78	Dholka	No	Yes	Yes	NA
79	Sanand	No	No	No	No
80	Botad	No	Yes	Yes	NA
81	Dhrangadhra	Yes	NA	Yes	NA
82	Viramgam	No	No	No	Yes
83	Bavla	Yes	NA	Yes	NA
84	Kapadvanj	Yes	NA	Yes	NA
85	Thangadh	Yes	NA	Yes	NA
86	Chotila - 1	Yes	NA	Yes	NA
87	Chotila - 2	Yes	NA	Yes	NA
88	Dhandhuka	Yes	NA	Yes	NA
89	Bareja	Yes	NA	Yes	NA
90	Mahemdabad	Yes	NA	Yes	NA
91	Kheda	Yes	NA	Yes	NA
92	Barvada	No	Yes	Yes	NA
93	Kanjari	Yes	NA	Yes	NA
94	Amreli	Yes	NA	Yes	NA
95	Savarkundla	As per Remarks		Yes	
96	Mahuva	Yes	NA	Yes	NA
97	Palitana	Yes	NA	Yes	NA
98	Keshod	Yes	NA	Yes	NA
99	Rajula	No	No	No	Yes
100	Shihor	Yes	NA	Yes	NA
101	Una	Yes	NA	Yes	NA
102	Kodinar	Yes	NA	Yes	NA
103	Bagsara	No	No	No	Yes
104	Babara	Yes	NA	Yes	NA
105	Lathi	No	Yes	Yes	NA
106	Gariyadhar	No	Yes	Yes	NA
107	Talaja	Yes	NA	Yes	NA

Annex IV CTE CCA Status					
#	Name of STP	CCA Available?	if No CCA Applied?	CTE Available?	If No CTE Applied?
		details	details	details	details
108	Sutrapada	Yes	NA	Yes	NA
109	Talala	Yes	NA	Yes	NA
110	Manavadar	Yes	NA	Yes	NA
111	Chorvad	No	No	No	Yes
112	Visavadar	Yes	NA	Yes	NA
113	Chalala	Yes	NA	Yes	NA
114	Damnagar	No	Yes	No	Yes
115	Vallabhipur	Yes	NA	Yes	NA
116	Bantwa	Yes	NA	Yes	NA
117	Kasba	Yes	NA	Yes	NA
118	Nagalpur	Yes	NA	Yes	NA
119	Deesa	Yes	NA	Yes	NA
120	Kalol	As per Remarks		Yes	
121	Kadi	Yes	NA	Yes	NA
122	Visnagar - 1	Yes	NA	Yes	NA
123	Visnagar - 2	Yes	NA	Yes	NA
124	Vadnagar	Yes	NA	Yes	NA
125	Patan	Yes	NA	Yes	NA
126	Himmatnagar	Yes	NA	Yes	NA
127	Dahegam	Yes	NA	Yes	NA
128	Unja	Yes	NA	Yes	NA
129	Radhanpur	Yes	NA	Yes	NA
130	Idar	Yes	NA	Yes	NA
131	Dhanera	Yes	NA	Yes	NA
132	Tharad	Yes	NA	Yes	NA
133	Bhabhar	Yes	NA	Yes	NA
134	Thara	Yes	NA	Yes	NA
135	Mansa	Yes	NA	Yes	NA
136	Kheralu	Yes	NA	Yes	NA
137	Vijapur	Yes	NA	Yes	NA
138	Harij	Yes	NA	Yes	NA
139	Khedbramha	Yes	NA	Yes	NA
140	Prantij	Yes	NA	Yes	NA
141	Talod	Yes	NA	Yes	NA
142	Vadali	Yes	NA	Yes	NA
143	Chansma	Yes	NA	Yes	NA
144	Morbi - 1	No	No	No	Yes

Annex IV CTE CCA Status					
#	Name of STP	CCA Available?	if No CCA Applied?	CTE Available?	If No CTE Applied?
		details	details	details	details
145	Morbi - 2	No	Yes	No	Yes
146	Gandhidham	Yes	NA	Yes	NA
147	Porbandar - 1	no	yes	yes	na
148	Porbandar - 2	no	yes	yes	na
149	Dwarka	Yes	NA	Yes	NA
150	Khambhaliya	Yes	NA	Yes	NA
151	Bhuj	No	Yes	Yes	NA
152	Anjar	Yes	NA	Yes	NA
153	Jetpur	Yes	NA	Yes	NA
154	Gondal	No	Yes	Yes	NA
155	Dhoraji	Yes	NA	Yes	NA
156	Okha	NA	NA	No	NA
157	Bhachau	Yes	NA	Yes	NA
158	Vankaner	NO	Yes	No	Yes
159	Jasdan	Yes	NA	YES	NA
160	Salaya	No	Yes	Yes	Na
161	Dhrol	Yes	Na	Yes	Na
162	Jamjodhpur	Yes	NA	Yes	NA
163	Kalavad	Yes	NA	Yes	NA
164	Sikka	Yes	NA	Yes	NA
165	Rapar	No	Yes	Yes	NA
166	Halvad	Yes	NA	Yes	NA
167	Bhayavadar	Yes	NA	Yes	NA
168	Maliya-Miyana	Yes	NA	Yes	NA
169	Kutiyana	Yes	NA	Yes	NA
170	Navsari (Viraval)	Yes	NA	Yes	NA
171	Vapi - 1	Yes	NA	yes	NA
172	Bharuch	Yes	NA	Yes	NA
173	Vyara	Yes	NA	Yes	NA
174	Jambusar	Yes	NA	Yes	NA
175	Rajpipla	No	Yes	Yes	NA
176	Bilimora	Yes	NA	Yes	NA
177	Bardoli	Yes	NA	Yes	NA
178	Kadodara	NA	NA	NA	NA
179	Mandvi (Surat)	Yes	NA	Yes	NA
180	Songadh	Yes	NA	Yes	NA
181	Dharampur	Yes	NA	Yes	NA

Annex IV CTE CCA Status					
#	Name of STP	CCA Available?	if No CCA Applied?	CTE Available?	If No CTE Applied?
		details	details	details	details
182	Amod	Yes	NA	Yes	NA
183	Gandevi	Yes	NA	Yes	NA
184	Anand - 1	Yes	NA	Yes	NA
185	Anand - 2	Yes	NA	Yes	NA
186	Anand Karamsad	Yes	NA	Yes	NA
187	Anand - 4	Yes	NA	Yes	NA
188	Khambhat - 1	Yes	NA	Yes	NA
189	Khambhat - 2	Yes	NA	Yes	NA
190	Dahod	Yes	NA	Yes	NA
191	Lunavada	Yes	NA	Yes	NA
192	Godhra	Yes	NA	Yes	NA
193	Borsad	Yes	NA	Yes	NA
194	Petlad	Yes	NA	Yes	NA
195	Chhotaudepur	Yes	NA	Yes	NA
196	Balasinor	Yes	NA	Yes	NA
197	Halol	Yes	NA	Yes	NA
198	Dabhoi	Yes	NA	Yes	NA
199	Padra	Yes	NA	Yes	NA
200	Umreth	Yes	NA	Yes	NA
201	Anklav	Yes	NA	Yes	NA
202	Oad	Yes	NA	Yes	NA
203	Boriyavi	Yes	NA	Yes	NA
204	Zalod	Yes	NA	Yes	NA
205	Devgadh bariya	Yes	NA	Yes	NA
206	Santrampur	Yes	NA	Yes	NA
207	Kaalol	Yes	NA	Yes	NA
208	Shahera	Yes	NA	Yes	NA
209	Karjan	Yes	NA	Yes	NA
210	Valsad - 1	Yes	NA	Yes	NA
211	Navagam Ghed	Yes	NA	yes	NA
212	Near Raj Nagar	No	Yes	Yes	NA

Action taken report – March 2026

Compliance to the directives of Hon'ble NGT on order Dated March 2023

Sr No	Points	Compliance
1.	Amount of Rs. 2100 crores be credited to a separate ring-fenced account within a month for utilization for sewage and solid waste management under the supervision of Chief Secretary (paras 26 & 65).	In compliance with the Hon'ble National Green Tribunal's directive, a ring-fenced account with an amount of ₹2100 crore was duly established on 3rd May 2023 and the same has been allocated to various implementation authorities for the construction of underground drainage networks and sewage treatment plants under various ongoing schemes. As on date ₹1894 crore has been disbursed and ₹ 1213.98 Crore have been utilized. The fund is allotted in appraisal and with approval of Hon'ble Chief Secretary.
2.	The State may work out strategy to utilize rejects (inserts, RDF, etc.) arising out of biomining of legacy waste for proper channelization within one month (para 33).	A model RFP document was prepared by SBM Urban and circulated to all the ULBs for engaging an agency for bioremediation and bio-mining. In the scope of work for the hired agency, detailed strategy and guidelines on utilization of inerts and rejects was laid out. Bioremediation of all the legacy waste dumpsites have been carried out / is being carried out as per this model RFP document prepared and ULB-wise details of the utilization of rejects have been collected.
3.	CPCB in consultation with some of the States PCBs and Municipal Corporations may work out environmentally safe methods/options for their use within one month (para 35).	Model RFP is prepared and circulated for legacy waste remediation for proper disposal of rejects out of biomining.

Sr No	Points	Compliance
4.	Plastic waste and construction and demolition waste processing plants be set up ensuring that bio-medical, hazardous, and E- waste are not co-mingled and treated with solid waste (para 36).	<p>For treatment of dry waste like plastic waste, under SBM 2.0, one dry waste plant (which will segregate plastic waste and send it to the plastic waste recyclers) is being set up in 161 ULBs at a cost of 506.335 crores.</p> <p>The SBM Urban Office has hired an agency for handholding of Nagarpalikas for preparation of DPRs and RFPs for these dry-waste plants. A total of 136 Work Orders have been issued for the development of 5962 MT of Dry waste processing capacity. The State is trying to operationalize these plants by March 2026.</p> <p>Similarly, as per guidelines of MoHUA, 12 C & D plants totaling 1379 MT capacity are under pipeline.</p> <ul style="list-style-type: none"> ● Ahmedabad MC - 1000 MT ● Bhavnagar MC - 50 MT ● Jamnagar MC - 49 MT ● Nadiad - 27 MT ● Surendranagar - 20 MT ● Mahesana - 36 MT ● Morbi - 28 MT ● Porbandar - 30 MT ● Gandhidham - 30 MT ● Navsari - 37 MT ● Vapi - 35 MT ● Anand - 37 MT <p>4 corporations (1600 MT capacity), Ahmedabad-1000 MT, Rajkot-200 MT, Surat-300 MT, Vadodara- 100 MT and already have functional C&D plants.</p> <p>Hazardous Waste : Certain non-biodegradable waste, segregated organic residues, highly concentrated effluents such as mother liquors and toxic effluents requires thermal destruction for its disposal in environmentally sound manner.</p> <p>However, as of now, State is having 5 common hazardous incineration facilities and 42 individual hazardous waste incinerations facilities.</p> <p>Bio-medical Waste :</p>

Sr No	Points	Compliance
		<p>Gap Analysis Study is conducted as per the guidelines/rules framed by CPCB for Biomedical Waste Management for Biomedical Waste Management.</p> <p>As per the guidelines published by the Central Pollution Control Board for Biomedical Waste Management under the Biomedical Waste Management Rules-2016, Gap Analysis Study is conducted by each State Pollution Control Board every five years as per the format mentioned in the guidelines.</p> <p>The Gap Analysis Study for Biomedical Waste Management in Gujarat covers a wide area, which includes all the 33 districts of the state.</p> <p>Under the Biomedical Waste Management, Gujarat Pollution Control Board has assigned the task of conducting a Gap Analysis Study on Biomedical Waste Management in the State of Gujarat to GUJARAT ENVIRONMENT MANAGEMENT INSTITUTE (GEMI), Gandhinagar.</p> <p>E-Waste management : For better management of E-waste, Extended Producer Responsibility (EPR) is introduced to ensure environmentally sound collection, recycling, and disposal of end-of-life electronic products.</p> <p>As per the E-waste (Management) Rules, 2022, all producers, manufacturers, recyclers, and refurbishes are required to obtain registration on the CPCB's EPR portal.</p> <p>As per the EPR portal (https://eprewastecpcb.in/), there are 579 registered Producers in the state.</p> <p>To implement the Extended producer Responsibility framework, GPCB entrusted the National Productivity Council (NPC) to carry out a capacity verification study of 15 registered e-waste recycling and dismantling facilities across the state.</p>
5.	Immediate efforts be made for ensuring connectivity with STPs having treatment capacity of 4754 MLD (para 37).	In response to the Hon'ble Tribunal's directive regarding the 4754 MLD sewage treatment capacity (March 2023). Present Sewage generation is 4903 MLD. The total installed treatment capacity has now increased to 6,125 MLD factoring in projected sewage generation and utilization capacity 4504 MLD.

Sr No	Points	Compliance
6.	The issues relating to compliance of STPs with standards and utilization of treated sewage be monitored and looked into by centralized mechanism at State level (para 46).	To centralize monitoring of municipal assets like WTP & STPs, an Integrated command and control center is proposed at state level.
7.	Chief Secretary may immediately set up an orientation program on a regular basis at appropriate institutional level to deal with environmental issues (para 53).	As directed, three workshops and training sessions have been organized for ULB staff, focusing on Liquid Waste Management (LWM) and Solid Waste Management (SWM). A state-level workshop on LWM and SWM has also been successfully conducted to enhance the capacity and knowledge of ULB personnel. Moreover, under the Gujarat Urban Development Institute (GUDI), eight capacity-building sessions for 400 officials from ULBs, including engineers, have been organized, and one dedicated session on water supply and wastewater management, in collaboration with IITRAM Ahmedabad, is scheduled for the last week of August.
8.	MoUD may review utilization of capacities of STPs established and utilization of treated sewage (para 60).	NA
9.	Ministry of Power and Ministry of Non-Renewal Energy (MNRE) may hasten the process of setting up of waste to energy projects and lay down rolling plan (para 60).	NA
10.	CPCB and MoEF&CC may specifically issue directions on management of rejects out of biomining processes of legacy waste to avoid haphazard disposal/dumping (para 60).	NA
11.	Chief Secretary may set up a centralized single window mechanism for planning, capacity building and monitoring of waste management at the State level (para 56)	The Gujarat Urban Development Institute, functioning under the Urban Development and Urban Housing Department of the Government of Gujarat, undertakes capacity-building exercises aimed at strengthening the skills and knowledge of ULB staff. These programmes are conducted on a periodic basis and include specialized sessions on water and wastewater management as well as solid waste management.

Sr No	Points	Compliance
		To centralize monitoring of municipal assets like WTP & STPs, an Integrated command and control center is proposed at state level.
12.	State level Monitoring Mechanism be set up under Chief Secretary and District level Monitoring Mechanism under District Magistrate for monthly review starting from 1st March 2023 (para 62).	<p>Monthly meetings are held at the level of Chief Secretary with all Commissioners of Municipal Corporations, All Commissioner of RCMs, Commissioner of Municipality Administration, Mission Director – SBM and Chairman - Gujarat Pollution Control board to monitor compliance with the directives of the Hon'ble NGT. To date, 22 meetings have been conducted under the chair of Chief Secretary and 4 under Principal Secretary.</p> <p>Moreover, the issues pertaining to solid and liquid waste management are regularly reviewed in weekly meetings chaired by the Principal Secretary with all Municipal Corporations and Regional Commissioners of Municipalities.</p>
13.	Community compost pits (15725) be properly maintained, ensuring that compost produced is fully utilized (para 31).	Under SBM(G) Phase - II, Community Compost pits assets are constructed and properly maintained, and most of the produced compost is utilized at the village level
14.	MoUD with MoEF&CC and CPCB may look into applicability of standards for STPs based on mode of disposal (para 60).	NA