

**Action Taken Report as per Hon'ble NGT, Principal Bench,
New Delhi Order dtd. 16/07/2021 in O.A. No. 47/2021 (WZ)**

Hon'ble NGT, Principal Bench, New Delhi vide Order dtd. 16/07/2021 in O.A. No. 47/2021 (WZ) directed a joint Committee of District Magistrate, Municipal Corporation, Ahmednagar & State PCB to ascertain facts and furnish a factual and action taken report in the matter.

The Joint Committee for the said matter is as follows.

- 1) Dr. Rajendra Bhosale, Collector, Ahmednagar.
- 2) Shri. Shankar Gore, Commissioner, Municipal Corporation, Ahmednagar.
- 3) Shri. Sanjeev Redasni, Sub Regional Officer, MPCB, Ahmednagar.

The Mobile Tower of Reliance Jio is installed at house of Shri. Rajendra Joshi, Plot No. 1, Haripriya Vihar, Asra Society, Pipeline Road, Ahmednagar, Maharashtra. The following action taken on the issue raised in the Hon'ble NGT order dtd. 16/07/2021.

The Field Officer of Sub Regional Office, Maharashtra Pollution Control Board, Ahmednagar and representative of Town Planning Department, Municipal Corporation, Ahmednagar jointly visited the site mentioned in the said order for verification of facts on 15/09/2021. A copy of joint visit report is annexed as Annexure-1.


During the said joint visit of MPCB and AMC representative in presence of Manager Reliance Jio, Ahmednagar on 15/09/2021, following observations are made.

- 1) There is no any permanent DG set and vehicle mounted generator at the aforesaid site for backup during power failure.


- 2) The Mobile Tower operator have provided battery backup (300 Ah) having capacity to supply the power for 4-5 hr. during power failure.
- 3) Manager Reliance Jio, Ahmednagar informed that the said Mobile Tower is installed in March-2017 and at that time they had installed DG set of capacity 10 KVA and same was removed in Oct-2019 as they have installed battery backup facility for power supply during failure of electricity.



(Dr. Rajendra Bhosale)
Collector, Ahmednagar



(Shri. Shankar Gore)
Commissioner, Municipal Corporation,
Ahmednagar



(Sanjeev Redasni)
Sub Regional Officer, MPCB,
Ahmednagar

Maharashtra Pollution Control Board

Sub Regional Office, Ahmednagar

E-Mail –
sroahmednagar@mpcb.gov.in



Savitribai Fule Vyapari sankul, 1st floor,
Hall No. 2 & 3, Near
T. V. Centre, Savedi, Ahmednagar-
414003

Ph.No. 0241-2470852

Date: 15/09/2021

Visit Report

As per Hon'ble NGT order dtd- 16/07/2021 in O.A. No. 47/2021 (WZ) I have visited the Mobile Tower located at Plot no. 1, Hariptiya vihar, Asta society, Pipeline Road, savedi, Ahmednagar - 414003 alongwith Representative of Ahmednagar Municipal Corporation, Town Planning Dept., Ahmednagar. During the visit Mr. Mukesh Khare, Manager, Reliance Jio, Ahmednagar also present.

During the visit no D.G. set and no vehical mounted generator for backup noticed at site.


Mr. Mukesh Khare, Manager, Reliance Jio, Ahmednagar informed that Mobile Tower installed in March - 2017


at Residential Bungalow of Mr. Rajendra Jashi,
 Plot no. 1, Hatipaiya vihar, Asda society,
 Pipeline Road, savedi, Ahmednagar - 414003.

At that time D.G. set of capacity 10 kVA
 was installed for power backup purpose
 and further they have also provided
 Battery backup 4-s hr (300 Ah).

They have removed ^{permanently} D.G. set (10 kVA) in
 Oct-2019 as there is no utilization
 of DG set due to Battery backup.


 (P.S. Dake)
 f.o.


 (Mr. Saswadkar J. S.)
 Representative of
 AMC, TP Dept,


 (Mr. Mukesh Khate)
 Manager
 Reliance Jio, Ahnagar