

BEFORE THE HON'BLE NATIONAL GREEN TRIBUNAL,  
PRINCIPAL BENCH, NEW DELHI

MISCELLANEOUS APPLICATION NO. 61 OF 2024

IN

ORIGINAL APPLICATION NO. 42 OF 2024

**IN THE MATTER OF:**

MADASIR HASAN & ORS.

...APPLICANTS

VERSUS

STATE OF U.P. & ORS.

...RESPONDENTS

**INDEX**

S. NO.	PARTICULARS	PAGE NO.
1.	Affidavit on behalf of U.P. Pollution Control Board	1-2
2.	<b>ANNEXURE 1:</b> A true copy the inspection report	3

THROUGH

DATE: 27.11.2024

PLACE: NEW DELHI



**STHAVI ASTHANA**  
**ADVOCATE FOR UPPCB**  
**C1/131 MOTI BAGH, SHANTI PATH,**  
**NEW DELHI-110021**  
**(M): 9711116034**  
**(E): [STHAVIASTHANA@GMAIL.COM](mailto:STHAVIASTHANA@GMAIL.COM)**

BEFORE THE HON'BLE NATIONAL GREEN TRIBUNAL,  
PRINCIPAL BENCH, NEW DELHI

MISCELLANEOUS APPLICATION NO. 61 OF 2024  
IN  
ORIGINAL APPLICATION NO. 42 OF 2024



**IN THE MATTER OF:**

MADASIR HASAN & ORS.

...APPLICANTS

VERSUS

STATE OF U.P. & ORS.

...RESPONDENTS

**AFFIDAVIT ON BEHALF OF UTTAR PRADESH POLLUTION  
CONTROL BOARD**

I, Ajeet Kumar Suman S/o Late Baliram Vimal, aged about 50 years,  
R/o HIG-1056, Sector-I, Aashiyana, Lucknow do hereby solemnly  
affirm and state as under:

1. That I am presently posted as Regional Officer of Uttar Pradesh Pollution Control Board (hereinafter "UPPCB"), Azamgarh. I say that I am fully conversant with the facts of the case and am competent and authorised to swear the present Affidavit.
2. That UPPCB has conducted an inspection of the site in question respectively on 23.11.2024 and 25.11.2024. During inspection dated

*AK Suman*

ATTESTED

23.11.2024 the Sewage Treatment Plant (STP) was found established and in inspection dated 25.11.2024 the STP was found operational. The concern official of the UPPCB has collected the water sample from the STP and sent the same to the authorized laboratory of the UPPCB, Varanasi for analysis. A true copy of the inspection report is annexed hereto and marked as **Annexure 1**.

3. That further it is mention that to establish the STP no prior consent under Water (Prevention and Control of Pollution) Act, 1974 and Air (Prevention and Control of Pollution) Act, 1981 has been obtained from the UPPCB against which the UPPCB has sent a notice to Jal Nigam, Azamgarh vide its letter dated 01.10.2024.



4. That the above response of Uttar Pradesh Pollution Control Board is submitted before Hon'ble Tribunal for kind perusal and consideration.

**ATTESTED**

**DEPONENT**  
AK  
Suman

**VERIFICATION:**

Verified at Azamgarh 27<sup>th</sup> of November, 2024 that the contents of the above affidavit are true and correct to the best of my knowledge and belief and nothing material has been concealed therefrom.

Verified that Sri/Smt. Ajeet Kumar Singh Suman 31 years self presents this affidavit before me on day at About 27.11.2024 at About 2.00 P.M. A.M./P.M. on dated 27.11.2024 oath u/s 8 of Notaries Act, 1952. Who has voluntarily affirmed to the contents of this affidavit I have satisfied myself by examining the deponent that he/she understands the contents of this affidavit which were read over and explained to Him/Sri/Smt. Ajeet Kumar Suman is Personally Know to me or identified by Sri Ajeet Kumar Suman Vakil/Advocate.

**DEPONENT**  
AK  
Suman

**ATTESTED**

**SHAUKAT SARDAR KHAN**  
Notary Distt. Azamgarh (U.P.)  
27/11/2024

मा0 राष्ट्रीय न्यायाधिकरण नई दिल्ली द्वारा एम.ए. नं0-61/2024 ओरीजनल एप्लीकेशन नं0-42/2024 में पारित आदेश दिनांक 0121.11.2024 के क्रम में जालन्धरी स्थित गड़ही तथा 8.0 एम0एल0डी0 क्षमता के उत्प्रवाह शुद्धिकरण संयंत्र के सम्बन्ध में अद्यतन निरीक्षण आख्या।

मा0 राष्ट्रीय न्यायाधिकरण नई दिल्ली द्वारा एम.ए. नं0-61/2024 ओरीजनल एप्लीकेशन नं0-42/2024 में पारित आदेश दिनांक 21.11.2024 तथा प्राप्त निर्देशों के तत्क्रम में दिनांक 23.11.2024 तथा 25.11.2024 को जालन्धरी स्थित गड़ही का निरीक्षण किया गया। निरीक्षण के समय जल निगम के प्रतिनिधि श्री भूपेन्द्र कुमार, सहायक अभियंता तथा नगर पालिका परिषद, आजमगढ़ के प्रतिनिधि श्री हरिशचन्द्र, कर निरीक्षक उपस्थित थे। विस्तृत निरीक्षण आख्या निम्नवत् है-

1. निरीक्षण के समय जालन्धरी स्थित मकानों/घरों का उत्प्रवाह सीवर लाइन से जोड़ दिया गया है तथा सीवर लाइन को उत्प्रवाह शुद्धिकरण संयंत्र से जोड़ दिया गया है। जालन्धरी स्थित गड़ही में मोहल्ला जालन्धरी के घरों का उत्प्रवाह नहीं जा रहा था तथा निरीक्षण के समय गड़ही लगभग सूखी पायी गयी।
2. निरीक्षण के समय स्थापित 8.0 एम0एल0डी0 क्षमता के उत्प्रवाह शुद्धिकरण संयंत्र से उत्प्रवाह निस्तारित नहीं हो रहा था। उपस्थित जल निगम के प्रतिनिधि द्वारा अवगत कराया गया कि उत्प्रवाह शुद्धिकरण संयंत्र का परिक्षण दिनांक 30.10.2024 को किया गया तथा उत्प्रवाह शुद्धिकरण संयंत्र दिनांक 14.11.2024 से संचालित है तथा उत्प्रवाह एस0बी0आर0 (Sequence Batch Reactor) में एकत्रित हो रहा है। उपस्थित प्रतिनिधि द्वारा अवगत कराया गया कि उत्प्रवाह का लोड (Load) कम है। अतः 02-03 दिन में उत्प्रवाह निस्तारित होना सम्भव है।
3. उत्प्रवाह शुद्धिकरण संयंत्र में निम्नलिखित इकाइयां पायी गयी-
  - Collection Tank
  - Receiving Chamber
  - Screen Chamber
  - M.P.S.(Main Pumping Station)
  - Grit Mechanism
  - S.B.R. (Sequence Batch Reactor)
  - Chlorine Tank
  - Chlorine Collection Chamber
  - Sludge Drying Bed
4. पुनः दिनांक 25.11.2024 को उत्प्रवाह शुद्धिकरण संयंत्र का निरीक्षण किया गया। निरीक्षण के समय उत्प्रवाह शुद्धिकरण संयंत्र संचालित पाया गया। उत्प्रवाह शुद्धिकरण संयंत्र से निस्तारित होने से पूर्व तथा निस्तारित शुद्धिकृत उत्प्रवाह का नमूना एकत्रित कर विश्लेषण हेतु क्षेत्रीय कार्यालय उ0प्र0 प्रदूषण नियंत्रण बोर्ड, वाराणसी स्थित प्रयोगशाला में भेजा गया है।
5. शुद्धिकृत उत्प्रवाह धरमू नाले में निस्तारित किया जा रहा था तथा धरमू नाला अन्ततः तमसा नदी में मिलता है।
6. उत्प्रवाह के शुद्धिकरण हेतु स्थापित किये गये 8.0 एम0एल0डी0 क्षमता के उत्प्रवाह शुद्धिकरण संयंत्र की स्थापना से पूर्व राज्य बोर्ड से अनापत्ति प्रमाण पत्र एवं संचालन हेतु जल/वायु सहमति प्राप्त नहीं किया गया है।
7. अधिषाशी अभियंता, जल निगम, आजमगढ़ को उत्प्रवाह शुद्धिकरण संयंत्र की स्थापना से पूर्व अनापत्ति प्रमाण पत्र प्राप्त करने हेतु इस कार्यालय के पत्र सं0-570/एस0टी0पी0-ई0टी0पी0/2024-25 दिनांक 01.10.2024 के माध्यम से नोटिस प्रेषित की गयी है।

उपरोक्त आख्या आपके अवलोकनार्थ एवं आवश्यक कार्यवाही हेतु प्रस्तुत है।

(ओ0एच0 सिद्दीकी) 27/11/2024

सहायक वैज्ञानिक अधिकारी

क्षेत्रीय अधिकारी महोदय

AK  
Sumou  
27/11/24