

2745

BEFORE THE HON'BLE NATIONAL GREEN TRIBUNAL,  
PRINCIPAL BENCH, NEW DELHI

In the matter of :

*Dharamvir*

..... Applicant

*Versus*

*State of Haryana and others*

..... Respondents

INDEX


S. No	Particulars	Page No.
1.	Compliance Report on behalf of Respondent No. 17	2-7
2.	Annexure –A Copy of Online Data report of CETP (OCWMS) from 08.09.2025 to 08.10.2025.	8-17
3.	Annexure –B Analysis report of sample of final outlet of CEPT of Kala Amb Infrastructure Development Company testing report by HP State Pollution Control Board	18-19
4.	Annexure –C Copy of Monthly progress report of CETP.	20-23

Filed by:

  
**Brijesh Chauhan,**  
**Chander Mohan Sharma &**  
**Advocates**  
267/7, Hindu Ashram Road,  
Near Delhi Gate, Nahan, H.P.  
Mob: 9882370777;  
Email: [brijeshhnhn@yahoo.com](mailto:brijeshhnhn@yahoo.com)

Dated: 12/10/2025

Place: Nahan HP

**ATTES 'ED**  
  
**NIKHIL AGGARWAL**  
Advocate  
Sub Division Nahan  
Distt. Sirmour H.P. India

BEFORE THE HON'BLE NATIONAL GREEN  
TRIBUNAL, PRINCIPAL BENCH, NEW DELHI

In the matter of :

*Dharamvir*

..... *Applicant*

*Versus*

*State of Haryana and others*

..... *Respondents*

COMPLIANCE REPORT ON BEHALF OF  
RESPONDENT NO. 17

MOST RESPECTFULLY SHOWETH:

1. At the outset, it is submitted that the M/s Kala Amb Infrastructure Company (KIDC) is operating CETP Kala Amb of capacity of 2.5 MLD, H.P state Pollution control board has already issued consent to operate to run the CETP for 2.5 MLD capacity.

**ATTES'ED**

*Nikhil Agarwal*  
NIKHIL AGARWAL  
Advocate & Notary  
Sub Division Nahan  
Distt. Sirmour H.P. India

The CETP Kala Amb is operational and currently 66 numbers of Units are sending their effluent to CETP Kala amb . First phase of CETP is currently receiving primary treated waste water of Pharmaceuticals formulations units excluding EC applicable units.

The treated water of CEPT Kala Amb is discharged as per the provision of the Consent to operate granted to the unit. Online continues water monitoring system (OCWMS) is installed at the outlet of CETP Kala Amb for real time continuous monitoring of parameters and connected to HPSPCB server. The real time data is available on the following web link.

<https://hppcb.accesssurveykhan.co.in/>

Online data from report from 08.09.2025 to 08.10.2025 is attached in Annexure –A.

**ATTES 'ED**

NIKHIL AGGARWAL  
Advocate & Notary  
Sub Division Nahan  
Distt. Sirmour H.P. India.

2. That the respondent No. 17, Kala amb Infrastructure Development Company is established for the purpose Betterment of Kala amb industrial area. The CEPT has been operational with effect from 04 December 2023 and working properly and there is no lapse of any kind of its part and effluent water (primary treated waste water) is being treated in the CETP plant and its parameters are under premise able limit copy of latest analysis report of month August (28.08.2025) is attached as Annexure-B for the kind perusal of Hon'ble Tribunal. Therefore the respondent No 17 is safely monitoring effluent water treatment CETP Plant and responsibly managing the disposal.

3. That the respondent No. 17 Kala Amb Infrastructure Development Company working properly and not a Single drop of water are left untreated, and the CETP plant is working effectively and efficiently. And monthly progress report is submitted to HPSPCB & GM DIC Nahan, District Sirmour, HP. Copy of monthly progress report is attached herewith as Annexure-C.

**ATTES 'ED**

**NIKHIL AGGARWAL**  
Advocate & Notary  
Sub Division Nahan  
Distt. Sirmour H.P. 175018

It is respectfully submitted that the respondent No. 17 assure that not a Single drop of water be left untreated, and the CETP plant is working effectively and efficiently. Which is clearly evident from the test report conduct from time to time. It is submitted that the respondent no. 17 does not produce any such pollution or hazardous waste whatsoever can be seen from the testing report done from time to time and hence all the allegations against respondent no 17 are wrong and false and filed with malicious intent.

Hence the complaint and all the allegation in the application /Complaint against the respondent No. 17 are liable to dismissed.

It is therefore most respectfully prayed that the present Application/complaint against the Respondent No. 17 and all the allegations be dismissed for the reasons stated above, with cost and pass such further

**ATTES 'ED**

NIKHIL AGGARWAL  
Advocate & Notary  
Sub Division Nahan  
Distt Sirmour H.P. India

2750

order, as this Hon'ble Court deem fit in the interest of justice and equity.

Date: 10/10/2025

Place: Nahan HP

  
Answering Respondent No. 17

through Counsels

**Brijesh Chauhan,  
Chander Mohan Sharma &  
Advocates..**  
267/7, Hindu Ashram Road,  
Near Delhi Gate, Nahan, H.P.  
Mob: 9882370777;  
Email: [brijeshnhn@yahoo.com](mailto:brijeshnhn@yahoo.com)

**ATTES'ED**

  
NIKHIL AGARWAL  
Advocate & Notary  
Sub Division Nahan  
Distt. Sirmour H.P. (India)

BEFORE THE HON'BLE NATIONAL GREEN TRIBUNAL, PRINCIPAL BENCH, NEW DELHI

In the matter of :

Dharamvir

..... Applicant

Versus

State of Haryana and others

..... Respondents

AFFIDAVIT

I, Chander Sheikhar Pushkarna, working as Chairman, authorised person for Kala Amb Infrastructure Development Company, Village Ogli, Tehsil Nahan, District Sirmaur, HP, 173030, do hereby solemnly affirm and declare as under:-

1. I am authorised person for aforesaid Kala Amb Infrastructure Development Company, I have gone through the records of the Respondent No. 17 and I have made myself conversant with the facts of the present case therefore, I am competent to depose, and contest the present matter on behalf of Respondent No. 17, i.e., Kala Amb Infrastructure Development Company.
2. That the accompanying reply (Compliance Report) has been drafted by my counsel under my instructions. The contents of accompanying reply may kindly be read as part and parcel of this affidavit, as the same are not being repeated herein for the sake of brevity

*Pushkarna*  
DEPONENT

VERIFICATION: I, the above named deponent, do hereby verify that the contents of this affidavit are true and correct to the best of my knowledge derived from the official record and nothing material is concealed therefrom.

*Pushkarna*  
DEPONENT

Verified at Nahan HP on this 10.10.2025

I know the Deponent personally & he/she has signed personally & he/she has signed his/her thumb impression signature in my presence  
SH. CHANDER MOHAN  
(Advocate)  
Nahan

Sub Division Nahan, District Sirmaur H.P. India

Nikhil  
Advocate & Notary  
Sub Division Nahan,  
District Sirmaur H.P. India

(Advocate)  
Nahan, Dist -  
Sirmaur (HP)  
7

Industry: Kala Amb Infrastructure Development Company  
 From Date: 2025-09-08 00:00:00 To Date: 2025-10-08 14:17:18

Report: 1 hour Avg Report

Date / Time	COD (ETP_1)	BOD (ETP_1)	TSS (ETP_1)	pH (ETP_1)	FLOW (ETP_1)	Today_Flow_Totalizer (ETP_1)
9/8/2025 0:00	90.87	18.84	22.65	7.11	0	0
9/8/2025 1:00	90.73	18.81	22.61	7.14	0	0
9/8/2025 2:00	90.4	18.8	22.56	6.97	0	0
9/8/2025 3:00	89.97	18.64	22.42	7.14	0	0
9/8/2025 4:00	89.63	18.65	22.33	7.11	0	0
9/8/2025 5:00	88.78	18.43	22.11	7.12	0	0
9/8/2025 6:00	88.2	18.32	21.98	7.13	0	0
9/8/2025 7:00	85.17	17.79	21.25	6.94	0	0
9/8/2025 8:00	81.31	16.84	20.24	7.14	0	0
9/8/2025 9:00	75.55	15.63	18.83	7.04	0	0
9/8/2025 10:00	71.97	14.87	17.92	7.11	0	0
9/8/2025 11:00	69.57	14.32	17.32	7.11	0	0
9/8/2025 12:00	71.92	14.89	17.9	7.2	0	0
9/8/2025 13:00						
9/8/2025 14:00	72.44	14.99	18.04	7.09	0	0
9/8/2025 15:00	72.72	15.15	18.1	7.1	0	0
9/8/2025 16:00						
9/8/2025 17:00						
9/8/2025 18:00						
9/8/2025 19:00						
9/8/2025 20:00						
9/8/2025 21:00						
9/8/2025 22:00						
9/8/2025 23:00						
9/9/2025 0:00						
9/9/2025 1:00						
9/9/2025 2:00						
9/9/2025 3:00						
9/9/2025 4:00						
9/9/2025 5:00						
9/9/2025 6:00						
9/9/2025 7:00						
9/9/2025 8:00						
9/9/2025 9:00	70.39	14.51	17.52	7.15	0	0
9/9/2025 10:00	66.33	13.62	16.51	7.13	0	0
9/9/2025 11:00	67.45	13.96	16.81	7.02	0	0
9/9/2025 12:00	63.71	13.07	15.85	7.09	0	3.13
9/9/2025 13:00	63.61	13.14	15.83	7.07	0	34
9/9/2025 14:00	70.05	14.41	17.44	7.16	0	69.94
9/9/2025 15:00	74.38	15.47	18.54	6.96	0	163.71
9/9/2025 16:00	77.2	15.95	19.23	7.08	0	433
9/9/2025 17:00	81.98	17.06	20.44	6.99	0	550
9/9/2025 18:00	86.66	18.01	21.6	7.09	0	634.24
9/9/2025 19:00	89.94	18.7	22.42	7.09	0	1302.47
9/9/2025 20:00	93.64	19.49	23.34	7.11	0.08	35224.88
9/9/2025 21:00	96.11	19.97	23.95	7.15	0.06	116040.76
9/9/2025 22:00	96.81	20.18	24.15	7.04	0	137555
9/9/2025 23:00	98.94	20.62	24.67	7.04	0	137555
9/10/2025 0:00	99.65	20.82	24.86	6.97	0	0
9/10/2025 1:00	99.87	20.81	24.9	7.1	0	0
9/10/2025 2:00	100.44	20.91	25.04	7.09	0	0
9/10/2025 3:00	100.65	20.97	25.09	7.05	0	0
9/10/2025 4:00	99.49	20.73	24.81	7.09	0	0
9/10/2025 5:00	100.03	20.84	24.95	7.1	0	0
9/10/2025 6:00	101.46	21.22	25.32	6.98	0	0
9/10/2025 7:00	96.04	19.92	23.94	7.15	0	0
9/10/2025 8:00	92.01	19.17	22.94	7.04	0	0
9/10/2025 9:00	92.92	19.38	23.16	7.07	0	0
9/10/2025 10:00	93.93	19.5	23.4	7.21	0	0
9/10/2025 11:00	91.51	19.08	22.82	7.04	0	0
9/10/2025 12:00	88.16	18.3	21.98	7.08	0	0
9/10/2025 13:00	85.56	17.7	21.31	7.15	0	0
9/10/2025 14:00	84.71	17.6	21.11	7.1	0	0
9/10/2025 15:00	85.83	17.82	21.4	7.06	0	0
9/10/2025 16:00	87.68	18.16	21.85	7.14	0	0
9/10/2025 17:00	89.19	18.46	22.22	7.18	0	0
9/10/2025 18:00	93.96	19.56	23.42	7.07	0	0
9/10/2025 19:00	98.31	20.43	24.51	7.11	0	0
9/10/2025 20:00	99.66	20.79	24.84	7.11	0	0
9/10/2025 21:00	98.82	20.64	24.65	7.06	0	0
9/10/2025 22:00	98.78	20.53	24.63	7.11	0	0
9/10/2025 23:00	100.05	20.89	24.94	7.11	0	0
9/11/2025 0:00	101.54	21.22	25.32	7.1	0	0
9/11/2025 1:00	101.25	21.16	25.25	7.04	0	0
9/11/2025 2:00	100.88	20.98	25.13	7.2	0	0

9/11/2025 3:00	99.95	20.75							
9/11/2025 4:00	97.11	20.24	24.91	7.17	0				0
9/11/2025 5:00	95.17	19.77	24.22	7.06	0				0
9/11/2025 6:00	94.21	19.56	23.72	7.15	0				0
9/11/2025 7:00	91.2	18.96	23.48	7.2	0				0
9/11/2025 8:00	85.62	17.87	22.74	7.08	0				0
9/11/2025 9:00	86.01	17.77	21.35	7.03	0				0
9/11/2025 10:00	88.25	18.37	21.43	7.17	0				0
9/11/2025 11:00	90.92	18.94	22.01	7.06	0				0
9/11/2025 12:00	90.46	18.79	22.68	7.02	0				0
9/11/2025 13:00	90.65	18.8	22.55	7.1	0				0
9/11/2025 14:00	90.32	18.84	22.59	7.15	0				0
9/11/2025 15:00	90.24	18.77	22.51	7.07	0				0
9/11/2025 16:00	91.75	19.14	22.5	7.06	0				0
9/11/2025 17:00	95.11	19.84	22.87	7.1	0				0
9/11/2025 18:00	99.46	20.7	23.72	7.03	0				0
9/11/2025 19:00	100.35	21.03	24.81	7.09	0				0
9/11/2025 20:00	101.3	21.12	25.04	7.01	0.03			7075.29	
9/11/2025 21:00	103.18	21.54	25.27	7.05	0.09			79350.06	
9/11/2025 22:00	103.56	21.64	25.73	7.13	0.02			143106.76	
9/11/2025 23:00	103.41	21.58	25.83	7.02	0			146782	
9/12/2025 0:00	104.4	21.78	25.79	7.03	0			146782	
9/12/2025 1:00	102.65	21.38	26.03	7.15	0			0	
9/12/2025 2:00	100.57	20.95	25.59	7.11	0			0	
9/12/2025 3:00	100.27	20.93	25.08	7.08	0			0	
9/12/2025 4:00	101.38	21.18	25.01	7.05	0			0	
9/12/2025 5:00	100.85	21	25.3	6.97	0			0	
9/12/2025 6:00	101.41	21.08	25.15	7.07	0			0	
9/12/2025 7:00	99.56	20.74	25.29	7.13	0			0	
9/12/2025 8:00	97.62	20.32	24.81	7.07	0			0	
9/12/2025 9:00	89.63	18.66	24.33	7.15	0			0	
9/12/2025 10:00	89.53	18.64	22.35	7.06	0			0	
9/12/2025 11:00	93.08	19.31	22.32	7.04	0			0	
9/12/2025 12:00	92.27	19.17	23.2	7.13	0			0	
9/12/2025 13:00	89.66	18.6	23	7.1	0			0	
9/12/2025 14:00	87.76	18.12	22.34	7.09	0			0	
9/12/2025 15:00	88.93	18.51	21.86	7.18	0			0	
9/12/2025 16:00	90.76	18.87	22.16	7.04	0			0	
9/12/2025 17:00	94.24	19.62	22.62	7.14	0			0	
9/12/2025 18:00	96.57	20.09	23.49	7.09	0			0	
9/12/2025 19:00	99.55	20.76	24.06	7.13	0			0	
9/12/2025 20:00	100.27	20.87	24.82	7.09	0			0	
9/12/2025 21:00	102.32	21.33	25	7.09	0			0	
9/12/2025 22:00	102.64	21.44	25.51	7.18	0			0	
9/12/2025 23:00	100.9	21.05	21.44	6.98	0			0	
9/13/2025 0:00	101.29	21.15	25.16	7.07	0			0	
9/13/2025 1:00	98.99	20.64	25.26	7.03	0			0	
9/13/2025 2:00	99.13	20.79	24.68	7.06	0			0	
9/13/2025 3:00	100.4	20.99	24.73	6.99	0			0	
9/13/2025 4:00	100.72	21	25.05	6.98	0			0	
9/13/2025 5:00	102.52	21.36	25.13	7.02	0			0	
9/13/2025 6:00	104.63	21.86	25.56	7.09	0			0	
9/13/2025 7:00	106.76	22.24	26.1	7.03	0			0	
9/13/2025 8:00	103.33	21.49	26.63	7.04	0			0	
9/13/2025 9:00	97.46	20.3	25.75	7.15	0			0	
9/13/2025 10:00	96.07	20.4	24.29	7.16	0			73.88	
9/13/2025 11:00	98.3	20.44	23.96	7.04	0			160	
9/13/2025 12:00	101.79	21.14	24.5	7.11	0			160	
9/13/2025 13:00	100.14	20.85	25.38	7.09	0			160	
9/13/2025 14:00	99.88	20.78	24.97	7.07	0			300.24	
9/13/2025 15:00	100.3	20.91	24.9	7.09	0			324	
9/13/2025 16:00	99.1	20.67	25	7.08	0			352.41	
9/13/2025 17:00	98.83	20.58	24.71	7.12	0			419	
9/13/2025 18:00	99.92	20.83	24.65	7.08	0			419	
9/13/2025 19:00	100.92	21.07	24.92	7.07	0			419	
9/13/2025 20:00	101.7	21.22	25.17	7.04	0.04			15750.71	
9/13/2025 21:00	102.75	21.51	25.37	7.04	0.09			86067.56	
9/13/2025 22:00	103.55	21.67	25.64	6.98	0.01			138280.12	
9/13/2025 23:00	102.39	21.3	25.84	6.99	0			139146	
9/14/2025 0:00	102.5	21.33	25.52	7.17	0			139146	
9/14/2025 1:00	102.18	21.24	25.56	7.11	0			0	
9/14/2025 2:00	100.54	20.92	25.47	7.17	0			0	
9/14/2025 3:00	99.81	20.85	25.07	7.12	0			0	
9/14/2025 4:00	99.45	20.71	24.9	7.02	0			0	
9/14/2025 5:00	98.86	20.57	24.8	7.07	0			0	
9/14/2025 6:00	98.95	20.52	24.66	7.1	0			0	
9/14/2025 7:00	97.58	20.31	24.66	7.21	0			106	
9/14/2025 8:00	95.77	19.96	24.33	7.11	0			2	
9/14/2025 9:00	95.18	19.84	23.88	7.1	0			2	
9/14/2025 10:00	94.42	19.7	23.73	7.07	0			2	
9/14/2025 11:00	92.93	19.36	23.54	7.09	0			2	
			23.17	7.05	0			2	

9/14/2025 12:00	91.7								
9/14/2025 13:00	89.97	19.07							
9/14/2025 14:00	86.53	18.74	22.87	7.06	0				
9/14/2025 15:00	81.96	18.06	22.41	7.15	0				2
9/14/2025 16:00	87.58	17.03	21.58	7.01	0				2
9/14/2025 17:00	93.83	18.15	20.43	7.06	0				2
9/14/2025 18:00	95.17	19.47	21.83	7.12	0				3.76
9/14/2025 19:00	99.31	19.88	23.38	7.15	0				5
9/14/2025 20:00	101.06	20.64	23.74	7.06	0				5
9/14/2025 21:00	101.49	21.1	24.75	7.09	0				5
9/14/2025 22:00	101.52	21.11	25.2	7.09	0				5
9/14/2025 23:00	102.29	21.09	25.3	7.14	0				5
9/15/2025 0:00	102.31	21.36	25.3	7.13	0				5
9/15/2025 1:00	100.41	21.3	25.51	7.08	0				5
9/15/2025 2:00	99.58	20.94	25.51	7.14	0				5
9/15/2025 3:00	99.4	20.7	25.05	7.06	0				0
9/15/2025 4:00	98.59	20.72	24.82	7.14	0				0
9/15/2025 5:00	97.21	20.54	24.78	7.12	0				0
9/15/2025 6:00	96.72	20.25	24.58	7.08	0				0
9/15/2025 7:00	92.86	20.14	24.23	7.14	0				0
9/15/2025 8:00	86.7	19.35	24.12	7.02	0				0
9/15/2025 9:00	87.83	18.05	23.17	6.99	0				0
9/15/2025 10:00	88.78	18.23	21.62	7.06	0				0
9/15/2025 11:00	85.72	18.47	21.89	7.08	0				0
9/15/2025 12:00	87.89	17.77	22.13	7.03	0				0
9/15/2025 13:00	87.59	18.3	21.36	7.1	0				6.73
9/15/2025 14:00	84.96	18.18	21.92	7.02	0				66.47
9/15/2025 15:00	85.77	17.66	21.84	7.07	0				170.76
9/15/2025 16:00	86.09	17.74	21.18	7.02	0				296.47
9/15/2025 17:00	88.15	17.85	21.36	7.21	0				323.47
9/15/2025 18:00	91.39	18.38	21.47	7.06	0				338.12
9/15/2025 19:00	94.48	19.02	21.98	7.02	0				471.41
9/15/2025 20:00	96.2	19.7	22.78	7.08	0				484
9/15/2025 21:00	98.81	20.07	23.55	7.08	0				544.47
9/15/2025 22:00	98.52	20.54	23.98	7.1	0				815.12
9/15/2025 23:00	98.12	20.55	24.62	7.17	0				905.34
9/16/2025 0:00	99.53	20.45	24.56	7.05	0				920.94
9/16/2025 1:00	101.94	20.7	24.47	7.07	0				935.59
9/16/2025 2:00	102.43	21.2	24.82	7.09	0				941.82
9/16/2025 3:00	103.54	21.35	25.41	7.18	0				14.76
9/16/2025 4:00	102.88	21.58	25.55	7.07	0				18
9/16/2025 5:00	102.68	21.51	25.81	7.13	0				19.47
9/16/2025 6:00	102.14	21.4	25.67	7.02	0				34.47
9/16/2025 7:00	100.89	21.23	25.6	7.11	0				74.06
9/16/2025 8:00	101.34	20.96	25.45	7.2	0				103
9/16/2025 9:00	100.21	21.15	25.15	7.16	0				130.18
9/16/2025 10:00	97.81	20.91	25.27	7.08	0				140
9/16/2025 11:00	94.2	20.32	24.99	7.04	0				146.35
9/16/2025 12:00	96.2	19.62	24.38	7.16	0				164.88
9/16/2025 13:00	98.67	20.06	23.5	7.03	0				215
9/16/2025 14:00	98.65	20.52	23.99	7.07	0				221
9/16/2025 15:00	97.2	20.55	24.6	7.12	0				500230
9/16/2025 16:00	99.23	20.24	24.61	7.06	0				500236
9/16/2025 17:00	99.87	20.64	24.23	7.14	0				500236
9/16/2025 18:00	103.93	20.79	24.74	7.11	0				500236.44
9/16/2025 19:00	100.59	20.79	24.89	7.11	0				500237
9/16/2025 20:00	104.74	21.75	25.95	6.99	0				500237
9/16/2025 21:00	104.09	21	25.08	7.03	0				500237
9/16/2025 22:00	103.12	21.83	26.11	7.13	0.03				500237
9/16/2025 23:00	102.8	21.72	25.95	7.08	0.09				504931.29
9/17/2025 0:00	102.99	21.51	25.71	7.11	0.02				572705.88
9/17/2025 1:00	102.08	21.46	25.63	7.06	0				632335.65
9/17/2025 2:00	101.52	21.5	25.69	7.1	0				634384
9/17/2025 3:00	101.76	21.3	25.45	7.08	0				0
9/17/2025 4:00	101.05	21.22	25.32	7	0				0
9/17/2025 5:00	101.94	21.19	25.37	7.12	0				0
9/17/2025 6:00	101.51	21.14	25.2	7.04	0				0
9/17/2025 7:00	99.04	21.35	25.43	7	0				0
9/17/2025 8:00	96.61	21.09	25.29	7.18	0				0
9/17/2025 9:00	95.37	20.62	24.68	7.14	0				4.24
9/17/2025 10:00	95.06	20.12	24.1	7.07	0				9
9/17/2025 11:00	97.06	19.8	23.78	7.11	0				9
9/17/2025 12:00	89.45	19.85	23.71	6.99	0				9
9/17/2025 13:00	91.34	20.26	24.2	7.07	0				9
9/17/2025 14:00	91.35	18.56	22.3	7.14	0				9
9/17/2025 15:00	89.89	19.03	22.78	7.09	0				9
9/17/2025 16:00	89.58	18.97	22.76	7.11	0				9
9/17/2025 17:00	92.24	18.7	22.4	7.14	0				9
9/17/2025 18:00	97.17	18.6	22.33	7.1	0				9
9/17/2025 19:00	99.86	19.22	23.02	7.02	0				9
9/17/2025 20:00	102.07	20.21	24.21	7.1	0				84.59
		20.81	24.89	7.11	0				428.54
		21.34	25.47	7.05	0				494
					0				494

9/17/2025 21:00							
9/17/2025 22:00	102.6						
9/17/2025 23:00	102.33	21.33					
9/18/2025 0:00	103.04	21.35	25.57	7.17	0		494
9/18/2025 1:00	104.73	21.44	25.5	7.13	0		494
9/18/2025 2:00	104.43	21.83	25.69	7.16	0		528.12
9/18/2025 3:00	104.22	21.77	26.11	7.1	0		0
9/18/2025 4:00	104.06	21.71	26.05	7.08	0		0
9/18/2025 5:00	103.68	21.67	25.99	7.08	0		1
9/18/2025 6:00	104.16	21.65	25.94	7.17	0		492.41
9/18/2025 7:00	102.79	21.69	25.85	7.09	0		777.94
9/18/2025 8:00	100.7	21.4	25.96	7.13*	0		985.59
9/18/2025 9:00	101.01	21.01	25.64	7.08	0		1265.65
9/18/2025 10:00	102.01	21.06	25.1	7.12	0		1370.24
9/18/2025 11:00	98.21	21.2	25.18	7.1	0		1585
9/18/2025 12:00	96.55	20.43	25.43	7.15	0		1851.35
9/18/2025 13:00	98.69	20.11	24.48	7.13	0		1855
9/18/2025 14:00	96.49	20.57	24.06	7.14	0		1857.8
9/18/2025 15:00	94.73	20.15	24.61	7.03	0		1873.2
9/18/2025 16:00	94.52	19.8	24.06	7.03	0		1880
9/18/2025 17:00		19.57	23.62	7.01	0		1907.35
9/18/2025 18:00			23.56	7.14	0		1942
9/18/2025 19:00							
9/18/2025 20:00							
9/18/2025 21:00							
9/18/2025 22:00							
9/18/2025 23:00							
9/19/2025 0:00							
9/19/2025 1:00							
9/19/2025 2:00							
9/19/2025 3:00							
9/19/2025 4:00							
9/19/2025 5:00							
9/19/2025 6:00	104.29	21.68					
9/19/2025 7:00	101.56	21.19	26	7.19	0		3.58
9/19/2025 8:00	93.25	19.36	25.32	7.07	0		31.88
9/19/2025 9:00	90.05	18.76	23.24	7.15	0		89.24
9/19/2025 10:00	90.64	18.89	22.44	7.08	0		223.94
9/19/2025 11:00	89.44	18.57	22.59	7.08	0		302.18
9/19/2025 12:00	89.34	18.51	22.3	7.08	0		405.82
9/19/2025 13:00	87.43	18.1	22.27	7.13	0		544
9/19/2025 14:00	85.66	17.82	21.78	7.16	0		675.38
9/19/2025 15:00	84.45	17.54	21.35	7.05	0		736.53
9/19/2025 16:00	87.41	18.15	21.05	7.11	0		976.12
9/19/2025 17:00	90.19	18.66	21.79	7.07	0		1129.88
9/19/2025 18:00	93.65	19.46	22.47	7.19	0		1165
9/19/2025 19:00	97.42	20.36	23.34	7.14	0		1176
9/19/2025 20:00	101.32	21.1	24.29	7.08	0		1305.18
9/19/2025 21:00	103.82	21.68	25.27	7.05	0		1418.12
9/19/2025 22:00	105.06	21.91	25.9	7.06	0		1437.76
9/19/2025 23:00	106.52	22.21	26.2	7.1	0		1453.41
9/20/2025 0:00	106.89	22.33	26.57	7.08	0		1472.12
9/20/2025 1:00	107.1	22.34	26.67	7.01	0		1.18
9/20/2025 2:00	107.79	22.47	26.71	7.12	0		4.88
9/20/2025 3:00	108.54	22.63	26.88	7.1	0		8.29
9/20/2025 4:00	108.28	22.59	27.06	7.12	0		10.47
9/20/2025 5:00	108.1	22.47	27	7.11	0		14.76
9/20/2025 6:00	107.18	22.34	26.95	7.18	0		26.94
9/20/2025 7:00	103.1	21.5	26.71	7.19	0		41.24
9/20/2025 8:00	88.85	18.46	25.7	7.13	0		43
9/20/2025 9:00	86.55	18	22.14	7.14*	0		43
9/20/2025 10:00	87.52	18.14	21.58	7.06	0		43.71
9/20/2025 11:00	85.97	17.82	21.8	7.18	0		60.35
9/20/2025 12:00	82.8	17.18	21.42	7.13	0		68.76
9/20/2025 13:00	82.35	17.15	20.62	7.1	0		135.41
9/20/2025 14:00	84.09	17.44	20.52	7.06	0		465.18
9/20/2025 15:00	87.16	18.11	20.96	7.06	0		1180.29
9/20/2025 16:00	89.11	18.52	21.72	7.1	0		1557.59
9/20/2025 17:00	92.97	19.38	22.22	7.03	0		1695.82
9/20/2025 18:00	97.62	20.28	23.18	7.06	0		1720
9/20/2025 19:00	101.74	21.26	24.33	7.15	0		1736.59
9/20/2025 20:00	103.94	21.71	25.38	6.99	0.05		17186.82
9/20/2025 21:00	104.71	21.87	25.91	7.1	0.07		89964.82
9/20/2025 22:00	105.86	22.1	26.11	7.08	0		118347
9/20/2025 23:00	107.72	22.48	26.41	7.08	0		118347
9/21/2025 0:00	108.21	22.6	26.86	7.12	0		118347
9/21/2025 1:00	107.92	22.53	26.99	7.12	0		0
9/21/2025 2:00	106.73	22.25	26.92	7.06	0		0
9/21/2025 3:00	106.48	22.21	26.92	7.05	0		0
9/21/2025 4:00	107.14	22.41	26.73	7.05	0		0
9/21/2025 5:00	108.61	22.58	27.08	7.16	0		0



9/24/2025 15:00	86.69						
9/24/2025 16:00	88.02	17.99					
9/24/2025 17:00	93.65	18.28	21.61	7.06	0		1316.59
9/24/2025 18:00	99.01	19.44	21.94	7.04	0		2304.35
9/24/2025 19:00	103.07	20.6	23.35	7.07	0		2767.87
9/24/2025 20:00	106.17	21.5	24.68	7.12	0		3207.47
9/24/2025 21:00	108.22	22.11	25.7	7.08	0		3294.53
9/24/2025 22:00	108.98	22.54	26.47	7.11	0		3318.41
9/24/2025 23:00	109.88	22.78	26.99	7.09	0		3330.29
9/25/2025 0:00	110.09	22.92	27.19	7.02	0		3340.88
9/25/2025 1:00	108.63	23	27.4	7.11	0		3360.47
9/25/2025 2:00	108.02	22.67	27.46	7.08	0		17.47
9/25/2025 3:00	107.6	22.53	27.09	7.14	0		47.06
9/25/2025 4:00	107.37	22.44	26.95	7.05	0		57.82
9/25/2025 5:00	107.37	22.45	26.84	7.1	0		65
9/25/2025 6:00	107.93	22.42	26.78	7.08	0		73.65
9/25/2025 7:00	105.29	22.53	26.78	7.04	0		79.94
9/25/2025 8:00	97.37	21.98	26.92	7.11	0		87.59
9/25/2025 9:00	94.39	20.26	26.26	7.06	0		145.94
9/25/2025 10:00	92.27	19.58	24.27	7.14	0		242.44
9/25/2025 11:00	88.28	19.21	23.52	7.16	0		296
9/25/2025 12:00	84.38	18.45	23.01	7.07	0		296
9/25/2025 13:00	79.44	17.55	22.01	7.04	0		305.88
9/25/2025 14:00	77.99	16.47	21.03	7.06	0		339.29
9/25/2025 15:00	80.17	16.16	19.8	7.07	0		340
9/25/2025 16:00	82.98	16.62	19.43	7.08	0		340
9/25/2025 17:00	87.42	17.26	19.99	7.05	0		359.18
9/25/2025 18:00	93.98	18.16	20.68	7.06	0		1182.47
9/25/2025 19:00	99.18	19.67	21.79	7.1	0		2484.63
9/25/2025 20:00	102.83	20.59	23.44	7.01	0		3399
9/25/2025 21:00	105.41	21.99	24.72	7.15	0.08		44619.59
9/25/2025 22:00	110.11	23.02	25.64	7.11	0		88385
9/25/2025 23:00	112.65	23.53	26.3	7.1	0		88385
9/26/2025 0:00	113.41	23.72	27.47	7.05	0		88385
9/26/2025 1:00	113.57	23.74	28.09	7.14	0		88385
9/26/2025 2:00	111.61	23.24	28.3	7.01	0		0
9/26/2025 3:00	111.62	23.28	28.34	7.04	0		0
9/26/2025 4:00	110.87	23.14	27.83	7.09	0		0
9/26/2025 5:00	109.62	22.89	27.84	7.16	0		0
9/26/2025 6:00	108.69	22.73	27.65	7.1	0		0
9/26/2025 7:00	108.02	22.58	27.34	7.08	0		0
9/26/2025 8:00	98.43	20.59	27.11	7.05	0		87.94
9/26/2025 9:00	96.81	20.11	26.94	7.08	0		435.82
9/26/2025 10:00	96.07	19.99	24.53	7.06	0		646.64
9/26/2025 11:00			24.14	7.11	0		993.42
9/26/2025 12:00	93.58	19.46	23.95	7.1	0		1408.88
9/26/2025 13:00	85.42	17.71	23.33	7.05	0		1539.46
9/26/2025 14:00	84.53	17.57	21.29	7.14	0		1717.38
9/26/2025 15:00	86.78	18.01	21.06	7.08	0		2197.36
9/26/2025 16:00	88.93	18.43	21.63	7.07	0		3487.24
9/26/2025 17:00	93.38	19.4	22.17	7.15	0		3991.69
9/26/2025 18:00	98.6	20.57	23.28	7.08	0		4236.67
9/26/2025 19:00	102.92	21.48	24.58	7.13	0		4289
9/26/2025 20:00	107.11	22.29	25.66	7.07	0		4356.29
9/26/2025 21:00	109.86	22.84	26.71	7.17	0		4565.59
9/26/2025 22:00	111.87	23.37	27.39	7.13	0		4801.63
9/26/2025 23:00	112.75	23.56	27.89	7.13	0		4904.35
9/27/2025 0:00	112.97	23.56	28.13	7.05	0		5014.41
9/27/2025 1:00	112.72	23.5	28.17	7.09	0		25.82
9/27/2025 2:00	111.85	23.36	28.1	7.12	0		78.94
9/27/2025 3:00	111.44	23.26	27.89	7.07	0		119.69
9/27/2025 4:00	109.98	23.04	27.8	7.07	0		125
9/27/2025 5:00	109.82	22.9	27.43	7.04	0		125.29
9/27/2025 6:00	109.14	22.76	27.38	7.17	0		129
9/27/2025 7:00	107.02	22.3	27.22	7.1	0		134.94
9/27/2025 8:00	95.2	19.81	26.68	7.12	0		137
9/27/2025 9:00	94.8	19.78	23.72	7.15	0		137
9/27/2025 10:00	94.56	19.66	23.64	7.05	0		137
9/27/2025 11:00	92.33	19.21	23.57	7.12	0		137
9/27/2025 12:00	89.07	18.56	23.02	7.04	0		137
9/27/2025 13:00	82.73	17.14	22.19	7.08	0		137
9/27/2025 14:00	83.83	17.36	20.61	7.11	0		137
9/27/2025 15:00	87.77	18.34	20.89	7.16	0		137
9/27/2025 16:00	86.02	17.86	21.89	6.99	0		138.87
9/27/2025 17:00	89.59	18.62	21.46	7.02	0		145.5
9/27/2025 18:00	95.2	19.79	22.35	7.06	0		1096.85
9/27/2025 19:00	100.08	20.85	23.73	7.13	0		2075.4
9/27/2025 20:00	104.69	21.74	24.96	7.03	0		2167
9/27/2025 21:00	106.8	22.28	26.09	7.16	0		2167
9/27/2025 22:00	108.2	22.66	26.65	7.02	0		2266.41
9/27/2025 23:00	109.06	22.78	26.99	7.05	0		2825.71
			27.2	7.07	0		2833
					0		2833

9/28/2025 0:00							
9/28/2025 1:00	109.61						
9/28/2025 2:00	111.21	22.87					
9/28/2025 3:00	111.48	23.18	27.34	7.12	0		0
9/28/2025 4:00	113.29	23.27	27.73	7.12	0		0
9/28/2025 5:00	113.44	23.63	27.81	7.02	0		0
9/28/2025 6:00	112.18	23.64	28.25	7.12	0		0
9/28/2025 7:00	110.62	23.45	28.29	7.09	0		0
9/28/2025 8:00	107.22	23.1	27.98	7.04	0		0
9/28/2025 9:00	98.58	22.35	27.59	7.08	0		0
9/28/2025 10:00	96.58	20.52	26.72	7.19	0		0
9/28/2025 11:00	91.36	20.11	24.57	7.13	0		0
9/28/2025 12:00	87.12	19.03	24.07	7.12	0		0
9/28/2025 13:00	83.66	18.12	22.78	7.07	0		0
9/28/2025 14:00	83.72	17.48	21.72	7.08	0		0
9/28/2025 15:00	79.41	17.41	20.87	6.95	0		0
9/28/2025 16:00		16.47	20.87	6.98	0		0.82
9/28/2025 17:00			19.77	7.14	0		93
9/28/2025 18:00							
9/28/2025 19:00							
9/28/2025 20:00							
9/28/2025 21:00							
9/28/2025 22:00							
9/28/2025 23:00							
9/29/2025 0:00							
9/29/2025 1:00							
9/29/2025 2:00							
9/29/2025 3:00							
9/29/2025 4:00							
9/29/2025 5:00							
9/29/2025 6:00	111.44	23.25	27.8	7.09	0		0
9/29/2025 7:00	105.7	22.09	26.37	7.06	0		0
9/29/2025 8:00	94.76	19.72	23.63	7.04	0		0
9/29/2025 9:00	92.74	19.25	23.12	7.11	0		0
9/29/2025 10:00	91.56	19.03	22.83	7.07	0		31250
9/29/2025 11:00	87.84	18.18	21.89	7.13	0		50000
9/29/2025 12:00	84.92	17.68	21.17	7.03	0		50000
9/29/2025 13:00	80.94	16.84	20.17	7.08	0		50000
9/29/2025 14:00	79.91	16.82	19.9	7	0		50000
9/29/2025 15:00							
9/29/2025 16:00							
9/29/2025 17:00							
9/29/2025 18:00							
9/29/2025 19:00							
9/29/2025 20:00							
9/29/2025 21:00							
9/29/2025 22:00							
9/29/2025 23:00							
9/30/2025 0:00							
9/30/2025 1:00							
9/30/2025 2:00							
9/30/2025 3:00							
9/30/2025 4:00							
9/30/2025 5:00							
9/30/2025 6:00							
9/30/2025 7:00							
9/30/2025 8:00							
9/30/2025 9:00							
9/30/2025 10:00							
9/30/2025 11:00							
9/30/2025 12:00							
9/30/2025 13:00							
9/30/2025 14:00							
9/30/2025 15:00							
9/30/2025 16:00							
9/30/2025 17:00	94.4	19.7	23.54	7.08	0		54444.44
9/30/2025 18:00	101.34	21.08	25.27	7.1	0		70000
9/30/2025 19:00	107.05	22.3	26.7	7.09	0		70000
9/30/2025 20:00	108.72	22.69	27.13	7	0		70000
9/30/2025 21:00	108.19	22.59	26.98	7.08	0		70000
9/30/2025 22:00	110.02	22.94	27.45	7.08	0		70000
9/30/2025 23:00	114.49	23.85	28.54	7.14	0		70000
10/1/2025 0:00	115.38	24.14	28.78	7.03	0		0
10/1/2025 1:00	117.18	24.56	29.24	7.01	0		0
10/1/2025 2:00	118.71	24.82	29.62	7.04	0		0
10/1/2025 3:00	119.09	24.86	29.69	7.09	0		0
10/1/2025 4:00	118.99	24.86	29.68	7.08	0		0
10/1/2025 5:00	119.68	25.1	29.86	7.03	0		0
10/1/2025 6:00	119.3	24.97	29.77	7.02	0		0
10/1/2025 7:00	116.7	24.45	29.11	7.08	0		0
10/1/2025 8:00	108.6	22.64	27.07	7.14	0		0

10/1/2025 9:00	105.1	21.86			0		0
10/1/2025 10:00	103.02	21.55	26.21	7.12	0		0
10/1/2025 11:00	98.11	20.56	25.7	7.02	0		0
10/1/2025 12:00	93.7	19.5	24.47	6.99	0		0
10/1/2025 13:00	90.8	19	23.35	7.12	0		0
10/1/2025 14:00	88.69	18.43	22.64	7.05	0		0
10/1/2025 15:00	91.57	19.08	22.11	7.09	0		0
10/1/2025 16:00	93.22	19.41	22.84	7.02	0		0
10/1/2025 17:00	96.31	20.04	23.25	7.03	0		0
10/1/2025 18:00	100.5	20.89	24.02	7.11	0		0
10/1/2025 19:00	103.51	21.63	25.05	7.14	0		0
10/1/2025 20:00	106.05	22.09	25.81	7.09	0.05		15214
10/1/2025 21:00	107.4	22.51	26.45	7.11	0.05		89086.77
10/1/2025 22:00	107.81	22.47	26.77	7.08	0		106428
10/1/2025 23:00	107.87	22.51	26.88	7.09	0		106428
10/2/2025 0:00	108.98	22.68	26.91	7.09	0		106428
10/2/2025 1:00	109.09	22.82	27.17	7.12	0		0
10/2/2025 2:00	111.17	23.15	27.21	7.01	0		0
10/2/2025 3:00	110.93	23.13	27.72	7.12	0		0
10/2/2025 4:00	111.18	23.25	27.67	7.12	0		0
10/2/2025 5:00	110.12	23.02	27.73	7.1	0		0
10/2/2025 6:00	110.34	23.04	27.47	7.07	0		0
10/2/2025 7:00	110.07	22.92	27.51	7.12	0		378.67
10/2/2025 8:00	102.74	21.42	27.45	7.09	0		938.4
10/2/2025 9:00	106.03	22.01	25.62	7.12	0		1132.11
10/2/2025 10:00	96.73	20.11	26.44	7.29	0		1310.67
10/2/2025 11:00	90.83	18.84	24.11	7.15	0		1461.12
10/2/2025 12:00	86.07	17.91	22.63	7.15	0		1590.18
10/2/2025 13:00	82.95	17.27	21.46	7.07	0		1766.24
10/2/2025 14:00	80.4	16.74	20.67	7.08	0		2092.47
10/2/2025 15:00	81.44	16.92	20.04	7.04	0		2646.12
10/2/2025 16:00	86.63	17.95	20.31	7.05	0		3422.94
10/2/2025 17:00	93.16	19.42	21.59	7.13	0		4022.24
10/2/2025 18:00	99.69	20.71	23.22	7.08	0		4573.5
10/2/2025 19:00	105	21.89	24.85	7.12	0		5073.35
10/2/2025 20:00	113.4	23.69	26.17	7.13	0		5530.59
10/2/2025 21:00	122.97	25.72	28.28	7.1	0		5624.88
10/2/2025 22:00	125.02	26.13	30.67	7.1	0		5629
10/2/2025 23:00	122.64	25.68	31.19	7.12	0		5629
10/3/2025 0:00	119.8	25.07	30.6	7.06	0		5629
10/3/2025 1:00	116.46	24.35	29.88	7.11	0		0
10/3/2025 2:00	114.55	24.01	29.04	7.09	0		0
10/3/2025 3:00	114.25	23.85	28.58	7.04	0		0
10/3/2025 4:00	114.54	23.98	28.5	7.11	0		213.06
10/3/2025 5:00	114.41	23.9	28.58	7.03	0		610.41
10/3/2025 6:00	114.22	23.87	28.53	7.15	0		1017.94
10/3/2025 7:00	112.03	23.39	28.51	7.06	0		1376.12
10/3/2025 8:00	105.5	21.97	27.96	7.03	0		2215.53
10/3/2025 9:00	100.2	20.81	26.31	7.1	0		3525.94
10/3/2025 10:00	98.88	20.66	24.98	7.15	0		3954.18
10/3/2025 11:00	96.05	20.03	24.66	7.06	0		5213.06
10/3/2025 12:00	90.31	18.73	23.95	7.04	0		6555.76
10/3/2025 13:00	84.2	17.48	22.51	7.09	0		7543.35
10/3/2025 14:00	82.38	17.17	20.98	7.07	0		8200.29
10/3/2025 15:00	86.57	18	20.54	7.03	0		8972.12
10/3/2025 16:00	90.64	18.88	21.59	7.01	0		9587.12
10/3/2025 17:00	95.12	19.83	22.6	7.08	0		9946.71
10/3/2025 18:00	100.46	20.91	23.73	7.04	0		10186.06
10/3/2025 19:00	105.74	21.97	25.03	7.13	0		10416.76
10/3/2025 20:00	108.3	22.59	26.36	7.17	0		10724
10/3/2025 21:00	109.95	22.98	27.01	7.11	0		10933.94
10/3/2025 22:00	111.68	23.3	27.42	7.12	0		11164.12
10/3/2025 23:00	112.63	23.48	27.86	7.11	0		11410.71
10/4/2025 0:00	112.63	23.53	28.09	7.12	0		11610.06
10/4/2025 1:00	112.28	23.5	28.09	7.08	0		101.24
10/4/2025 2:00	111.66	23.33	28	7.05	0		297
10/4/2025 3:00	111.88	23.38	27.85	7.13	0		455.88
10/4/2025 4:00	112.08	23.43	27.9	7.06	0		674.47
10/4/2025 5:00	112.07	23.33	27.96	7.05	0		878.12
10/4/2025 6:00	112.74	23.55	27.95	7.15	0		1004
10/4/2025 7:00	110.49	23.13	28.12	7.14	0		1152.12
10/4/2025 8:00	100.26	20.82	27.58	7	0		1401.35
10/4/2025 9:00	97.61	20.32	24.99	7.15	0		1564.24
10/4/2025 10:00	96.6	20.16	24.33	7.12	0		61614.44
10/4/2025 11:00	93.11	19.36	24.1	6.99	0		61632
10/4/2025 12:00	89.03	18.56	23.22	7.08	0		61706.35
10/4/2025 13:00	84.5	17.54	22.2	7.07	0		61919
10/4/2025 14:00	82.81	17.2	21.07	7.03	0		61992.12
10/4/2025 15:00	86.73	18.03	20.64	7.05	0		62675.12
10/4/2025 16:00	90.55	18.9	21.62	7.08	0		63838.76
10/4/2025 17:00	95.82	19.92	22.58	7.06	0		64291
			23.88	7.13	0		64291



10/8/2025 3:00	125.74							
10/8/2025 4:00	126.24	26.34				0		0
10/8/2025 5:00	127.64	26.35	31.38		7.01	0		0
10/8/2025 6:00	126.9	26.67	31.48		7.14	0		0
10/8/2025 7:00	125.95	26.54	31.83		7.14	0		0
10/8/2025 8:00	123.37	26.31	31.65		7.13	0		0
10/8/2025 9:00	120.18	25.78	31.42		7.1	0		0
10/8/2025 10:00	118.21	25.18	30.78		7.1	0		0
10/8/2025 11:00	116.15	24.65	30		7.01	0		0
10/8/2025 12:00	108.93	24.27	29.48		7.14	0		0
10/8/2025 13:00	98.52	22.7	28.97		7.09	0		0
10/8/2025 14:00	93.27	20.54	27.16		7.11	0		0
Average Data	100.89	19.33	24.57		7.05	0		0
		21.03	23.24		7.14	0		0
			25.16		7.09	0		60111.61



**H.P. STATE POLLUTION CONTROL BOARD**  
**FORM X**  
**REPORT BY STATE BOARD ANALYST**  
 (See Rule 26)

Report No: 83684/W-19248

28/08/2025

I hereby certify that I **Dr Kuldeep Negi, SO**, State Board Analyst duly appointed under sub-section (3) of section 53 of the Water (Prevention and Control of Pollution) Act, 1974 (6 of 1974) received on **06/08/2025** from **Jitender Singh, JEE**, HP State Pollution Control Board **RO Paonta** a **Grab** sample of **Final Outlet** of **KALA AMB INFRASTRUCTURE DEVELOPMENT COMPANY**, **Ogli, Nahan, Sirmour**, **Nahan Distt. Sirmaur, H.P. 173030** on dated **05/08/2025** for analysis. The sample was in a condition fit for analysis reported below:

I further certify that I have analyzed the aforementioned sample on **06/08/2025** to **28/08/2025** and declare the result of analysis is to be as follows :-

Method of analysis					
IS- 2488(I-V), IS-3025(Part 44): 1933, 'Standard method for examination of water', 23rd edition prepared and published jointly by:-					
1. American Public Health Association 2. American Water Works Association 3. Water Pollution Control Federation					
SAMPLING PARAMETERS					
Sr. No.	Parameter Name	Results	Units	Permissible Limit	Remark/Result Analysis
1	BOD	7.5	mg/L	30	Within Permissible Limit
2	Hexavalent Chromium	BDL (DL-0.05)	mg/L	0.1	--
3	Oil and Grease	4.4	mg/L	10	Within Permissible Limit
4	Sulphat�	79.36	mg/L	1000	Within Permissible Limit
5	TSS	6.95	mg/L	100	Within Permissible Limit
6	Total KJELDAHL-N	Not Analyzed	-	50	--
7	TDS	1950.00	mg/L	NA	NA
8	Mercury	BDL (DL-0.005)	mg/L	0.01	--
9	Lead	BDL (DL-0.05)	mg/L	0.1	--
10	Sulfide (S2-)	BDL (DL-1.0)	mg/L	N/A	-
11	pH	8.17	--	6.0-9.0	Within Permissible Limit
12	COD	205.0	mg/L	250	Within Permissible Limit

13	Bio-assay Test	90.0	%	90-100	Within Permissible Limit
14	Phenolic Compounds(as C <sub>6</sub> H <sub>5</sub> OH)	BDL (DL-0.1)	mg/L	1	--
15	Total Phosphate	4.87	mg/L	5	Within Permissible Limit
16	Phosphate (as P)	1.59	mg/L	N/A	-
17	Ammonical Nitrogen	BDL ( DL-5.0)	mg/L	50	--

The condition of the seals, fastening and container on receipt was as: sealed as HPPCB  
Signed this on 28/08/2025

**Remarks of Lab Head:**

'BDL' and 'DL' stands for Below Detection Limit and Detection Limit, respectively.



Dr Kuldeep Negi, SO  
(State Board Analyst)  
RL Paonta

**From:**

H.P. STATE POLLUTION CONTROL BOARD,  
RL Paonta

**To:**

KALAMB INFRASTRUCTURE DEVELOPMENT COMPANY  
Ogli, Nahan, Sirmour, Nahan,  
Distt.Sirmour, H.P.173030

Ref. No. :- KIDC/ DIC - 46/25)

Dated: - 08.09.2025

To,  
The General Manager,  
District Industries Center, DIC,  
Nahan, District Sirmour, H.P.

**Subject: - Submission of monthly progress report of CETP Kala Amb.**

Sir,  
With reference to above, please find enclosed herewith progress report on CETP Kala Amb for the month of ending August 2025 on the prescribed format as under:

**Status of compliance and operation of the CETPs**

Town	No. of Industries	Industrial Discharge	Status of ETPs	Status of CETPs
Kala Amb	70 (Pharma industries to be covered in 1 <sup>st</sup> Phase)	<b>0.65 MLD</b> Total Capacity <b>2.5 MLD</b>	It Pertains to HP PCB	The CETP has been operational with effect from 4 <sup>th</sup> December 2023.

The Progress report for the month of August shows the work done on the following aspects.

1. 67 Pharma and 5 other than Pharma Industries registered in CETP Kala Amb till today out of 70 Pharma Industries and 66 Industries send their effluent to CETP Kala Amb.
2. We have resumed lifting of effluent from our member industries to CETP Kala Amb w.e.f. 04.12.2023. Till present time we have received approx. 57455 KL Effluent (Waste Water) from our member industries and 54714 KL has been leave in outlet tank after treatment. We have presently engaged three water tankers duly lifted with GPS.
3. Aeration process is going on 24x7.

2765  
ALA-AMB INFRASTRUCTURE DEVELOPMENT COMPANY (KIDC)  
C/o Common Facility Centre, Kala Amb, Distt. Sirmour, H.P.

Email :- kidc.cetp@gmail.com

Ref. No. :- KIDC/946/25)

4. Treat water parameters were found under norms which were set by the Honorable NGT, CPCB and HPPCB. Parameters of the treated water define by the HPPCB on dated 26.08.2025 which was collected by the JE HPPCB RO Paonta, Sirmour (H.P.) on dated 06.08.2025. Sample testing report enclosed with the letter.
5. KIDC need fund per month Rs. 8.84 Lakhs from Jal Shakti Vibhag for smooth functioning of CETP Kala Amb.

We are facing problem due to shortage of fund for smooth running of CETP Kala Amb. So, you are therefore requested to available fund for smooth running of CETP Kala Amb.

Thanking You



(C.S. Pushkarna)

Chairman, KIDC Kala Amb

Cc to

1. The Member Secretary, SWCA Kala Amb, Tehsil Nahan, District Sirmour H.P.
2. The Regional Officer, HPPCB Paonta Sahib, District Sirmour H.P.



**H.P. STATE POLLUTION CONTROL BOARD**  
**FORM X**  
**REPORT BY STATE BOARD ANALYST**  
(See Rule 26)

Report No: 83684/W-19248

28/08/2025

I hereby certify that I **Dr Kuldeep Negi, SO**, State Board Analyst duly appointed under sub-section (3) of section 53 of the Water (Prevention and Control of Pollution) Act, 1974 (6 of 1974) received on **06/08/2025** from **Jitender Singh, JEE**, HP State Pollution Control Board **RO Paonta a Grab sample of Final Outlet of KALA AMB INFRASTRUCTURE DEVELOPMENT COMPANY, Ogli, Nahan, Sirmour, Nahan Distt. Sirmaur, H.P. 173030** on dated **05/08/2025** for analysis. The sample was in a condition fit for analysis reported below:

I further certify that I have analyzed the aforementioned sample on **06/08/2025** to **28/08/2025** and declare the result of analysis is to be as follows :-

Method of analysis					
IS- 2488(I-V), IS-3025(Part 44): 1933, 'Standard method for examination of water', 23rd edition prepared and published jointly by:-					
1. American Public Health Association 2. American Water Works Association 3. Water Pollution Control Federation					
SAMPLING PARAMETERS					
Sr. No.	Parameter Name	Results	Units	Permissible Limit	Remark/Result Analysis
1	BOD	7.5	mg/L	30	Within Permissible Limit
2	Hexavalent Chromium	BDL (DL-0.05)	mg/L	0.1	--
3	Oil and Grease	4.4	mg/L	10	Within Permissible Limit
4	Sulphate	79.36	mg/L	1000	Within Permissible Limit
5	TSS	6.95	mg/L	100	Within Permissible Limit
6	Total KJELDAHL-N	Not Analyzed	-	50	--
7	TDS	1950.00	mg/L	NA	NA
8	Mercury	BDL (DL-0.005)	mg/L	0.01	--
9	Lead	BDL (DL-0.05)	mg/L	0.1	--
10	Sulfide (S <sup>2-</sup> )	BDL (DL-1.0)	mg/L	N/A	-
11	pH	8.17	--	6.0-9.0	Within Permissible Limit
12	COD	205.0	mg/L	250	Within Permissible Limit

2767

13	Bio-assay Test	90.0			
14	Phenolic Compounds(as C6H5OH)	BDL (DL-0.1)	%	90-100	Within Permissible Limit
15	Total Phosphate	4.87	mg/L	1	--
16	Phosphate (as P)	1.59	mg/L	5	Within Permissible Limit
17	Ammonical Nitrogen	BDL ( DL-5.0)	mg/L	N/A	-
			mg/L	50	--

The condition of the seals, fastening and container on receipt was as scaled as HPPCB  
Signed this on 28/08/2025

**Remarks of Lab Head:**

'BDL' and 'DL' stands for Below Detection Limit and Detection Limit, respectively.



Dr Kuldeep Negi, SO  
(State Board Analyst)  
RL Paonta

**From:**

H.P. STATE POLLUTION CONTROL BOARD,  
RL Paonta

**To:**

KALA AMB INFRASTRUCTURE DEVELOPMENT COMPANY  
Ogli, Nahan, Sirmour, Nahan,  
Distt.Sirmaur, H.P.173030