

# 42416

**BEFORE THE HON'BLE NATIONAL GREEN TRIBUNAL,  
PRINCIPAL BENCH, NEW DELHI**

**O.A. No. 200/2014**

**(IA No 340/2022, MA No 480/2018, MA No 872/2018, MA No 875/2014)**

**(In respect of State of Uttar Pradesh)**

**In the matter of: -**

M.C. Mehta

Applicant(s)

Versus

Union of India & Ors.

Respondent(s)

**Index**

<b>S. No</b>	<b>Particulars</b>	<b>Page No.</b>
1.	<b>Compliance report</b> on behalf of Central Pollution Control Board (CPCB) in compliance to Hon'ble NGT order dated 04.09.2025 in OA 200/2014 titled MC Mehta VS Union of India & Ors.	
2.	<b>Annexure I-</b> A copy of Hon'ble NGT order dated 04.09.2025 in O.A No. 200/2014.	



**Filed by Advocate Suman Arora  
On behalf of Central Pollution Control Board**

Place: Delhi

Dated: 19.11.2024

**COMPLIANCE REPORT ON BEHALF OF CPCB IN COMPLIANCE TO HON'BLE NGT ORDER DATED 04.09.2025 IN THE MATTER OF M.C. MEHTA VS UNION OF INDIA & ORS., O.A. NO. 200/2014**

This report is submitted in compliance to Hon'ble NGT order dated 04.09.2025 (**Annexure-I**) in OA No. 200/2014 titled M.C. Mehta vs Union of India & Ors. The concerned matter is related to remedying of pollution in River Ganga. The verbatim of the order is as follows:

*“1..... The Respondent-CPCB is directed to ascertain the performance and functioning status of the STPs on river Ganga and submit the report.”*

In compliance to the above mentioned NGT order, the operational and compliance status of 49 Sewage Treatment Plants (STPs) located in 17 front towns in the state of Uttar Pradesh is given below:

**Status of Sewage Management in Ganga front towns in Uttar Pradesh**

There are 49 STPs located in 17 Ganga front towns in the state of Uttar Pradesh having a designed capacity of 1499 MLD. These STPs are monitored on tri-annual basis by Central Pollution Control Board (CPCB). As per the monitoring carried out by CPCB during April-July, 2025, 44 out of 49 STPs having operational capacity of 1443.9 MLD and utilized capacity of 1226.62 MLD (i.e approx. 82% of operational capacity) were found operational. In the Consent to Operate issued by Uttar Pradesh Pollution Control Board (UPPCB), STPs are required to be complied with the treated sewage discharge norms notified by Ministry of Environment Forests & Climate Change (MoEF & CC) dated 13.10.2017. As per the monitoring carried out during April-July,2025,20 STPs were found complying and 24 were found non-complying with the same. The remaining 05 STPs having a designed capacity of 55.04 MLD were found non-operational. The operational and compliance status of the STPs located in the state of Uttar Pradesh is given in Table 1 below:

**Table 1: Operational and compliance status of Sewage Treatment Plants in Uttar Pradesh**

S. No.	Name of STPs	Ganga Front Town	Treatment Technology	Design Capacity (MLD)	Utilized Capacity (MLD)	Date of Monitoring	Operational/Non-Operational Status	pH	TS (mg/l)	BOD (mg/l)	FC (MPN)/100 ml	Compliance norms
1.	24 MLD STP Bijnor, Near Hemraj Colony	Bijnor	UASB	24	23.95	30.04.2025	Operational	8.2	32	12	<1.8	Complying
2.	Brajghat (03 MLD) STP	Garhmukteshwar	UASB	3	2.5	22.04.2025	Operational	8.2	BDL	2	260	Complying
3.	Garhmukteshwar STP	Garhmukteshwar	UASB	6	4	03.07.2025	Operational	7.7	BDL	BDL	11x10 <sup>3</sup>	Non-complying FC
4.	Narora NAPS Township STP	Narora	ASP	2.25	0.97	22.04.2025	Operational	7.6	BDL	3	<1.8	Complying -
5.	Narora Town (4.0 MLD)	Narora	SBR	4	2	22.04.2025	Operational	7.9	130	45	47x10 <sup>4</sup>	Non-complying BOD, TSS, FC
6.	Anupshahr 1.5 MLD STP, Zone A	Anupshahr	MBBR	1.5	0.75	23.04.2025	Operational	7.4	58	38	<1.8	Non-complying BOD
7.	Anupshahr 0.81 MLD	Anupshahr	WSP	0.81	1	23.04.2025	Operational	7.9	BDL	12	68x10 <sup>2</sup>	Non-complying


	STP, Zone A											FC
8.	Anupshahr 1.75 MLD STP, Zone B	Anupshahr	WSP	1.75	4	23.04.2025	Operational	7.4	BDL	10	BDL	Complying
9.	Anupshahr 1.0 MLD STP, Zone B	Anupshahr	MBBR	1	0.5	23.04.2025	Operational	7.8	46	18	33x10 <sup>4</sup>	Non-complying FC
10.	Jalalpur Amara (13 MLD) STP	Kannauj	SBR	13	6.9	17.07.2025	Operational	7.3	15.6	12	45	Complying
11.	130 MLD Jajmau STP Kanpur	Kanpur	ASP	130	128.97	15.05.2025	Operational	7.3	38.6	51	7.9x10 <sup>4</sup>	Non-complying BOD, FC
12.	43 MLD Jajmau Kanpur	Kanpur	ASP	43	25.9	15.05.2025	Operational	7.4	26.8	12.6	7.9x10 <sup>4</sup>	Non-complying FC
13.	Jajmau (5 MLD) Kanpur	Kanpur	UASB	5	-	22.05.2025	Non-operational	-	-	-	-	-
14.	210 MLD Binawan STP, Kanpur	Kanpur	UASB	210	136.01	16.07.2025	Operational	7.7	25.4	33.7	490	Non-Complying BOD
15.	30 MLD STP at Pankha	Kanpur	SBR	30	29.28	01.07.2025	Operational	7.0	21.1	7.95	40	Complying
16.	42 MLD Sajari STP, Kanpur	Kanpur	ASP	42	27.36	16.07.2025	Operational	7.8	13.8	14	45	Complying

17.	Bithoor (80 KL D) STP	Bithoor	Constru cted we tland	0.08	0.04	15.05 .2025	Opera tional	7.5	45.6	12 .2	1.3x 10 <sup>5</sup>	Non-Co mplyin g FC
18.	32 KL D FST P, Nan dauli V illage	Unnao	FSTP	0.03 2	-	17.06 .2025	Non- opera tional	-	-	-	-	-
19.	15 ML D, STP Dakari	Unnao	SBR	15	-	17.06 .2025	Non- opera tional	-	-	-	-	-
20.	29 ML D STP , Salori , Praya graj	Prayagr aj	FAB re actor	29	36.0 7	18.06 .2025	Opera tional	7.5	19.4	15	610	Comply ing -
21.	Salori (Bakshi Bandh) 14 ML D Praya graj	Prayagr aj	SBR	14	10.9 9	18.06 .2025	Opera tional	7.4	<2. 5	5	2.2x 10 <sup>5</sup>	Non-Co mplyin g FC
22.	60 ML D STP, Rajapu r, Praya graj	Prayagr aj	UASB	60	80.9 7	28.05 .2025	Opera tional	7.3	13	27 .8	180	Comply ing
23.	10 ML D STP , Pongh at, Praya graj	Prayagr aj	BTT fol lowed b y ASP	10	15.7	28.05 .2025	Opera tional	7.3	17.8	13 .5	200	Comply ing
24.	25 ML D STP , Kodra , Praya graj	Prayagr aj	BTT fol lowed b y ASP	25	33.9 7	28.05 .2025	Opera tional	7.2	3.6	15	1.7x 10 <sup>3</sup>	Non-co mplyin g FC
25.	80 ML D STP , Naini, Prayagr aj	Prayagr aj	ASP	80	109. 51	17.06 .2025	Opera tional	7.4	13.5	14 .7	200	Comply ing

26.	42 ML D STP, Naini 2	Prayagraj	FCR	42	47.39	17.06 .2025	Operational	7.7	19.7	10.4	1.3x 10 <sup>4</sup>	Non-complying FC
27.	50 ML D STP, Numayadhai, Prayagraj	Prayagraj	BTT followed by ASP	50	57.14	17.06 .2025	Operational	7.6	18.9	17.3	1.7x 10 <sup>5</sup>	Non-complying FC
28.	14 ML D STP Phaphamau Prayagraj	Prayagraj	FCR	14	18.46	18.06 .2025	Operational	7.5	5.6	< 1.0	9.3 X10 <sup>3</sup>	Non-complying FC
29.	16 ML D STP, Jhunsi	Prayagraj	FCR	16	13.55	18.06 .2025	Operational	7.6	7.4	8	680	Complying
30.	14 ML D STP Mirzapur (Pakka Pokhra)	Mirzapur	UASB	14	13.29	09.07 .2025	Operational	6.9	21.7	17.9	1.7 X10 <sup>4</sup>	Non-complying FC
31.	7 MLD , STP, Vindhyachal,	Vindhyachal, Mirzapur	SBR	7	3.416	25.06 .2025	Operational	7.5	< 2.5	< 5.0	4.5 X10 <sup>4</sup>	Non-complying FC
32.	8.5 ML D, New STP, Pakka Pokhra	Mirzapur	SBR	8.5	6.433	09.07 .2025	Operational	6.7	10.3	24.7	20	Complying
33.	8.5 ML D, STP, Bisundarpur	Mirzapur	SBR	8.5	6.43	25.06 .2025	Operational	7.2	2.6	5.1	2.0 X10 <sup>4</sup>	Non-complying FC
34.	10 KL D FSTP Chunar, Mirzapur	Chunar	FSTP	0.01	-	09.07 .2025	Non-Operational	-	-	-	-	-
35.	80 ML D STP	Varanasi	TF & ASP	80	55	24.06 .2025	Operational	7.6	10.6	8	20	Complying

	at Dina pur												
36.	50 ML D STP, Raman na	Varana si	SBR	50	51.6 2	18.06 .2025	Opera tional	7. 3	19.5	7	2.2x 10 <sup>5</sup>	Non-co mplyin g FC	
37.	32 KL D FST P, Near Bairog hat Te mple F arrukha bad	Farruk habad	ABR	0.03 2	0.00 5	16.07 .2025	Opera tional	7. 5	11.8	7. 5	330	Comply ing -	
38.	30 ML D STP, near B haiogh at Tem ple,	Farruk habad	SBR	30	17.4	16.07 .2025	Opera tional	7. 3	10	9	140	Comply ing -	
39.	17.7 M LD ST P, Fate hgarh	Farruk habad	SBR	17.7	17.6	16.07 .2025	Opera tional	7. 3	9.8	13	220 0	Non-Co mplyin g FC	
40.	140 M LD ST P at Di napur	Varana si	ASP	140	98.5 1	24.06 .2025	Opera tional	7. 4	< 2. 5	< 5. 0	20	Comply ing	
41.	10 ML D STP, Ramna gar	Ramna gar, Va ranasi	A2O	10	9.58	18.06 .2025	Opera tional	7. 6	6.5	< 5. 0	110	Comply ing	
42.	9.8 ML D Bhag wanpur , Varan asi	Varana si	ASP	9.8	9.9	18.06 .2025	Opera tional	7. 5	< 2. 5	5	3.3x 10 <sup>3</sup>	Non-co mplyin g FC	
43.	120 M LD ST P at Go ithaha	Varana si	SBR	120	53.5	24.06 .2025	Opera tional	7. 6	7.6	< 5. 0	40	Comply ing	
44.	12 ML D BL W ( for	Varana si	ASP	12	2.82 3	18.06 .2025	Opera tional	7. 6	2.6	< 5. 0	4.9x 10 <sup>3</sup>	Non-co mplyin g	

	mer known as DLW)												FC
45.	35 ML D STP Plant, Sarai Talafi, Bareilly, U.P.	Bareilly	Extended Aeration	35	15.1	09.07.2025	Non-Operational	-	-	-	-	-	-
46.	01 ML D STP, Girdharipur, Bareilly	Bareilly	SBR	1	0.87	09.07.2025	Operational	6.8	7.2	7.4	2.2x10 <sup>4</sup>	Non-Complying FC	
47.	20 ML D STP, Chaubari, Bareilly	Bareilly	SBR	20	18.09	09.07.2025	Operational	6.9	8.4	12.5	4.9x10 <sup>3</sup>	Non-Complying FC	
48.	42 ML D STP, Harunagla, Bareilly	Bareilly	SBR	42	43.05	09.07.2025	Operational	6.8	4	6.3	1.4x10 <sup>4</sup>	Non-Complying FC	
49.	21 ML D STP, Jamuna Deva, Ghazipur	Ghazipur	SBR	21	1.23	31.07.2025	Operational	7.6	5.2	12	< 1.8	Complying	



**(Dinabandhu Gouda)**

Scientist 'F'

Central Pollution Control Board

19.11.2025

Item No. 14

Court No. 1

**BEFORE NATIONAL GREEN TRIBUNAL  
PRINCIPAL BENCH, NEW DELHI**

Original Application No. 200/2014  
(IA No 340/2022, MA No 480/2018,  
MA No 872/2018, MA No 875/2014)  
**(In respect of State of Uttar Pradesh)**

M C Mehta

Applicant

Versus

Union of India &amp; Ors.

Respondent(s)

Date of hearing: 04.09.2025

**CORAM: HON'BLE MR. JUSTICE PRAKASH SHRIVASTAVA, CHAIRPERSON  
HON'BLE DR. A. SENTHIL VEL, EXPERT MEMBER  
HON'BLE MR. SUDHIR KUMAR CHATURVEDI, EXPERT MEMBER  
HON'BLE DR. SUJIT KUMAR BAJPAYEE, EXPERT MEMBER**

Applicant: Ms. Katyayni, Adv. for Applicant (Through VC)

Respondents: Mr. Bhanwar Pal Singh Jadon, Ms. Gargi Chaturvedi, Ms. Anjali Sharma  
& Mr. Shivansh Sharma, Advs. for the State of UP  
Mr. Pradeep Misra & Mr. Daleep Dhyani, Advs. for UPPCB (Through VC)  
Mr. Gigi. C. George, Mr. Ishwer Singh & Mr. Sunil Kumar, Advs. for  
NMCG  
Ms. Suman Arora, Adv. for CPCB

**ORDER**

1. A letter has been circulated by the learned Counsel appearing for the State of UP seeking an adjournment on the ground that he has been recently engaged. The prayer is allowed. Learned counsel appearing for the State of UP is also directed to ensure compliance of the directions contained in paragraph 9 and 10 of the order dated 23.07.2025. The Respondent-CPCB is directed to ascertain the performance and functioning status of the STPs on river Ganga and submit the report.
2. List on 21.11.2025.

Prakash Shrivastava, CP

42425

Dr. A. Senthil Vel, EM

Sudhir Kumar Chaturvedi, EM

Dr. Sujit Kumar Bajpayee, EM

September 04, 2025  
Original Application No. 200/2014  
A