

**BEFORE THE HON'BLE NATIONAL GREEN TRIBUNAL
SOUTHERN ZONE, CHENNAI
OA No. 107 of 2023(SZ)**

IN THE MATTER OF

Tribunal on its own motion **Suo Motu**
based on the news item published in
The New Indian Express, dt. 09.08.2023,
under the caption "**Huge pollution risk
in 8 Km around NLC**" and in The Times
of India, Chennai Edition dt. 09.08.2023
under the caption "**Water near NLC full
of Mercury**".

Versus

The Managing Director
NLC India Limited,
Chennai and Ors.

...Respondents

REPORT FILED BY THE 6TH RESPONDENT



THROUGH
M/S. GAUTAM S. RAMAN
COUNSEL FOR 6TH RESPONDENT

**BEFORE THE HON'BLE NATIONAL GREEN TRIBUNAL
SOUTHERN ZONE, CHENNAI
OA No. 107 of 2023(SZ)**

IN THE MATTER OF

Tribunal on its own motion **Suo Motu**
based on the news item published in
The New Indian Express, dt. 09.08.2023,
under the caption "**Huge pollution risk
in 8 Km around NLC**" and in The Times
of India, Chennai Edition dt. 09.08.2023
under the caption "**Water near NLC full
of Mercury**".

Versus

The Managing Director
NLC India Limited,
Chennai and Ors.

...Respondents

INDEX

SL. NO	DATE	DESCRIPTION	PAGE NO
1.	24.02.2026	Report filed by the 6 th Respondent	1
2.	11.02.2026	Test report	4

Dated at Chennai on this 24th day of February 2026



Counsel For 6th Respondent


BEFORE THE NATIONAL GREEN TRIBUNAL
SOUTHERN ZONE, CHENNAI
Original Application No. 107 of 2023(SZ)

IN THE MATTER OF

Tribunal on its own motion Suo Motu
based on the news item published in
The New Indian Express, dt. 09.08.2023,
under the caption "Huge pollution risk
in 8 Km around NLC" and in The Times
of India, Chennai Edition dt. 09.08.2023
under the caption "Water near NLC full
of Mercury". ...Suo Motu

And

- 1) The Managing Director,
NLC India Limited,
No.135, EVR Periyar High Road,
Kilpauk, Chennai – 600 010.
- 2) Union of India Rep. by its Secretary Ministry
of Environment Forest and Climate Change,
Indira Paryavaran Bhawan Jorbag Road,
New Delhi – 110003, India
Secy-moef@nic.in
- 3) Additional Chief Secretary to Government,
Department of Environment, Climate Change
and Forests, Government of Tamil Nadu,
Secretariat, Chennai 600009.
- 4) Chairman, Central Pollution Control Board,
Parivesh Bhavan, East Arjun Nagar,
Delhi – 110032
Ccb.epcb@nic.in
- 5) Chairman,
Tamil Nadu Pollution Control Board,
No. 76, mount Salai,
Guindy, Chennai 600032
grievance@tnpcb.gov.in


EXECUTIVE ENGINEER (Veeranam)
C.M.W.S.S. Board
No.1 Pumping Station Road,
Chindadripet, Chennai - 600002


Superintending Engineer (WT & T)
CMWSS Board
No. 1, Pumping Station Road,
Chintadripet, Chennai-600 002.

- 6) Chennai Metropolitan Water Supply and Sewerage Board,
No.1, Pumping Station Road,
Chennai – 600002
md@cmwssb.in, dmwssb@tn.gov.in
- 7) Directorate of Public Health and
Preventive Medicine,
359, Anna Salai, DMS Complex, Teynampet,
Chennai 600006
Tamil Nadu. Dphpm.tn@nic.in
- 8) District Collector,
Gundu Salai Rd,
Alpet, Manjakuppam,
Cuddalore 607001,
collreud@nic.in
- 9) Department of Municipal Administration and
Water Supply,
Secretariat,
Chennai 600009,
Tamil Nadu.
mawssec@tn.gov.in
- 10) Tamil Nadu Water Supply and Drainage
Board (TWAD),
31, Kamarajar Salai,
Chepauk, Chennai -600005
twadho@gmail.com
- 11) Prabhakaran Veeraarasu,
No. 72, Anjugam nagar,
3rd Street, Jafferkhanpet,
Chennai – 600 083.... Respondent(s)

REPORT FILED BY THE 6th RESPONDENT

I, V. Siva Kumar, S/o.P. Varadharajan aged about 58 years, working as Superintending Engineer (WT&T), CMWSSB having office at No.1 Pumping Station Road, Chindatripet, Chennai 600002 do hereby solemnly affirm and sincerely state as follows:-


EXECUTIVE ENGINEER (Veeranam)
C.M.W.S.S. Board
No.1 Pumping Station Road,
Chindadripet, Chennai - 600002


Superintending Engineer (WT & T)
CMWSS Board
No. 1, Pumping Station Road,
Chintadripet, Chennai-600 002.

01. I am the Superintending Engineer (WT&T), CMWSSB of the 6th Respondent Board and filing this report on behalf of the 6th Respondent herein as I am well acquainted with the facts of the case.

02. I submit that CMWSSB is drawing surface water only from Veeranam lake and supplying to Chennai city after water treatment process at Vadakuthu. The treated water samples from the Vadakuthu Water Treatment Plant of CMWSSB were tested periodically at the NABL accredited and CPCB recognized Laboratory viz. M/s.Chennai Mettex Lab Private Ltd.,Guindy, Chennai, the same lab where the samples of NGO Poovulagin Nanbargal was tested for complete chemical and biological Analysis.Based on the test reports received from M/s.Chennai Mettex Lab Private Ltd, it was seen that the Mercury as Hg in tested treated water sample is **below detectable level of 0.0005 mg/l** as against the requirement (acceptable limit)of 0.001 mg/l (Max.) as per IS 10500/2012 and hence it is confirmed that the water supplied from the Vadakuthu Water Treatment Plant of CMWSSB in Cuddalore District to Chennai city meets the drinking water standards as per IS 10500/2012 and is safe. The lab test report is annexed herewith for kind perusal of this Hon'ble Tribunal.

It is therefore prayed that, this Hon'ble Tribunal may be pleased to accept the above response on behalf of the 6th Respondent and thus render Justice.

Solemnly affirmed at Chennai on this]
the 24th day of February, 2026 and]
signed his name in my presence]

Before me

S. Jobal
Ms. 6/24/2021

[Signature]
Superintending Engineer (WT & T)
CMWSS Board
No. 1, Pumping Station Road,
Chintadripet, Chennai-600 002.

[Signature]
EXECUTIVE ENGINEER (Veeranam)
C.M.W.S.S. Board
No.1 Pumping Station Road,
Chindadripet, Chennai - 600002



4

CHENNAI METTEX LAB PRIVATE LIMITED

Jothi Complex, 83, M.K.N. Road, Guindy, Chennai - 600 032, Tamil Nadu, INDIA
 Phone : +91 44 22323163, 22311034, 42179490, 42179491 | CIN : U74999TN2008PTC069459
 Email : test@mettexlab.com | Web : www.mettexlab.com

TC-5589

TEST REPORT

Page:1 of 3

ISSUED TO : **M/s. Executive Engineer/Veeranam (CMWSSB),**
 No : 180, MLD Water Treatment Plant,
 Vadakuthu,
 Cuddalore-607 303,Tamil Nadu, India.

Test Certificate No : CML/25-26/T114862
 Test Certificate Date : 11/02/2026
 Date of Receipt : 03/02/2026

Customer Reference : SRF Date : 03/02/2026

Analysis Commenced : 04/02/2026

Laboratory No : 2654531/001

Analysis Completed On : 09/02/2026

Sample Description : **Treated Water (UGT)**
 (as stated by customer) **Lat: 11.592732, Long: 79.553118.**

ULR : **TC558926000011970F**
 Sample Qty : 10 Ltr + 100ml (Microbiology Analysis)

Sample Collected By : M/s. Chennai Mettex Lab Representative.

S.No.	Test Parameters	Test Method	Units	Results	Limit as per IS: 10500:2012 (Reaff.2023) With Amendment No : 4 November 2021	
					Acceptable Limit (Max)	Permissible Limit in the absence of alternate source (Max)
Table 1 : Organoleptic and Physical Parameters						
Discipline :Chemical						Group: Water
1	Colour	IS: 3025 Part: 4 -2021	Hazen	5.0	5.0	15
2	Odour	IS: 3025 Part: 5-2018	-	Agreeable	Agreeable	Agreeable
3	pH at 25°C	IS 3025 Part 11 - 2022 (electrometric method)	-	7.35	6.5 - 8.5	No Relaxation
4	Turbidity	IS 3025 Part 10 - 2023	NTU	2.8	1.0	5.0
5	Total Dissolved Solids	IS 3025 Part 16 - 2023	mg/l	175	500	2000
Table 2 : General Parameters Concerning Substances Undesirable in Excess Amounts						
Discipline :Chemical						Group: Water & Residues in Water
6	Aluminium as Al	IS 3025 part 65 : 2022	mg/l	0.072	0.03	0.2
7	Ammonia (as total ammonia-N)	IS 3025 Part 34 -1988 (Nesslerization method)	mg/l	BDL(DL:0.01)	0.5	No Relaxation
8	Anionic surface active Agent (as MBAS)	IS 3025 Part 68 - 2019	mg/l	BDL(DL:0.01)	0.2	1.0
9	Barium as Ba	IS 3025 part 65 : 2022	mg/l	BDL(DL:0.05)	0.7	No Relaxation
10	Boron as B		mg/l	0.08	0.5	2.4
11	Calcium as Ca	IS 3025 Part 40 - 1991 (EDTA titrimetric method)	mg/l	14	75	200
12	Chloramines as Cl ₂	APHA 24th Edition 2023 - 4500 Cl -G	mg/l	BDL(DL:0.1)	4.0	No Relaxation
13	Chloride as Cl	IS 3025 Part 32 -1988 (Argentometric Method)	mg/l	33.1	250	1000
14	Copper as Cu	IS 3025 part 65 : 2022	mg/l	BDL(DL:0.02)	0.05	1.5
15	Fluoride as F	APHA 24th Edition 2023 - 4500 - F -D	mg/l	0.28	1.0	1.5
16	*Residual Free Chlorine	IS: 3025 Part 26-2021	mg/l	0.41	0.2 (Min)	1.0 (Min)
17	Iron as Fe	IS 3025 Part 53 -2003 (1, 10 phenanthroline method)	mg/l	0.33	1.0	No Relaxation
18	Magnesium as Mg	IS 3025 Part 46 - 2023	mg/l	6.8	30	100
19	Manganese as Mn	IS 3025 part 65 : 2022	mg/l	BDL(DL:0.02)	0.1	0.3
20	Mineral Oil	IS: 3025 Part 39-2021	mg/l	BDL(DL:0.01)	1.0	No Relaxation

[Signature]
 Reviewed & Authorized by:
P. KAVITHA
 Technical Manager
 Authorized Signatory

NOTE: Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders will be liable for legal action. Unless otherwise stated the submitted results in this test report refer only to the sample(s) tested and such sample(s) are retained for 15 days only from the completion date of testing... except in case of regulatory samples, which will be retained for a specific period as per statutory requirement; while perishable & environmental testing related remnant samples will be discarded consequent upon completion of testing. Samples are not drawn by us unless otherwise stated. This document cannot be reproduced except in full, without prior written approval of the laboratory. This report is for the exclusive use of Chennai Mettex Lab's customer, and is provided in accordance with the agreement between Chennai Mettex Lab and its Customer.

CML/LAB/F/7.8/1

CML/LAB/F/7.8/1



CHENNAI METTEX LAB PRIVATE LIMITED



TC-5589

Jothi Complex, 83, M.K.N. Road, Guindy, Chennai - 600 032, Tamil Nadu, INDIA
 Phone : +91 44 22323163, 22311034, 42179490, 42179491 | CIN : U74999TN2008PTC069459
 Email : test@mettexlab.com | Web : www.mettexlab.com

Test Certificate No : CML/25-26/T114862

Page:2 of 3

Test Certificate Date : 11/02/2026

ULR : TC55892600011970F

S.No.	Test Parameters	Test Method	Units	Results	Limit as per IS: 10500:2012 (Reaff.2023) With Amendment No : 4 November 2021	
					Acceptable Limit (Max)	Permissible Limit in the absence of alternate source (Max)
Discipline :Chemical				Group: Water & Residues in Water		
21	Nitrate as NO ₃	APHA 24th Edition 2023 - 4500 NO3 - B	mg/l	4.2	45	No Relaxation
22	Phenolic compounds as C ₆ H ₅ OH	IS 3025 Part 43/Sec 1 - 2022	mg/l	BDL(DL:0.0005)	0.001	0.002
23	Selenium as Se	IS 3025 part 65 : 2022	mg/l	BDL(DL:0.005)	0.01	No Relaxation
24	Silver as Ag		mg/l	BDL(DL:0.005)	0.1	No Relaxation
25	Sulphate as SO ₄	IS 3025 Part 24/Sec 1 - 2022	mg/l	35.7	200	400
26	Sulphide as H ₂ S	IS 3025 Part 29 - 2022	mg/l	BDL(DL:0.01)	0.05	No Relaxation
27	Total Alkalinity as CaCO ₃	IS 3025 Part 23 - 2023	mg/l	47.7	200	600
28	Total Hardness as CaCO ₃	IS 3025 Part 21 - 2009(EDTA titrimetric method)	mg/l	62.0	200	600
29	Zinc as Zn	IS 3025 part 65 : 2022	mg/l	BDL(DL:0.05)	5.0	15
Table 3 : Parameters Concerning Toxic Substances						
Discipline :Chemical				Group: Water & Residues in Water		
30	Cadmium as Cd	IS 3025 part 65 : 2022	mg/l	BDL(DL:0.001)	0.003	No Relaxation
31	Cyanide as CN	IS 3025 Part 27/Sec 1 -2021 (colorimetric method)	mg/l	BDL(DL:0.005)	0.05	No Relaxation
32	Lead as Pb	IS 3025 part 65 : 2022	mg/l	BDL(DL:0.005)	0.01	No Relaxation
33	Mercury as Hg	IS 3025 part-65: 2022	mg/l	BDL(DL:0.0005)	0.001	No Relaxation
34	Molybdenum as Mo	IS 3025 part 65 : 2022	mg/l	BDL(DL:0.02)	0.07	No Relaxation
35	Nickel as Ni		mg/l	BDL(DL:0.005)	0.02	No Relaxation
36	Poly Chlorinated Biphenyls (PCB)	APHA 24th Edition 2023 - 6431	mg/l	ND(DL:0.00001)	0.0005	No Relaxation
37	Poly Nuclear Aromatic hydrocarbons (PAH)	APHA 24th Edition 2023- 6440	mg/l	ND(DL:0.00001)	0.0001	No Relaxation
38	Total Arsenic as As	IS 3025 part 65 : 2022	mg/l	BDL(DL:0.005)	0.01	No Relaxation
39	Total Chromium as Cr		mg/l	BDL(DL:0.02)	0.05	No Relaxation
Trihalomethanes						
40	Bromoform	APHA 24th Edition 2023 - 6232	mg/l	ND(DL:0.00001)	0.1	No Relaxation
41	Dibromochloromethane		mg/l	ND(DL:0.00001)	0.1	No Relaxation
42	Bromodichloromethane		mg/l	ND(DL:0.00001)	0.06	No Relaxation
43	Chloroform		mg/l	ND(DL:0.00001)	0.2	No Relaxation
44	Uranium as U	IS 3025 part-65: 2022	mg/l	BDL(DL:0.001)	0.03	No Relaxation
Table 5 : Pesticide Residues Limits						
Discipline :Chemical				Group: Water & Residues in Water		
45	Alachlor	USEPA 525.2	µg/l	ND(DL:0.01)	-	20
46	Atrazine	USEPA 8141 A	µg/l	ND(DL:0.01)	-	2.0
47	Aldrin	USEPA 525.2	µg/l	ND(DL:0.01)	-	0.03
48	Dieldrin	USEPA 508.1	µg/l	ND(DL:0.01)	-	0.03
49	Alpha HCH		µg/l	ND(DL:0.01)	-	0.01
50	Beta HCH		µg/l	ND(DL:0.01)	-	0.04
51	Butachlor	USEPA 8141 A	µg/l	ND(DL:0.01)	-	125

Reviewed & Authorised by
P. KAVITHA
 Technical Manager
 Authorised Signatory

NOTE: Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders will be liable for legal action. Unless otherwise stated the submitted results in this test report refer only to the sample(s) tested and such sample(s) are retained for 15 days only from the completion date of testing, except in case of regulatory samples, which will be retained for a specific period as per statutory requirement; while perishable & environmental testing related remnant samples will be discarded consequent upon completion of testing. Samples are not drawn by us unless otherwise stated. This document cannot be reproduced except in full, without prior written approval of the laboratory. This report is for the exclusive use of Chennai Mettex Lab's customer, and is provided in accordance with the agreement between Chennai Mettex Lab and its Customer.

CML/LAB/F/7.8/1

CML/LAB/F/7.8/1



6

CHENNAI METTEX LAB PRIVATE LIMITED



Jothi Complex, 83, M.K.N. Road, Guindy, Chennai - 600 032, Tamil Nadu, INDIA
Phone : +91 44 22323163, 22311034, 42179490, 42179491 | CIN : U74999TN2008PTC069459
Email : test@mettexlab.com | Web : www.mettexlab.com

Test Certificate No : CML/25-26/T114862

Page:3 of 3

Test Certificate Date : 11/02/2026

ULR : TC558926000011970F

S.No.	Test Parameters	Test Method	Units	Results	Limit as per IS: 10500:2012 (Reaff:2023) With Amendment No: 4 November 2021	
					Acceptable Limit (Max)	Permissible Limit in the absence of alternate source (Max)
Discipline :Chemical					Group: Water & Residues in Water	
52	Chlorpyrifos	USEPA 525.2	µg/l	ND(DL:0.01)	-	30
53	Delta - BHC (HCH)	USEPA 508.1	µg/l	ND(DL:0.01)	-	0.04
54	2, 4-Dichlorophenoxy acetic acid	USEPA 515.1	µg/l	ND(DL:0.01)	-	30
55	O,P - DDT	USEPA 508.1	µg/l	ND(DL:0.01)	-	1.0
56	P,P - DDT		µg/l	ND(DL:0.01)	-	1.0
57	O,P - DDE		µg/l	ND(DL:0.01)	-	1.0
58	P,P - DDE		µg/l	ND(DL:0.01)	-	1.0
59	O,P - DDD		µg/l	ND(DL:0.01)	-	1.0
60	P,P - DDD		µg/l	ND(DL:0.01)	-	1.0
61	Alpha - Endosulfan		µg/l	ND(DL:0.01)	-	0.4
62	Beta - Endosulfan		µg/l	ND(DL:0.01)	-	0.4
63	Endosulfan sulphate	µg/l	ND(DL:0.01)	-	0.4	
64	Ethion	USEPA 1657 A	µg/l	ND(DL:0.01)	-	3.0
65	Gamma HCH (Lindane)	USEPA 508.1	µg/l	ND(DL:0.01)	-	2.0
66	Isoproturon	USEPA 532	µg/l	ND(DL:0.01)	-	9.0
67	Malathion	USEPA 8141 A	µg/l	ND(DL:0.01)	-	190
68	Methyl parathion		µg/l	ND(DL:0.01)	-	0.3
69	Monochrotophos		µg/l	ND(DL:0.01)	-	1.0
70	Phorate		µg/l	ND(DL:0.01)	-	2.0
Table 6 : Bacteriological Quality of Drinking Water						
Discipline :Biological					Group: Water	
71	<i>Escherichia coli</i>	IS 15185 - 2016 (Reaff.2021)	-	Absent/100 ml	Shall not be detectable in any 100ml sample	Shall not be detectable in any 100ml sample
72	Total Coliform		-	Absent/100 ml	Shall not be detectable in any 100ml sample	Shall not be detectable in any 100ml sample
<p>Note: The above water sample Complies with Permissible limits of drinking water specification as per IS: 10500:2012(Reaff:2023) With Amendment No: 4 November 2021 with respect to above parameters tested. * To be applicable only when water is chlorinated. Abbreviation: ND - Not Detected, BDL: Below Detection Limit; DL: Detection Limit</p>						

Reviewed & Authorised by
G.S. RADHA
Technical Manager
Authorised Signatory

.....End of Report.....



For Chennai Mettex Lab Private Limited

Reviewed & Authorised by
P. KAVITHA
Technical Manager
Authorised Signatory



NOTE: Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders will be liable for legal action. Unless otherwise stated the submitted results in this test report refer only to the sample(s) tested and such sample(s) are retained for 15 days only from the completion date of testing, except in case of regulatory samples, which will be retained for a specific period as per statutory requirement; while perishable & environmental testing related remnant samples will be discarded consequent upon completion of testing. Samples are not drawn by us unless otherwise stated. This document cannot be reproduced except in full, without prior written approval of the laboratory. This report is for the exclusive use of Chennai Mettex Lab's customer, and is provided in accordance with the agreement between Chennai Mettex Lab and its Customer.



CHENNAI METTEX LAB PRIVATE LIMITED[®]

Jothi Complex, 83, M.K.N. Road, Guindy, Chennai - 600 032, Tamil Nadu, INDIA
 Phone : +91 44 22323163, 22311034, 42179490, 42179491 | CIN : U74999TN2008PTC069459
 Email : test@mettexlab.com | Web : www.mettexlab.com



TC-5589



TEST REPORT

Page:1 of 1

ISSUED TO : **M/s. Executive Engineer/Veeranam (CMWSSB),**
 No : 180, MLD Water Treatment Plant,
 Vadakuthu,
 Cuddalore, 607 303, Tamil Nadu, India.

Test Certificate No : CML/25-26/T114942
 Test Certificate Date : 12/02/2026

Date of Receipt : 03/02/2026

Customer Reference : SRF Date : 03/02/2026

Analysis Commenced On : 04/02/2026

Laboratory No : 2654531/002

Analysis Completed On : 11/02/2026

ULR No : TC558926000012039F

Sample Description : **Raw Water.**
 (as stated by customer)

S.No.	Test Parameters	Test Method	Units	Results
Discipline : Chemical				Group : Water
1	Turbidity	IS 3025 Part 10 - 2023	NTU	6.70
2	pH at 25°C	IS 3025 Part 11 - 2022 (electrometric method)	NA	7.80
3	Total Hardness as CaCO ₃	IS 3025 Part 21 - 2009(EDTA titrimetric method)	mg/l	174
4	Total Organic Carbon	APHA 24th Edition 2023 - 5310 B	mg/l	11.60
5	Total Suspended Solids	IS 3025 Part 17 - 2022	mg/l	24
6	Chemical Oxygen Demand	IS 3025 Part 58-2023	mg/l	41
7	Total Dissolved Solids	IS 3025 Part 16 - 2023	mg/l	478
8	Total Nitrogen as N	IS 3025 Part 73 - 2021	mg/l	14.30
9	Residual Free Chlorine	IS: 3025 Part 26-2021	mg/l	BDL(DL:0.1)

Abbreviation: BDL: Below Detection Limit; DL: Detection Limit.

.....End of Report.....



For Chennai Mettex Lab Private Limited

Reviewed & Authorised by
P. KAVITHA
 Technical Manager
 Authorised Signatory

NOTE: Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders will be liable for legal action. Unless otherwise stated the submitted results in this test report refer only to the sample(s) tested and such sample(s) are retained for 15 days only from the completion date of testing, except in case of regulatory samples, which will be retained for a specific period as per statutory requirement; while perishable & environmental testing related remnant samples will be discarded consequent upon completion of testing. Samples are not drawn by us unless otherwise stated. This document cannot be reproduced except in full, without prior written approval of the laboratory. This report is for the exclusive use of Chennai Mettex Lab's customer, and is provided in accordance with the agreement between Chennai Mettex Lab and its Customer.

**BEFORE THE HON'BLE NATIONAL GREEN TRIBUNAL
SOUTHERN ZONE, CHENNAI
OA No. 107 of 2023(SZ)**

IN THE MATTER OF

Tribunal on its own motion **Suo Motu**
based on the news item published in
The New Indian Express, dt. 09.08.2023,
under the caption "**Huge pollution risk
in 8 Km around NLC**" and in The Times
of India, Chennai Edition dt. 09.08.2023
under the caption "**Water near NLC full
of Mercury**".

Versus

The Managing Director
NLC India Limited,
Chennai and Ors.

...Respondents

REPORT FILED BY THE 6TH RESPONDENT



THROUGH
M/S. GAUTAM S. RAMAN
COUNSEL FOR 6TH RESPONDENT