

**BEFORE THE NATIONAL GREEN TRIBUNAL,
SOUTH ZONE, CHENNAI**

Original OA No. 16 of 2022 (SZ)

Between:

Dr. Lubna Sarwath,
Environmental worker and Social Worker,
State President, WICCI-Water Resources Council,
H#12-2-389/A/72/A, Mahaveer Nagar
Karwan Sahu, Hyderabad 500006,
Telangana State.

.....Applicant

And

The Chief Secretary to Government of Telangana,
Hyderabad, Telangana and ors

...Respondent(s)

REPORT FILED BY THE HMWSSB (RESPONDENT No. 5)

Mrs. H. YASMEEN ALI,

H. Yasmeen Ali

COUNSEL FOR THE 5th RESPONDENT

1

**BEFORE THE NATIONAL GREEN TRIBUNAL,
SOUTH ZONE, CHENNAI.**

Original OA No. 16 of 2022 (SZ)

Between:

Dr. Lubna Sarwath,
Environmental worker and Social Worker,
State President, WICCI-Water Resources Council,
H#12-2-389/A/72/A, Mahaveer Nagar
Karwan Sahu, Hyderabad 500006,
Telangana State.

.....Applicant

And

The Chief Secretary to Government of Telangana,
Hyderabad, Telangana and others

....Respondent(s)

REPORT FILED BY THE HMWSSB (RESPONDENT No.5)

1. The Hon'ble National Green Tribunal, OA. No. 16 of 2022 (SZ) filed by Dr. Lubna Sarwath V/s. The Chief Secretary to Government of Telangana, Hyderabad, Telangana and others, regarding saving of Bum-Rukn-Ud-Doula Lake, Rajendra Nagar Circle, R.R District, Hyderabad urban.


GENERAL MANAGER(ENGG)
STP CIRCLE-I, HMWS&SB
KHAJRATABAD, HYDERABAD-500004.

2. It is to submit that the Hon'ble NGT in O.A. No. 16 of 2022 (SZ) has issued orders on the subject, from time to time, with reference to the Joint Inspection Report submitted by the TSPCB. As per the Report the following, *inter-alia*, are submitted by the Committee.

(i) GHMC has laid 2 diversion pipelines to divert the sewage of Rasheed Colony, Kings Colony and Raghavendra colony which are in the vicinity of the lake and around 0.5 MLD of Sewage was generated from these colonies. Presently GHMC has laid diversion channel of length 340 Mtrs (32 manhole chambers) and the entire sewage entering the Bum-Rukm-Ud-Doula Lake is diverted into Miralam Tank STP of Capacity 10 MLD.

(ii) The STP is already receiving 9.3 to 9.8 MLD sewage from surrounding residential area and can barely take further load. Hence sewage diverted from Bum-Rukm-Ud-Dowla Lake is sometimes discharged into Miralam Tank without any treatment. Another STP of 11.5 MLD is sanctioned by the Government to treat the further load of sewage generated by the surrounding


CHIEF GENERAL MANAGER(ENGG)
STP CIRCLE-I, HMWS&SB
KHAIRATABAD, HYDERABAD-500004.

areas. It is further to submitted that 340 m of diversion channel and 32 manhole chambers are located with FTL boundary of the Lake.

3. It is submitted that prior to September, 2021, the Sewerage Management was under the purview of GHMC. However, the maintenance of sewerage network in the peripheral circles was handed over to HMWSSB from GHMC vide G.O.Rt.No. 667, dated 18.09.2021 of MA & UD (GHMC-II) Department.
4. Presently 10 MLD STP at Miralam, sewer is being received from two trunk mains i.e. 600mm dia RCC Main of Ansari Road and 1600mm dia RCC Main of Hasan Nagar (Old 450 dia Hasan Nagar, & Raghavendra colony connected to 1600 dia). To treat the excess sewage water which comes from upstream of the Miralam Tank and surrounding areas, HMWSSB has successfully completed and commissioned 41.5 MLD STP at Miralm Tank instead of 11.5 MLD vide GO Rt.No.669, dated: 22.09.2021 of MA&UD (Engg) Department and also informed that there is no sewer flow into the above Lake as


CHIEF GENERAL MANAGER(ENGG)
STP CIRCLE-I, HMWS&SB
KHAIRATABAD, HYDERABAD-500004.

reported by the field officers. The IIMWSSB will take necessary care of preventing any flow of domestic sewage into Bum-Rukm-Ud-Doula Lake.

5. This is the submission of the Report before the Hon'ble National Green Tribunal.

Date: June, 2024,
Place: Hyderabad.



Chief General Manager (Engg),
STP Circle - I
HMWSSB, Hyderabad.
CHIEF GENERAL MANAGER (ENGG)
STP CIRCLE-I, HMWSSB
HYDERABAD, HYDERABAD DISTRICT