

**HP STATE POLLUTION CONTROL BOARD,
BELOW BCS, PHASE-III, NEW SHIMLA**

No. HPPCB/ OA No. 801/2018 /- 9403

Dated: 01-10-2021

From: The Member Secretary

To

✓ The Registrar General,
Hon'ble National Green Tribunal, Copernicus Marg,
New Delhi

Subject:- Report of the Joint Committee in compliance to order dated 23-6-2021 passed by Hon'ble NGT in OA No. 801/2018 titled Jasmeet Singh V/s State of HP & others.

Sir,


This has reference to order dated 23-06-2021 passed by Hon'ble NGT in the afore-cited matter related to non-compliance of CETP Baddi wherein following directions have been passed :-

".....7. Accordingly, let further remedial action be taken to enforce the environmental rule of law in the interest of protection of environment and public health and a report of status of compliance filed after inspection by a four Member joint Committee comprising a representative of MoEF&CC, CPCB, State PCB and District Magistrate, Solan by e-mail at judicial-ngt@gov.in preferably in the form of searchable PDF/ OCR Support PDF and not in the form of Image PDF. The State PCB will be the nodal agency for coordination and compliance. List for further consideration on 05.10.2021....."

In compliance to afore-cited order dated 23-6-2021, the Joint Committee comprising of representatives of MoEF &CC, Govt of India, CPCB, HPSPCB and District Magistrate Solan conducted field visit and collected various samples on 6th - 7th September, 2021. The copy of progress report submitted by the Joint Committee is annexed as **Annexure-A** which may kindly be placed on record please.

(Encl. As above)

↓
Apoorv Devgan (IAS)
Member Secretary
HPSPCB Shimla



No. HPSPCB/ O.A. No.801/2018-Jasmeet Singh Vs State of HP & Ors./2021-²²⁰¹⁻⁰²

Dated: 30-09-2021

To

The Member Secretary,
 H.P. State Pollution Control Board,
 HIM Parivesh, Phase-III, New Shimla-171009.

Subject: Regarding Progress Report of the Joint Committee in compliance to the directions of Hon'ble National Green Tribunal orders passed in OA No.801/2018 titled Jasmeet Singh Vs State of HP & Ors.

Sir,

Kindly refer to your office letter No. PCB/OA No.136/2020/Consent/2021-6650-51 dated 26.08.2021 on the subject cited above. In this context, please find enclosed herewith the Progress Report of the Joint Committee in compliance to the directions of Hon'ble NGT passed in OA No.801/2018 titled Jasmeet Singh Vs State of HP & Ors.

This is for kind information and necessary action please.


Yours faithfully,

Encl: As Above.


Chief Environmental Engineer,
 HP State Pollution Control Board.
 Baddi, Distt. Solan-173205.

Copy forwarded to:

1. The Sr. Law Officer, HP State Pollution Control Board, Shimla for information.


Chief Environmental Engineer,
 HP State Pollution Control Board.
 Baddi, Distt. Solan-173205.

Report of the Joint Committee in compliance to NGT Orders dated 23.6.2021 in the matter of OA 801/2018; Jasmeet Singh v/s State of HP

1. Background

The issue for consideration in the matter of OA 801/2018 titled Jasmeet Singh v/s State of HP is the remedial action against pollution of River Balad in Baddi industrial area in District Solan, on account of leakage from the Common Effluent Treatment Plant (CETP).

In the last report filed by State PCB on dated 06.05.2021, followed by further report dated 16.06.2021, it was submitted that

- “
- i. *The latest sample taken on 21-5-2021 and 7-6-2021 has been found within the prescribed limits w.r.t. FDS as the same has been reduced to the 2019 mg/ltr and 2072 mg/ltr respectively. The sampling chart of the CETP Baddi is annexed as Annexure —A which reveals that there is continuous improvement and now the analysis results of latest sample taken are meeting the norms w.r.t. FDS.*
 - ii. *As regard to the issue of industries having effluent generation of more than 200 KLD, the State Board had identified and issued directions to 16 numbers of industries to operate their treatment plants i.e. primary, secondary and tertiary treatment system for the effluent treatment as per Environment Conditions of CETP and also directed to recycle / reuse to the maximum extent and also to reduce the FDS.*
 - iii. *Now as per report received from the Regional Office Baddi, these 16 units are operating the effluent treatment plants prior to their effluent discharge to CETP. The State Board has conducted inspection and sampling of these 16 units. The earlier results of sampling conducted on 21-1- 2021, 29-1-2021, 1- 3-2021, 23-3-2021 and 16-4-2021, were found within limits (except of three units of M/s Vardhman and one unit of Winsome Textile) which has already been placed on record along with interim report dated 6-5-2021.*

aliso


W

W

- iv. However, the latest results of sampling conducted on 21-5-2021 the results of three units namely M/s P&G Home Products Baddi, M/s Torrent Pharmaceutical Ltd. Baddi and M/s Abbott Health care, Baddi were found above the prescribed limits for which notices dated 16-6-2021 has been issued to these units. Copy of sample results and notices issued are annexed as Annexure-B and Annexure-C (colly).
- v. The sample results of other units were found within the prescribed limits. It is further submitted that as reported by Regional Officer, Baddi the member industries having flow less than 200 KLD are disposing off their effluent to CETP, Baddi after primary treatment.
- vi. As regard to the compliance by the four textile units namely Auro Textile, Auro Textile unit - II, Auro Dyeing of Vardhman Textile and one unit of Winsome Textile, it is submitted that as per report received from the Regional Office, Baddi, the work of installation of advance treatment system by M/s Vardhman textile to reduce FDS is under progress and Reverse Osmosis system of capacity of 2 MLD shall be operational by 30-6-2021. In addition to Reverse Osmosis, M/s Vardhman Textile is also installing the Multi Effect Evaporator of capacity of 370 KLD.
- vii. As regard to progress of installation of advance treatment system by M/s Winsome Textile it is submitted that as per report received from Regional Office, Baddi the unit has completed the civil construction work. The installation of Reverse Osmosis system and other components is under progress.
- viii. The latest sample results of these four textile units are still not meeting the norms. Sample results are annexed as Annexure-F. As already submitted in interim progress report dated 6-5-2021, it is again submitted here that State Board had issued directions on 1-1-2021 to these four textile units under section 33-A of Water Act, 1974 for closure and levied Environmental Compensation which were challenged by these units before the Hon'ble High Court of HP vide CWP No.

above





414/2021, 416/2021 417/2021 and 418/2021. The Hon'ble High Court of HP vide order dated 11-1-2021 and 15-3-2021 has stayed the operation of the directions issued by the State Board and the matter is still pending before the Hon'ble High Court of Himachal Pradesh for adjudication.

- ix. The two consecutive latest samples of CETP outlet are meeting the norms prescribed by the MoEF &CC vide notification dated 1-1-2016. In future, the State Board shall continue to make all efforts in form of surveillance, regular monitoring and regulation on the CETP and member industries, so that the CETP remains compliant in future as well.....”

Further In view of above report submitted the Hon'ble NGT on dated 23/6/2021 passed following orders:

“From the above, it is clear that violations are still continuing. Stay of order of closure and assessment of compensation for the past violations does not justify inaction for failure to take action for further violations after the order of stay and to initiate prosecution of the industrial units in question, including their Owners/Directors and the CETP operators. We also find that merely keeping an eye on units discharging more than 200 KLD is not enough. Violation by those discharging less than 200 KLD is not less serious violation nor less harmful for the environment and public health.”


“Accordingly, let further remedial action be taken to enforce the environmental rule of law in the interest of protection of environment and public health and a report of status of compliance filed after inspection by a four Member joint Committee comprising a representative of MoEF&CC, CPCB, State PCB and District Magistrate, Solan.”

2.0. Submission of the Joint Committee:

i) In compliance to NGT Orders in the above matter, the joint committee comprising of the following members was constituted by the State Pollution Control Board based on the nomination received from the Central pollution Control Board, Deputy Commissioner Solan and MOEF&CC. The nomination from MOEF&CC was received on 24.08.2021

aliso

LD



- Sh. Mahendra Pal Gurjar, IAS, Sub-Divisional Magistrate, Nalagarh, Solan (Member nominated by District Magistrate, Solan)
- Dr. Narender Sharma, Additional Director, CPCB Regional Directorate, Chandigarh (Nominated by CPCB).
- Sh. P. C. Gupta, Regional Officer, HPSPCB, Baddi (Nominated by HPPCB)
- Smt. Nisha Limba, Assistant Director, IRO, MoEF&CC Shimla (Nominated by MoEF&CC)

ii) In view of the fact that Joint Committee was constituted after two months of passing the orders, the Joint Committee could get only around one month's time to comply with the directions, against the three months' time granted by Hon'ble National Green Tribunal in its order.


iii) The category-wise and sector wise details of the industries alongwith Volume and mode of effluent discharge located in catchment of CETP Baddi is **Annexed as Annexure-1**

iv) The Joint committee conducted the field visit and collected various samples on 06th September, 2021 and 07th September, 2021

v) The analysis of the sample of CETP discharge at River Sirsa (**Annexure-2**) indicates the compliance of prescribed parameters. However, in view of the fact that it was observed by the earlier Joint Committee in the report dated 6/11/19 that "While collecting the sample from the final outlet of tertiary clarifier and discharge point at River Sirsa, difference in colour of effluent was observed. The sample collected from the discharge point was lighter in colour than that of outlet of tertiary clarifier; giving rise to possibility of dilution." Therefore, in view of the above observation made earlier by the Joint Committee confirmation of the compliance of prescribed norms by taking samples of treated effluent from the tertiary clarifies and other stages of CETP by the joint committee, is further required.

above

4



vi) The analysis results of primary treated Category-I effluent (Discharged to CETP for further treatment) from M/s Vardhman Textiles Limited (Auro Textile-I, Auro Textile-II & Auro Dyeing-I) is complying to CETP inlet Norms. The unit M/s Vardhman Textiles Limited has stopped discharging CAT-IV effluent to CETP and now all the effluent after tertiary treatment is recycled in the plant. The Category-I effluent discharged to CETP after primary treatment from M/s Winsome Textile Limited is complying with CETP inlet norms & category-IV effluent discharged from unit is still not complying with CETP inlet norms. The analysis reports are **annexed as Annexure-3**. The Hon'ble High Court vide CWP No. 417 of 2021 have stayed the action taken by the State Board under section 33 A of Water Act, 1974.

In this regard, as mentioned earlier in the report filed by the Joint Committee in the matter of 136/2020 related to the same area, the industries generating more than 200 KLD effluent are required to fully treat the effluent, before routing the same to CETP, for discharging into the Sirsa River, as per terms of Environmental Clearance granted to CETP by the Ministry of Environment, Forest and Climate Change.

vii) M/s Vardhman Textiles Limited and M/s Winsome textiles Limited, have installed the tertiary treatment system comprising of RO and MEE installed for Category-IV and it was verified by the Joint Committee. The System installed by M/s Vardhman textiles limited was found to be operational, whereas, the system installed by M/s winsome textiles Limited was found to be under trial run for commissioning. Treatment in the RO and MEE seemed to help the CETP meet the discharge norms of FDS/TDS as indicated in the analysis results of the sample collected from the discharge point at Sirsa.

viii) The detail w.r.t category wise, Sector wise effluent volume wise compliance along with date of samples collection, of the industries located in the catchment of CETP Baddi based on the inspections done by HPPCB along with analysis results is Annexed as **Annexure-4**. Further no action was initiated against the units which are non-complying to CETP inlet norms as the Hon'ble High Court of HP has issued directions to the SPCB not to take coercive action against the petitioner qua violation of notification dated 26.12.2019 in CWP No. 4961/2021 dated 01.09.2021.

above

42




HPPCB provided a report on the remedial action taken by State PCB to the Joint Committee, which is attached herewith as **Annexure-5**, for the consideration of Hon'ble National Green Tribunal.

Prayer:

In view of the fact that the Joint Committee could get only one month's time for the compliance of the directions of Hon'ble National Green Tribunal for the reasons explained in the above submission at 2.0 of the report, against the timeline of three months granted by Hon'ble NGT it is humbly prayed that the above report of **the progress made by the Joint Committee may kindly be considered** by the Hon'ble National Green Tribunal and extension of timeline for two months i.e. upto 30/11/2021 may kindly be granted for submission of the final report by the Joint Committee.

The Joint Committee will abide by further directions of Hon'ble National Green Tribunal.



Ms Nisha Limba,
MoEF&CC, IRO
Shimla



P.C. Gupta,
HPPCB, Baddi

On tour

Dr. Narender Sharma
CPCB, Chandigarh



Mahendra Pal Gurjar, IAS
Distt. Admn, Solan

Dated: 30/09/2021

(Annexure -I)

S.No.	Industry name	Status	Flow as per consent	Type	Cat.	Conveyance System
1	Auro Dying -4	Operational	4660	Textile	CAT 4	Pipe line
	Auro Dying -1	operational		Textile	CAT 1	
2	Auro Spinning Mills	CLOSED		Sewage	CAT 1	
3	Arisht Spining Mills	CLOSED		Sewage	CAT 1	
4	Auro Textile -I	operational	3700	Textile	CAT 1	Pipe line
	Auro Textile -4	operational		Textile	CAT 4	
5	Auro Textile Unit-2	operational	2500	Textile	CAT 1	Pipe line
6	Master Builders Solutions India Pvt Ltd(BASF India Ltd.)	operational	2	Chemical	CAT 2	Tanker
7	Bhandari Deepak	Closed	1000 (Closed)	Paper	CAT 1	Pipe line
8	Birla Textile	operational	600	Textile	CAT 1	Pipe line
9	Colgate palmolive Ltd.	operational	80	Soap & Detergent	CAT 2	Pipe line
10	Deepak Spinner	operational	800	Textile	CAT 1	Pipe line
11	DP Chocolate	operational	19.5	Food	CAT 1	Pipe line
12	D.P. Cocoa	operational	10	Food	CAT 1	Pipe line
13	Amico Textiles	Closed	7	Soap & Detergent	CAT 2	Tanker
14	Enviro Enterprises	operational	10	Misc.	CAT 5	Tanker
15	Godrej Products Ltd.-I-katha	operational	25	Soap & Detergent	CAT 2	Pipe line
16	Godrej Products Ltd.-II-thana	operational	12	Soap & Detergent	CAT 2	Tanker
17	Hygienic Research Ltd.-II	operational	10	Soap & Detergent	CAT 2	Tanker
18	Kandhari Beverages	operational	505	Food	CAT 1	Pipe line
19	Legacy Food	operational	40	Food	CAT 1	Pipe line
20	Loreal Ltd	operational	100	Soap & Detergent	CAT 2	Pipe line
21	Mondlez Ltd-I	operational	792	Food	CAT 1	Pipe line
22	Mondlez Ltd-II	operational		Food	CAT 1	Pipe line
23	Auro Dying -II	operational	1050	Textile	CAT 1	Pipe line
24	Winsome Textile-1	operational	4440	Textile	CAT 1	Pipe line
	Winsome Textile-4	operational		Textile	CAT 4	
25	Naxpar	operational	100	Soap & Detergent	CAT 2	Tanker
26	Wrigley	operational	80	Food	CAT 1	Pipe line
27	R M Chemicals-II	operational	20	Soap & Detergent	CAT 2	Pipe line
28	Jupiter solar power Ltd	operational	48	Misc.	CAT 2	Tanker/Pipe line
29	Penguin Electronics Ltd.	operational	5	STP	CAT 1	Tanker
30	Celebrity Biopharma Ltd	operational	20	STP	CAT 1	Pipe line
31	Gillete	operational	50	STP	CAT 1	Pipe line

10 W

32	Gogia Flavour & Frangrances (p) Ltd	operational	1	Chemical	CAT 2	Tanker
33	Axiom Control Ltd.	operational	3	Chemical	CAT 2	Tanker
34	Yodeva Plastics Pvt. Ltd.9Alpa India Pvt. Ltd. (UNIT-III) name change	operational	20	Chemical	CAT 2	Tanker
35	Nirmaya Pharmaceutical Pvt Ltd	operational	10	Pharma	CAT 3	Tanker
36	JSK International	operational	4.5	STP	CAT 1	Tanker
37	ION HealthCare P. Ltd.	operational	6	Pharma	CAT 3	Pipe line
38	Kunal Alluminium	operational	25	STP	CAT 1	Pipe line
39	Grindwell Norton Ltd.	operational	30	Chemical	CAT 2	Tanker
40	Groupe Seb India Pvt. Ltd(Maharaja)	operational	2	STP	CAT 1	Tanker
41	Eastman Auto Power Ltd	operational	35	Misc.	Cat.5	Tanker
42	Maneesh Pharmaceuticals Ltd	operational	5	Pharma	Cat 3	Tanker
43	Helios Pharmaceuticals Ltd.	operational	25	Pharma	Cat 3	Pipe line
44	VVF India Ltd.	operational	169	Soap & Detergent	CAT 2	Pipe line
45	Hygienic Research Ltd.-I	operational	5	Soap & Detergent	CAT 2	Tanker
46	Comed Chemicals Ltd.	operational	7.5	Pharma	Cat 3	Pipe line
47	MDC Pharma Unit-II	operational	10	Pharma	Cat 3	Tanker
48	MDC Pharma Unit-III	operational	5	Pharma	Cat 3	Tanker
49	Johnson & Johnson Ltd UNIT II.	operational	100	Soap & Detergent	Cat 2	Pipe line
50	Morepen Laboratories Ltd	operational	60	Pharma	Cat 3	Tanker
51	C&E Ltd -I	operational	2.7	Chemical	CAT 2	Tanker
52	C & E Ltd -ii	operational		Chemical	CAT 2	Tanker
53	Galpha Laboratories Ltd -I	operational	31	Pharma	Cat 3	Tanker
54	Galpha Laboratories Ltd -II	operational	10	Pharma	Cat 3	Tanker
55	Maya Biotech Pvt. Ltd.	operational	6	Pharma	Cat 3	Tanker
56	Alkem Laboratory Ltd -I	operational	120	Pharma	Cat 3	Tanker
57	Alkem Laboratory Ltd -II	operational	22	Pharma	Cat 3	Tanker
58	Nikvin Healthcare (I) Ltd	operational	2	Pharma	Cat 3	Tanker
59	Cachet Pharmaceuticals (p) Ltd.	operational	18	Pharma	Cat 3	Tanker
60	Hetro Labs Limited -I	operational	28	Pharma	Cat 3	Tanker
61	Hetro Labs Limited -II	operational	8.5	Pharma	Cat 3	Tanker
62	Vaishanvi Koshmeticos (P) Ltd.	operational	14	Soap & Detergent	Cat 2	Tanker
63	pidilite industries ltd (Dharampur)	operational	6.2	Misc.	Cat 2	Tanker
64	Unispeed Pharmaceuticals Pvt. Ltd.	operational	5	Pharma	Cat 3	Tanker
65	Samson Laboratories Pvt. Ltd.	operational	2	Pharma	Cat 3	Tanker
66	Aroma Aromatics	operational	1.5	Soap & Detergent	Cat 2	Tanker

12 4

67	pidillite industries ltd (Bhatolikalan)	operational	2.5	Misc.	Cat 2	Tanker
68	Sylvan Green Pvt. Ltd	operational	32.4	Paper	Cat-1	Pipe line
69	Ancorotti Cosmetics India (P) Ltd	operational	5	Soap & Detergent	Cat 2	Tanker
70	R M Chemicals-I	operational	15	Soap & Detergent	Cat 2	Pipe line
72	USV Pharma -I	operational	30	Pharma	Cat 3	Pipe line
73	USV Pharma- II	operational	100	Pharma	Cat 3	Pipe line
74	Heal Kraft Pharma	operational	5	Pharma	Cat 3	Tanker
75	Bakelite Hylam Laminates	Closed	11.5	Paper	Cat-1	Tanker
76	Indchemie Health Specialities Pvt. Ltd.	operational	7.5	Pharma	Cat 3	Tanker
77	Universal Twin Lab	operational	7.5	Pharma	Cat 3	Tanker
78	Nector Lifesciences Ltd. vi	operational	50	Pharma	Cat 3	Pipe line
79	Dr. Sabarbal	operational	3	Pharma	Cat 3	Tanker
80	Nector Lifesciences Ltd. VII	operational	15	Pharma	Cat 3	Pipe line
81	Royal Park Hotel	operational	20	Sewage	Cat 1	Tanker
82	Him Engineers (India) P. Ltd.	Closed	10	Sewage	Cat 1	Tanker
83	Grauer & Wells India Ltd.	operational	3	Misc	Cat-2	Tanker
84	Faiveley Transport Rail Technologies (i)L	operational	15	Misc.	Cat-2	Tanker
85	Aishwarya Healthcare	operational	7	Pharma	Cat 3	Tanker
86	All kind health care -III	operational	120	Pharma	Cat 3	Tanker
87	Martin & Brown Bio-Sciences	operational	14.5	Pharma	Cat 3	Tanker
88	Fresenius Kabi Oncology Limited	operational	10	Pharma	Cat 3	Tanker
89	Appasamy Ocular Devices (P) Ltd.	operational	4	Pharma	Cat 3	Pipe line
90	Adley Formulation	operational	4	Pharma	Cat 3	Tanker
91	Pioneer Pesticides Pvt. Ltd.	operational	3.5	Chemical	Cat -2	Tanker
92	D M Pharma	operational	3	Pharma	Cat 3	Pipe line
93	Amster Labs	operational	2	Pharma	Cat 3	Tanker
94	FDC Ltd.	operational	37.5	Pharma	Cat 3	Pipe line
95	Unix Biotech	operational	10	Pharma	Cat 3	Pipe line
96	Raghav Lifestyle Products -II	operational	8	Pharma	Cat 3	Tanker
97	A.H.Enterprises	operational	5	Misc.	Cat-5	Tanker
98	Wipro Enterprises Unit -I (77) Jharmajri	operational	50	Soap & Detergent	Cat 2	Pipe line
99	Wipro Enterprises Unit -katha	Closed	18	Sewage	Cat 1	Pipe line
100	Wipro Enterprises Unit-II (87)Kunjahal	operational	20	Soap & Detergent	Cat 2	Pipe line
101	NiCkunj EDM WIRES & Consumables p.Ltd	operational	10	Misc.	Cat 5	Tanker
102	Transasia Bio Madicals	operational	2	Pharma	Cat 3	Tanker
103	Aristo Pharmaceuticals Pvt. Ltd.	operational	185	Pharma	Cat 3	Pipe line
104	Teshna Tech. Pvt. Ltd.	operational	2.5	Sewage	Cat 1	Tanker

12

105	Aristo Laboratories Ltd.	operational	73	Pharma	Cat 3	Pipe line
106	Yash Appliances	operational	7.5	Misc.	Cat-2	Tanker
107	Cadila Healthcare Ltd.	operational	85	Pharma	Cat 3	Pipe line
108	All kind health care	operational	5	Pharma	Cat 3	Tanker
109	Dr. Ready Laboratories Ltd. Unti-8	operational	180	Pharma	Cat 3	Tanker
110	Dr. Ready Laboratories Ltd. Unti-6	operational	135	Pharma	Cat 3	Tanker
111	Saar Biotech	operational	4.8	Pharma	Cat 3	Pipe line
112	Svizera Health Remedies Pvt. Ltd.(maneesh Pharma)	Closed	5 (closed)	Pharma	Cat 3	Tanker
113	Ayurved Limited	operational	40	Pharma	Cat 3	Pipe line
114	United Spirits Ltd. (Closed)	Closed	10 (closed)	Food	Cat 1	Tanker
115	Charak Pharma Pvt. Ltd.	operational	8	Pharma	Cat 3	Pipe line
116	Secure meter-II	operational	10	Sewage	Cat 1	Tanker
117	Secure meter-III	Closed	10 (closed)	Sewage	Cat 1	Tanker
118	Viown Mettube (P) Ltd.	operational	3.6	Misc.	Cat 5	Tanker
119	BRD Medilabs -Unit-II	operational	5	Pharma	Cat 3	Tanker
120	Sarvotam Remedies Ltd.	operational	15	Pharma	Cat 3	Pipe line
121	Alpla India Pvt. Ltd.	operational	4	Pharma	Cat 3	Tanker
122	Pearl Polimers Ltd	operational	10	Sewage	Cat 1	Tanker
123	Aqua Vitoe Laboratories	operational	20	Pharma	Cat 3	Pipe line
124	Aspee Spring Limited	operational	15	Sewage	Cat 1	Tanker
125	Sarvotham Care -I	operational	10	Soap & Detergent	Cat 2	Pipe line
126	Sarvotham Care limited -II	operational	15	Soap & Detergent	Cat 2	Pipe line
127	Shree Cosmetics Ltd.	operational	8	Soap & Detergent	Cat 2	Pipe line
128	Johnson & Johnson Ltd. Jharmajri	Closed	8	Pharma	Cat 3	Pipe line
129	Betts India Pvt. Ltd	operational	10	Sewage	Cat 1	Pipe line
130	Acme Life Tech LLP	operational	15	Pharma	Cat 3	Pipe line
131	JSTI Transformers Pvt. Ltd. (JST Stesalit Transfermers (p) Ltd.)	operational	2.5	Sewage	Cat 1	Tanker
132	Ultratech Pharmaceuticals	operational	15	Pharma	Cat 3	Tanker
133	Allengers Medi Systems	operational	5	Misc.	Cat 5	Tanker
134	Wockhardt Ltd.	operational	75	Pharma	Cat 3	Pipe line
135	Hindustan Unilever Limited (Soap Div.)	operational	130	Soap & Detergent	Cat 2	Pipe line
136	Medicef Pharma	operational	8	Pharma	Cat 3	Pipe line
137	Emmbros Auto comp. Ltd	operational	2	Sewage	Cat 1	Tanker
138	Spanker Biotech Ltd.	operational	10	Pharma	Cat 3	Pipe line
139	Hema Herbs Pvt. Ltd.	operational	50	Ayurvedic	Cat 3	Tanker
140	Panam Cyclenders Pvt Ltd	operational	5	Sewage	Cat 1	Pipe line
141	Hindustan Unilever Limited (Food Div.)	operational	8	Food	Cat 1	Pipe line
142	Devyani Food Industries Ltd.	Closed	120	Food	Cat 1	Tanker

1.D

4

143	Sysmex India Pvt. Ltd.	operational	10	Pharma	Cat 3	Tanker
144	PEE ESS Dishnet Pvt. Ltd.	operational	3	Sewage	Cat 1	Pipe line
145	Jupiter International Ltd.	operational	75	Misc.	CAT 2	Tanker/Pipe line
146	Venus Remedies Ltd.	operational	40	Pharma	Cat 3	Pipe line
147	Camex Oil Pvt. Ltd.	operational	125	Chemicals	Cat 2	Pipe line
148	Haripur Paper Company	operational	31.15	Paper	Cat 1	Pipe line
149	Cipla Limited	operational	60	Pharma	Cat 3	Pipe line
150	Torrent Pharma	operational	320	Pharma	Cat 3	Pipe line
151	Empire Home Appliances	operational	9	Chemicals	Cat 2	Tanker
152	Haripur Kraft Company	operational	26.7	paper	Cat 1	Pipe line
153	Regal Kitchen Foods Ltd.	operational	7	Food	Cat 1	Pipe line
154	Panacea Biotech Ltd.-I	operational	50	Pharma	Cat 3	Pipe line
155	Panacea Biotech Ltd.-II	operational	25	Pharma	Cat 3	Pipe line
156	N G Electro Products Pvt. Ltd.	operational	1	Soap & Detergent	CAT 2	Tanker
157	Czar Faucets Ltd.	operational	4.2	Misc.	CAT 5	Tanker
158	Krishi Rasayan Export Pvt. Ltd.	operational	2	Chemicals	Cat 2	Tanker
159	Milano Bathroom Fitting (PRISM JOHNSON LTD.)	operational	1.2 kl	Misc.	CAT 5	Tanker
160	GMH Organics	operational	10	Pharma	Cat 3	Pipe line
161	Rainbow Human Care Pvt. Ltd.	operational	7.5	Pharma	Cat 3	Pipe line
162	Trisis Ventures	operational	2	Chemical	Cat 2	Tanker
163	Newedge Research & Development Pvt. Ltd.	operational	5	Pharma	Cat 3	Tanker
164	Kanha Biogenetic	operational	5	Pharma	Cat 3	Pipe line
165	Dallas Formulation Pvt. Ltd.	operational	2	Pharma	Cat 3	Pipe line
166	Quixotic Healthcare -Thana	operational	4	Pharma	Cat 3	Tanker
167	Preet Remedies Pvt. Ltd -II	operational	4	Pharma	Cat 3	Tanker
168	Prosperity 6 Pharamaceutics	operational	3.6	Pharma	Cat 3	Tanker
169	Maxtar Bio-Genics	operational	3.5	Pharma	Cat 3	Tanker
170	P&G UNIT-I	operational		Soap & Detergent	Cat 2	Pipe line
171	P&G UNIT-II	operational	300	Soap & Detergent	Cat 2	Pipe line
172	Bhojia Charitable Trust for science Reaserch & Social Welfare	operational	20	STP	Cat 1	Tanker
173	Innova CapTab	operational	27	Pharma	Cat 3	Pipe line
174	Wep Solutions Ltd	operational	10	STP	Cat 1	Tanker
175	Quixotic Healthcare -II -Kalujhanda	Closed	5 (CLOsed)	Pharma	Cat 3	Tanker
176	The Engravures	operational	2	Misc.	CAT 5	Tanker
177	Innova Cap Tab Pvt. Ltd	operational	4	Pharma	Cat 3	Pipe line
178	Neptune Life Sciences Pvt. Ltd.	operational	6	Pharma	Cat 3	Tanker
179	Jyothy Laboratories Ltd.	operational	29	Soap & Detergent	Cat 2	Pipe line

102 44

180	Crescent Therapeutics Ltd. (Sanctus Global Formulations Ltd.)	operational	5	Pharma	Cat 3	Tanker
181	E.G.Pharmaceuticals	operational	2.5	Pharma	Cat 3	Tanker
182	Alive Healthcare	operational	2	Pharma	Cat 3	Tanker
183	Euphoria India Pharmaceuticals	operational	3	Pharma	Cat 3	Tanker
184	Curetech Skin Care	operational	10	Pharma	Cat 3	Pipe line
185	VADSP Pharmaceuticals (Unison Pharmaceuticals)	operational	10	Pharma	Cat 3	Pipe line
186	Anand Zippers (Pvt) Ltd	operational	6	Misc.	CAT 5	Tanker
187	Avenue Remedies (India) Pvt. Ltd.	operational	9	Pharma	Cat 3	Pipe line
188	Shervotec Pharmaceuticals	operational	5	Pharma	Cat 3	Tanker
189	Park Pharmaceutical	operational	2	Pharma	Cat 3	Tanker
190	Shri Sai Balaji PharmaTech Pvt. Ltd.	operational	5	Pharma	Cat 3	Tanker
191	MSJ Bath Fittings and Accessories Pvt. Ltd (ESS ESS Bathroom Product Pvt. Ltd)	operational	25	Misc.	CAT 5	Pipe line
192	A.V. Auto Industries (p) Ltd.	operational	5	Misc.	CAT 5	Tanker
193	Dabur india ltd (Chwanprash)	operational		Food	Cat 1	Pipe line
194	Dabur india ltd (Shampoo+Hajmola)	operational	205	Food	Cat 1	Pipe line
195	Su-Kam power systems	Closed	35	Misc.	CAT 5	Tanker
196	Solitare Pharmacia Pvt. Ltd.	operational	1.15	Pharma	Cat 3	Tanker
197	Steelbird Hi-Tech India Ltd.	operational	10	STP	Cat 1	Pipe line
198	Alpha Products	operational	10	Pharma	Cat 3	Tanker
199	Rama Sports & Finess Industries	operational	1.1	STP	Cat 1	Tanker
200	Scott-Edil Pharmacia Ltd	operational	7	Pharma	Cat 3	Tanker
201	PineTree Packaging Pvt. Ltd.	operational	1	STP	Cat 1	Tanker
202	Regalia Laminates	Closed	2.2 (Closed)	STP	Cat 1	Tanker
203	Osper Formulation	operational	5	Pharma	Cat 3	Tanker
204	Abbott Healthcare Pvt. Ltd.	operational	216	Pharma	Cat 3	Pipe line
205	Polo Pharmaceuticals Pvt. Ltd	operational	5	Pharma	Cat 3	Tanker
206	Valco Industries Ltd	operational	5	STP	Cat 1	Tanker
207	Gopal Lifescience -II	operational	3.5	Pharma	Cat 3	Tanker
208	Ozone Pharmaceuticals Ltd.	operational	10	Pharma	Cat 3	Tanker
209	Gopal Cylinders- I	operational	4.8	STP	Cat 1	Tanker
210	Gopal Cylinders- III	operational	1.94	STP	Cat 1	Tanker
211	Alliance Biotech -Katha	operational	6	Pharma	Cat 3	Pipe line
212	Shree Balaji Enterprises	operational	7	Misc.	CAT 5	Tanker
213	ESS ESS Industries	operational	10	Misc.	CAT 5	Tanker
214	Cosmic Nutracos Solutions Pvt. Ltd	operational	5	Soap & Detergent	Cat 2	Tanker
215	Ozone Ayurvedics -II (Name change as Ozone Pharmaceuticals Ltd. Unit-II)	operational	4.5	Pharma	Cat 3	Tanker
216	AAR GEE Formulations	operational	3.5	Pharma	Cat 3	Tanker
217	Agri Science India	operational	1.2	Chemical	Cat 2	Tanker
218	Scott-Edil Reaserch Lab	operational	30	Pharma	Cat 3	Tanker
219	Simartech Controls	operational	1	Misc.	CAT 5	Tanker
220	Life Vision Healthcare	operational	5	Pharma	Cat 3	Pipe line

12 44

221	Indogreen Plastic Technologies	operational	4.5	Soap & Detergent	Cat 2	Tanker
222	Volcano Electrical Industries	operational	2	Soap & Detergent	Cat 2	Pipe line
223	Claridge Moulded Fiber Ltd.-I	operational	2.5	STP	Cat 1	Tanker
224	Claridge Moulded Fiber Ltd.-II	operational	2.5	STP	Cat 1	Tanker
225	ANG Lifesciences India Ltd (Ind Swift Ltd -III)	operational	12.2	Pharma	Cat 3	Tanker
226	ANG Lifesciences India Ltd (Ind Swift Ltd -iv)	operational	8	Pharma	Cat 3	Tanker
227	Hotel The Ascent	Closed	2(closed)	STP	Cat 1	Tanker
228	Shrishti Technologies	operational	1	Misc.	CAT 5	Tanker
229	Shrishti Technologies -III (Shrishti Engineering)	operational	2.5	Misc.	CAT 5	Tanker
230	Marc Enterprises Pvt. Ltd	operational	30	Misc.	CAT 5	Tanker
231	Geon International	operational	5	Misc.	CAT 5	Tanker
232	Shri Ram Cylinders	operational	1	STP	Cat 1	Tanker
233	Shri Ram Cylinders-II	operational	0.5	STP	Cat 1	Tanker
234	Indoco Remedies	operational	24	Pharma	Cat 3	Pipe line
235	Temple Packaging Pvt. Ltd.	operational	4.5	Paper	Cat 1	Pipe line
236	Ashoka Spanners Pvt. Ltd.	operational	2.5	Misc.	CAT 5	Tanker
237	Ashok Impex	operational	1	STP	Cat 1	Tanker
238	Rescuers Life Sciences Ltd	operational	3.5	Pharma	Cat 3	Pipe line
239	Mrigman Incorporation	operational	1.5	Soap & Detergent	Cat 2	Tanker
240	Health Biotech Ltd	operational	8	Pharma	Cat 3	Pipe line
241	Sanshul Engineers	operational	1.2	Misc.	CAT 5	Tanker
242	Simla Chemical-II	operational	3	Soap & Detergent	Cat 2	Tanker
243	Able Pharma	operational	2	Pharma	Cat 3	Tanker
244	Milestone -IV	operational	1	STP	Cat 1	Pipe line
245	Milestone VIII	operational	8	STP	Cat 1	Pipe line
246	Sun pharmaceuticals Ind. Ltd (Solrex Pharmaceuticals company)	operational	39	Pharma	Cat 3	pipe line
247	Balaji Industries	operational	5	chemical	Cat 2	Tanker
248	Biogenetics Drugs Pvt. Ltd	operational	5	Pharma	Cat 3	Tanker
249	Xcell Labs	operational	2	Pharma	Cat 3	Tanker
250	Microturner-II-Jharmajri	operational	2.6	STP	Cat 1	Tanker
251	Symbiotic Drugs & Diabetic Care (P) Ltd.	operational	4	Pharma	Cat 3	pipe line
252	Heesa Pharma	operational	13.7	Pharma	Cat 3	pipe line
253	Ankur Drugs	Closed	10 (Closed)	Pharma	Cat 3	Tanker
254	Cosmas Pharma	operational	5	Pharma	Cat 3	Tanker
255	Parasol Laboratories India Pvt. Ltd.	operational	4	Pharma	Cat 3	Tanker
256	Unichem Laboratories Ltd. -I	operational	6	Pharma	Cat 3	pipe line
257	Unichem Laboratories Ltd. -II	operational	30	Pharma	Cat 3	pipe line
258	Unichem Laboratories Ltd. -III	operational	9	Pharma	Cat 3	pipe line




259	Torque Pharmaceuticals Pvt. Ltd.	operational	40	Pharma	Cat 3	pipe line
260	Shree Ram Health care	operational	10	Pharma	Cat 3	pipe line
261	Smilex healthcare drugs company	operational	5	Pharma	Cat 3	pipe line
262	Greef Formulations	operational	2.7	Pharma	Cat 3	Tanker
263	GINI & Joni Ltd -II	operational	36.5	Chemical/ST P	Cat 2	pipe line
264	Crest Healthcare p ltd- katha	operational	5	Pharma	Cat 3	Pipe line
265	Crest Topicals P Ltd. - jarmajri	operational	11	Pharma /Cosmetics	Cat 3	Pipe line
266	Aliana Healthcare Pvt. Ltd	operational	50	Pharma	Cat 3	Pipe line
267	Inox Air Product	operational	55	Pharma	Cat 3	Pipe line
268	Rine Engineering Pvt. Ltd.	operational	10	Chemical/ST P	Cat 2	Pipe line
269	Mahalakshmi Spintex Pvt. Ltd.	operational	40	Chemical/ST P	Cat 2	Pipe line
270	Nirmal Furnishing Fabrics	operational	12	textile/washi ng	Cat 2	Tanker
271	HimChem Industries	operational	1.5	chemical	Cat 2	Tanker
272	Zeiss pharma Pvt. Ltd	operational	20	Pharma	Cat 3	Pipe line
273	G.S.B. Pharmaceuticals (India)	operational	4	Pharma	Cat 3	Tanker
274	Unimark Pharma (India) Ltd.	operational	8.9	Pharma	Cat 3	Pipe line
275	Unibiotech Formulations	operational	8.8	Pharma	Cat 3	Pipe line
276	RSH Global Pvt. Ltd(Ratnasagar Herbals Pvt. Ltd. -II)	operational	11.4	Soap & Detergent	Cat 2	Pipe line
277	Admac Lifesciences	operational	13	Pharma	Cat 3	Tanker
278	Kaizen Pharmaceuticals	operational	5	Pharma	Cat 3	Pipe line
279	Go-Ish Remedies Ltd	operational	2	Pharma	Cat 3	Tanker
280	Marine Lifesciences	operational	5	Pharma	Cat 3	Tanker
281	M & B Footwear Pvt. Ltd.	Closed	12	STP	Cat 1	Pipe line
282	Blue Heaven Cosmetics (p) Ltd.(Cosmetica Corporation)	operational	2.5	Soap & Detergent	Cat 2	Tanker
283	Shree Ganesh Fats Pvt. Ltd	operational	1	Food	Cat 1	Pipe line
284	Mayasha Lifesceince (Glyco Labs)	operational	1.4	Pharma	Cat 3	Tanker
285	Boss Pharma	operational	4	Pharma	Cat 3	Pipe line
286	Crest Lifesceince P Ltd- Jharmajri	operational	11	Pharma	Cat 3	Pipe line
287	Hitech Formulation (P) Ltd	operational	5	Pharma	Cat 3	Tanker
288	Sobhagia Clothing Company	operational	10	Textile	cat 1	Pipe line
289	Kingston Aqua Industries Pvt. Ltd.	operational	2.8	Pharma	Cat 3	Tanker
290	Reckitt Benckiser Healthcare India Ltd.	operational	93	Pharma	Cat 3	Pipe line
291	Knox Life Sciences	operational	3.5	Pharma	Cat 3	Tanker
292	Ratnasagar Herbal Pvt. Ltd -Katha	operational	8.5	Pharma	Cat 3	pipe line
293	REXCIN PHARMACEUTICALS PVT. LTD. (Discontinued w.e.f. 12.02.2019)	Closed	6(closed)	Pharma	Cat 3	Pipe line

1.2

44

294	Addii Biotech Pvt. Ltd.	operational	6	Pharma	Cat 3	Tanker
295	Fujikawa Power	operational	10	Misc.	cat 5	tanker
296	Cosmo Herbals ltd -Bhud	operational	5	Soap & Detergent	cat 2	tanker
297	Lotus Herbals Color Cosmetics	operational	20	Soap & Detergent	cat 3	Pipe line
298	GLL Industries	operational	5	Misc	Cat 1	Pipe line
299	Luminous Power Technologies Pvt. Ltd.	operational	24	STP	Cat 1	Pipe line
300	Wings Biotech-Baddi	operational	25	Pharma	cat 3	Pipe line
301	Nexus Health & Beauty Care Pvt. Ltd.	Closed	5	Soap & Detergent	cat 2	tanker
302	Pentachem Pharmaceutical	operational	10	Pharma	Cat 3	Tanker
303	Torque Pharmaceuticals Pvt. Ltd. -III	operational	5	Soap & Detergent	cat 2	tanker
304	Affy Parenterals	operational	3.5	Pharma	Cat 3	Tanker
305	Life care Neuro Products Ltd.	operational	3	Pharma	Cat 3	Tanker
306	IBN Herbal (A unit of Curetech Formulation)	operational	19	Pharma	Cat 3	pipe line
307	Curetech Formulations (Pvt) Ltd.	operational	5	Pharma	Cat 3	pipe line
308	Marc Laboratories Ltd III	operational	7	Pharma	Cat 3	pipe line
309	Marc Laboratories Pvt. Ltd	operational	6.4	Pharma	Cat 3	pipe line
310	Healers Lab Unit-II	operational	1.5	Pharma	Cat 3	Tanker
311	Bhandora Organic Product	operational	5	Soap & Detergent	cat 2	pipe line
312	Indo Farm Equipment Ltd	operational	2	Misc	Cat2	tanker
313	Venus Bioscience Pvt. Ltd.	Closed	4	Pharma	Cat 3	Tanker
314	Hira Filters (01.09.2019 to 30.11.2019 0.5 KLD)	operational	5	Misc	Cat2	tanker
315	K K Enterprises	operational	5	Misc	Cat2	tanker
316	Wings Biotech-Jharmajri	operational	15	Pharma	cat 3	pipeline
317	Hurry Nath & Company Pvt. Ltd	operational	1.75	Misc	Cat 2	Tanker
318	S.K.Files & Tools	operational	10.5	Misc	Cat 2	Tanker
319	Medipol Pharmaceutical India Pvt. Ltd.	operational	6	Pharma	cat 3	Tanker
320	Horizon Packs Pvt. Ltd.(Monad Tech. Pvt. Ltd)	operational	5	Paper (cogg boxes)	Cat-1	Tanker
321	Omar Healthcare	operational	4.5	Pharma	cat 3	pipeline
322	Redico Remedies	operational	12	Pharma	Cat 3	Tanker
323	Regal Synthetic (P) Ltd.	operational	0.7	Misc.	Cat 2	Tanker
324	Aqua Metal Technologies	operational	0.8	Misc.	Cat 2	Tanker
325	Shamshree Lifesciences Ltd.	operational	22	Pharma	Cat 3	Tanker
326	Strausswell Organics	operational	1	Pharma	Cat 3	Tanker
327	G M H Laboratories	operational	3.5	Pharma	Cat 3	pipeline
328	Sabsons Fastners (p) Ltd	operational	0.6	Misc	Cat 2	Tanker
329	Tridev Spices Pvt. Ltd	operational	3.5	Misc	Cat-2	Tanker
330	Himachal Fiber Ltd.	operational	36	Textiles/STP	Cat 1	pipeline
331	Shivalik Steel & Alloys Pvt. Ltd. (Kamla Organic pvt. Ltd)	operational	4	soap & noodles	Cat 2	pipeline

1,2

332	Kamla Oleo Pvt. Ltd.	operational	25	soap & noodles	Cat 2	pipeline
333	Captab Biotech-II	operational	4	Pharma	Cat 3	Tanker
334	Alliance India -II (Hill Top)	operational	10	Soap	Cat 2	Pipe line
335	Rieke Packaging India Pvt. Ltd. (Lion Care Products Pvt. Ltd.)	operational	25	chemical/cleaner	Cat 2	Tanker
336	Naina Enterprises-Gullarwala	operational	2	Misc	Cat 2	Tanker
337	M Rauf Enterprises-I	operational	2	Misc	Cat 2	Tanker
338	M Rauf Enterprises-II	operational	1.8	Misc	Cat 2	Tanker
339	Vinca Life Science	operational	5	Pharma	Cat 3	PIPELINE
340	Noel Pharma -III Judikalan	operational	7.5	Pharma	Cat 3	Tanker
341	Aeon Polymers -Jharmajri	operational	1	STP	Cat -1	Tanker
342	Laj Motors	operational	0.5	STP	Cat -1	Tanker
343	Medwor Pharma	operational	3	Pharma	Cat 3	Tanker
344	Super Trading	operational	5	Misc	Cat 2	Tanker
345	Gulshan Trading Co.	operational	1.8	Misc	Cat 2	Tanker
346	GMP Technical Solutions Pvt. Ltd.-I	operational	15	STP	Cat -1	Tanker
347	GMP Technical Solutions Pvt. Ltd.-II	operational	5	STP	Cat -1	Tanker
348	Balaji Trading Co. -swarajmajra	operational	4.5	Misc	Cat 2	Tanker
349	Kamal Enterprises	operational	5	Misc	Cat 2	Tanker
350	DSR Lifecare-Gullarwala	operational	5	Pharma	Cat 3	Tanker
351	Agricides India	operational	0.2	Chemical	Cat -2	Tanker
352	Altop Healthcare	operational	0.1	Pharma	Cat 3	Tanker
353	Vidya Nutraceuticals Pvt. Ltd.	operational	5	Pharma	Cat 3	Tanker
354	Supreme Engravours	operational	3.5	Misc	Cat 2	Tanker
355	Cyper Pharma	operational	5.7	Pharma	Cat 3	Tanker
356	Neha Enterprises	operational	5	Misc	Cat 2	Tanker
357	A K Enterprises	operational	5	Misc	Cat 2	Tanker
358	Anrose Pharma	operational	6	Pharma	Cat 3	Tanker
359	Alliance Formulation -Jharmajri	operational	2.5	Pharma	Cat 3	pipeline
360	MBP Pharmaceutical Pvt. Ltd.	operational	3	Pharma	Cat 3	Tanker
361	Biomatrix Research Laboratories Pvt. Ltd	operational	2	Pharma	Cat 3	Tanker
362	3 Generations	operational	3	Chemical	Cat 2	Tanker
363	Shivani Formulation-Sai Road	operational	0.88	Pharma	Cat 3	Tanker
364	Him Trading Co.	operational	0.8	Misc	Cat 2	Tanker
365	Ojb Herbal Pvt. Ltd	operational	4.1	cosmetics	Cat 2	Tanker
366	Verax Life Science Pvt. Ltd (Trimurti Vegoils Pvt. Ltd)	operational	2	Pharma	Cat 3	Tanker
367	Shri Ram International	operational	1.5	STP	Cat 1	Tanker
368	Lyra Laboratories (P) Ltd.	operational	0.5	Pharma	Cat 3	Tanker
369	Cosmic Industries	operational	1	Cosmetics	Cat 2	Tanker
370	Rumy Life Science	operational	1.1	Pharma	Cat 3	Tanker
371	Harman Bawa Pvt. Ltd.	Closed	0.8	Misc	Cat-2	Tanker
372	Unital Formulation	operational	5	Pharma	Cat 3	Tanker
373	G.N. Laminates	operational	0.5	Misc	Cat-2	Tanker
374	Arora Herbal Beauty Products Pvt. Ltd	operational	0.1	STP	Cat 1	Tanker
375	S.K.Trading Co.	operational	2.1	Misc	Cat-2	Tanker
376	Asha Coop.	operational	0.5	Chemical	Cat-2	Tanker
377	J C International	operational	2.6	Misc	Cat-2	Tanker

12 4

378	Aishwarya Lifescience -Lodhimajra	operational		40	Pharma	Cat 3	Tanker
379	Affy Pharma Pvt. Ltd.	Closed		4.7	Pharma	Cat 3	Tanker
380	Indoco Remedies-III	operational		50	Pharma	Cat 3	Pipe line
381	Ajay Ferti-Chem (Bombay) Pvt. Ltd.	operational		5.6	Chemical	Cat 2	Tanker
382	VMT Spining Co. Ltd.	operational		70	STP	Cat 1	Pipeline
383	Signum Electrowave	operational		60	Misc	Cat 2	Pipe line
384	Kanha Biogenetic Laboratory	operational		5	Pharma	Cat 3	Pipe line
385	Cortex Medical Inc	operational		5	pharma	Cat 3	Tanker
386	Polestar Power Industries	operational		1.2	pharma	Cat 3	Tanker
387	Bansal Starch and Foods Pvt. Ltd.	Closed		20 (closed)	Food	Cat 1	tanker
388	Shree Raghunath wires	operational		1	Misc	Cat 5	Tanker
389	Surya Enviro	operational		1	STP	Cat 1	tanker
390	Raddison Pharmaceuticals	operational		5.5	pharma	Cat 3	Tanker
391	Hotel MG Regency	operational		6	STP	Cat 1	tanker
392	Vedage Naturals Pvt. Ltd.	operational		2	pharma	Cat 3	Tanker
393	Macleods Pharmaceuticals Ltd.	operational		150	pharma	Cat 3	Tanker
394	Oxalis Lab	operational		135	pharma	Cat 3	Tanker
395	The Cosmetic	operational		10	soap & Detergent	Cat 2	Tanker
396	Jai Bhawani Industries Pvt. Ltd.	operational		4.7	soap & Detergent	Cat 2	Tanker
397	Shrinivas (Gujrat) Laboratories Pvt. Ltd.	operational		4	pharma	Cat 3	Tanker
398	Paclean Ventures	operational		2.6	soap & Detergent	Cat 2	Tanker
399	Sumati Food	operational		2	Food	Cat 1	tanker
400	Montek Biopharma	operational		5	pharma	Cat 3	Tanker
401	Healcure	operational		1.2	pharma	Cat 3	Tanker
402	Modern Appliances	Closed		5 (Closed)	pharma	Cat 3	Tanker
403	Metrocraft	operational		4.4	pharma	Cat 3	Tanker
404	Garg Electronics -II	operational		5	Chemical	Cat 2	Pipeline
405	Scott EDIL Pharmecia Unit -II	operational		45	pharma	Cat 3	Pipeline
406	Crius Life Science Pvt. Ltd	operational		20	pharma	Cat 3	Tanker
407	Soundrya and prasadhan India Pvt. Ltd.	operational		2.6	soap & Detergent	Cat 2	Tanker
408	Sigma soft gel & Formulations	operational		1.7	Pharma	Cat 3	Pipeline
409	Abhishek Pharmaceutical	operational		2.5	pharma	Cat 3	Tanker
410	Radiant Casting Pvt. Ltd	operational		8	STP	Cat 1	Pipeline
411	Livguard Batteries Pvt. Ltd.(Vave India Energy Solutions Pvt. Ltd)	operational		65	Misc.	CAT 5	Tanker
412	Associated Biotech	operational		10	pharma	Cat 3	Tanker
413	Mas Pharma Chem	operational		3	Pharma	Cat 3	Tanker
414	Two star trading co.	operational		5	Misc	Cat2	tanker
415	Munix (India) Pvt. Ltd.	operational		40	Misc.	CAT 5	Tanker
416	Microturners-VI	operational		16	Misc	Cat2	tanker
417	Yuventis Life Sciences	operational		1.25	Pharma	Cat 3	Tanker
418	GINI & Joni Ltd	operational		18.2	STP	Cat 1	tanker
419	Industrial Waste Management Co.	operational		1.3	Misc	Cat2	tanker

12 W

420	Richfeel Health and beauty Pvt. Ltd-II	operational	5	soap & Detergent	Cat 2	Tanker
421	Yash Fans & Appliances Ltd	operational	5	Misc	CAT 5	Tanker
422	Pidilite industries Ltd -IV	operational	10	Misc.	Cat 2	Tanker
423	Logos Pharma	operational	5	Pharma	Cat 3	Tanker
424	Emmbros Automotives Pvt. Ltd	operational	10	STP	Cat 1	Pipeline
425	Sri Ram Healthcare (p) Ltd -II	operational	5	pharma	Cat 3	Tanker
426	Zoya Herboceuticals	operational	5	soap & Detergent	Cat 2	Tanker
427	Nihal Healthcare	operational	1.5	pharma	Cat 3	Pipeline
428	Brooklyn Himalayan Hospital	operational	7.5	STP	Cat 1	tanker
429	Aptar Pharma India Pvt. Ltd	Closed	10 (closed)	STP	Cat 1	tanker
430	A R Engravour	operational	5	Misc	Cat2	tanker
431	Stylo Tableware	operational	5	STP	Cat 1	tanker
432	Pinacle Lifesceince Pvt. Ltd	operational	14.5	pharma	Cat 3	Tanker
433	Tasmed India Pvt. Ltd	operational	5	Pharma	Cat 3	Pipeline
434	Black Smith Metal Works	operational	5	Misc	Cat 5	Tanker
435	Divyadhan Consultant Pvt. Ltd	operational	10	Misc	Cat 2	Pipeline
436	Plena Remedies	operational	5	pharma	Cat 3	Tanker
437	IVM Pharmacia	operational	5	Pharma	Cat 3	Pipeline
438	Wincure Pharma	operational	0.5	Pharma	Cat 3	Tanker
439	Tiruvision Medicare	operational	3	Pharma	Cat 3	Tanker
440	Him Corp	operational	1.5	soap & Detergent	Cat 2	Tanker
441	Govind Gopal LPG Industries Ltd	operational	5	Misc	Cat 2	Tanker
442	Dabur India Ltd- Manpura	operational	400	Misc	Cat 2	Tanker
443	Navkar Life Science	operational	8	Pharma	Cat 3	Tanker
444	Manjushree Technopach Limited	operational	30	Misc	Cat 2	Pipeline
445	Ultra Drugs Pvt. Ltd-II (Katha)	operational	5	Pharma	Cat 3	Tanker
446	AVN Footsteps	operational	2	cosmetics	Cat 2	Tanker
447	Indogreen Plastic Technologies-II	operational	9	cosmetics	Cat 2	Tanker
448	Sarika Industries Pvt. Ltd.	operational	1.5	Misc	Cat 5	Tanker
449	Diversey India Hygiene Limited	operational	26	soap & Detergent	Cat 2	Tanker
450	Winner Nippon Leatherette Pvt. Ltd	operational	5	STP	Cat 1	tanker
451	DS Drinks and Beverages Pvt. Ltd.	operational	204	Food	Cat 1	pipeline
452	N.G. ElectroProducts Pvt. Ltd.-II	operational	1.3	soap & Detergent	Cat 2	Tanker
453	Balaji International	operational	0.7	STP	Cat 1	tanker
454	Glorious Life Sceince	operational	1.4	Pharma	Cat 3	Tanker
455	Navkriti Builders Pvt. Ltd (Hotel Sarovar Portico)	operational	20	STP	Cat 1	Pipeline
456	Eastman Auto Power Ltd-II	operational	50	Misc.	Cat.5	Tanker
457	Perfect Packaging	operational	20	Misc.	Cat.5	Tanker
458	Beta Drugs Limited	operational	2	Pharma	Cat 3	Tanker
459	K.N. Papers & Packages	operational	1.1	Paper	Cat 1	Tanker
460	Shivani Pharmaceuticals	operational	1	Pharma	Cat 3	Tanker
461	IM Healthcare Pvt. Ltd	operational	3	Food	Cat 1	Tanker
462	Jasco Paper Products	operational	2	STP	Cat 1	tanker

12 44

463	Gupta Property Developers Pvt. LTD.	operational	40	STP	Cat 1	Pipeline
464	Pharminox Laboratories	operational	5	Pharma	Cat 3	Tanker
465	Auriga Research Pvt. Ltd.	operational	10	Chemical	Cat 2	Tanker
466	Morepen Laboratories Ltd-Parwanoo	operational	72	Pharma	Cat 3	Tanker
467	Allkind Healthcare -II	operational	25	Pharma	Cat 3	Tanker
468	Pivot Fabrique HP	operational	2	Chemical	Cat 2	Tanker
469	Amster Labs -II	operational	2.80	Pharma	Cat 3	Tanker
470	Him Overseas	operational	0.60	Misc.	Cat.5	Tanker
471	Chembond Chemicals Ltd.	operational	1	Chemical	Category-2	Tanker
472	Manikaran Enterprises	operational	2.2	Misc.	Category-2	Tanker
473	SHRI RAMESTH INDUSTRY PVT.LTD.	operational	4.3	Pharma	Category-3	Tanker
474	Shiva Biogenetic Laboratories Pvt Ltd	operational	8.4	Pharma	Category-3	Tanker
475	Shiva Biogenetic Pharmaceutical Pvt Ltd	operational	3	Pharma	Category-3	Tanker
476	Birla Textiles Unit-2	operational	1000	textile	Category-1	Pipeline
477	Asian Pharma	operational	9.6	Pharma	Category-3	Tanker
478	Sunshine Industries	operational	1.6	Pharma	Category-2	Tanker

LD

4

(Arno x100 - 2)

Table-1(Discharge point of CETP at River Sirsa)

Sr. No.	Parameter Name	Result	Permissible Limit	Remark/Result Analysis
1.	Nitrate-N	0.00 mg/L	10	Within Limit
2.	Fluoride	0.166 mg/L	2	Within Limit
3.	Phenolic Compounds (as C6H5OH)	0.00 mg/L	1	Within Limit
4.	Ammonical Nitrogen	1.00 mg/L	50	Within Limit
5.	pH	7.48	6-9	Within Limit
6.	BOD	20.0 mg/L	30	Within Limit
7.	Oil and Grease	0.0 mg/L	10	Within Limit
8.	Total KJELDAHL-N	1.4 mg/L	50	Within Limit
9.	Total Phosphate	0.36 mg/L	5	Within Limit
10.	TSS	22.4 mg/L	100	Within Limit
11.	COD	176.0 mg/L	250	Within Limit
12.	Cadmium	0.00 mg/L	0.05	Within Limit
13.	Trivalent Chromium	0.00 mg/L	2	Within Limit
14.	Iron	0.240 mg/L	3	Within Limit
15.	Manganese	0.00 mg/L	2	Within Limit
16.	Copper	0.062 mg/L	3	Within Limit
17.	Selenium	0.00 mg/L	0.05	Within Limit
18.	Sulphides	0.00 mg/L	2	Within Limit
19.	FDS	1262.5 mg/L	2100	Within Limit
20.	Nickel	0.0 mg/L	3	Within Limit
21.	Hexavalent Chromium	0.00 mg/L	0.1	Within Limit
22.	Lead	0.00 mg/L	0.1	Within Limit
23.	Sulphate	82.0 mg/L	1000	Within Limit
24.	Chloride	109.89 mg/L	1000	Within Limit

12 W

(Annexure-3)

Sr. No.	Parameter Name	Sampling Point	CAT-I discharged to CETP	
		Result	Permissible Limit CETP Norms inlet	Remark/Result Analysis
1.	pH	7.32	6.0-9.0	Within limit
2.	BOD	140 mg/l	300 mg/l	Within limit
3.	Sulphides	0.32 mg/l	5 mg/l	Within limit
4.	Phenolic Compounds	0.00 mg/l	5 mg/l	Within limit
5.	Ammonical Nitrogen	11.2 mg/l	50 mg/l	Within limit
6.	Total Chromium	0.00 mg/l	2 mg/l	Within limit
7.	TSS	29.2 mg/l	250 mg/l	Within limit
8.	TDS	1015.83 mg/l	2100 mg/l	Within limit
9.	Oil & Grease	1.04 mg/l	15 mg/l	Within limit

12

Table-2 (Winsome Textile Limited)				
Sr. No.	Parameter Name	Sampling Point	CAT-IV discharged to CETP	
		Result	Permissible Limit CETP inlet Norms	Remark/Result Analysis
1.	pH	7.05	6.0-9.0	Within limit
2.	BOD	22.0 mg/l	350 mg/l	Within limit
3.	Oil & Grease	0.88 mg/l	15 mg/l	Within limit
4.	Sulphides	0.0 mg/l	5 mg/l	Within limit
5.	Phenolic Compounds	0.00 mg/l	5 mg/l	Within limit
6.	Ammonical Nitrogen	1.4 mg/l	50 mg/l	Within limit
7.	TSS	34.8 mg/l	250 mg/l	Within limit
8.	COD	96.0 mg/l	1000 mg/l	Within limit
9.	TDS	4372.66 mg/l	2100 mg/l	Above limit
10.	Total Chromium	0.00 mg/l	2	Within limit

12. 4

Table-2 (Auro Textile-I)				
Sr. No.	Parameter Name	Sampling Point	CAT-I discharged to CETP	
		Result	Permissible Limit CETP inlet Norms	Remark/Result Analysis
1.	pH	6.01	6.0-9.0	Within limit
2.	BOD	310.0 mg/l	350 mg/l	Within limit
3.	Oil & Grease	1.52 mg/l	15 mg/l	Within limit
4.	Phenolic Compounds	0.00 mg/l	5 mg/l	Within limit
5.	Ammonical Nitrogen	8.4 mg/l	50 mg/l	Within limit
6.	TSS	37.4 mg/l	250 mg/l	Within limit
7.	COD	680.0 mg/l	1000 mg/l	Within limit
8.	TDS	690.12 mg/l	2100 mg/l	Within limit
9.	Sulphides	0.96 mg/l	5 mg/l	Within limit
10.	Total Chromium	0.00 mg/l	2 mg/l	Within limit

12

4

Table-2 (Auro Textile-II)				
Sr. No.	Parameter Name	Sampling Point	CAT-I discharged to CETP	
		Result	Permissible Limit CETP inlet Norms	Remark/Result Analysis
1.	pH	7.31	6.0-9.0	Within limit
2.	BOD	112.0 mg/l	350 mg/l	Within limit
3.	Oil & Grease	0.96 mg/l	15 mg/l	Within limit
4.	Sulphides	0.00 mg/l	5 mg/l	Within limit
5.	Phenolic Compounds	0.00 mg/l	5 mg/l	Within limit
6.	Ammonical Nitrogen	4.2 mg/l	50 mg/l	Within limit
7.	Total Chromium	0.00 mg/l	2 mg/l	Within limit
8.	TSS	74.6 mg/l	250 mg/l	Within limit
9.	COD	248.0 mg/l	100 mg/l	Within limit
10.	TDS	634.03 mg/l	2100 mg/l	Within limit

12

Table-2 (Auro Dyeing-I)				
	Auro Dyeing	Sampling Point	CAT-I discharged to CETP	
Sr. No.	Parameter Name	Result	Permissible Limit CETP inlet Norms	Remark/Result Analysis
1.	pH	6.6	6.0-9.0	Within limit
2.	BOD	220.0 mg/l	350 mg/l	Within limit
3.	Oil & Grease	1.12 mg/l	15 mg/l	Within limit
4.	Sulphides	0.32 mg/l	5 mg/l	Within limit
5.	Ammonical Nitrogen	9.8 mg/l	50 mg/l	Within limit
6.	Total Chromium	0.00 mg/l	2 mg/l	Within limit
7.	TSS	31.7 mg/l	250 mg/l	Within limit
8.	COD	448.0 mg/l	1000 mg/l	Within limit
9.	TDS	854.22 mg/l	2100 mg/l	Within limit
10.	Phenolic Compounds	0.00 mg/l	5 mg/l	Within limit

13

14

Sr.No	Name of Unit	Address of Unit	Sampling point	Date of collection	Report No	pH 6-9	Total Suspended Solid 250 mg/l	Chemical Oxygen Demand 1000 mg/l	Biochemical Oxygen Demand 350 mg/l	FDS 2100 mg/l	Oil & Grease 15 mg/l	Compliance w.r.t. CETP Inlet norms
1	Anand Zippers Pvt Ltd	Vill. Dharampur, Tehsil Baddi Distt Solan HP	Fol of ETP (discharge to CETP)	31.07.2021	483	7.23	58	164	30	1280	NIL	Within limit
2	Heal kraft Pharma Unit-2	Plot No 135-C EPIP Phase-I, Jharmajri	Fol of ETP (discharge to CETP)	29.07.2021	407	7.18	32	104	20	1066	NIL	Within limit
3	Medicef pharmaceuticals	Plot no 28-29 EPIP-1 Jharmajri Tehsil Baddi	Fol of ETP (discharge to CETP)	29.07.2021	398	7.8	62.2	316	92	1270	..	Within limit
4	Scott Edil Pharmacia Ltd.	Plot No 56 EPIP Phase I Jharmajri	Fol of ETP (discharge to CETP)	20.07.2021	387	7.68	47.6	140	22	1836	NIL	Within limit
5	Shimla Chemical Pvt. Ltd., Unit-II	Plot No 45 DIC Baddi	Collection tank discharge to CETP	31.07.2021	487	6.48	82	320	54	770	0.16	Within limit
6	IndChemic Health Specialities Pvt Ltd	Vill Thana Tehsil Baddi Dist Solan HP	Fol of ETP cum STP (discharge to CETP)	31.07.2021	470	7.76	75	120	30	1284	0.16	Within limit
7	Alive Health Care	Plot N. 123, HPSIDC, Baddi.	Fol discharge to CETP	31.07.2021	442	7.16	72	364	148	1264	..	Within limit
8	Allenger Medical System	Plot No 193, First Floor, HPSIDC Baddi Tehsil Baddi Distt Solan HP	discharge to CETP	30.07.2021	438	7.68	48	160	44	976	0.12	Within limit
9	Czar Faucets Ltd	Village BhatoliKalan Tehsil Baddi Distt Solan HP	Fol of ETP (discharge to CETP)	29.07.2021	369	7.34	89	320	78	1466	0.24	Within limit
10	NG Electro Products Pvt. Ltd	Plot No. 36 HIMUDA Ind Area Bhatolikalan	Fol discharge to CETP	29.07.2021	366	6.48	108	480	320	2062	0.68	Within limit
11	Higgs Healthcare	Village Bhatolikalan Tehsil Baddi Distt Solan HP	Fol discharge to CETP	29.07.2021	361	6.96	60.4	380	124	840	0.16	Within limit
12	Garg Electronics, Unit-II.	Plot No 24 Bhatolikalan Ind Area Baddi	Fol discharge to CETP	29.07.2021	357	7.1	18.2	160	24	1540	0.16	Within limit
13	Milano Bathroom Fittings	Plot No 30 HIMUDA Ind Area Bhatolikalan	Fol discharge to CETP	29.07.2021	351	7.79	47	340	94	1870	0.24	Within limit
14	Asian Pharma Pvt. Ltd.	Vill. Katha	Collection tank discharge to CETP	29.07.2021	342	7.68	74	360	104	1476	0.28	Within limit
15	Scott Edil Advance Research	Vill Bhatolikalan Tehsil Baddi Distt. Solan HP	Fol discharge to CETP	28.07.2021	330	7.82	78	324	88	1910	0.14	Within limit
16	Unison Pharmaceuticals	Plot No. 124, EPIP Phase I Jharmajri	collection tank discharge to CETP	31.07.2021	328	6.1	78	540	160	1470	0.26	Within limit
17	Zeiss Pharmaceuticals Pvt Ltd	Plot No 72 EPIP Phase I Jharmajri	Fol discharge to CETP	28.07.2021	327	7.34	74	440	164	1558	0.18	Within limit
18	Nectar Life Science (Unit-7)	Village Bhatolikalan Adjoining Jharmajri EPIP	Discharge to CETP	28.07.2021	320	7.91	64	264	84	2262	0.26	Above limit
19	Wings Biotech Unit -II	Plot No 4&6 EPIP Phase-I Jharmajri	Discharge to CETP	28.07.2021	319	7.19	87	680	320	860	0.3	Within limit
20	Huhtamaki PPL Ltd	Ajanta Packaging (New Name: Huhtamaki India Pvt. Ltd.)	FOL of ETP	28.07.2021	318	7.19	48	320	98	2260	0.3	Above limit
21	Shri Ram Cylinders	Vill BhatoliKalan Hill Top Near Jharmajri	Discharge to CETP	28.07.2021	317	8.68	54	264	60	1710	0.18	Within limit
22	Nectar Lifesciences Ltd Formulation	Vill Bhatolikalan Adjoining Jharmajri EPIP	Collection tank discharge to CETP	29.07.2021	306	7.82	102	288	64	2260	0.18	Above limit
23	SteelBird Hi-Tech India,	, P.N. 11, 12& 13, EPIP, Phase-I, Jharmajri, Bhatolikalan	Fol of Etp cum STP (discharge to CETP)	28.07.2021	302	7.12	52	104	20	785	NIL	Within limit
24	RM Chemicals (P) Ltd	EPIP-I, Jharmajri, Baddi	Fol of Etp (inlet to CETP)	29.07.2021	300	7.12	352	344	120	2415	0.64	Above limit
25	Munix India Pvt. Ltd., Unit-II,	Village Nihla Khara,	Fol of Etp	23.07.2021	291	7.12	32	128	18	1236	0.12	Within limit
26	Micro Turners Unit VI	Vill Hariapur Bhud Tehsil Baddi Distt Solan HP	discharge to CETP Baddi	21.07.2021	273	8.69	64	264	80	2060	0.22	Within limit
27	Mahalaxmi Spintex Pvt. Ltd	1188/2 Katha Tehsil Baddi Distt Solan HP	Fol of Etp	29.07.2021	447	7.4	89	240	26	1466	0.64	Within limit
28	Celebrity biopharma	Hill top vill panga jharmajri	FOL of ETP discharge to CETP	28.07.2021	309	8.12	762	2080	960	1434	6.12	Above limit
29	Metrocraft	Bhatolikalan Baddi	FOL of ETP discharge to CETP	29.07.2021	343	6.49	176	1640	680	1220	1.86	Above limit
30	Indoco Remedies Ltd.	Katha	Direct discharge to CETP	29.07.2021	344	7.26	86	840	380	970	0.8	Above limit
31	Indoco Remedies Ltd. (Unit-III)	Katha	FOL of ETP discharge to CETP	29.07.2021	345	7.89	286	940	404	1570	1.2	Above limit
32	Charak Pharma	Kh.No 186/1, 139/3 Katha	FOL of ETP discharge to CETP	29.07.2021	346	7.16	86	140	30	870	nil	Within limit
33	Pidilite Industries ltd Unit-4	Bhatolikalan Baddi	FOL of ETP discharge to CETP	29.07.2021	347	7.2	56	104	24	1120	nil	Within limit

Handwritten initials: "KJ" and "LL" are present at the bottom of the page.

34	Wringley india ltd.	Katha Baddi	FOL of ETP discharge to CETP	29.07.2021	348	7.06	356	968	460	1074	1.02	Above limit
35	Ium Pharmacia	Plot No 5A Bhatolikalan	FOL of ETP discharge to CETP	29.07.2021	349	8.63	335	628	384	1484	0.82	Above limit
36	Panam cylinders	Plot No 11 IA Bhatolikalan	Collection discharge to CETP	29.07.2021	352	8.62	262	686	384	1140	0.28	Above limit
37	Parasol Laboratories Pvt. Ltd.	Plot No 23 Himuda IA Baddi	Collection discharge to CETP	29.07.2021	353	8.02	369	1420	684	984	1.18	Above limit
38	R. Kindustries (tasmed india) Pvt Ltd	Plot no-8 himuda Bhatolikalan Baddi.	FOL of ETP discharge to CETP	29.07.2021	354	7.22	68	120	24	1124	nil	Within limit
39	Bhandora organic products Ltd.	Plot no-26 Himuda Bhatolikalan Baddi	FOL of ETP discharge to CETP	29.07.2021	356	6.38	198	2020	824	2226	2.68	Above limit
40	Sarvotham Remedies Ltd.	katha	Collection discharge to CETP	29.07.2021	359	7.18	68	320	104	1260	0.18	Within limit
41	Shree Cosmetic Ltd.	Katha Baddi	FOL of ETP discharge to CETP	29.07.2021	360	7.18	182	440	124	2260	1.02	Above limit
42	Sylvan Green	Viii. Kularhiwala brotiwala Baddi	FOL of ETP discharge to CETP	29.07.2021	374	7.64	158	620	240	1620	0.18	Within limit
43	Stylo table ware	village kunjhal barotiwala	FOL OF STP (inlet to CETP)	28.7.21	295	8.6	146	320	80	1522	0.18	Within limit
44	Acme life (tech llp)	Plot no 103-105 EPIP -1	FOL OF ETP (inlet to CETP)	28.7.21	296	7.95	252	820	224	2310	1.2	Above limit
45	M/s JSTI Transformer	Bhatolikalan Baddi	FOL OF ETP cum STP	28.7.21	299	7.6	106	220	68	1522	nil	Within limit
46	GMH Organics	kunjhal barotiwala	FOL OF ETP (Inlet to CETP)	28.7.21	301	5.98	132	620	124	2210	1.2	Within limit
47	Aqua viote laboratories	plot no 4 kunjhal jharmajri	FOL OF ETP (discharge to CETP)	28.7.21	305	7.13	52	112	24	1110	nil	Within limit
48	Avenu remedies	plot no 7 ia Phase-iv Bhatolikalan	FOL OF ETP (discharge to CETP)	29.7.21	355	7.78	67	108	20	1250	nil	Within limit
49	Aspo pharmaceutical	plot no 10 ia Phase-iv Bhatolikalan	FOL OF ETP cum STP	29.7.21	362	7.25	61	160	26	1478	nil	Within limit
50	Scott Edil pharmacia	Plot no 56 EPIP -1 Baddi	FOL OF ETP (discharge to CETP)	29.7.21	287	7.23	52	320	124	2280	nil	Above limit
51	Aikon formulation	plot no 158 IA EPIP jharmajri	FOL OF ETP (discharge to CETP)	29.7.21	391	7	69	120	30	1268	nil	Within limit
52	Mile stone unit 8	jharmajri baddi	FOL OF ETP (discharge to CETP)	30.7.21	413	7.89	82	340	84	2610	0.38	Above limit
53	Sanshul engineer	P.No 114 EPIP -I engineers	Collection tank to CETP	28.7.21	322	8.37	124	440	88	2330	0.12	Above limit
54	Indogreen plastic technologies	Kh.no 12 Katha Baddi	FOL of ETP	29.7.21	339	7.1	626	1200	480	1520	1.4	Above limit
55	Gil Industries	Plot no 8 EPIP-I Jharmajri Baddi	Collection tank to CETP	28.7.21	316	7.89	184	380	128	2420	0.18	Above limit
56	SV ltd unit-II	Hill Top Jharmajri Baddi	FOL of ETP cum STP	28.7.21	329	7.78	206	364	88	1464	0.16	Within limit
57	Curetech Skincare	Plot No -34 Phase-IV Bhatolikalan Baddi	final outlet of ETP	29.7.21	335	6.76	336	2200	640	828	3.12	Above limit
58	Mediwell Biotech	Bhatolikalan Baddi	final outlet of ETP	29.7.21	336	8.38	267	880	400	1628	1.43	Above limit
59	Kingston Aqua Industries	Plot -3 Himuda Flats Bhatolikalan	final outlet of ETP	29.7.21	334	7.86	236	440	104	2282	0.12	Above limit
60	Montek Biopharma	45 IA Baddi	FOL of ETP	29.7.21	337	8.38	176	820	380	1420	0.23	Above limit
61	Osper formulation	Pot no 134 B EPIP -I Jharmajri	FOL OF ETP (discharge to CETP)	28.7.21	315	7.5	79	200	68	1480	0.12	Within limit
62	Lotus herbal color cosmetics	Pot no 80B EPIP -I Jharmajri	FOL discharge to CETP)	28.7.21	325	7.39	262	2040	620	1116	2.1	Above limit
63	M/s Rescuers Life Science Ltd	Plot no 131-132 EPIP-I Jharmajri	FOL OF ETP (discharge to CETP)	28.7.21	314	7.39	68	188	62	980	0.12	Within limit
64	Sun Pharma	Barotiwala baddi	final outlet of ETP	28.7.21	297	7.98	134	320	84	2010	1.2	Within limit
65	VENUS REMEDIES	Hill top ind estate EPIP -I Baddi	FOL OF ETP (discharge to CETP)	28.7.21	298	7.14	152	640	220	2380	0.46	Above limit
66	Hindustan unilever	Hill top IA Bhatolikalan	FOL OF ETP (discharge to CETP)	28.7.21	308	7.12	62	188	46	1264	0.12	Within limit
67	Gopal life science unit-2	Hill top ind estate near jharmajri	FOL OF ETP (discharge to CETP)	28.7.21	307	7.78	72	204	76	1120	0.16	Within limit

10

68	Plane remedies	plot no 17 HPSIDC baddi	FOL OF ETP (discharge to CETP)	29.7.21	332	7.9	76	404	120	2184	0.14	Within limit
69	Colgate palmolive india	jharmajri baddi	discharge to CETP	28.7.21	324	7.1	62	140	20	1476	Nil	Within limit
70	Aliance india unit-ii	EPIP Exp Bhatolikalan	FOL OF ETP (discharge to CETP)	28.7.21	311	7.62	86	200	76	1420	0.2	Within limit
71	Temple packaging	bhatolikalan baddi	collectioun tank to cetp	28.7.21	321	7.14	684	1280	384	1850	3.8	Above limit
72	Admac Lifescience	Plot no 107-A EPIP -I Jharmajri Baddi	FOL OF ETP (discharge to CETP)	28.7.21	312	7.32	76	260	94	1080	0.24	Within limit
73	Amster lab unit-ii	Hill top bhatolikalan	FOL OF ETP (discharge to CETP)	28.7.21	310	7.62	272	2100	1060	2434	4.82	Above limit
74	Unichem laboratories unit-1	bhatolikalan	FOL OF ETP (discharge to CETP)	28.7.21	331	7.16	76	104	20	984	nil	Within limit
75	wockhard	kunjhal barotiwala	FOL OF ETP (discharge to CETP)	28.7.21	304	7.78	42	104	26	1490	0.06	Within limit
76	Gogia flavours & fragrances	jharmajri baddi	FOL OF ETP (discharge to CETP)	28.7.21	303	8.22	152	384	120	980	0.46	Within limit
77	Saundrya prasadhan	Jharmajri baddi	FOL OF ETP (discharge to CETP)	28.7.21	313	7.58	108	380	120	2240	0.28	Above limit
78	Yash appliances	Katha baddi	FOL OF ETP (discharge to CETP)	29.7.21	340	7.16	526	1280	488	1420	1.12	Above limit
79	hesa pharema	bhatolikalan baddi	collectioun tank to cetp	29.7.21	333	6.78	136	940	220	984	0.24	Within limit
80	GMH LABO	Bhatolikalsan baddi	FOL OF ETP (discharge to CETP)	29.7.21	338	8	286	2660	1280	1540	2.18	Above limit
81	Ayurvet	Katha baddi	FOL OF ETP (discharge to CETP)	29.7.21	341	7.16	66	94	18	820	nil	Within limit
82	Wockhardt ltd	kunjhal barotiwala	FOL OF ETP (discharge to CETP)	20.7.21	254	6.74	78.8	240	88	1820	0.2	Within limit
83	M/s P & G Home products	Katha baddi	FOL OF ETP (discharge to CETP)	20.7.21	255	7.35	28.2	96	12	2304	0.11	Above limit
84	Acme life (tech llp)	LLP Jharmajri Baddi	FOL OF ETP (discharge to CETP)	20.7.21	256	7.33	153.6	824	184	2250	0.62	Above limit
85	Sun Pharma	Hill top Bhatolikalan Baddi	FOL OF ETP (discharge to CETP)	20.7.21	257	7.01	30.9	820	174	3170	1.26	Above limit
86	Nectar lifesciences ltd unit-ii	Hill top Bhatolikalan Baddi	FOL OF ETP (discharge to CETP)	20.7.21	258	7.67	16.7	880	380	2817	1.06	Above limit
87	Innova Caplab ltd	Hill top Bhatolikalan Baddi	FOL OF ETP (discharge to CETP)	20.7.21	259	6.61	719.6	1240	444	2750	1.28	Above limit
88	Scott Edli pharmacia	EPIP-I Jharmajri	FOL OF ETP (discharge to CETP)	20.7.21	260	7.41	27.6	640	220	936	0.22	Within limit
89	Loreal india pvt ltd	EPIP Phase-I Jharmajri	FOL OF ETP (discharge to CETP)	20.7.21	261	7.13	101.4	1280	600	2420	1.1	Above limit
90	Winsome Textile Industries	Sai Road Tehsil Baddi	Discharge to CETP Category I	20.7.2021	262	7.67	47.2	116	26	887	-	Above limit
91	Winsome Textile Industries	Sai Road Tehsil Baddi	Discharge to CETP Category IV	20.7.2021	263	7.03	89.9	108	22	4832	-	Above limit
92	M/S Sara Textile Ltd	VPO Bhatian	final outlet of ETP cum STP	21.7.2021	264	7.78	17	120	26	1812	Nil	Within limit
93	Siddhartha Super Spinning Mills Ltd	Village Nihal Khera, Nalagarh	FOL of ETP cum STP	21.7.2021	265	7.81	15.6	84	12	1450	Nil	Within limit
94	Auro Textile Unit-I	Sai Road Tehsil Baddi	Discharge to CETP baddi	21.7.2021	266	8.18	55.8	316	98	1101	0.18	Above limit
95	Auro Textile Unit-I	Sai Road Tehsil Baddi	FOL of ETP after RO (Recycle)	21.7.2021	267	8.19	3.8	4	1	330	0.16	Within limit
96	Auro Dyeing Unit-I	Sai Road Tehsil Baddi	Discharge to CETP Baddi Category I	21.7.2021	268	7.64	54.2	188	62	920	-	Above limit
97	Auro Textile Unit-II	Sai Road Tehsil Baddi	Discharge to CETP Baddi Category-I.	21.7.2021	269	7.07	69.4	940	320	804	-	Above limit
98	Elfin Drugs Pvt. Ltd	Village Bersam, Nalagarh	FOL of ETP cum STP.	21.7.2021	270	7.04	22.5	264	84	650	0.14	Above limit
99	Onyx Biotech Pvt. Ltd	Village saini majra, Nalagarh	FOL of STP	21.7.2021	271	8.06	46.8	280	94	920	0.16	Within limit
100	Macleods Pharmaceutical Ltd	Village Theda, Nalagarh	Discharge to CETP	21.7.2021	272	7.78	87.5	960	320	2062	0.86	Within limit
101	Morepen Laboratories Ltd	Village Thana, Nalagarh	Discharge to CETP	21.7.2021	275	7.67	9.3	64	8	438	Nil	Within limit
102	Johnson & Johnson	Village Bhatolikalan, Baddi	Discharge to CETP	21.7.2021	276	7.04	158	268	58	3840	0.44	Above limit

12

103	Panacea Biotech	Village Bhud, Baddi,	FOL Discharge to CETP	21.7.2021	277	6.88	160.4	780	280	2740	0.44	Above limit
104	Kandhari Beverages Pvt. Ltd.,	Village Katha, Baddi	Final outlet of ETP Discharge to CETP	12.7.2021	223	7.34	51.5	372	78	1494.8	1.82	Within limit
105	Green Lam Industries Ltd	Panjhera, Nakagrh	final outlet of ETP cum STP	13.07.2021	238	7.61	3.9	8	2	595	Nil	Within limit
106	Green Lam Industries Ltd	Panjhera, Nakagrh	observatory well near ETP	13.07.2021	239	8.16	14.7	12	1	294	Nil	Within limit
107	Yash Appliances	Plot No 04 & 06, Behind Coca Cola, Katha,	FOL of ETP discharge to CETP	29.07.2021	364	7.1	384	1280	320			
108	Signam Electrowave	Plot no 7 DIC IA abddi	FOL of ETP discharge to CETP	20.07.2021	247	7.21	87.8	260	58	2219	0.18	Above limit
109	Hetro Lab Unit-1	kalyanpur Baddi	FOL of ETP discharge to CETP	20.07.2021	248	6.22	136	884	278	2610	0.26	Above limit
110	Hetro Lab Unit-II	kalyanpur Baddi	FOL of ETP discharge to CETP	20.07.2021	249	6.03	583	1480	620	2670	1.2	Above limit
111	Jupiter international ltd.	katha Baddi	FOL of ETP discharge to CETP	20.07.2021	250	6.58	13.4	64	12	1608	0.1	Within limit
112	Jupiter Solar power Ltd.	katha Baddi	FOL of ETP discharge to CETP	20.07.2021	251	6.33	27.9	94	18	3320	0.14	Above limit
113	Mac Enterprises pvt. Ltd.	katha Baddi	FOL of ETP discharge to CETP	20.07.2021	252	7.17	179.2	340	120	1137	0.26	Within limit
114	Eastman power Ltd.	Bated Barotiwala	FOL of ETP discharge to CETP	20.07.2021	253	8	72.8	540	184	1757	Within limit
115	Immacule life Science	Thaehwal Ropar Road Nalagarh	FOL of ETP	4.02.2021	1060	8.36	1.9	52	10	757.4	..	Within limit
116	life vision healthcare	Plot no140 EPI phase _I Jharmajri Baddi	FOL of ETP discharge to CETP	29.07.2021	375	6.3	243	2024	640	1006	0.8	Above limit
117	Live Well healthcare	Pl. No 90A-1 EPIP phase-i Jharmajri Baddi	storage tank to CETOP	29.07.2021	376	6.47	358	580	204	1206	0.6	Within limit
118	Innova Captab	EPIP phase-I Jharmajri Baddi	FOL of ETP discharge to CETP	29.07.2021	377	6.47	180	610	228	2306	0.6	Above limit
119	Captab Biotech Unit-II	EPIP phase-I Jharmajri Baddi	FOL of ETP discharge to CETP	29.07.2021	378	7.78	146	580	224	1860	0.6	Within limit
120	Xcell labs	146 EPIP phase-I Jharmajri Baddi	FOL of ETP discharge to CETP	29.07.2021	379	6.13	526	6240	1480	1530	0.6	Above limit
121	Alpha products	Kh.No 171/1 bhatolikalan Baddi	FOL of ETP discharge to CETP	29.07.2021	380	6.8	190	2000	620	960	0.48	Above limit
122	Unix biotech Pvt. Ltd	Pl.No 27 EPIP Baddi	FOL of ETP discharge to CETP	29.07.2021	381	6.7	205	2240	840	1460	1.12	Above limit
123	Nihal Healthcare	Plot nO 33 EPIP Baddi	FOL of STP	29.07.2021	382	6.82	75	220	62	860	0.14	Above limit
124	Axiom Controls Ltd.	Pl.no 2-III Epip Baddi	FOL of ETP	29.07.2021	383	6.92	85	200	58	1660	0.1	Above limit
125	Pee Ess Dishnet Pvt. Ltd	Pl.No-84 EPIP Baddi	FOL of ETP discharge to CETP	29.07.2021	384	6.92	84	340	88	982	0.14	Within limit
126	Smilax healthcare Pvt. Ltd.	Plot no -EPIP Phase-I Jharmajri	FOL of ETP discharge to CETP	29.07.2021	388	7.45	122	424	180	1510	0.1	Within limit
127	M/s Krypton Pharmaceutical	plot no 69,EPIP-I Jharmajri	FOL OF ETP (discharge to CETP)	29.7.21	389	6.18	122	1460	620	1650	1.4	Above limit
128	Aeon polymer	plot no -80,EPIP-I Jharmajri	FOL OF ETP (discharge to CETP)	29.7.21	392	7.89	212	960	340	2436	0.34	Above limit
129	Manjushree Technopack Ltd	plot no -70,71,EPIP-I Jharmajri	storage tank to cetp	29.7.21	390	7.58	342	380	124	1378	0.28	Above limit
130	M/s Shri ram healthcare unit-i	plot no -81,EPIP-I Jharmajri	FOL OF ETP (discharge to CETP)	29.7.21	393	6.89	212	960	340	2436	0.34	Above limit
131	Crest life science	plot no -127-128,EPIP-I Jharmajri	FOL OF ETP (discharge to CETP)	29.7.21	394	7.29	122	260	80	1106	0.14	Within limit
132	crest tropical pvt ltd	plot no -81 c,EPIP-I Jharmajri	FOL OF ETP (discharge to CETP)	29.7.21	395	7.27	640	1460	580	2206	0.48	Above limit

102 103

133	AAR GEE Formulation	plot no -123,EPIP-I	FOL OF ETP (discharge to CETP)	29.7.21	397	6.94	520	2020	840	1346	0.48	Above limit
134	Alliance formulation	plot no -30-31-32,EPIP-I	FOL OF ETP (discharge to CETP)	29.7.21	399	7.34	73	220	40	1255	nil	Within limit
135	Torque pharmaceutical pvt ltd	plot no -13B-14,EPIP-I	FOL OF ETP (discharge to CETP)	29.7.21	400	4.34	208	1420	440	1346	NIL	Above limit
136	Symbiotic Drugs & diabetic care p ltd	plot no -35,EPIP-I	FOL OF ETP (discharge to CETP)	29.7.21	401	6.14	312	880	320	1602	0.12	Above limit
137	Wipro Enterprises pvt ltd unit-ii	plot no -87,EPIP-I	FOL OF ETP (discharge to CETP)	29.7.21	402	7.02	212	120	26	1562	nil	Within limit
138	Indogreen plastic technologies	Kno 12 katha Baddi	FOL OF ETP (discharge to CETP)	29.7.21	339	7.1	626	1200	480	1520	1.4	Above limit
139	Kahna Biogenotic	plot no 1C EPIP-I Jharmajri	FOL OF ETP (discharge to CETP)	29.7.21	403	7.78	312	432	160	1450	nil	Above limit
140	Sobhagia cothing co	plot no 6&8 EPIP-I Jharmajri	FOL OF ETP (discharge to CETP)	29.7.21	404	7.45	142	384	140	1250	0.16	Within limit
141	Raddison Pharmaceutical	plot no 53,EPIP-I Jharmajri	FOL OF ETP (discharge to CETP)	29.7.21	406	7.67	92	184	48	1020	0.12	Within limit
142	Radiant casting	plot no 288,EPIP-I Jharmajri	FOL OF ETP (discharge to CETP)	29.7.21	408	4.27	92	340	68	1123	0.24	Above limit
143	ESS ESS Industries,	Kh. 137/1, Behind Coca Cola, Katha,	FOL of ETP discharge to CETP	29.07.2021	363	6.18	182	2140	324	1860	0.82	Above limit
144	Yash Appliances	Plot No 04 & 06, Behind Coca Cola, Katha,	FOL of ETP discharge to CETP	29.07.2021	364	7.1	384	1280	320	1420	0.82	Above limit
145	Volcano Electrical Industries	Plot No 37, Himuda IA Baddi	FOL of ETP discharge to CETP	29.07.2021	368	7.21	414	1840	820	1133	0.82	Above limit
146	Blue Heaven Cosmetics Pvt. Ltd	HPSIDC Baddi	FOL of ETP discharge to CETP	29.07.2021	370	6.86	152	540	160	880	0.28	Within limit
147	Healer Lab, Unit-II	Plot no.33, HPSIDC Extn. Baddi	FOL of ETP discharge to CETP	29.07.2021	371	7.18	210	380	164	1475	0.12	Within limit
148	Marine Life Sciences	Plot no 30, HPSIDC Extn. Baddi	FOL of ETP discharge to CETP	29.07.2021	372	7.9	292	480	224	1456	0.16	Within limit
149	Dr Sabharwal Wound care Unit-II	Bulanwala Barotiwal, Baddi	FOL of ETP discharge to CETP	30.07.2021	416	7.67	108	220	56	1130	0.16	Within limit
150	Hindustan Unilever Ltd	Balyana, Barotiwala	FOL of ETP discharge to CETP	30.07.2021	417	7.06	68	120	26	1410	Nil	Within limit
151	Pinetree Packaging Pvt Ltd	Timber Depot, Katha, Baddi	FOL of STP discharge to CETP	30.07.2021	419	7.15	78	220	64	970	0.12	Within limit
152	Kunal Aluminium co.	EPIP-I, Jharmajri, Baddi	FOL of ETP discharge to CETP	31.07.2021	421	7.58	78	104	22	750	Nil	Within limit
153	Maneesh Pharmaceuticals	Balyana near Hill Top Barotiwala,	FOL of ETP discharge to CETP	30.07.2021	418	7.98	268	720	384	1670	0.28	Above limit
154	Nikvin Healthcare PVT Ltd	Village Katha, Baddi	FOL of ETP discharge to CETP	30.07.2021	420	7	48	320	88	950	0.12	Within limit
155	Inox Air products ltd.	kunjhal IA baddi	FOL of ETP discharge to CETP	29.07.2021	415	7.45	142	240	60	960	0.122	Within limit
156	Micro Turner Unit-II	Jharmajri Baddi	FOL of ETP discharge to CETP	29.07.2021	414	7.16	542	1640	360	1286	2.22	Above limit
157	Sarvotham care	Jharmajri baddi	FOL of ETP discharge to CETP	29.07.2021	412	7.12	142	404	92	2286	0.22	Above limit
158	Gopal Cylinder	Near Export Zone Hill top Jharmajri	FOL of ETP discharge to CETP	29.07.2021	409	7.3	316	404	128	1306	0.8	Above limit
159	Ozone pharma	Katha baddi	FOL of ETP discharge to CETP	29.07.2021	411	6.88	323	2004	940	3606	2.62	Above limit
160	SSF Plastic india ltd.	Kh. 681/82 hadblast No-211 Katha	FOL of STP	29.07.2021	410	6.38	123	204	44	906	0.18	Above limit

Handwritten signatures and initials at the bottom of the page.

161	Himachal Fibre Limited,	43-44 Plot No. 43-44, Industrial Area B	FO of STP(Discharge to CETP)	08-03-21	4070109 /W-85	7.14	159.8	196	24	263.8	0.88	Within limit
162	Samson Laboratories Pvt Limited	152 Sansiwala, Barotiwala,	FO of ETP cum STP(Discharge to CETP)	08-03-21	4070110 /W-86	9	10.6	212	28	354.2	1.28	Within limit
163	Navkriti Builders Pvt Ltd,	Village Malpur, Tehsil Nalagarh	FOL of STP discharge to CETP	08-02-21	4070556 /W-81	6.88	33.6	44	8	502.3	0.24	Within limit
164	Alpla India Pvt.Ltd	Plot No.100, PLOT NO 100 EPIP PHASE	FO of ETP discharge to CETP	08-04-21	4087127 /W-82	7.22	40	112	22		0.8	Within limit
165	Cadila Healthcare Limited	Village Swaraj Majra, Juddi kalan, Baddi	FO of ETP cum STP discharge to CETP	08-05-21	4095640 /W-78	6.78	964	136	22		0.84	Above limit
166	Ion Healthcare Pvt.Ltd.,	JUDI KALAN Vill.Juddi-Kalan Barotiwala	FOL of ETP discharge to cetsp	08-05-21	4095994 /W-77	6.5	155	192	28	403.4	1.12	Within limit
167	Asian industries	Katha Baddi	Collection tank	30.7.21	463	7.64	206	240	84	1198	0.26	Within limit
168	Appaswamy ocular devices	katha baddi	Final outlet of ETP	30.7.21	462	7.64	106	140	64	978	0.26	Within limit
169	Shree balaji Enterprise	Katha Baddi	Final outlet of ETP	30.7.21	461	6.74	172	440	124	1138	0.26	Within limit
170	Faively Transport India limited	Katha Bhatolikalan	Collection tank to CETP	30.7.21	460	8.14	276	280	88	1316	0.28	Within limit
171	Polo pharmaceutical pvt ltd	200 HPDIDC BADDI	Final outlet of ETP	30.7.21	459	7.82	122	380	104	1440	0.12	Within limit
172	M/s Sigma Softgel formulation	17 HPSIDC Baddi	Collection tank discharge to CETP	30.7.21	458	8.82	260	480	200	1296	0.16	Within limit
173	Euphoria India Pharmaceutical	145 HPSIDC Baddi	Collection tank discharge to CETP	30.7.21	457	5.62	936	980	440	2340	1.2	Above limit
174	Ssrika Industries	111HPSIDC BADDI	FOL OF ETP (discharge to CETP)	30.7.21	456	7.02	60	180	38	936	0.11	Within limit
175	RCI Industries & Technologies	84 HPSIDC baddi	FOL OF ETP (discharge to CETP)	30.7.21	455	7.76	1236	380	108	268	0.32	Above limit
176	Cure tech =Formulation	Judi kalan Baddi	FOL OF ETP (discharge to CETP)	30.7.21	454	7.18	1120	1280	408	264	2.12	Above limit
177	IVN HERBAL	Khasra no 63 judikalan Baddi	FOL OF ETP (discharge to CETP)	30.7.21	453	7.05	1080	1128	440	104	2	Above limit
178	Preet remedies	184 HPSIDC	FOL OF ETP (discharge to CETP)	30.7.21	451	7.01	120	240	80	2540	0.1	Above limit
179	Unimark Pharma	130HPSIDC Baddi	FOL OF ETP (discharge to CETP)	30.7.21	450	6.69	26	104	40	540	0.1	Within limit
180	Marc laboratories	107 HPSIDC Baddi	FOL OF ETP (discharge to CETP)	30.7.21	449	8.8	202	1480	640	2200	0.14	Above limit
181	Embbros Auto Components	Katha Baddi	FOL OF STP (discharge to CETP)	30.7.21	448	6.2	102	148	44	1342	0.14	Within limit
182	Truvision Medicare	plot no -177 HPSIDC Baddi	Discharge to CETP	30.07.2021	439	7.12	106	184	46	1105	0.14	Within limit
183	Winner nippon leatherite P.Ltd.	Plot no 83 HPSIDC IA Baddi	Fol of STP discharge to CETP	30.07.2021	440	7.12	105	224	76	1405	0.18	Within limit
184	black Smith metal Work Pvt. Ltd	Plot no 93 HPSIDC IA	Fol of STP discharge to CETP	30.07.2021	441	7.92	127	280	72	1324	0.22	Within limit
185	Cosmic Industries	Plot no 19 DIC Baddi	FOL of ETP discharge to CETP	31.7.21	482	7.34	168	400	184	1280	0.28	Within limit
186	Cyper Pharma	Sai Road Baddi	Storage tank to CETP	31.7.21	484	6.14	310	460	204	1350	0.18	Above limit
187	Lifecare Remedies (MPL pharma-)	IA Ext-II Baddi	Storage tank discharge to CETP	31.7.21	485	6.02	278	620	244	1270	0.2	Above limit
188	The Engravure	Plot no 154 Baddi	FOL of ETP discharge to CETP	31.7.21	486	7.12	178	140	40	936	Nil	Within limit
189	AV Auto Industries p Ltd	Plot No 59-60 IA Baddi	FOL of ETP discharge to CETP	31.7.21	488	7.78	278	104	38	1592	Nil	Above limit
190	Trisis Venture (Trisi Corp Unit-II)	116 IA Baddi	FOL of ETP discharge to CETP	31.7.21	489	7.56	268	284	108	1172	0.12	Within limit
191	Padlean Venture	175 DIC IA Baddi	FOL of ETP discharge to CETP	31.7.21	490	7.22	360	680	188	1365	0.18	Above limit
192	Arcon Lab	100 DIC IA Baddi	FOL of ETP discharge to CETP	31.7.21	491	7.62	160	280	78	1028	0.1	Within limit
193	Pidlite Industries Limited	Plot No 85 , Bhatolikalan	FOL of ETP discharge to CETP	31.7.21	492	7.08	48	80	12	820	Nil	Within limit
194	Pidlite Industries Limited	Plot no 75-77Bhatolikalan Baddi	FOL of ETP discharge to CETP	31.7.21	493	7.12	76	120	28	980	Nil	Within limit
195	Gopal Cylinder Unit-III	EPIP-I, Bhatolikalan, Baddi	FOL of ETP discharge to CETP	31.07.2021	422	7.15	118	224	42	1122	0.14	Within limit
196	Govind Gopal LPG industries Ltd	Near Jharmajri Bus Stand, baddi	FOL of ETP discharge to CETP	31.07.2021	423	7.89	218	312	92	1732	0.14	Within limit
197	Alana Healthcare Pvt Ltd	Jharmajri, Baddi	FOL of ETP discharge to CETP	31.07.2021	424	6.69	348	1880	980	1056	3.14	Above limit
198	Biogenetic Drugs Pvt Ltd.	Jharmajri, Baddi	FOL of ETP discharge to CETP	31.07.2021	425	5.2	1380	3080	1280	3056	6.14	Above limit
199	Chemex Oil Pvt Ltd	Barotiwala baddi	FOL of ETP cum STP	31.07.2021	426	7.2	180	180	40	756	0.14	Within limit
200	Shree Ganesh Fats Pvt Ltd	Bharotiwala, Baddi	FOL of ETP cum STP	30.07.2021	427	7.1	62	184	42	1756	0.12	Within limit
201	Hygienic Research Institute	Buranwala, Baddi	FOL of ETP discharge to CETP	31.07.2021	428	7.24	39	204	44	756	0.12	Within limit
202	Him Corp (Near Chintamani School)	Buranwala, Barotiwala,	FOL of ETP discharge to CETP	30.07.2021	429	7.24	59	164	38	956	0.12	Within limit
203	Greef Formulations	Plot No 134, IA Kotla Road, Barotiwala	FOL of ETP discharge to CETP	30.07.2021	430	7.18	89	244	42	926	0.12	Within limit
204	Adley Formulations,	Kotla Road, Barotiwala	FOL of ETP discharge to CETP	30.07.2021	431	7.58	296	440	120	1912	0.16	Within limit

12 ll

205	Kamal Enterprises Unit-II	Kotla, Barotiwala	FOL of ETP discharge to CETP	30.07.2021	433	6.87	100	140	20	854	0.04	Within limit
206	Ultra Drugs Pvt Ltd Unit-II,	Katha, Barotiwala	FOL of ETP discharge to CETP	30.07.2021	434	4.97	178	840	424	2354	1.14	Above limit
207	Alliance Biotech	440/3, Katha, Barotiwala	Collection Tank to CETP	30.07.2021	435	6.72	158	140	44	885	0.14	Within limit
208	Heal Care Lifesciences	Plot No. 730, HPSIDC Juddikalan, Baddi	Discharge to CETP	30.07.2021	436	7.42	178	240	64	935	0.14	Within limit
209	Shree Raghunath Wire	Plot No. 176, HPSIDC, Baddi	Discharge to CETP	30.07.2021	437	4.42	125	160	36	2305	0.14	Within limit
210	Cosmas Pharmacls	Kotla, Barotiwala	FOL of ETP discharge to CETP	30.07.2021	438	7.18	186	640	220	1354	1.04	Within limit
211	MSJ Bath fitting & accessories pvt ltd	Village Jharmajri PO Barotiwala	FOL of ETP discharge to CETP	3.8.21	149	7.47	29	72	12	1396	0.56	Within limit
212	Vaidya Nutraceutical pvt ltd	Village Balyana PO Barotiwala	FOL of ETP discharge to CETP	3.8.21	178	7.38	13.6	24	8	329.5	0	Within limit
213	SK Files & Tools	Village Bauranwala PO Barotiwala	FOL of ETP discharge to CETP	3.8.21	179	4.49	62.3	100	34	8754.3	0.56	Above limit
214	KN Paper & Packaging	Village Bated Barotiwala	FOL of ETP discharge to CETP	3.8.21	181	7.11	80.5	416	200	335.7	2.88	Within limit
215	Milestone gear unit-IV	Barotiwala Nalagarh	Discharge to CETP	3.8.21	182	6.83	4938	4700	2100	443.9	16.48	Above limit
216	Regal kitchen foods limited	Plot no 7 IA Barotiwala	FOL of ETP cum STP discharge to cetp	3.8.21	183	7.77	3.2	16	4	275.4	0	Within limit
217	Himachal Fibre Limited,	Plot no 43-44 IA barotiwala	FOL OF STP (discharge to CETP)	3.8.21	85	7.14	159.8	196	24	263.8	0.88	Within limit
218	Samson laboratories pvt limited	152 Sansiwala barotiwala	FOL of ETP cum STP discharge to cetp	3.8.21	86	6.88	10.6	212	28	354.2	1.28	Within limit
219	Anrose pharma	147 Sansiwala barotiwala	FOL of ETP discharge to CETP	3.8.21	184	7.51	5.3	40	10	406.9	0	Within limit
220	Haripur kradft company	Village bated barotiwala	Discharge to CETP	3.8.21	185	7.01	113.2	576	380	534.3	3.52	Above limit
221	Haripur paper company	villaged bated bnarotiwala	Discharge to CETP	3.8.21	186	6.52	177	1968	960	1183	8.2	above limit
222	Pofestar power industries	Haripur road barotiwala	FOL of ETP discharge to CETP	3.8.21	187	3.89	184.4	4120	1840	226.7	15.4	above limit
223	RSH Global pvt ltd	Plot no 74, DIC IA baddi	FOL of ETP discharge to CETP	3.8.21	188	6.91	1157	1292	460		6.2	Above limit
224	RSH Global pvt ltd	Plot no 3c Katha baddi	FOL of ETP discharge to CETP	3.8.21	199	12.11	165.1	804	360		2.32	Above limit
225	Critus life science pvt ltd	Malpur baddi	FOL of ETP discharge to CETP	2.8.21	191	7.95	145	888	400		2.56	Above limit
226	Godrej consumer product	Plot no 6 IA Katha Baddi	FOL of ETP discharge to CETP	3.8.21	200	7.33	219.4	864	380		1.92	Above limit
227	YL Pharma	Katha Baddi	FOL of ETP discharge to CETP	3.8.21	201	7.26	149.6	1204	610		1.12	Above limit
228	Luminous Power Technologies	Village Malpur Bhud Baddi	FOL OF STP (discharge to CETP)	2.8.21	193	6.8	703.2	1200	480		2.4	Above limit
229	Health Biotech limited	Village Sandholi Baddi	FOL of ETP discharge to CETP	3.8.21	202	6.38	137.6	1072	280		2.56	Above limit
230	Ancorotti Cosmetic india	Plot no 12 Katha Baddi	FOL of ETP discharge to CETP	2.8.21	194	7.56	84.2	940	440		2.72	Above limit
231	Helios Pharmaceutical	Malpur Bhud baddi	FOL of ETP discharge to CETP	2.8.21	195	7.9	132.4	1144	580		3.2	Above limit
232	JSK International	Village Gullarwala Baddi	Collection tank discharge to CETP	3.8.21	208	7.34	100	96	28		0.6	Within limit
233	Reckitt benkiser healthcare	Village Sandholi Baddi	FOL of ETP cum STP discharge to cetp	2.8.21	198	7.82	131.6	820	380		2.88	Above limit
234	Navkriti Builder pvt ltd	Malpur baddi	FOL OF STP (discharge to CETP)	2.8.21	81	6.88	33.6	44	8	502.3	0.24	Within limit
235	Pearl polymer Limited	Village Sandholi Baddi	FOL OF STP (discharge to CETP)	2.8.21	190	7.86	233.2	864	410		2.72	Above limit
236	Knox Life Sciences	Khasra no 370 village Gullerwala	FOL of ETP discharge to CETP	3.8.21	209	7.67	98.2	20	2.8	356.9	0	Within limit
237	Aeristo laboratories	Makhnu majra Bhud Baddi	FOL of ETP discharge to CETP	3.8.21	252	8.34	16.8	32	3.2	721.3	0	Within limit

1/20

The representative of HPSPCB in the Joint Committee apprised that the following action has been taken by HPPCB for consideration of Hon'ble National Green Tribunal:

1. In compliance to orders of Hon'ble NGT dated 23.06.2021 the State Board has again filed second criminal complaint against the Baddi Infrastructure (operator of CETP) in the Court of Ld Civil Judge Nalagarh on 12.8.2021 for violations observed during the period w.e.f. 17.12.2019 to 04.05.2021 after approval from competent authority.
2. The State Pollution Control Board has also filed Criminal Complaints against the Textile units i.e. Vardhman Textile Limited (Auro textile-I, Auro Textile-II & Auro Dyeing-I) for violation observed during the period 21.01.2021 to 30.06.2021 and Winsome Textile Limited, for the violation observed during the period 21.01.2021 to 30.06.2021 in the court of Ld Civil Judge Nalagarh on 4.8.2021 after approval from competent authority.
3. That as the Winsome Textile Limited had not installed the Tertiary system for treatment of Category-IV and the unit was still non-complaint to parameter of FDS (CAT-IV) upto 20.7.2021 hence HPSPCB has issued directions under section 33-A of Water Act, 1974 for power disconnection of Winsome Textile Limited on 19.08.2021. The unit has further obtained the stay from the Hon'ble High Court of HP by filing CMP in already pending matter i.e. CWP No. 417 of 2021 on dated 24.08.2021 against directions of the HPSPCB. The matter is listed for 26.10.2021 for final hearing and which is being strongly contested by the Board.
4. In compliance to orders of Hon'ble NGT dated 23.06.2021 HPSPCB has filed applications on 13.7.2021 for early hearing in four pending matters i.e. CWP No. 414/2021, 416/2021 417/2021, 418/2021 filed by M/s Vardhman Textile (Auro Textile-I, Auro Textile-II & Auro Dyeing-I) and M/s Winsome Textile against the Board's directions for levy of Environment Compensation and closure of dyeing sections. The applications were allowed on 24.7.2021 and matters were partly heard on 10.9.2021. These matters have been further listed for final hearing on 26.10.2021 by the Hon'ble High Court of HP wherein PCB has been directed to produce record of the units. These matters are being strongly contested by the Board before the Hon'ble High Court **(Copies of orders annexed as Annexure-A)**.
5. The State Board has also filed an application on 20.7.2021 for early hearing of the CWP No. 3462/2019 pending before the Hon'ble High Court of HP wherein the Baddi Infrastructure (operator of CETP) has obtained stay order against the Board's directions for levy of Environment Compensation. Considering Board's application Hon'ble High Court of HP ordered to list the matter for final hearing on 13.9.2021. On 13.9.2021 due to sudden demise of Hon'ble Mr Justice P.N. Nag (Retired) matter was adjourned for 29.10.2021. **(Copies of orders annexed as Annexure-B)**.
6. The HPSPCB further conducted sampling of Industries having hydraulic load more than 200 KLD which are connected with the CETP Baddi was conducted during the Month July and August and as per analysis reports received from the laboratory the results of all the units are

complying with norms except M/s Winsome Textile Limited which is still non complying to prescribed norms for CAT-IV effluent discharged to CETP Baddi. **(Copy Annexed as Annexure-C & C1).**

7. The HPSPCB has conducted sampling of Industries having hydraulic load less than 200 KLD which are connected with the CETP Baddi in the month of July, 2021 and August, 2021. In this regard it is pertinent to mention here that the Baddi Barotiwala Nalagarh Industrial Association (BBNIA) has filed a CWP No. 4961/2021 before the Hon'ble High Court of HP on the ground that the notification dated 26.12.2019 (reg. inlet parameters) is not applicable to the member industries having discharge of less than 200 KLD in terms of Environmental Clearance Granted by MOEF & CC to the CETP Baddi. Before the State Board could have taken any action for violation of norms, the Hon'ble High Court of HP vide order dated 1.9.2021 restrained the HPSPCB not to take coercive action against the petitioners qua violation of notification dated 26.12.2019. The Matter is further listed on 27.10.2021 before the Hon'ble High Court of HP and is being vehemently contested by the State Board. **(Copy of order is annexed as Annexure-D).**
8. The unit M/s Vardhman Textiles limited has installed and made functional the Reverse Osmosis plant along with Multi Effect Evaporator and has stopped discharging the Cat-IV- effluent (High TDS/FDS) to CETP Baddi and now whole the CAT-IV effluent after treatment is recycled in the plant. The Analysis results of sample collected after treatment from RO plant is complying to norms as prescribed in Environment Protection Act, 1986 for textile industries.
9. The unit M/s Winsome Textile limited has completed the work for installation of proposed Reverse osmosis plant and the same is on trial run and is still continuing to discharge its high TDS/FDS effluent to CETP Baddi. The analysis results of sample collected were not found complying to CETP inlet norms. The State Pollution Control Board has initiated the action against Winsome Textile Limited on dated 19.08.2021 under section 33-A of Water Act **(Copy Annexed as Annexure-E)** as the unit had not installed the Tertiary system for treatment of Category-IV and the unit was still non-complaint to parameter of FDS (CAT-IV) at that time. As mentioned above the unit has further taken stay from the Hon'ble High Court of HP in CWP No. 417 of 2021 on dated 24.08.2021 against the action initiated by the State Pollution Control Board. The State Pollution Control Board has also filed Criminal Complaints against the M/s Winsome Textile Limited, for the violation observed during the period 21.01.2021 to 30.06.2021 in the court of Ld Civil Judge Nalagarh on 4.8.2021 in which the proceedings are ongoing. **(Copy Annexed as Annexure-F).**
10. The State Pollution Control Board is conducting regular sampling of Common Effluent Treatment plant at Baddi and as on date the analysis results of sample collected since 21.05.2021, the CETP is complying to discharge standards prescribed for Common Effluent Treatment plant in Environment Protection Act, 1986 **(Copy Annexed as Annexure-G).**



(Annexure - A)

CWP No. 416 of 2021

11.01.2021 Present: Mr. R.L.Sood, Sr. Advocate with M/s Arjun Lall and Sanjay Kumar, Advocates, for the petitioner.

Mr. Ashok Sharma, Advocate General with M/s Ranjan Sharma, Adarsh Sharma and Vinod Thakur, Additional Advocates General for respondent No.1.

Mr. Maan Singh, Advocate for respondents No. 2 and 3, through video conference.

CMP No. 632 of 2021

Allowed and disposed of.

CWP No. 416 of 2021 & CMP No. 634 of 2021

Notice. Mr. Adarsh Sharma, learned Additional Advocate General accepts notice on behalf of respondent No. 1. On his instructions, Mr. Ashok Sharma, learned Advocate General appears for respondent No. 1. Mr. Maan Singh, learned Counsel accepts notice on behalf of respondents No. 2 and 3. As prayed for, reply be filed within six weeks.

List on 15.03.2021, before the appropriate Bench. Till the next date of hearing, operation of impugned orders, i.e. Annexures P-23, dated 29.12.2020 and P-24, dated 01.01.2021, shall remain stayed.

CMP No. 636 of 2021

This application is disposed of with the direction that the applicant shall file legible/typed copies of documents in issue within a period of four weeks.

Copy *dasti*.

(Ajay Mohan Goel)
Vacation Judge

January 11, 2021
(narender)

12

12



CWP No.416 of 2021

10.09.2021 Present: Mr. R.L. Sood, Sr. Advocate, with Mr. Arjun Lall, Advocate, for the petitioner.

Mr. Adarsh Sharma, Mr. Sumesh Raj, Mr. Sanjeev Sood, Additional Advocates General, for the respondent No.1.

Mr. K.D. Shereedhar, Sr. Advocate, with Mr. Maan Singh, Advocate, for respondents No.2 and 3.

CWP No.416 of 2021 & CMP No.7936 of 2021

Heard for some time. List for continuation on 26.10.2021 as part heard matter, on which date relevant record pertaining to the case shall be kept available by the respondents concerned. Interim to continue.

(Ajay Mohan Goel)
Judge

September 10, 2021
(Rishi)

12

4



CWP No.417 of 2021

02.09.2021 Present: Mr. R.L. Sood, Sr. Advocate, with Mr. Arjun Lall, Advocate, for the petitioner.

Mr. Adarsh Sharma, Mr. Sumesh Raj, Mr. Sanjeev Sood, Additional Advocates General, with Mr. Kamal Kant Chandel, Deputy Advocate General, for the respondent No.1.

Mr. K.D. Shreedhar, Sr. Advocate, with Mr. Maan Singh, Advocate, for respondents No.2 and 3.

CWP No.417 of 2021 & CMP No.7937 of 2021

Learned Senior Counsel, appearing for the petitioner, on instructions, submits that rejoinders to the replies have been filed by the petitioner. Registry is directed to place the same on record, if in order.

As prayed for, list for consideration on

10.09.2021. Interim to continue.

(Ajay Mohan Goel)
Judge

September 02, 2021
(Rishi)

12 44



CWP No.417 of 2021

10.09.2021 Present: Mr. R.L. Sood, Sr. Advocate, with Mr. Arjun Lall, Advocate, for the petitioner.

Mr. Adarsh Sharma, Mr. Sumesh Raj, Mr. Sanjeev Sood, Additional Advocates General, for the respondent No.1.

Mr. K.D. Shereedhar, Sr. Advocate, with Mr. Maan Singh, Advocate, for respondents No.2 and 3.

CWP No.417 of 2021 & CMP No.7937 of 2021

Heard for some time. List for continuation on 26.10.2021 as part heard matter, on which date relevant record pertaining to the case shall be kept available by the respondents concerned. Interim to continue.

(Ajay Mohan Goel)
Judge

September 10, 2021

(Rishi)

12 4



CWP No. 418 of 2021

11.01.2021 Present: Mr. R.L.Sood, Sr. Advocate with M/s Arjun Lall and Sanjay Kumar, Advocates, for the petitioner.

Mr. Ashok Sharma, Advocate General with M/s Ranjan Sharma, Adarsh Sharma and Vinod Thakur, Additional Advocates General for respondent No.1.

Mr. Maan Singh, Advocate for respondents No. 2 and 3, through video conference.

CMP No. 639 of 2021

Allowed and disposed of.

CWP No. 418 of 2021 & CMP No. 641 of 2021

Notice. Mr. Adarsh Sharma, learned Additional Advocate General accepts notice on behalf of respondent No. 1. On his instructions, Mr. Ashok Sharma, learned Advocate General appears for respondent No. 1. Mr. Maan Singh, learned Counsel accepts notice on behalf of respondents No. 2 and 3. As prayed for, reply be filed within six weeks.

List on 15.03.2021, before the appropriate Bench. Till the next date of hearing, operation of impugned orders, i.e. Annexures P-23, dated 29.12.2020 and P-24, dated 01.01.2021, shall remain stayed.

CMP No. 642 of 2021

This application is disposed of with the direction that the applicant shall file legible/typed copies of documents in issue within a period of four weeks.

Copy *dasti*.

(Ajay Mohan Goel)
Vacation Judge

January 11, 2021
(narender)

12
11



CWP No.418 of 2021

10.09.2021 Present: Mr. R.L. Sood, Sr. Advocate, with Mr. Arjun Lall, Advocate, for the petitioner.

Mr. Adarsh Sharma, Mr. Sumesh Raj, Mr. Sanjeev Sood, Additional Advocates General, for the respondent No.1.

Mr. K.D. Shreedhar, Sr. Advocate, with Mr. Maan Singh, Advocate, for respondents No.2 and 3.

CWP No.418 of 2021 & CMP No.7938 of 2021

Heard for some time. List for continuation on 26.10.2021 as part heard matter, on which date relevant record pertaining to the case shall be kept available by the respondents concerned. Interim to continue.

(Ajay Mohan Goel)
Judge

September 10, 2021
(Rishi)



(Annexure-B)

CWP No. 3462 of 2019

13.9.2021

Present: Mr.Rahul Gathania, Advocate, vice Mr.ZArjun Lal, Advocate, for the petitioner.

Mr.Anil Jaswal, Additional Advocate General, for respondent No. 1.

Mr.Shakti Bhardwaj, Advocate, vice Mr.Maan Singh, Advocate, for respondents No. 2 to 4.

Due to sudden demise of Hon'ble Mr.Justice P.N. Nag (Retired), original counsel for private parties are not available. On request made on their behalf, adjourned.

List on 29th October, 2021, as prayed.

(Vivek Singh Thakur),
Judge.

13th September, 2021
(Keshav)

1.2

4

Annexure-C

Sr. No.	Name And Address of Units	Sampling Point.	Date of Sampling	Parameters(CETP Inlet Norms)					Remarks.
				pH (6.0 - 9.0)	FDS (<2100 mg/L)	TSS (<250 mg/L)	COD (<1000 mg/L)	BOD (<350 mg/L)	
1.	Abbot Healthcare Sai Road Baddi	FOL of ETP cum STP	12-07-2021	7.21	768	72	128	20	Within limit
2.	Mondelez India Food Pvt. Ltd. Unit-I&II	FOL discharge to CETP	23-08-2021	7.44	659.64	2.8	19.92	4.0	Within limit
3.	Torrent Pharmaceuticals, Vill Bhud, Malkhumajra, Baddi.	Final outlet of ETP discharge to CETP	12-07-2021	8.36	918.4	7.9	56	10	Within limit
4.	Dabur India Ltd (Food Supplement) Plot no 220-221 HPSIDC, Baddi	Final outlet of ETP Discharge to CETP	12.07.2021	8.04	693	33.8	64	14	Within limit
5.	Kandhari Beverages Ltd. (unit-I&II). Industrial Area Katha, Baddi	Final outlet of ETP Discharge to CETP	12-07-2021	7.34	1494.8	51.5	372	78	Within limit
6.	Procter & Gamble (P&G) Home Products (Unit-I&II), Industrial Area Katha, Baddi	Final outlet of ETP Discharge to CETP(12.07.2021	7.15	1449	7.7	408	180	Within limit
7.	Deepak Spinner Ltd. Plot No 121 DIC IA Baddi	FoL of ETP Discharge to CETP	12.07.2021	7.77	486	16.7	100	22	Within limit
8.	Dabur India Ltd Green field Unit- Manakpur Manpura Nalagarh	Final outlet of ETP cum STP	21.05.2021	7.97	945	83.2	144	40	Within limit
			09.08.2021	7.97	332.2	5.1	19.8	4.0	Within limit
9.	DS Drinks and Beverages Pvt. Ltd Unit V, Village Damowala, PO Barotiwala, Tehsil Baddi, Distt. Solan HP	FOL of ETP discharged to CETP	12-07-2021	7.01	658	126.4	568	260	Within limit

12

4

(Annexure - C1)

Sampling Result of Auro Textile-I w.r.t. CETP Inlet Norms							
Date of sampling	Sampling point	pH	BOD	COD	FDS	TSS	Analysis Result
		(6 to 9)	350 mg/lit	1000 mg/lit	2100 mg/lit	250 mg/lit	
1-Nov-19	Final outlet discharge to CETP (CAT-IV)	8.43				50	With in limit
25-Jul-20	Combined discharge to CETP Baddi after treatment (CAT-IV)	7.55	128	280	5800	18.1	Above limit
25-Jul-20	Inlet of CAT-I	6.89	110	220	1840	69.9	With in limit
18-Aug-20	Discharge to cetp after treatment CAT-IV	7.41	380	1480	2516	557.8	Above limit
18-Aug-20	Discharge to CETP Baddi CAT-I	6.77	164	528	1246	133.4	With in limit
1-Sep-20	Discharge to CETP Baddi CAT-I	6.53	164	728	1026	141	With in limit
1-Sep-20	Combined discharge to CETP (CAT-IV)	8.82	72	264	3846	128	Above limit
21-Sep-20	Discharge to CETP Baddi CAT-I	6.02	200	960	1240	76.2	With in limit
21-Sep-20	Combined discharge to CETP (CAT-IV)	7.34	22	80	9084	34.3	Above limit
6-Oct-20	Discharge to cetp after treatment CAT-IV	7.31	26	124	8420	22.2	Above limit
6-Oct-20	Discharge to CETP Baddi CAT-I	6.48	212	576	940	53.9	With in limit
28-Oct-20	Combined discharge to CETP Baddi after treatment (CAT-IV)	5.69	70	136	4920	28.8	Above limit
28-Oct-20	Discharge to CETP Baddi CAT-I	6.95	340	784	819	66	With in limit
17-Nov-20	Combined discharge to CETP Baddi after treatment (CAT-IV)	8.38	22	82	3650	80	Above limit
17-Nov-20	Discharge to CETP Baddi CAT-I	7.9	420	120	1240	130	With in limit
3-Dec-20	Combined discharge to CETP Baddi after treatment (CAT-IV)	7.71	24	72	5210	23.6	Above limit
3-Dec-20	Discharge to CETP Baddi CAT-I	6.62	330	840	922	197	With in limit
10-Dec-20	Combined discharge to CETP Baddi after treatment (CAT-IV)	7.67	26	100	7750	22.8	Above limit
30-Dec-20	Combined discharge to CETP Baddi (CAT-IV)	7.93	32	116	6550	20.2	Above limit
31-Dec-20	Discharge to CETP Baddi CAT-I	6.82	216	488	1456	117.3	With in limit
7-Jan-21	Discharge to CETP Baddi	6.15	320	920	1680	175	With in limit
21-Jan-21	Discharge to CETP CAT-I	7.6	290	524	767	151.3	With in limit
21-Jan-21	Combined discharge to CETP Baddi after treatment (CAT-IV)	8.59	28	128	5520	54.4	Above limit
9-Feb-21	Discharge to CETP Baddi (CAT-I)	7.56	46	180	823.6	37	With in limit
9-Feb-21	Combined discharge after treatment (CAT-IV)	8.44	30	136	6066.8	17.8	Above limit
1-Mar-21	Discharge to CETP Baddi (CAT-I)	7.32	40	156.3	898	60.6	With in limit
1-Mar-21	Combined discharge after treatment (CAT-IV)	8.11	36	148	7517	51.2	Above limit
23-Mar-21	Discharge to CETP Baddi (CAT-I)	7.96	96	300	906.67	182	With in limit

12 4

23-Mar-21	Discharge cetp after treatment CAT-IV	8.85	28	112	6987.2	50	Above limit
21-May-21	Discharge to cetp baddi cat-i	7.51	36	132	864	82.5	With in limit
21-May-21	Discharge to cetp CAT-IV	7.13	56	164	5992	102	Above limit
21-Jul-21	Discharge to CETP baddi	8.18	98	316	1101	55.8	With in limit
21-Jul-21	FOL of ETP after RO (Recycle)	8.19	1	4	330	3.8	With in limit
6-Aug-21	Discharge to CETP(CAT-I)	6.31	72	168	1042	92.6	With in limit
24-Aug-21	Discharge to CETP(CAT-I)	5.79	218	148	693	71.1	With in limit
6-Sep-21	Discharge to CETP(CAT-I)	6.01	310	680	690.12	37.4	With in limit

LD

LD

Sampling Result of Auro Textile-II w.r.t. CETP Inlet Norms							
Date	Sampling point	PH	BOD	COD	FDS	TSS	Analysis
		(6 to 9)	350 mg/lt	1000 mg/lt	2100 mg/lt	250 mg/lt	
25-Jul-20	CAT-I	9.23	92	308	1246	204.4	with in limit
18-Aug-20	Discharge to CETP Baddi(CAT-I)	8.91	660	1760	1344	553	with in limit
18-Aug-20	Discharge to CETP Baddi(CAT-I)	9.7	160	768	1075	289	with in limit
1-Sep-20	Discharge to CETP Baddi(CAT-I)	8.7	122	380	1042	108.8	with in limit
21-Sep-20	Discharge to CETP Baddi(CAT-I)	9.45	240	984	1296	42.4	with in limit
6-Oct-20	Discharge to CETP Baddi(CAT-I)	9.71	280	668	1180	53.7	Above limit
28-Oct-20	Discharge to CETP Baddi(CAT-I)	7.76	280	608	1810	162	with in limit
17-Nov-20	Discharge to CETP Baddi(CAT-I)	8.15	40	270	810	256	Above limit
3-Dec-20	Discharge to CETP Baddi(CAT-I)	7.15	240	504	908	181	with in limit
21-Jan-21	Discharge to CETP Baddi(CAT-I)	8.62	240	484	1260	246	with in limit
9-Feb-21	Discharge to CETP Baddi(CAT-I)	8.24	242	496	1251.6	240	with in limit
1-Mar-21	Discharge to CETP Baddi(CAT-I)	7.86	200	464	1367.6	205	with in limit
23-Mar-21	Discharge to CETP Baddi(CAT-I)	8.95	242	540	1469.7	238	with in limit
21-May-21	Discharge to CETP Baddi(CAT-I)	7.37	102	488	1264	206.5	with in limit
21-Jul-21	Discharge to CETP Baddi Category-I	7.07	320	940	804	69.4	with in limit
6-Aug-21	Discharge to CETP Baddi(CAT-I)	6.82	68	136	1257	67.2	With in limit
24-Aug-21	Discharge to CETP Baddi(CAT-I)	8.71	260	480	570	53.5	With in limit
6-Sep-21	Discharge to CETP Baddi(CAT-I)	7.31	112	248	634.03	74.6	With in limit
Sampling Result of Auro Dyeing-I w.r.t. CETP Inlet Norms							
Date	Sampling point	PH	BOD	COD	FDS	TSS	Analysis Result
		6 to 9	1000 mg/l	350mg /l	2100 mg/l	250 mg/l	
1-Nov-19	FOL Discharge to CETP Baddi CAT-i	8.57				48	With in limit
25-Jul-20	Inlet to cat-i	6.58	192	380	1990	100.83	With in limit
18-Aug-20	Discharge to CETP Baddi CAT-i	6.74	220	608	1131	96.6	With in limit
1-Sep-20	Discharge to CETP Baddi CAT-i	7.78	124	380	1272	162	With in limit
21-Sep-20	Discharge to CETP Baddi CAT-i	8.25	78	332	1120	80.3	With in limit
28-Oct-20	Discharge to CETP Baddi CAT-i	6.4	210	364	1120	229.33	With in limit
17-Nov-20	Discharge to CETP Baddi CAT-i	8.08	38	210	1810	122	With in limit
3-Dec-20	Discharge to CETP Baddi CAT-i	6.89	180	480	1390	83.2	With in limit
3-Dec-20	Discharge to CETP Baddi	7.38	46	120	1350	32	With in limit
10-Dec-20	Final outlet of ETP (CAT-I)	7.37	124	356	1440	67	With in limit
10-Dec-20	Final outlet of ETP (CAT-I)	7.47	102	408	1494	72.2	With in limit
10-Dec-20	Final outlet of ETP (CAT-I)	7.47	102	408	1494	72.2	With in limit
7-Jan-21	Inlet to Equalization tank	7.37	54	152	1626	87	With in limit
21-Jan-21	Discharge to CETP Baddi CAT-i	7.43	140	340	950	1144.8	With in limit
9-Feb-21	Discharge to CETP Baddi CAT-i	7.93	96	296	958.3	96	With in limit
1-Mar-21	Final outlet of CETP (CAT-I)	6.9	104	320	1484.6	186	With in limit
23-Mar-21	Discharge to CETP Baddi CAT-i	8.33	84	240	1596	64.8	With in limit
21-May-21	Final outlet of CETP (CAT-I)	6.8	54	160	1673	82	With in limit
21.7.2021	Discharge to CETP Baddi Category I	7.64	62	188	920	54.2	With in limit
6-Aug-21	Discharge to CETP Baddi Category I	7.0	24	128	804	91.3	With in limit
24-Aug-21	Discharge to CETP Baddi Category I	5.26	80	240	1054	94.5	With in limit
6-Sep-21	Discharge to CETP Baddi Category I	6.63	220	448	854.22	31.7	With in limit

12

W

Sampling result of Winsome Textile Limited

Date	Sampling point	PH	BOD	COD	FDS/TDS	TSS	Analysis Result
		6 to 9	350 mg/l	1000mg/l	2100 mg/l	250 mg/l	
25-Jul-20	Final outlet discharge to cetp (CAT-I)	6.75	180	352	560	69.57	with In limit
25-Jul-20	Discharge to CETp Cat-IV	6.59	68	140	7850	56	Above limit
18-Aug-20	Discharge to CETp Cat-IV	6.91	232	76	8220	343.6	Above limit
18-Aug-20	Final outlet discharge to CETP(CAT-I)	7.28	604	280	644	130.83	with In limit
1-Sep-20	Discharge to CETP Cat-I	7.09	204	46	560	107.3	with In limit
1-Sep-20	Discharge to CETP Cat-IV	6.93	520	160	7140	79.5	Above limit
21-Sep-20	Discharge to CETP Cat-IV	6.82	220	62	8080	124.8	Above limit
6-Oct-20	Discharge to CETP after treatment Cat-IV	7.31	176	28	6628	40.2	Above limit
28-Oct-20	Discharge to CETp Cat-IV	7.04	240	62	7140	210	Above limit
28-Oct-20	Discharge to CETp Cat-I	6.82	448	200	848	236	with In limit
17-Nov-20	Combined discharge to CETP Baddi After treatment Cat-IV	7.78	110	26	6480	136	Above limit
17-Nov-20	Discharge to CETP Baddi (CAT-I)	7.45	184	36	724	71	with In limit
3-Dec-20	Combined discharge to CETP Baddi After treatment Cat-IV	7.82	176	32	8480	147.7	Above limit
3-Dec-20	Discharge to CETP Baddi (CAT-I)	7.16	280	62	840	109.54	with In limit
10-Dec-20	Finaloutlet of ETP(CAT-I)	7.32	308	76	884	72	with In limit
10-Dec-20	Finaloutlet of ETP(CAT-IV)	7.75	192	52	6820	190	Above limit
30-Dec-20	Finaloutlet of ETP(CAT-IV)	8.02	232	78	6150	92.6	Above limit
30-Dec-20	Finaloutlet of ETP(CAT-I)	8.69	360	140	914	75.8	with In limit
7-Jan-21	Discharge to CETP Baddi	6.6	256	72	1060	58	with In limit
21-Jan-21	Finaloutlet of ETP(CAT-I)	8.08	112	380	932	76.8	with In limit
21-Jan-21	Finaloutlet of ETP(CAT-IV)	7.88	70	192	6910	268.4	Above limit

1.0 4

9-Feb-21	Discharge to CETP CAT-IV after treatment	7.57	280	88	7128	160.2	Above limit
9-Feb-21	Discharge to CETP CAT-I after treatment	7.86	336	108	1033.6	58.2	with In limit
1-Mar-21	Discharge to CETP CAT-IV after treatment	7.3	216	76	1808	122.8	with In limit
1-Mar-21	Discharge to CETP Baddi CAT-I	7.39	196	64	1152	107	with In limit
23-Mar-21	Discharge to CETP Baddi CAT-I	7.8	404	188	898.4	144	with In limit
23-Mar-21	Discharge to CETP CAT-IV after treatment	7.04	64	16	5880	68.8	Above limit
21-May-21	Discharge to CETP Cat-I	7.2	116	24	868	41.4	with In limit
21-May-21	Discharge to CETP Cat-IV	7.16	84	20	6776	200.5	Above limit
10.June-21	Discharge to CETP Category I	7.17	30	192	716	61.2	with In limit
10.June-21	Discharge to CETP Category IV	7.05	22	96	6148	32.1	Above limit
20-Jul-21	Discharge to CETP Category I	7.67	26	116	887	47.2	with In limit
20-Jul-21	Discharge to CETP Category IV	7.03	22	108	4832	89.9	Above limit
6-Aug.21	Discharge to CETP Category I	7.03	72	160		86.6	with In limit
6-Aug.21	Discharge to CETP Category IV	7.26	20	80	4693.3	23.7	Above limit
24-Aug-21	Discharge to CETP Category I	7.18	24	88	947	69.8	with In limit
24-Aug-21	Discharge to CETP Category IV	9.3	38	120	4364	279.8	Above limit
06-Sep-21	Discharge to CETP Category I	7.32	140	296	1015.83	29.2	with In limit
06-Sep-21	Discharge to CETP Category IV	7.05	22	96	4372.66	34.8	Above limit

12

44

**CWP No.4961 of 2021**

01.09.2021 Present: Mr. R.L. Sood, Senior Advocate with Mr. Arjun Lal, Advocate, for the petitioner.
 Mr. Ashok Sharma, A.G. Mr. Rajinder Dogra, Sr. Addl. A.G., Mr. Vinod Thakur, Mr. Shiv Pal Manhans, Mr. Hemanshu Misra, Addl. A.Gs. and Mr. Bhupinder Thakur, Dy. A.G., for the respondent No.1/State
 Mr. Maan Singh, Advocate, for respondent No.2 and 3.
 Mr. Dinesh Bhanot, Advocate, for respondent No.4.

Notice. Mr. Vinod Thakur, learned Additional Advocate General, Mr. Maan Singh, Advocate & Mr. Dinesh Bhanot, Advocate, appear and waive service of notice on behalf of respondents No.1, 2, 3 and 4, respectively. Reply/instructions be filed/obtained within a period of two weeks.

CMP N.10189 of 2021

Notice in the aforesaid terms. In the meanwhile, respondents are restrained from taking any coercive action against the petitioner.

List on 15.09.2021.

Copy dasti.

(Tarlok Singh Chauhan)
Judge

(Satyen Vaidya)
Judge

September 01, 2021 (tarun)

12 u



CWP No. 4961 of 2021

15.09.2021

Present:

Mr. R.L. Sood, Senior Advocate with Mr. Arjun Lal Advocate, for the petitioner.

Mr. Rajinder Dogra, Sr. Addl. A.G., with Mr. Vinod Thakur, Mr. Shiv Pal Manhans, Mr. Hemanshu Misra, Additional Advocates General and Mr. Bhupinder Thakur, Deputy Advocate General, for respondent No.1.

Mr. Vir Bahadur Vemra, Advocate, for respondents No.2 and 3.

Mr. Dinesh Bhanot, Advocate, for respondent No.4.

Learned counsel for respondents pray for and are granted six weeks' time to file reply.

List on **27th October, 2021.**

Interim order to continue.

(Tarlok Singh Chauhan)
Judge

September 15, 2021
(ravinder)

(Satyen Vaidya)
Judge

1/2
44

(Annexure - E)

Registered (W/A)



H.P. STATE POLLUTION CONTROL BOARD
"HIM PARIVESH", PHASE III,
NEW SHIMLA-171 009.



OFFICE ORDER

Whereas the M/s Winsome Textile Limited, Plot No. 1, Sai Road, Baddi, Distt Solan, HP is not complying the environmental standards prescribed for parameter FDS to the inlet of CETP.

Whereas the directions were issued by the State Board vide office order dated 01.01.2021 U/s 33-A of Water Act, 1974 for the violation period from 25.07.2020 to 31.12.2020 for levying of Environmental Compensation and closure of dyeing section which were stayed by Hon'ble High Court of HP in CWP No. 417/2021 vide order dated 11.01.2021 and no further action is taken for such violation period.

Whereas as per report received from the Sr. Environmental Engineer, HPSPCB, Baddi vide letter No. PCB/SEE (RO) (Baddi)/ M/s Winsome Textile Ltd./ 2021-1041 dated 09/08/2021, it has been informed that unit M/s Winsome Textile Limited, Plot No. 1, Sai Road, Baddi, Distt Solan, HP was visited on 06.08.2021 and it was observed that: (i) the unit has procured all the parts of RO system which is not made operative till date. (ii) Presently unit is discharging CAT-IV to CETP Baddi alongwith effluent of CAT-I which is proposed to be utilized once the RO system is made operational. (iii) Unit has failed to achieve the standards for inlet quality of Common Effluent Treatment Plant (CETP) at Baddi notified by Government of Himachal Pradesh Department of Env, Sci. & Tech. vide notification No. STE-F (2)-1/2017 dated 26.12.2019 specifically for Fixed Dissolved Solids and continuously discharging effluent of high FDS to CETP. (iv) As per the latest sample analysis report of the sampling conducted on 20.07.2021 unit is still non-compliant to the parameter of FDS (CAT-IV) to the inlet of CETP which is tantamount to a new /fresh cause of action necessitating action under the relevant provisions of Law.

Whereas in view of above stated facts, the Sr. Environmental Engineer, HPSPCB, Baddi has recommended action under Section 33-A of Water (Prevention & Control of Pollution) Act, 1974 for disconnection of power supply of unit.

In consideration of the facts stated above, H.P. State Pollution Control Board in exercise of power conferred under section 33-A of Water Act, 1974, hereby directs the HP State Electricity Board in general and the Executive Engineer, Electrical Division, Baddi, Distt. Solan, HP in particular to disconnect the power supply of M/s. Winsome Textile Limited, Plot No. 1, Sai Road, Baddi, Distt Solan, HP forthwith.

Direction is also issued to M/s. Winsome Textile Ltd., Plot No. 1, DIC IA Baddi, Distt Solan, HP, not to operate even on DG set or any other source of energy. All concerned shall report compliance within three days.

The non-compliance of these directions shall constitute a cognizable offence and liable for following action:-

Fine and imprisonment up to six years as provided under section 41, 43 & 44 of the Water (Prevention and Control of Pollution) Act, 1974.

Strict compliance from all concerned is solicited to avoid legal liability on their part.

Apoorv Devgan, IAS
Member Secretary

-Contd.-

No. PCB/ (1435)/M/s Winsome Textile Industries/Baddi/2020- ⁶⁴³⁰⁻³⁴ Dated: 19.08.202

Copy forwarded to the following for information and immediate necessary action:

1. The Chairman. H.P. State Electricity Board, Vidyut Bhawan. Shimla.
2. The Executive Engineer, Electrical Division, HPSEB, Electrical Div. Baddi. Distt. Solan. HP.
3. The Asstt. Executive Engineer, Electrical Division. HPSEB, Electrical Div. Baddi, Distt. Solan. HP.
4. The Sr. Environmental Engineer, HPSPCB, Baddi to give compliance report immediately. He is directed to assess/ levy the environmental compensation upon the violation committed by the unit as per Hon'ble NGT orders.
5. M/s Winsome Textile Ltd., Plot No. 1, DIC IA Baddi, Tehsil Baddi, Distt Solan. HP,
6. Case file.

Apoorv Devgan, IAS

Member Secretary

⊙

12



CWP No.417 of 2021

24.08.2021 Present: Mr. R.L. Sood, Sr. Advocate, with Mr. Arjun Lall, Advocate, for the petitioner.

Mr. Sumesh Raj, Mr. Sanjeev Sood, Additional Advocates General, with Mr. Jagdeep Singh Guleria and Kamal Kant Chandel, Deputy Advocates General, for the respondent No.1/State.

Mr. K.D. Shreedhar, Sr. Advocate, with Mr. Maan Singh, Advocate, for respondents No.2 and 3.

CMP No.9933 of 2021

Notice. Mr. Sumesh Raj, learned Additional Advocate General, accepts notice on behalf of non-applicants/State. Mr. Maan Singh, Advocate, accepts notice on behalf of non-applicant/respondents No.2 and 3 and on his instructions, Mr. K.D. Shreedhar, learned Senior Counsel has put in appearance on behalf of said non-applicants.

By way of this application, a prayer has been made to stay the operation of order dated 19.08.2021, appended with the present application as Annexure P-31, which is an Office Order, issued by the Member Secretary of the respondent/Board (H.P. State Pollution Control Board), vide which following directions stand passed:-

12
4

"Whereas, in view of the above stated facts, the Sr. Environmental Engineer, HPSPCB, Baddi has recommended action under Section 33-A of the Water (Prevention & Control of Pollution) Act, 1974 for disconnection of power supply of unit.

In consideration of the facts stated above, H.P. State Pollution Control Board in exercise of power conferred under Section 33-A of Water Act, 1974, hereby directs the HP State Electricity Board in general and the Execution Engineer, Electrical Division, Badi, District Solan, H.P. in particular to disconnect the power supply of M/s Winsome Textile Limited, Plot No.1, Sai Road, Baddi, District Solan, H.P. forthwith.

Direction is also issued to M/s Winsome Textile Ltd., Plot No.1, DIC IA Baddi, District Solan, H.P., not to operate even on DG set or any other source of energy. All concerned shall report compliance within three days.

The non-compliance of these directions shall constitute a cognizable offence and liable for following action:-

Fine an imprisonment up to six years as provided under sections 41, 43 & 44 of the Water (Prevention and Control of Pollution) Act, 1974.

Strict compliance from all concerned is solicited to avoid legal liability on their part."

Learned Senior Counsel, appearing for the applicant/petitioner, has argued that passing of this order by the respondent/ Board is nothing, but an act to overreach the protection granted to the petitioner by this Court and as the matter is

12

u

subjudice, the respondent-Board should have had waited for the adjudication of the lis rather than passing the impugned order.

Learned Senior Counsel, appearing for respondents No.2 and 3 submits that the Office order which now stands impugned by way of this application has nothing to do with the litigation which is pending with this Court, as same is issued by the Member Secretary of the respondent-Board on the breach committed subsequently by the applicant.

Be that as it may, as vide previous order, the case has already fixed for 02.09.2021, when an endeavour shall be made by the Court to hear the case finally, this application is ordered to be taken up for consideration on the said date itself and till further orders, office order dated 19.08.2021, appended with this application as Annexure P-31, shall not be given effect, without the leave of the Court.

Copy *dasti*.

(Ajay Mohan Goel)
Judge

August 24, 2021
(Rishi)



CWP No.417 of 2021

10.09.2021 Present: Mr. R.L. Sood, Sr. Advocate, with Mr. Arjun Lall, Advocate, for the petitioner.

Mr. Adarsh Sharma, Mr. Sumesh Raj, Mr. Sanjeev Sood, Additional Advocates General, for the respondent No.1.

Mr. K.D. Shereedhar, Sr. Advocate, with Mr. Maan Singh, Advocate, for respondents No.2 and 3.

CWP No.417 of 2021 & CMP No.7937 of 2021

Heard for some time. List for continuation on 26.10.2021 as part heard matter, on which date relevant record pertaining to the case shall be kept available by the respondents concerned. Interim to continue.

(Ajay Mohan Goel)
Judge

September 10, 2021
(Rishi)

12 4



CWP No.417 of 2021

02.09.2021 Present: Mr. R.L. Sood, Sr. Advocate, with Mr. Arjun Lall, Advocate, for the petitioner.

Mr. Adarsh Sharma, Mr. Sumesh Raj, Mr. Sanjeev Sood, Additional Advocates General, with Mr. Kamal Kant Chandel, Deputy Advocate General, for the respondent No.1.

Mr. K.D. Shreedhar, Sr. Advocate, with Mr. Maan Singh, Advocate, for respondents No.2 and 3.

CWP No.417 of 2021 & CMP No.7937 of 2021

Learned Senior Counsel, appearing for the petitioner, on instructions, submits that rejoinders to the replies have been filed by the petitioner. Registry is directed to place the same on record, if in order.

As prayed for, list for consideration on **10.09.2021**. Interim to continue.

(Ajay Mohan Goel)
Judge

September 02, 2021
(Rishi)

12

4

(Annexure - G)

Sr. No.	Date of Sampling	Sampling Point	pH (5.5-9.5)	TSS (<100 mg/L)	COD (<250mg /L)	BOD (<30mg/ L)	FDS(2100 mg/l)	Remarks
1	21-May-21	Discharge of CETP in Sirsa River	7.27	55	120	28	2083	with in limit
2	21-May-21	Final outlet of CETP	7.31	51	128	28	2019	with in limit
3	07-Jun-21	fol of cetp	7.26	16.6	112	22	2072	with in limit
4	07-Jun-21	discharge of cetp near river sirsa	7.36	21.4	164	28	2095	with in limit
5	19-Jun-21	fol of cetp	7.57	34.3	148	26	1918	with in limit
6	19-Jun-21	discharge of cetp near river sirsa	7.64	38.5	120	22	1883	with in limit
7	07-Jul-21	fol of cetp	7.23	46.4	128	22	2100	with in limit
8	07-Jul-21	discharge of cetp near river sirsa	7.38	51.8	156	30	2072	with in limit
9	02-Aug-21	FOL of CETP discharge into river Sirsa	7.24	51.3	220	28	1209.4	with in limit
10	02-Aug-21	FOL of CETP	7.37	27.2	80	16	1400.8	with in limit
11	23-Aug-21	FOL of CETP	7.79	19	148	30	1418	with in limit
12	23-Aug-21	FOL of CETP discharge into river Sirsa	7.7	14.1	128	26	1240	with in limit
13	06-Sep-21	FOL of CETP discharge into river Sirsa	7.48	22.4	176	20	1262.5	with in limit

12

u