



# आगरा नगर निगम, आगरा

Phone : +91-562-2850670 Fax : +91-562-2850499 Email : amcagra@yahoo.com

प्रेषक,

नगर आयुक्त,  
नगर निगम, आगरा

सेवा में,

मा0 न्यायालय राष्ट्रीय हरित अधिकरण,  
नई दिल्ली।

पत्रांक:-419/डी0/विधि/23

दिनांक:-22/08/2023

**विषय:-** मा0 न्यायालय राष्ट्रीय हरित अधिकरण, नई दिल्ली में योजित ओ0ए0 संख्या-840/2022 डा0 संजय कुलश्रेष्ठ बनाम उ0 प्र0 राज्य व अन्य में पारित आदेश दिनांक-11.04.2023 की अनुपालन आख्या।

श्रीमान जी,

कृपया सादर अवगत कराना है कि मा0 न्यायालय राष्ट्रीय हरित अधिकरण, नई दिल्ली में योजित ओ0ए0 संख्या-840/2022 डा0 संजय कुलश्रेष्ठ बनाम उ0 प्र0 राज्य व अन्य में दिनांक-11.04.2023 को एक्शन रिपोर्ट प्रेषित किये जाने हेतु आदेश पारित किये गये थे। दिनांक-11.04.2023 को पारित आदेश के सम्बन्ध में नगर निगम, आगरा से सम्बन्धित अनुपालन आख्या/एक्शन रिपोर्ट संलग्न कर सादर प्रेषित की जा रही है।

भवदीय

नगर आयुक्त  
नगर निगम, आगरा।

**प्रतिलिपि:-**

1. संयुक्त सचिव, उ0प्र0 शासन, नगर विकास अनुभाग-5 को सूचनार्थ प्रेषित।
2. आयुक्त महोदय, आगरा मण्डल को सूचनार्थ सादर प्रेषित।
3. जिलाधिकारी महोदय, आगरा को सूचनार्थ सादर प्रेषित।

नगर आयुक्त  
नगर निगम, आगरा।



प्रेषक,

नगर आयुक्त,  
नगर निगम, आगरा

सेवा में,

मा0 न्यायालय राष्ट्रीय हरित अधिकरण,  
नई दिल्ली।

पत्रांक:- 419/डी0/विधि/23

दिनांक:- 22/08/2023

**विषय:-** मा0 न्यायालय राष्ट्रीय हरित अधिकरण, नई दिल्ली में योजित ओ0ए0 संख्या-840/2022 डा0 संजय कुलश्रेष्ठ बनाम उ0 प्र0 राज्य व अन्य में पारित आदेश दिनांक-11.04.2023 की अनुपालन आख्या।

श्रीमान जी,

कृपया सादर अवगत कराना है कि मा0 न्यायालय राष्ट्रीय हरित अधिकरण, नई दिल्ली में योजित ओ0ए0 संख्या-840/2022 डा0 संजय कुलश्रेष्ठ बनाम उ0 प्र0 राज्य व अन्य में दिनांक-11.04.2023 को एक्शन रिपोर्ट प्रेषित किये जाने हेतु आदेश पारित किये गये थे। दिनांक-11.04.2023 को पारित आदेश के सम्बन्ध में नगर निगम, आगरा से सम्बन्धित अनुपालन आख्या/एक्शन रिपोर्ट संलग्न कर सादर प्रेषित की जा रही है।

भवदीय

नगर आयुक्त  
नगर निगम, आगरा।

**प्रतिलिपि:-**

1. संयुक्त सचिव, उ0प्र0 शासन, नगर विकास अनुभाग-5 को सूचनार्थ प्रेषित।
2. आयुक्त महोदय, आगरा मण्डल को सूचनार्थ सादर प्रेषित।
3. जिलाधिकारी महोदय, आगरा को सूचनार्थ सादर प्रेषित।

नगर आयुक्त  
नगर निगम, आगरा।



# BIRASINI TEST HOUSE

80

Govt. Approved / ISO IEC : 17025 : 2017 / ISO : 9001 : 2015  
ISO : 14001 : 2015 & OHSAS 45001 : 2018 Certified Laboratory  
(NABL Accredited Testing Laboratory)

BIRASINI TEST HOUSE



20142

## TEST REPORT

Issued To,  
M/S SIGN AGE INDIA PVT. LTD.  
B-49, Sector-83, Phase-II  
Extension Noida (U.P.)

Report No. : 50-26062023-20  
Date of Receiving : 26/06/2023  
Date of Starting : 26/06/2023  
Date of Completion : 07/07/2023  
Date of Reporting : 07/07/2023  
Submitted By : Customer

Page 1 of 1

Sample Description : Waste Water  
Location : At the Bank of Yamuna, Agra  
Cluster 1 : Ganesh Nagar

S.No.	Test Parameters	Units	Results	Test Method
1.	pH Value	-	7.29	IS: 3025 (P-11)-2022
2.	Biochemical Oxygen Demand (BOD) (3 days at 27°C)	mg/l	42	IS: 3025 (P-44)-1993
3.	Chemical Oxygen Demand (COD)	mg/l	124	IS: 3025 (P-58)-2006
4.	Total Suspended Solids (TSS)	mg/l	68	IS: 3025 (P-17)-1984
5.	Total Coliform	Per 100ml	Absent	IS: 15185-2016

\*\*\*END OF REPORT\*\*\*

\*The above test parameter by Client request.

Authorised Signatory

- Note :
1. The test results listed pertain to the sample tested and applicable parameters.
  2. Total liability of this lab is limited to Invoice amount
  3. Any discrepancy found in the test report may be communicated with in seven days from the date of issue to Test Report.
  4. Remainder of Sample tested may be collected within 15 days from the date of issue of test report After which it shall be disposed off.
  5. The test report should not be produced as an evidence for any legal purpose, Court, Advertising media without the prior permission of the director, BTH.



# BIRASINI TEST HOUSE

81

BIRASINI TEST HOUSE



20143

Govt. Approved / ISO IEC : 17025 : 2017 / ISO : 9001 : 2015  
ISO : 14001 : 2015 & OHSAS 45001 : 2018 Certified Laboratory  
(NABL Accredited Testing Laboratory)

## TEST REPORT

Issued To,  
M/S SIGN AGE INDIA PVT. LTD.  
B-49, Sector-83, Phase-II  
Extension Noida (U.P.)

Report No. : 50-26062023-21  
Date of Receiving : 26/06/2023  
Date of Starting : 26/06/2023  
Date of Completion : 07/07/2023  
Date of Reporting : 07/07/2023  
Submitted By : Customer

Page 1 of 1

Sample Description : Waste Water  
Location : At the Bank of Yamuna, Agra  
Cluster 2 : Katrawajir Khan Drain 2

S.No.	Test Parameters	Units	Results	Test Method
1.	pH Value	-	7.46	IS: 3025 (P-11)-2022
2.	Biochemical Oxygen Demand (BOD) (3 days at 27°C)	mg/l	34	IS: 3025 (P-44)-1993
3.	Chemical Oxygen Demand (COD)	mg/l	109	IS: 3025 (P-58)-2006
4.	Total Suspended Solids (TSS)	mg/l	72	IS: 3025 (P-17)-1984
5.	Total Coliform	Per 100ml	Absent	IS: 15185-2016

\*\*\*END OF REPORT\*\*\*

\*The above test parameter by Client request.

Authorised Signatory

- Note : 1. The test results listed pertain to the sample tested and applicable parameters.  
2. Total liability of this lab is limited to Invoice amount  
3. Any discrepancy found in the test report may be communicated with in seven days from the date of issue to Test Report.  
4. Remainder of Sample tested may be collected within 15 days from the date of issue of test report After which it shall be disposed off.  
5. The test report should not be produced as an evidence for any legal purpose, Court, Advertising media without the prior permission of the director, BTH.

Laboratory Office: 4/31 B, Site-IV, Industrial Area, Sahibabad, Ghaziabad, U.P. - 201010  
Ph:- 0120-4526493, E-mail : birasinitesthouse1@gmail.com, Website : www.birasinitesthouse.in



# BIRASINI TEST HOUSE

Govt. Approved / ISO IEC : 17025 : 2017 / ISO : 9001 : 2015  
ISO : 14001 : 2015 & OHSAS 45001 : 2018 Certified Laboratory  
(NABL Accredited Testing Laboratory)

82

BIRASINI TEST HOUSE



20138

## TEST REPORT

Issued To,  
M/S SIGN AGE INDIA PVT. LTD.  
B-49, Sector-83, Phase-II  
Extension Noida (U.P.)

Report No. : 50-26062023-22  
Date of Receiving : 26/06/2023  
Date of Starting : 26/06/2023  
Date of Completion : 07/07/2023  
Date of Reporting : 07/07/2023  
Submitted By : Customer  
Page 1 of 1

Sample Description : Waste Water  
Location : At the Bank of Yamuna, Agra  
Cluster 3 : Gali Subedar Nagar Drain

S.No.	Test Parameters	Units	Results	Test Method
1.	pH Value	-	7.26	IS: 3025 (P-11)-2022
2.	Biochemical Oxygen Demand (BOD) (3 days at 27°C)	mg/l	33	IS: 3025 (P-44)-1993
3.	Chemical Oxygen Demand (COD)	mg/l	102	IS: 3025 (P-58)-2006
4.	Total Suspended Solids (TSS)	mg/l	71	IS: 3025 (P-17)-1984
5.	Total Coliform	Per 100ml	Absent	IS: 15185-2016

\*\*\*END OF REPORT\*\*\*

\*The above test parameter by Client request.



Authorised Signatory

- Note :
1. The test results listed pertain to the sample tested and applicable parameters.
  2. Total liability of this lab is limited to Invoice amount
  3. Any discrepancy found in the test report may be communicated with in seven days from the date of issue to Test Report.
  4. Remainder of Sample tested may be collected within 15 days from the date of issue of test report After which it shall be disposed off.
  5. The test report should not be produced as an evidence for any legal purpose, Court, Advertising media without the prior permission of the director, BTH.

Laboratory Office: 4/31 B, Site-IV, Industrial Area, Sahibabad, Ghaziabad, U.P. - 201010  
Ph:- 0120-4526493, E-mail : birasintesthouse1@gmail.com, Website : www.birasintesthouse.in



# BIRASINI TEST HOUSE

83

Govt. Approved / ISO IEC : 17025 : 2017 / ISO : 9001 : 2015  
ISO : 14001 : 2015 & OHSAS 45001 : 2018 Certified Laboratory  
(NABL Accredited Testing Laboratory)

BIRASINI TEST HOUSE



20139

## TEST REPORT

Issued To,  
M/S SIGN AGE INDIA PVT. LTD.  
B-49, Sector-83, Phase-II  
Extension Noida (U.P.)

Report No. : 50-26062023-23  
Date of Receiving : 26/06/2023  
Date of Starting : 26/06/2023  
Date of Completion : 07/07/2023  
Date of Reporting : 07/07/2023  
Submitted By : Customer

Page 1 of 1

Sample Description : Waste Water  
Location : At the Bank of Yamuna, Agra  
Cluster 4 : Shyamlal Vidya Mandir Drain

S.No.	Test Parameters	Units	Results	Test Method
1.	pH Value	-	7.0	IS: 3025 (P-11)-2022
2.	Biochemical Oxygen Demand (BOD) (3 days at 27°C)	mg/l	33	IS: 3025 (P-44)-1993
3.	Chemical Oxygen Demand (COD)	mg/l	108	IS: 3025 (P-58)-2006
4.	Total Suspended Solids (TSS)	mg/l	66	IS: 3025 (P-17)-1984
5.	Total Coliform	Per 100ml	Absent	IS: 15185-2016

\*\*\*END OF REPORT\*\*\*

\*The above test parameter by Client request.



Authorized Signatory

- Note :
1. The test results listed pertain to the sample tested and applicable parameters.
  2. Total liability of this lab is limited to Invoice amount
  3. Any discrepancy found in the test report may be communicated with in seven days from the date of issue to Test Report.
  4. Remainder of Sample tested may be collected within 15 days from the date of issue of test report After which it shall be disposed off.
  5. The test report should not be produced as an evidence for any legal purpose, Court, Advertising media without the prior permission of the director, BTH.

Laboratory Office: 4/31 B, Site-IV, Industrial Area, Sahibabad, Ghaziabad, U.P. - 201010  
Ph:- 0120-4526493, E-mail : birasintesthouse1@gmail.com, Website : www.birasintesthouse.in



# BIRASINI TEST HOUSE

Govt. Approved / ISO IEC : 17025 : 2017 / ISO : 9001 : 2015  
ISO : 14001 : 2015 & OHSAS 45001 : 2018 Certified Laboratory  
(NABL Accredited Testing Laboratory)

84

BIRASINI TEST HOUSE



20140

## TEST REPORT

**Issued To,**  
M/S SIGN AGE INDIA PVT. LTD.  
B-49, Sector-83, Phase-II  
Extension Noida (U.P.)

**Report No.** : 50-26062023-24  
**Date of Receiving** : 26/06/2023  
**Date of Starting** : 26/06/2023  
**Date of Completion** : 07/07/2023  
**Date of Reporting** : 07/07/2023  
**Submitted By** : Customer

Page 1 of 1

**Sample Description** : Waste Water  
**Location** : At the Bank of Yamuna, Agra  
**Cluster 5** : Moti Mahal-1

S.No.	Test Parameters	Units	Results	Test Method
1.	pH Value	-	7.26	IS: 3025 (P-11)-2022
2.	Biochemical Oxygen Demand (BOD) (3 days at 27°C)	mg/l	33	IS: 3025 (P-44)-1993
3.	Chemical Oxygen Demand (COD)	mg/l	104	IS: 3025 (P-58)-2006
4.	Total Suspended Solids (TSS)	mg/l	69	IS: 3025 (P-17)-1984
5.	Total Coliform	Per 100ml	Absent	IS: 15185-2016

\*\*\*END OF REPORT\*\*\*

\*The above test parameter by Client request.



Authorized Signatory

- Note :
1. The test results listed pertain to the sample tested and applicable parameters.
  2. Total liability of this lab is limited to Invoice amount
  3. Any discrepancy found in the test report may be communicated with in seven days from the date of issue to Test Report.
  4. Remainder of Sample tested may be collected within 15 days from the date of issue of test report After which it shall be disposed off.
  5. The test report should not be produced as an evidence for any legal purpose, Court, Advertising media without the prior permission of the director, BTH.

Laboratory Office: 4/31 B, Site-IV, Industrial Area, Sahibabad, Ghaziabad, U.P. - 201010  
Ph:- 0120-4526493, E-mail : birasintesthouse1@gmail.com, Website : www.birasintesthouse.in



# BIRASINI TEST HOUSE

85

Govt. Approved / ISO IEC : 17025 : 2017 / ISO : 9001 : 2015  
ISO : 14001 : 2015 & OHSAS 45001 : 2018 Certified Laboratory  
(NABL Accredited Testing Laboratory)

BIRASINI TEST HOUSE



20135

## TEST REPORT

Issued To,  
M/S SIGN AGE INDIA PVT. LTD.  
B-49, Sector-83, Phase-II  
Extension Noida (U.P.)

Report No. : 50-26062023-25  
Date of Receiving : 26/06/2023  
Date of Starting : 26/06/2023  
Date of Completion : 07/07/2023  
Date of Reporting : 07/07/2023  
Submitted By : Customer

Page 1 of 1

Sample Description : Waste Water  
Location : At the Bank of Yamuna, Agra  
Cluster 6 : Moti Mahal-5

S.No.	Test Parameters	Units	Results	Test Method
1.	pH Value	-	7.50	IS: 3025 (P-11)-2022
2.	Biochemical Oxygen Demand (BOD) (3 days at 27°C)	mg/l	33	IS: 3025 (P-44)-1993
3.	Chemical Oxygen Demand (COD)	mg/l	96	IS: 3025 (P-58)-2006
4.	Total Suspended Solids (TSS)	mg/l	68	IS: 3025 (P-17)-1984
5.	Total Coliform	Per 100ml	Absent	IS: 15185-2016

\*\*\*END OF REPORT\*\*\*

\*The above test parameter by Client request.

Authorised Signatory

- Note : 1. The test results listed pertain to the sample tested and applicable parameters.  
2. Total liability of this lab is limited to Invoice amount  
3. Any discrepancy found in the test report may be communicated with in seven days from the date of issue to Test Report.  
4. Remainder of Sample tested may be collected within 15 days from the date of issue of test report After which it shall be disposed off.  
5. The test report should not be produced as an evidence for any legal purpose, Court, Advertising media without the prior permission of the director, BTH.



# BIRASINI TEST HOUSE

86

Govt. Approved / ISO IEC : 17025 : 2017 / ISO : 9001 : 2015  
ISO : 14001 : 2015 & OHSAS 45001 : 2018 Certified Laboratory  
(NABL Accredited Testing Laboratory)

BIRASINI TEST HOUSE



20136

## TEST REPORT

Issued To,  
M/S SIGN AGE INDIA PVT. LTD.  
B-49, Sector-83, Phase-II  
Extension Noida (U.P.)

Report No. : 50-26062023-26  
Date of Receiving : 26/06/2023  
Date of Starting : 26/06/2023  
Date of Completion : 07/07/2023  
Date of Reporting : 07/07/2023  
Submitted By : Customer

Page 1 of 1

Sample Description : Waste Water  
Location : At the Bank of Yamuna, Agra  
Cluster 7 : Moti Mahal Drain 8

S.No.	Test Parameters	Units	Results	Test Method
1.	pH Value	-	7.68	IS: 3025 (P-11)-2022
2.	Biochemical Oxygen Demand (BOD) (3 days at 27°C)	mg/l	35	IS: 3025 (P-44)-1993
3.	Chemical Oxygen Demand (COD)	mg/l	112	IS: 3025 (P-58)-2006
4.	Total Suspended Solids (TSS)	mg/l	74	IS: 3025 (P-17)-1984
5.	Total Coliform	Per 100ml	Absent	IS: 15185-2016

\*\*\*END OF REPORT\*\*\*

\*The above test parameter by Client request.



Authorised Signatory

- Note :
1. The test results listed pertain to the sample tested and applicable parameters.
  2. Total liability of this lab is limited to Invoice amount
  3. Any discrepancy found in the test report may be communicated with in seven days from the date of issue to Test Report.
  4. Remainder of Sample tested may be collected within 15 days from the date of issue of test report After which it shall be disposed off.
  5. The test report should not be produced as an evidence for any legal purpose, Court, Advertising media without the prior permission of the director, BTH.

Laboratory Office: 4/31 B, Site-IV, Industrial Area, Sahibabad, Ghaziabad, U.P. - 201010  
Ph:- 0120-4526493, E-mail : birasintesthouse1@gmail.com, Website : www.birasintesthouse.in



# BIRASINI TEST HOUSE

87

Govt. Approved / ISO IEC : 17025 : 2017 / ISO : 9001 : 2015  
ISO : 14001 : 2015 & OHSAS 45001 : 2018 Certified Laboratory  
(NABL Accredited Testing Laboratory)

BIRASINI TEST HOUSE



20137

## TEST REPORT

Issued To,  
M/S SIGN AGE INDIA PVT. LTD.  
B-49, Sector-83, Phase-II  
Extension Noida (U.P.)

Report No. : 50-26062023-27  
Date of Receiving : 26/06/2023  
Date of Starting : 26/06/2023  
Date of Completion : 07/07/2023  
Date of Reporting : 07/07/2023  
Submitted By : Customer

Page 1 of 1

Sample Description : Waste Water  
Location : At the Bank of Yamuna, Agra  
Independent Drains : Islam Nagar

S.No.	Test Parameters	Units	Results	Test Method
1.	pH Value	-	7.76	IS: 3025 (P-11)-2022
2.	Biochemical Oxygen Demand (BOD) (3 days at 27°C)	mg/l	43	IS: 3025 (P-44)-1993
3.	Chemical Oxygen Demand (COD)	mg/l	124	IS: 3025 (P-58)-2006
4.	Total Suspended Solids (TSS)	mg/l	72	IS: 3025 (P-17)-1984
5.	Total Coliform	Per 100ml	Absent	IS: 15185-2016

\*\*\*END OF REPORT\*\*\*

\*The above test parameter by Client request.

Authorised Signatory

- Note : 1. The test results listed pertain to the sample tested and applicable parameters.  
2. Total liability of this lab is limited to Invoice amount  
3. Any discrepancy found in the test report may be communicated with in seven days from the date of issue to Test Report.  
4. Remainder of Sample tested may be collected within 15 days from the date of issue of test report After which it shall be disposed off.  
5. The test report should not be produced as an evidence for any legal purpose, Court, Advertising media without the prior permission of the director, BTH.



# BIRASINI TEST HOUSE

88

Govt. Approved / ISO IEC : 17025 : 2017 / ISO : 9001 : 2015  
ISO : 14001 : 2015 & OHSAS 45001 : 2018 Certified Laboratory  
(NABL Accredited Testing Laboratory)

BIRASINI TEST HOUSE



20132

## TEST REPORT

Issued To,  
M/S SIGN AGE INDIA PVT. LTD.  
B-49, Sector-83, Phase-II  
Extension Noida (U.P.)

Report No. : 50-26062023-28  
Date of Receiving : 26/06/2023  
Date of Starting : 26/06/2023  
Date of Completion : 07/07/2023  
Date of Reporting : 07/07/2023  
Submitted By : Customer

Page 1 of 1

Sample Description : Waste Water  
Location : At the Bank of Yamuna, Agra  
Independent Drains : Shambhu Nath Junior High School

S.No.	Test Parameters	Units	Results	Test Method
1.	pH Value	-	7.50	IS: 3025 (P-11)-2022
2.	Biochemical Oxygen Demand (BOD) (3 days at 27°C)	mg/l	33	IS: 3025 (P-44)-1993
3.	Chemical Oxygen Demand (COD)	mg/l	110	IS: 3025 (P-58)-2006
4.	Total Suspended Solids (TSS)	mg/l	72	IS: 3025 (P-17)-1984
5.	Total Coliform	Per 100ml	Absent	IS: 15185-2016

\*\*\*END OF REPORT\*\*\*

\*The above test parameter by Client request.

Authorised Signatory

- Note : 1. The test results listed pertain to the sample tested and applicable parameters.  
2. Total liability of this lab is limited to Invoice amount  
3. Any discrepancy found in the test report may be communicated within seven days from the date of issue to Test Report.  
4. Remainder of Sample tested may be collected within 15 days from the date of issue of test report After which it shall be disposed off.  
5. The test report should not be produced as an evidence for any legal purpose, Court, Advertising media without the prior permission of the director, BTH.



# BIRASINI TEST HOUSE

89

Govt. Approved / ISO IEC : 17025 : 2017 / ISO : 9001 : 2015  
ISO : 14001 : 2015 & OHSAS 45001 : 2018 Certified Laboratory  
(NABL Accredited Testing Laboratory)

BIRASINI TEST HOUSE



20133

## TEST REPORT

**Issued To,**  
M/S SIGN AGE INDIA PVT. LTD.  
B-49, Sector-83, Phase-II  
Extension Noida (U.P.)

**Report No.** : 50-26062023-29  
**Date of Receiving** : 26/06/2023  
**Date of Starting** : 26/06/2023  
**Date of Completion** : 07/07/2023  
**Date of Reporting** : 07/07/2023  
**Submitted By** : Customer

Page 1 of 1

**Sample Description** : Waste Water  
**Location** : At the Bank of Yamuna, Agra  
**Independent Drains** : Peelipokhar

S.No.	Test Parameters	Units	Results	Test Method
1.	pH Value	-	7.36	IS: 3025 (P-11)-2022
2.	Biochemical Oxygen Demand (BOD) (3 days at 27°C)	mg/l	32	IS: 3025 (P-44)-1993
3.	Chemical Oxygen Demand (COD)	mg/l	102	IS: 3025 (P-58)-2006
4.	Total Suspended Solids (TSS)	mg/l	62	IS: 3025 (P-17)-1984
5.	Total Coliform	Per 100ml	Absent	IS: 15185-2016

\*\*\*END OF REPORT\*\*\*

\*The above test parameter by Client request.

**Authorised Signatory**

- Note :**
1. The test results listed pertain to the sample tested and applicable parameters.
  2. Total liability of this lab is limited to Invoice amount
  3. Any discrepancy found in the test report may be communicated with in seven days from the date of issue to Test Report.
  4. Remainder of Sample tested may be collected within 15 days from the date of issue of test report After which it shall be disposed off.
  5. The test report should not be produced as an evidence for any legal purpose, Court, Advertising media without the prior permission of the director, BTH.



# BIRASINI TEST HOUSE

90

Govt. Approved / ISO IEC : 17025 : 2017 / ISO : 9001 : 2015  
ISO : 14001 : 2015 & OHSAS 45001 : 2018 Certified Laboratory  
(NABL Accredited Testing Laboratory)

BIRASINI TEST HOUSE



20134

## TEST REPORT

**Issued To,**  
M/S SIGN AGE INDIA PVT. LTD.  
B-49, Sector-83, Phase-II  
Extension Noida (U.P.)

**Report No.** : 50-26062023-30  
**Date of Receiving** : 26/06/2023  
**Date of Starting** : 26/06/2023  
**Date of Completion** : 07/07/2023  
**Date of Reporting** : 07/07/2023  
**Submitted By** : Customer

Page 1 of 1

**Sample Description** : Waste Water  
**Location** : At the Bank of Yamuna, Agra  
**Independent Drains** : Cheeni Roja Drain 1

S.No.	Test Parameters	Units	Results	Test Method
1.	pH Value	-	7.42	IS: 3025 (P-11)-2022
2.	Biochemical Oxygen Demand (BOD) (3 days at 27°C)	mg/l	34	IS: 3025 (P-44)-1993
3.	Chemical Oxygen Demand (COD)	mg/l	110	IS: 3025 (P-58)-2006
4.	Total Suspended Solids (TSS)	mg/l	66	IS: 3025 (P-17)-1984
5.	Total Coliform	Per 100ml	Absent	IS: 15185-2016

\*\*\*END OF REPORT\*\*\*

\*The above test parameter by Client request.



Authorized Signatory

- Note :**
1. The test results listed pertain to the sample tested and applicable parameters.
  2. Total liability of this lab is limited to Invoice amount
  3. Any discrepancy found in the test report may be communicated with in seven days from the date of issue to Test Report.
  4. Remainder of Sample tested may be collected within 15 days from the date of issue of test report After which it shall be disposed off.
  5. The test report should not be produced as an evidence for any legal purpose, Court, Advertising media without the prior permission of the director, BTH.

Laboratory Office: 4/31 B, Site-IV, Industrial Area, Sahibabad, Ghaziabad, U.P. - 201010  
Ph:- 0120-4526493, E-mail : birasintesthouse1@gmail.com, Website : www.birasintesthouse.in



# BIRASINI TEST HOUSE

91

Govt. Approved / ISO IEC : 17025 : 2017 / ISO : 9001 : 2015  
ISO : 14001 : 2015 & OHSAS 45001 : 2018 Certified Laboratory  
(NABL Accredited Testing Laboratory)

BIRASINI TEST HOUSE



20129

## TEST REPORT

Issued To,  
M/S SIGN AGE INDIA PVT. LTD.  
B-49, Sector-83, Phase-II  
Extension Noida (U.P.)

Report No. : 50-26062023-31  
Date of Receiving : 26/06/2023  
Date of Starting : 26/06/2023  
Date of Completion : 07/07/2023  
Date of Reporting : 07/07/2023  
Submitted By : Customer

Page 1 of 1

Sample Description : Waste Water  
Location : At the Bank of Yamuna, Agra  
Independent Drains : Dayanand Asharam Drain

S.No.	Test Parameters	Units	Results	Test Method
1.	pH Value	-	7.60	IS: 3025 (P-11)-2022
2.	Biochemical Oxygen Demand (BOD) (3 days at 27°C)	mg/l	34	IS: 3025 (P-44)-1993
3.	Chemical Oxygen Demand (COD)	mg/l	106	IS: 3025 (P-58)-2006
4.	Total Suspended Solids (TSS)	mg/l	64	IS: 3025 (P-17)-1984
5.	Total Coliform	Per 100ml	Absent	IS: 15185-2016

\*\*\*END OF REPORT\*\*\*

\*The above test parameter by Client request.

Authorised Signatory

- Note :
1. The test results listed pertain to the sample tested and applicable parameters.
  2. Total liability of this lab is limited to Invoice amount
  3. Any discrepancy found in the test report may be communicated with in seven days from the date of issue to Test Report.
  4. Remainder of Sample tested may be collected within 15 days from the date of issue of test report After which it shall be disposed off.
  5. The test report should not be produced as an evidence for any legal purpose, Court, Advertising media without the prior permission of the director, BTH.



# BIRASINI TEST HOUSE

92

Govt. Approved / ISO IEC : 17025 : 2017 / ISO : 9001 : 2015  
ISO : 14001 : 2015 & OHSAS 45001 : 2018 Certified Laboratory  
(NABL Accredited Testing Laboratory)

BIRASINI TEST HOUSE



20130

## TEST REPORT

Issued To,  
M/S SIGN AGE INDIA PVT. LTD.  
B-49, Sector-83, Phase-II  
Extension Noida (U.P.)

Report No. : 50-26062023-32  
Date of Receiving : 26/06/2023  
Date of Starting : 26/06/2023  
Date of Completion : 07/07/2023  
Date of Reporting : 07/07/2023  
Submitted By : Customer

Page 1 of 1

Sample Description : Waste Water  
Location : At the Bank of Yamuna, Agra  
Independent Drains : Moti Mahal-2

S.No.	Test Parameters	Units	Results	Test Method
1.	pH Value	-	7.10	IS: 3025 (P-11)-2022
2.	Biochemical Oxygen Demand (BOD) (3 days at 27°C)	mg/l	33	IS: 3025 (P-44)-1993
3.	Chemical Oxygen Demand (COD)	mg/l	106	IS: 3025 (P-58)-2006
4.	Total Suspended Solids (TSS)	mg/l	64	IS: 3025 (P-17)-1984
5.	Total Coliform	Per 100ml	Absent	IS: 15185-2016

\*\*\*END OF REPORT\*\*\*

\*The above test parameter by Client request.



Authorized Signatory

- Note :
1. The test results listed pertain to the sample tested and applicable parameters.
  2. Total liability of this lab is limited to Invoice amount
  3. Any discrepancy found in the test report may be communicated with in seven days from the date of issue to Test Report.
  4. Remainder of Sample tested may be collected within 15 days from the date of issue of test report After which it shall be disposed off.
  5. The test report should not be produced as an evidence for any legal purpose, Court, Advertising media without the prior permission of the director, BTH.



# BIRASINI TEST HOUSE

93

Govt. Approved / ISO IEC : 17025 : 2017 / ISO : 9001 : 2015  
ISO : 14001 : 2015 & OHSAS 45001 : 2018 Certified Laboratory  
(NABL Accredited Testing Laboratory)

BIRASINI TEST HOUSE



20131

## TEST REPORT

Issued To,  
M/S SIGN AGE INDIA PVT. LTD.  
B-49, Sector-83, Phase-II  
Extension Noida (U.P.)

Report No. : 50-26062023-33  
Date of Receiving : 26/06/2023  
Date of Starting : 26/06/2023  
Date of Completion : 07/07/2023  
Date of Reporting : 07/07/2023  
Submitted By : Customer

Page 1 of 1

Sample Description : Waste Water  
Location : At the Bank of Yamuna, Agra  
Independent Drains : Moti Mahal Drain 7

S.No.	Test Parameters	Units	Results	Test Method
1.	pH Value	-	7.64	IS: 3025 (P-11)-2022
2.	Biochemical Oxygen Demand (BOD) (3 days at 27°C)	mg/l	33	IS: 3025 (P-44)-1993
3.	Chemical Oxygen Demand (COD)	mg/l	98	IS: 3025 (P-58)-2006
4.	Total Suspended Solids (TSS)	mg/l	60	IS: 3025 (P-17)-1984
5.	Total Coliform	Per 100ml	Absent	IS: 15185-2016

\*\*\*END OF REPORT\*\*\*

\*The above test parameter by Client request.

Authorised Signatory

- Note :
1. The test results listed pertain to the sample tested and applicable parameters.
  2. Total liability of this lab is limited to Invoice amount
  3. Any discrepancy found in the test report may be communicated with in seven days from the date of issue to Test Report.
  4. Remainder of Sample tested may be collected within 15 days from the date of issue of test report After which it shall be disposed off.
  5. The test report should not be produced as an evidence for any legal purpose, Court, Advertising media without the prior permission of the director, BTH.



# BIRASINI TEST HOUSE

Govt. Approved / ISO IEC : 17025 : 2017 / ISO : 9001 : 2015  
ISO : 14001 : 2015 & OHSAS 45001 : 2018 Certified Laboratory  
(NABL Accredited Testing Laboratory)

94

BIRASINI TEST HOUSE



20126

## TEST REPORT

Issued To,  
M/S SIGN AGE INDIA PVT. LTD.  
B-49, Sector-83, Phase-II  
Extension Noida (U.P.)

Report No. : 50-26062023-34  
Date of Receiving : 26/06/2023  
Date of Starting : 26/06/2023  
Date of Completion : 07/07/2023  
Date of Reporting : 07/07/2023  
Submitted By : Customer

Page 1 of 1

Sample Description : Waste Water  
Location : At the Bank of Yamuna, Agra  
Independent Drains : Gali Antram Baghichi Drain 2

S.No.	Test Parameters	Units	Results	Test Method
1.	pH Value	-	7.34	IS: 3025 (P-11)-2022
2.	Biochemical Oxygen Demand (BOD) (3 days at 27°C)	mg/l	34	IS: 3025 (P-44)-1993
3.	Chemical Oxygen Demand (COD)	mg/l	104	IS: 3025 (P-58)-2006
4.	Total Suspended Solids (TSS)	mg/l	64	IS: 3025 (P-17)-1984
5.	Total Coliform	Per 100ml	Absent	IS: 15185-2016

\*\*\*END OF REPORT\*\*\*

\*The above test parameter by Client request.

Authorised Signatory

- Note :
1. The test results listed pertain to the sample tested and applicable parameters.
  2. Total liability of this lab is limited to Invoice amount
  3. Any discrepancy found in the test report may be communicated with in seven days from the date of issue to Test Report.
  4. Remainder of Sample tested may be collected within 15 days from the date of issue of test report After which it shall be disposed off.
  5. The test report should not be produced as an evidence for any legal purpose, Court, Advertising media without the prior permission of the director, BTH.



# BIRASINI TEST HOUSE

95

Govt. Approved / ISO IEC : 17025 : 2017 / ISO : 9001 : 2015  
ISO : 14001 : 2015 & OHSAS 45001 : 2018 Certified Laboratory  
(NABL Accredited Testing Laboratory)



## TEST REPORT

Issued To,  
M/S SIGN AGE INDIA PVT. LTD.  
B-49, Sector-83, Phase-II  
Extension Noida (U.P.)

Report No. : 50-26062023-35  
Date of Receiving : 26/06/2023  
Date of Starting : 26/06/2023  
Date of Completion : 07/07/2023  
Date of Reporting : 07/07/2023  
Submitted By : Customer

Page 1 of 1

Sample Description : Waste Water  
Location : At the Bank of Yamuna, Agra  
Independent Drains : Ambedkar Park Drain

S.No.	Test Parameters	Units	Results	Test Method
1.	pH Value	-	7.30	IS: 3025 (P-11)-2022
2.	Biochemical Oxygen Demand (BOD) (3 days at 27°C)	mg/l	33	IS: 3025 (P-44)-1993
3.	Chemical Oxygen Demand (COD)	mg/l	104	IS: 3025 (P-58)-2006
4.	Total Suspended Solids (TSS)	mg/l	64	IS: 3025 (P-17)-1984
5.	Total Coliform	Per 100ml	Absent	IS: 15185-2016

\*\*\*END OF REPORT\*\*\*

\*The above test parameter by Client request.



- Note :
1. The test results listed pertain to the sample tested and applicable parameters.
  2. Total liability of this lab is limited to Invoice amount
  3. Any discrepancy found in the test report may be communicated with in seven days from the date of issue to Test Report.
  4. Remainder of Sample tested may be collected within 15 days from the date of issue of test report After which it shall be disposed off.
  5. The test report should not be produced as an evidence for any legal purpose, Court, Advertising media without the prior permission of the director, BTH.



# BIRASINI TEST HOUSE

Govt. Approved / ISO IEC : 17025 : 2017 / ISO : 9001 : 2015  
ISO : 14001 : 2015 & OHSAS 45001 : 2018 Certified Laboratory  
(NABL Accredited Testing Laboratory)

96

BIRASINI TEST HOUSE



20128

## TEST REPORT

Issued To,  
M/S SIGN AGE INDIA PVT. LTD.  
B-49, Sector-83, Phase-II  
Extension Noida (U.P.)

Report No. : 50-26062023-36  
Date of Receiving : 26/06/2023  
Date of Starting : 26/06/2023  
Date of Completion : 07/07/2023  
Date of Reporting : 07/07/2023  
Submitted By : Customer

Page 1 of 1

Sample Description : Waste Water  
Location : At the Bank of Yamuna, Agra  
Independent Drains : Moti Mahal Drain 4

S.No.	Test Parameters	Units	Results	Test Method
1.	pH Value	-	7.26	IS: 3025 (P-11)-2022
2.	Biochemical Oxygen Demand (BOD) (3 days at 27°C)	mg/l	35	IS: 3025 (P-44)-1993
3.	Chemical Oxygen Demand (COD)	mg/l	108	IS: 3025 (P-58)-2006
4.	Total Suspended Solids (TSS)	mg/l	74	IS: 3025 (P-17)-1984
5.	Total Coliform	Per 100ml	Absent	IS: 15185-2016

\*\*\*END OF REPORT\*\*\*

\*The above test parameter by Client request.

Authorised Signatory

- Note : 1. The test results listed pertain to the sample tested and applicable parameters.  
2. Total liability of this lab is limited to Invoice amount  
3. Any discrepancy found in the test report may be communicated with in seven days from the date of issue to Test Report.  
4. Remainder of Sample tested may be collected within 15 days from the date of issue of test report After which it shall be disposed off.  
5. The test report should not be produced as an evidence for any legal purpose, Court, Advertising media without the prior permission of the director, BTH.



# BIRASINI TEST HOUSE

Govt. Approved / ISO IEC : 17025 : 2017 / ISO : 9001 : 2015  
ISO : 14001 : 2015 & OHSAS 45001 : 2018 Certified Laboratory  
(NABL Accredited Testing Laboratory)

97

BIRASINI TEST HOUSE



20123

## TEST REPORT

Issued To,  
M/S SIGN AGE INDIA PVT. LTD.  
B-49, Sector-83, Phase-II  
Extension Noida (U.P.)

Report No. : 50-26062023-37  
Date of Receiving : 26/06/2023  
Date of Starting : 26/06/2023  
Date of Completion : 07/07/2023  
Date of Reporting : 07/07/2023  
Submitted By : Customer

Page 1 of 1

Sample Description : Waste Water  
Location : At the Bank of Yamuna, Agra  
Independent Drains : Rambagh Drain - II

S.No.	Test Parameters	Units	Results	Test Method
1.	pH Value	-	7.78	IS: 3025 (P-11)-2022
2.	Biochemical Oxygen Demand (BOD) (3 days at 27°C)	mg/l	35	IS: 3025 (P-44)-1993
3.	Chemical Oxygen Demand (COD)	mg/l	116	IS: 3025 (P-58)-2006
4.	Total Suspended Solids (TSS)	mg/l	69	IS: 3025 (P-17)-1984
5.	Total Coliform	Per 100ml	Absent	IS: 15185-2016

\*\*\*END OF REPORT\*\*\*

\*The above test parameter by Client request.



Authorized Signatory

- Note :
1. The test results listed pertain to the sample tested and applicable parameters.
  2. Total liability of this lab is limited to Invoice amount
  3. Any discrepancy found in the test report may be communicated with in seven days from the date of issue to Test Report.
  4. Remainder of Sample tested may be collected within 15 days from the date of issue of test report After which it shall be disposed off.
  5. The test report should not be produced as an evidence for any legal purpose, Court, Advertising media without the prior permission of the director, BTH.



# BIRASINI TEST HOUSE

98

Govt. Approved / ISO IEC : 17025 : 2017 / ISO : 9001 : 2015  
ISO : 14001 : 2015 & OHSAS 45001 : 2018 Certified Laboratory  
(NABL Accredited Testing Laboratory)



## TEST REPORT

Issued To,  
M/S SIGN AGE INDIA PVT. LTD.  
B-49, Sector-83, Phase-II  
Extension Noida (U.P.)

Report No. : 50-26062023-38  
Date of Receiving : 26/06/2023  
Date of Starting : 26/06/2023  
Date of Completion : 07/07/2023  
Date of Reporting : 07/07/2023  
Submitted By : Customer  
Page 1 of 1

Sample Description : Waste Water  
Location : At the Bank of Yamuna, Agra  
Cluster 8 : Lohiya Nagar

S.No.	Test Parameters	Units	Results	Test Method
1.	pH Value	-	7.60	IS: 3025 (P-11)-2022
2.	Biochemical Oxygen Demand (BOD) (3 days at 27°C)	mg/l	33	IS: 3025 (P-44)-1993
3.	Chemical Oxygen Demand (COD)	mg/l	98	IS: 3025 (P-58)-2006
4.	Total Suspended Solids (TSS)	mg/l	70	IS: 3025 (P-17)-1984
5.	Total Coliform	Per 100ml	Absent	IS: 15185-2016

\*\*\*END OF REPORT\*\*\*

\*The above test parameter by Client request.

Authorised Signatory

- Note : 1. The test results listed pertain to the sample tested and applicable parameters.  
2. Total liability of this lab is limited to Invoice amount  
3. Any discrepancy found in the test report may be communicated with in seven days from the date of issue to Test Report.  
4. Remainder of Sample tested may be collected within 15 days from the date of issue of test report After which it shall be disposed off.  
5. The test report should not be produced as an evidence for any legal purpose, Court, Advertising media without the prior permission of the director, BTH.



# BIRASINI TEST HOUSE

Govt. Approved / ISO IEC : 17025 : 2017 / ISO : 9001 : 2015  
ISO : 14001 : 2015 & OHSAS 45001 : 2018 Certified Laboratory  
(NABL Accredited Testing Laboratory)

99

BIRASINI TEST HOUSE



20125

## TEST REPORT

Issued To,  
M/S SIGN AGE INDIA PVT. LTD.  
B-49, Sector-83, Phase-II  
Extension Noida (U.P.)

Report No. : 50-26062023-39  
Date of Receiving : 26/06/2023  
Date of Starting : 26/06/2023  
Date of Completion : 07/07/2023  
Date of Reporting : 07/07/2023  
Submitted By : Customer  
Page 1 of 1

Sample Description : Waste Water  
Location : At the Bank of Yamuna, Agra  
Independent Drains : Wavepur

S.No.	Test Parameters	Units	Results	Test Method
1.	pH Value	-	7.40	IS: 3025 (P-11)-2022
2.	Biochemical Oxygen Demand (BOD) (3 days at 27°C)	mg/l	34	IS: 3025 (P-44)-1993
3.	Chemical Oxygen Demand (COD)	mg/l	104	IS: 3025 (P-58)-2006
4.	Total Suspended Solids (TSS)	mg/l	74	IS: 3025 (P-17)-1984
5.	Total Coliform	Per 100ml	Absent	IS: 15185-2016

\*\*\*END OF REPORT\*\*\*

\*The above test parameter by Client request.



Authorized Signatory

- Note :
1. The test results listed pertain to the sample tested and applicable parameters.
  2. Total liability of this lab is limited to Invoice amount
  3. Any discrepancy found in the test report may be communicated with in seven days from the date of issue to Test Report.
  4. Remainder of Sample tested may be collected within 15 days from the date of issue of test report After which it shall be disposed off.
  5. The test report should not be produced as an evidence for any legal purpose, Court, Advertising media without the prior permission of the director, BTH.



# BIRASINI TEST HOUSE

100

Govt. Approved / ISO IEC : 17025 : 2017 / ISO : 9001 : 2015  
ISO : 14001 : 2015 & OHSAS 45001 : 2018 Certified Laboratory  
(NABL Accredited Testing Laboratory)

BIRASINI TEST HOUSE



20120

## TEST REPORT

Issued To,  
M/S SIGN AGE INDIA PVT. LTD.  
B-49, Sector-83, Phase-II  
Extension Noida (U.P.)

Report No. : 50-26062023-40  
Date of Receiving : 26/06/2023  
Date of Starting : 26/06/2023  
Date of Completion : 07/07/2023  
Date of Reporting : 07/07/2023  
Submitted By : Customer

Page 1 of 1

Sample Description : Waste Water  
Location : At the Bank of Yamuna, Agra  
Independent Drains : Kailash Mandir

S.No.	Test Parameters	Units	Results	Test Method
1.	pH Value	-	7.16	IS: 3025 (P-11)-2022
2.	Biochemical Oxygen Demand (BOD) (3 days at 27°C)	mg/l	34	IS: 3025 (P-44)-1993
3.	Chemical Oxygen Demand (COD)	mg/l	105	IS: 3025 (P-58)-2006
4.	Total Suspended Solids (TSS)	mg/l	74	IS: 3025 (P-17)-1984
5.	Total Coliform	Per 100ml	Absent	IS: 15185-2016

\*\*\*END OF REPORT\*\*\*

\*The above test parameter by Client request.

Authorised Signatory

- Note :
1. The test results listed pertain to the sample tested and applicable parameters.
  2. Total liability of this lab is limited to Invoice amount
  3. Any discrepancy found in the test report may be communicated with in seven days from the date of issue to Test Report.
  4. Remainder of Sample tested may be collected within 15 days from the date of issue of test report After which it shall be disposed off.
  5. The test report should not be produced as an evidence for any legal purpose, Court, Advertising media without the prior permission of the director, BTH.

Laboratory Office: 4/31 B, Site-IV, Industrial Area, Sahibabad, Ghaziabad, U.P. - 201010  
Ph:- 0120-4526493, E-mail : birasintesthouse1@gmail.com, Website : www.birasintesthouse.in



# BIRASINI TEST HOUSE

101

Govt. Approved / ISO IEC : 17025 : 2017 / ISO : 9001 : 2015  
ISO : 14001 : 2015 & OHSAS 45001 : 2018 Certified Laboratory  
(NABL Accredited Testing Laboratory)

BIRASINI TEST HOUSE



20121

## TEST REPORT

Issued To,  
M/S SIGN AGE INDIA PVT. LTD.  
B-49, Sector-83, Phase-II  
Extension Noida (U.P.)

Report No. : 50-26062023-41  
Date of Receiving : 26/06/2023  
Date of Starting : 26/06/2023  
Date of Completion : 07/07/2023  
Date of Reporting : 07/07/2023  
Submitted By : Customer

Page 1 of 1

Sample Description : Waste Water  
Location : At the Bank of Yamuna, Agra  
Independent Drains : K.K. Nagar Drain

S.No.	Test Parameters	Units	Results	Test Method
1.	pH Value	-	7.30	IS: 3025 (P-11)-2022
2.	Biochemical Oxygen Demand (BOD) (3 days at 27°C)	mg/l	33	IS: 3025 (P-44)-1993
3.	Chemical Oxygen Demand (COD)	mg/l	112	IS: 3025 (P-58)-2006
4.	Total Suspended Solids (TSS)	mg/l	72	IS: 3025 (P-17)-1984
5.	Total Coliform	Per 100ml	Absent	IS: 15185-2016

\*\*\*END OF REPORT\*\*\*

\*The above test parameter by Client request.

  
Authorised Signatory

- Note : 1. The test results listed pertain to the sample tested and applicable parameters.  
2. Total liability of this lab is limited to Invoice amount  
3. Any discrepancy found in the test report may be communicated with in seven days from the date of issue to Test Report.  
4. Remainder of Sample tested may be collected within 15 days from the date of issue of test report After which it shall be disposed off.  
5. The test report should not be produced as an evidence for any legal purpose, Court, Advertising media without the prior permission of the director, BTH.

Laboratory Office: 4/31 B, Site-IV, Industrial Area, Sahibabad, Ghaziabad, U.P. - 201010  
Ph:- 0120-4526493, E-mail : birasintesthouse1@gmail.com, Website : www.birasintesthouse.in



# BIRASINI TEST HOUSE

102

Govt. Approved / ISO IEC : 17025 : 2017 / ISO : 9001 : 2015  
ISO : 14001 : 2015 & OHSAS 45001 : 2018 Certified Laboratory  
(NABL Accredited Testing Laboratory)

BIRASINI TEST HOUSE



20122

## TEST REPORT

Issued To,  
M/S SIGN AGE INDIA PVT. LTD.  
B-49, Sector-83, Phase-II  
Extension Noida (U.P.)

Report No. : 50-26062023-42  
Date of Receiving : 26/06/2023  
Date of Starting : 26/06/2023  
Date of Completion : 07/07/2023  
Date of Reporting : 07/07/2023  
Submitted By : Customer  
Page 1 of 1

Sample Description : Waste Water  
Location : At the Bank of Yamuna, Agra  
Independent Drains : Kamayeni Hospital Drain

S.No.	Test Parameters	Units	Results	Test Method
1.	pH Value	-	7.76	IS: 3025 (P-11)-2022
2.	Biochemical Oxygen Demand (BOD) (3 days at 27°C)	mg/l	33	IS: 3025 (P-44)-1993
3.	Chemical Oxygen Demand (COD)	mg/l	104	IS: 3025 (P-58)-2006
4.	Total Suspended Solids (TSS)	mg/l	74	IS: 3025 (P-17)-1984
5.	Total Coliform	Per 100ml	Absent	IS: 15185-2016

\*\*\*END OF REPORT\*\*\*

\*The above test parameter by Client request.

Authorised Signatory

- Note :
1. The test results listed pertain to the sample tested and applicable parameters.
  2. Total liability of this lab is limited to Invoice amount
  3. Any discrepancy found in the test report may be communicated with in seven days from the date of issue to Test Report.
  4. Remainder of Sample tested may be collected within 15 days from the date of issue of test report After which it shall be disposed off.
  5. The test report should not be produced as an evidence for any legal purpose, Court, Advertising media without the prior permission of the director, BTH.

Laboratory Office: 4/31 B, Site-IV, Industrial Area, Sahibabad, Ghaziabad, U.P. - 201010  
Ph:- 0120-4526493, E-mail : birasintesthouse1@gmail.com, Website : www.birasintesthouse.in



# BIRASINI TEST HOUSE

103

Govt. Approved / ISO IEC : 17025 : 2017 / ISO : 9001 : 2015  
ISO : 14001 : 2015 & OHSAS 45001 : 2018 Certified Laboratory  
(NABL Accredited Testing Laboratory)

BIRASINI TEST HOUSE



20117

## TEST REPORT

Issued To,  
M/S SIGN AGE INDIA PVT. LTD.  
B-49, Sector-83, Phase-II  
Extension Noida (U.P.)

Report No. : 50-26062023-43  
Date of Receiving : 26/06/2023  
Date of Starting : 26/06/2023  
Date of Completion : 07/07/2023  
Date of Reporting : 07/07/2023  
Submitted By : Customer

Page 1 of 1

Sample Description : Waste Water  
Location : At the Bank of Yamuna, Agra  
Independent Drains : Artoni Drain

S.No.	Test Parameters	Units	Results	Test Method
1.	pH Value	-	7.24	IS: 3025 (P-11)-2022
2.	Biochemical Oxygen Demand (BOD) (3 days at 27°C)	mg/l	34	IS: 3025 (P-44)-1993
3.	Chemical Oxygen Demand (COD)	mg/l	108	IS: 3025 (P-58)-2006
4.	Total Suspended Solids (TSS)	mg/l	69	IS: 3025 (P-17)-1984
5.	Total Coliform	Per 100ml	Absent	IS: 15185-2016

\*\*\*END OF REPORT\*\*\*

\*The above test parameter by Client request.

  
Authorised Signatory

- Note :
1. The test results listed pertain to the sample tested and applicable parameters.
  2. Total liability of this lab is limited to Invoice amount
  3. Any discrepancy found in the test report may be communicated with in seven days from the date of issue to Test Report.
  4. Remainder of Sample tested may be collected within 15 days from the date of issue of test report After which it shall be disposed off.
  5. The test report should not be produced as an evidence for any legal purpose, Court, Advertising media without the prior permission of the director, BTH.

Laboratory Office: 4/31 B, Site-IV, Industrial Area, Sahibabad, Ghaziabad, U.P. - 201010  
Ph:- 0120-4526493, E-mail : birasintesthouse1@gmail.com, Website : www.birasintesthouse.in



# BIRASINI TEST HOUSE

104

Govt. Approved / ISO IEC : 17025 : 2017 / ISO : 9001 : 2015  
ISO : 14001 : 2015 & OHSAS 45001 : 2018 Certified Laboratory  
(NABL Accredited Testing Laboratory)

BIRASINI TEST HOUSE



20118

## TEST REPORT

Issued To,  
M/S SIGN AGE INDIA PVT. LTD.  
B-49, Sector-83, Phase-II  
Extension Noida (U.P.)

Report No. : 50-26062023-44  
Date of Receiving : 26/06/2023  
Date of Starting : 26/06/2023  
Date of Completion : 07/07/2023  
Date of Reporting : 07/07/2023  
Submitted By : Customer

Page 1 of 1

Sample Description : Waste Water  
Location : At the Bank of Yamuna, Agra  
Independent Drains : Jalma Drain

S.No.	Test Parameters	Units	Results	Test Method
1.	pH Value	-	7.78	IS: 3025 (P-11)-2022
2.	Biochemical Oxygen Demand (BOD) (3 days at 27°C)	mg/l	32	IS: 3025 (P-44)-1993
3.	Chemical Oxygen Demand (COD)	mg/l	98	IS: 3025 (P-58)-2006
4.	Total Suspended Solids (TSS)	mg/l	62	IS: 3025 (P-17)-1984
5.	Total Coliform	Per 100ml	Absent	IS: 15185-2016

\*\*\*END OF REPORT\*\*\*

\*The above test parameter by Client request.

Authorised Signatory

- Note : 1. The test results listed pertain to the sample tested and applicable parameters.  
2. Total liability of this lab is limited to Invoice amount  
3. Any discrepancy found in the test report may be communicated with in seven days from the date of issue to Test Report.  
4. Remainder of Sample tested may be collected within 15 days from the date of issue of test report After which it shall be disposed off.  
5. The test report should not be produced as an evidence for any legal purpose, Court, Advertising media without the prior permission of the director, BTH.

Laboratory Office: 4/31 B, Site-IV, Industrial Area, Sahibabad, Ghaziabad, U.P. - 201010  
Ph:- 0120-4526493, E-mail : birasintesthouse1@gmail.com, Website : www.birasintesthouse.in



# BIRASINI TEST HOUSE

105

Govt. Approved / ISO IEC : 17025 : 2017 / ISO : 9001 : 2015  
ISO : 14001 : 2015 & OHSAS 45001 : 2018 Certified Laboratory  
(NABL Accredited Testing Laboratory)

BIRASINI TEST HOUSE



20119

## TEST REPORT

Issued To,  
M/S SIGN AGE INDIA PVT. LTD.  
B-49, Sector-83, Phase-II  
Extension Noida (U.P.)

Report No. : 50-26062023-45  
Date of Receiving : 26/06/2023  
Date of Starting : 26/06/2023  
Date of Completion : 07/07/2023  
Date of Reporting : 07/07/2023  
Submitted By : Customer

Page 1 of 1

Sample Description : Waste Water  
Location : At the Bank of Yamuna, Agra  
Independent Drains : Khairati Tola Drain

S.No.	Test Parameters	Units	Results	Test Method
1.	pH Value	-	7.09	IS: 3025 (P-11)-2022
2.	Biochemical Oxygen Demand (BOD) (3 days at 27°C)	mg/l	35	IS: 3025 (P-44)-1993
3.	Chemical Oxygen Demand (COD)	mg/l	106	IS: 3025 (P-58)-2006
4.	Total Suspended Solids (TSS)	mg/l	69	IS: 3025 (P-17)-1984
5.	Total Coliform	Per 100ml	Absent	IS: 15185-2016

\*\*\*END OF REPORT\*\*\*

\*The above test parameter by Client request.



Authorised Signatory

- Note :
1. The test results listed pertain to the sample tested and applicable parameters.
  2. Total liability of this lab is limited to Invoice amount
  3. Any discrepancy found in the test report may be communicated with in seven days from the date of issue to Test Report.
  4. Remainder of Sample tested may be collected within 15 days from the date of issue of test report After which it shall be disposed off.
  5. The test report should not be produced as an evidence for any legal purpose, Court, Advertising media without the prior permission of the director, BTH.



# BIRASINI TEST HOUSE

106

Govt. Approved / ISO IEC : 17025 : 2017 / ISO : 9001 : 2015  
ISO : 14001 : 2015 & OHSAS 45001 : 2018 Certified Laboratory  
(NABL Accredited Testing Laboratory)

BIRASINI TEST HOUSE



20114

## TEST REPORT

Issued To,  
M/S SIGN AGE INDIA PVT. LTD.  
B-49, Sector-83, Phase-II  
Extension Noida (U.P.)

Report No. : 50-26062023-46  
Date of Receiving : 26/06/2023  
Date of Starting : 26/06/2023  
Date of Completion : 07/07/2023  
Date of Reporting : 07/07/2023  
Submitted By : Customer

Page 1 of 1

Sample Description : Waste Water  
Location : At the Bank of Yamuna, Agra  
Independent Drains : Gailana Drain

S.No.	Test Parameters	Units	Results	Test Method
1.	pH Value	-	7.26	IS: 3025 (P-11)-2022
2.	Biochemical Oxygen Demand (BOD) (3 days at 27°C)	mg/l	33	IS: 3025 (P-44)-1993
3.	Chemical Oxygen Demand (COD)	mg/l	104	IS: 3025 (P-58)-2006
4.	Total Suspended Solids (TSS)	mg/l	72	IS: 3025 (P-17)-1984
5.	Total Coliform	Per 100ml	Absent	IS: 15185-2016

\*\*\*END OF REPORT\*\*\*

\*The above test parameter by Client request.

  
Authorised Signatory

- Note :
1. The test results listed pertain to the sample tested and applicable parameters.
  2. Total liability of this lab is limited to Invoice amount
  3. Any discrepancy found in the test report may be communicated with in seven days from the date of issue to Test Report.
  4. Remainder of Sample tested may be collected within 15 days from the date of issue of test report After which it shall be disposed off.
  5. The test report should not be produced as an evidence for any legal purpose, Court, Advertising media without the prior permission of the director, BTH.



# BIRASINI TEST HOUSE

107

Govt. Approved / ISO IEC : 17025 : 2017 / ISO : 9001 : 2015  
ISO : 14001 : 2015 & OHSAS 45001 : 2018 Certified Laboratory  
(NABL Accredited Testing Laboratory)

BIRASINI TEST HOUSE



20115

## TEST REPORT

Issued To,  
M/S SIGN AGE INDIA PVT. LTD.  
B-49, Sector-83, Phase-II  
Extension Noida (U.P.)

Report No. : 50-26062023-47  
Date of Receiving : 26/06/2023  
Date of Starting : 26/06/2023  
Date of Completion : 07/07/2023  
Date of Reporting : 07/07/2023  
Submitted By : Customer  
Page 1 of 1

Sample Description : Waste Water  
Location : At the Bank of Yamuna, Agra  
Independent Drains : Poiya Ghat-1

S.No.	Test Parameters	Units	Results	Test Method
1.	pH Value	-	7.72	IS: 3025 (P-11)-2022
2.	Biochemical Oxygen Demand (BOD) (3 days at 27°C)	mg/l	32	IS: 3025 (P-44)-1993
3.	Chemical Oxygen Demand (COD)	mg/l	104	IS: 3025 (P-58)-2006
4.	Total Suspended Solids (TSS)	mg/l	60	IS: 3025 (P-17)-1984
5.	Total Coliform	Per 100ml	Absent	IS: 15185-2016

\*\*\*END OF REPORT\*\*\*

\*The above test parameter by Client request.

  
Authorised Signatory

- Note : 1. The test results listed pertain to the sample tested and applicable parameters.  
2. Total liability of this lab is limited to Invoice amount  
3. Any discrepancy found in the test report may be communicated with in seven days from the date of issue to Test Report.  
4. Remainder of Sample tested may be collected within 15 days from the date of issue of test report After which it shall be disposed off.  
5. The test report should not be produced as an evidence for any legal purpose, Court, Advertising media without the prior permission of the director, BTH.



# BIRASINI TEST HOUSE

108

Govt. Approved / ISO IEC : 17025 : 2017 / ISO : 9001 : 2015  
ISO : 14001 : 2015 & OHSAS 45001 : 2018 Certified Laboratory  
(NABL Accredited Testing Laboratory)

BIRASINI TEST HOUSE



20116

## TEST REPORT

**Issued To,**  
M/S SIGN AGE INDIA PVT. LTD.  
B-49, Sector-83, Phase-II  
Extension Noida (U.P.)

**Report No.** : 50-26062023-48  
**Date of Receiving** : 26/06/2023  
**Date of Starting** : 26/06/2023  
**Date of Completion** : 07/07/2023  
**Date of Reporting** : 07/07/2023  
**Submitted By** : Customer  
Page 1 of 1

**Sample Description** : Waste Water  
**Location** : At the Bank of Yamuna, Agra  
**Independent Drains** : Poiya Ghat-2

S.No.	Test Parameters	Units	Results	Test Method
1.	pH Value	-	7.76	IS: 3025 (P-11)-2022
2.	Biochemical Oxygen Demand (BOD) (3 days at 27°C)	mg/l	34	IS: 3025 (P-44)-1993
3.	Chemical Oxygen Demand (COD)	mg/l	102	IS: 3025 (P-58)-2006
4.	Total Suspended Solids (TSS)	mg/l	66	IS: 3025 (P-17)-1984
5.	Total Coliform	Per 100ml	Absent	IS: 15185-2016

\*\*\*END OF REPORT\*\*\*

\*The above test parameter by Client request.

Authorised Signatory

- Note :
1. The test results listed pertain to the sample tested and applicable parameters.
  2. Total liability of this lab is limited to Invoice amount
  3. Any discrepancy found in the test report may be communicated with in seven days from the date of issue to Test Report.
  4. Remainder of Sample tested may be collected within 15 days from the date of issue of test report After which it shall be disposed off.
  5. The test report should not be produced as an evidence for any legal purpose, Court, Advertising media without the prior permission of the director, BTH.

Laboratory Office: 4/31 B, Site-IV, Industrial Area, Sahibabad, Ghaziabad, U.P. - 201010  
Ph:- 0120-4526493, E-mail : birasintesthouse1@gmail.com, Website : www.birasintesthouse.in



# BIRASINI TEST HOUSE

109

Govt. Approved / ISO IEC : 17025 : 2017 / ISO : 9001 : 2015  
ISO : 14001 : 2015 & OHSAS 45001 : 2018 Certified Laboratory  
(NABL Accredited Testing Laboratory)

BIRASINI TEST HOUSE



20111

## TEST REPORT

Issued To,  
M/S SIGN AGE INDIA PVT. LTD.  
B-49, Sector-83, Phase-II  
Extension Noida (U.P.)

Report No. : 50-26062023-49  
Date of Receiving : 26/06/2023  
Date of Starting : 26/06/2023  
Date of Completion : 07/07/2023  
Date of Reporting : 07/07/2023  
Submitted By : Customer

Page 1 of 1

Sample Description : Waste Water  
Location : At the Bank of Yamuna, Agra  
Independent Drains : Manoharpur Drain

S.No.	Test Parameters	Units	Results	Test Method
1.	pH Value	-	7.16	IS: 3025 (P-11)-2022
2.	Biochemical Oxygen Demand (BOD) (3 days at 27°C)	mg/l	34	IS: 3025 (P-44)-1993
3.	Chemical Oxygen Demand (COD)	mg/l	96	IS: 3025 (P-58)-2006
4.	Total Suspended Solids (TSS)	mg/l	64	IS: 3025 (P-17)-1984
5.	Total Coliform	Per 100ml	Absent	IS: 15185-2016

\*\*\*END OF REPORT\*\*\*

\*The above test parameter by Client request.



- Note :
1. The test results listed pertain to the sample tested and applicable parameters.
  2. Total liability of this lab is limited to Invoice amount
  3. Any discrepancy found in the test report may be communicated with in seven days from the date of issue to Test Report.
  4. Remainder of Sample tested may be collected within 15 days from the date of issue of test report After which it shall be disposed off.
  5. The test report should not be produced as an evidence for any legal purpose, Court, Advertising media without the prior permission of the director, BTH.

Laboratory Office: 4/31 B, Site-IV, Industrial Area, Sahibabad, Ghaziabad, U.P. - 201010  
Ph:- 0120-4526493, E-mail : birasinitesthouse1@gmail.com, Website : www.birasinitesthouse.in



# BIRASINI TEST HOUSE

110

Govt. Approved / ISO IEC : 17025 : 2017 / ISO : 9001 : 2015  
ISO : 14001 : 2015 & OHSAS 45001 : 2018 Certified Laboratory  
(NABL Accredited Testing Laboratory)

BIRASINI TEST HOUSE



20112

## TEST REPORT

Issued To,  
M/S SIGN AGE INDIA PVT. LTD.  
B-49, Sector-83, Phase-II  
Extension Noida (U.P.)

Report No. : 50-26062023-50  
Date of Receiving : 26/06/2023  
Date of Starting : 26/06/2023  
Date of Completion : 07/07/2023  
Date of Reporting : 07/07/2023  
Submitted By : Customer

Page 1 of 1

Sample Description : Waste Water  
Location : At the Bank of Yamuna, Agra  
Independent Drains : Bahdurpur Gaon Drain

S.No.	Test Parameters	Units	Results	Test Method
1.	pH Value	-	7.64	IS: 3025 (P-11)-2022
2.	Biochemical Oxygen Demand (BOD) (3 days at 27°C)	mg/l	35	IS: 3025 (P-44)-1993
3.	Chemical Oxygen Demand (COD)	mg/l	116	IS: 3025 (P-58)-2006
4.	Total Suspended Solids (TSS)	mg/l	64	IS: 3025 (P-17)-1984
5.	Total Coliform	Per 100ml	Absent	IS: 15185-2016

\*\*\*END OF REPORT\*\*\*

\*The above test parameter by Client request.



Authorized Signatory

- Note : 1. The test results listed pertain to the sample tested and applicable parameters.  
2. Total liability of this lab is limited to Invoice amount  
3. Any discrepancy found in the test report may be communicated with in seven days from the date of issue to Test Report.  
4. Remainder of Sample tested may be collected within 15 days from the date of issue of test report After which it shall be disposed off.  
5. The test report should not be produced as an evidence for any legal purpose, Court, Advertising media without the prior permission of the director, BTH.

Laboratory Office: 4/31 B, Site-IV, Industrial Area, Sahibabad, Ghaziabad, U.P. - 201010  
Ph:- 0120-4526493, E-mail : birasintesthouse1@gmail.com, Website : www.birasintesthouse.in



# BIRASINI TEST HOUSE

111

Govt. Approved / ISO IEC : 17025 : 2017 / ISO : 9001 : 2015  
ISO : 14001 : 2015 & OHSAS 45001 : 2018 Certified Laboratory  
(NABL Accredited Testing Laboratory)

BIRASINI TEST HOUSE



20113

## TEST REPORT

Issued To,  
M/S SIGN AGE INDIA PVT. LTD.  
B-49, Sector-83, Phase-II  
Extension Noida (U.P.)

Report No. : 50-26062023-51  
Date of Receiving : 26/06/2023  
Date of Starting : 26/06/2023  
Date of Completion : 07/07/2023  
Date of Reporting : 07/07/2023  
Submitted By : Customer  
Page 1 of 1

Sample Description : Waste Water  
Location : At the Bank of Yamuna, Agra  
Independent Drains : Eklavya Water Plant Drain

S.No.	Test Parameters	Units	Results	Test Method
1.	pH Value	-	7.19	IS: 3025 (P-11)-2022
2.	Biochemical Oxygen Demand (BOD) (3 days at 27°C)	mg/l	32	IS: 3025 (P-44)-1993
3.	Chemical Oxygen Demand (COD)	mg/l	98	IS: 3025 (P-58)-2006
4.	Total Suspended Solids (TSS)	mg/l	64	IS: 3025 (P-17)-1984
5.	Total Coliform	Per 100ml	Absent	IS: 15185-2016

\*\*\*END OF REPORT\*\*\*

\*The above test parameter by Client request.

  
Authorised Signatory

- Note : 1. The test results listed pertain to the sample tested and applicable parameters.  
2. Total liability of this lab is limited to Invoice amount  
3. Any discrepancy found in the test report may be communicated with in seven days from the date of issue to Test Report.  
4. Remainder of Sample tested may be collected within 15 days from the date of issue of test report After which it shall be disposed off.  
5. The test report should not be produced as an evidence for any legal purpose, Court, Advertising media without the prior permission of the director, BTH.

Laboratory Office: 4/31 B, Site-IV, Industrial Area, Sahibabad, Ghaziabad, U.P. - 201010  
Ph:- 0120-4526493, E-mail : birasinitesthouse1@gmail.com, Website : www.birasinitesthouse.in



# BIRASINI TEST HOUSE

112

Govt. Approved / ISO IEC : 17025 : 2017 / ISO : 9001 : 2015  
ISO : 14001 : 2015 & OHSAS 45001 : 2018 Certified Laboratory  
(NABL Accredited Testing Laboratory)

BIRASINI TEST HOUSE



20108

## TEST REPORT

Issued To,  
M/S SIGN AGE INDIA PVT. LTD.  
B-49, Sector-83, Phase-II  
Extension Noida (U.P.)

Report No. : 50-26062023-52  
Date of Receiving : 26/06/2023  
Date of Starting : 26/06/2023  
Date of Completion : 07/07/2023  
Date of Reporting : 07/07/2023  
Submitted By : Customer  
Page 1 of 1

Sample Description : Waste Water  
Location : At the Bank of Yamuna, Agra  
Independent Drains : Mau Nala-1

S.No.	Test Parameters	Units	Results	Test Method
1.	pH Value	-	7.67	IS: 3025 (P-11)-2022
2.	Biochemical Oxygen Demand (BOD) (3 days at 27°C)	mg/l	33	IS: 3025 (P-44)-1993
3.	Chemical Oxygen Demand (COD)	mg/l	98	IS: 3025 (P-58)-2006
4.	Total Suspended Solids (TSS)	mg/l	62	IS: 3025 (P-17)-1984
5.	Total Coliform	Per 100ml	Absent	IS: 15185-2016

\*\*\*END OF REPORT\*\*\*

\*The above test parameter by Client request.



Authorised Signatory

- Note :
1. The test results listed pertain to the sample tested and applicable parameters.
  2. Total liability of this lab is limited to Invoice amount
  3. Any discrepancy found in the test report may be communicated with in seven days from the date of issue to Test Report.
  4. Remainder of Sample tested may be collected within 15 days from the date of issue of test report After which it shall be disposed off.
  5. The test report should not be produced as an evidence for any legal purpose, Court, Advertising media without the prior permission of the director, BTH.



# BIRASINI TEST HOUSE

113

Govt. Approved / ISO IEC : 17025 : 2017 / ISO : 9001 : 2015  
ISO : 14001 : 2015 & OHSAS 45001 : 2018 Certified Laboratory  
(NABL Accredited Testing Laboratory)

BIRASINI TEST HOUSE



20109

## TEST REPORT

Issued To,  
M/S SIGN AGE INDIA PVT. LTD.  
B-49, Sector-83, Phase-II  
Extension Noida (U.P.)

Report No. : 50-26062023-53  
Date of Receiving : 26/06/2023  
Date of Starting : 26/06/2023  
Date of Completion : 07/07/2023  
Date of Reporting : 07/07/2023  
Submitted By : Customer

Page 1 of 1

Sample Description : Waste Water  
Location : At the Bank of Yamuna, Agra  
Independent Drains : Mau Nala-2

S.No.	Test Parameters	Units	Results	Test Method
1.	pH Value	-	7.29	IS: 3025 (P-11)-2022
2.	Biochemical Oxygen Demand (BOD) (3 days at 27°C)	mg/l	35	IS: 3025 (P-44)-1993
3.	Chemical Oxygen Demand (COD)	mg/l	102	IS: 3025 (P-58)-2006
4.	Total Suspended Solids (TSS)	mg/l	62	IS: 3025 (P-17)-1984
5.	Total Coliform	Per 100ml	Absent	IS: 15185-2016

\*\*\*END OF REPORT\*\*\*

\*The above test parameter by Client request.

Authorised Signatory

- Note :
1. The test results listed pertain to the sample tested and applicable parameters.
  2. Total liability of this lab is limited to Invoice amount
  3. Any discrepancy found in the test report may be communicated with in seven days from the date of issue to Test Report.
  4. Remainder of Sample tested may be collected within 15 days from the date of issue of test report After which it shall be disposed off.
  5. The test report should not be produced as an evidence for any legal purpose, Court, Advertising media without the prior permission of the director, BTH.



# BIRASINI TEST HOUSE

114

Govt. Approved / ISO IEC : 17025 : 2017 / ISO : 9001 : 2015  
ISO : 14001 : 2015 & OHSAS 45001 : 2018 Certified Laboratory  
(NABL Accredited Testing Laboratory)

BIRASINI TEST HOUSE



20110

## TEST REPORT

Issued To,  
M/S SIGN AGE INDIA PVT. LTD.  
B-49, Sector-83, Phase-II  
Extension Noida (U.P.)

Report No. : 50-26062023-54  
Date of Receiving : 26/06/2023  
Date of Starting : 26/06/2023  
Date of Completion : 07/07/2023  
Date of Reporting : 07/07/2023  
Submitted By : Customer

Page 1 of 1

Sample Description : Waste Water  
Location : At the Bank of Yamuna, Agra  
Independent Drains : Bhalla Ji ke Makan Wali Drain

S.No.	Test Parameters	Units	Results	Test Method
1.	pH Value	-	7.34	IS: 3025 (P-11)-2022
2.	Biochemical Oxygen Demand (BOD) (3 days at 27°C)	mg/l	35	IS: 3025 (P-44)-1993
3.	Chemical Oxygen Demand (COD)	mg/l	106	IS: 3025 (P-58)-2006
4.	Total Suspended Solids (TSS)	mg/l	66	IS: 3025 (P-17)-1984
5.	Total Coliform	Per 100ml	Absent	IS: 15185-2016

\*\*\*END OF REPORT\*\*\*

\*The above test parameter by Client request.

Authorised Signatory

- Note :
1. The test results listed pertain to the sample tested and applicable parameters.
  2. Total liability of this lab is limited to Invoice amount
  3. Any discrepancy found in the test report may be communicated with in seven days from the date of issue to Test Report.
  4. Remainder of Sample tested may be collected within 15 days from the date of issue of test report After which it shall be disposed off.
  5. The test report should not be produced as an evidence for any legal purpose, Court, Advertising media without the prior permission of the director, BTH.

Laboratory Office: 4/31 B, Site-IV, Industrial Area, Sahibabad, Ghaziabad, U.P. - 201010  
Ph:- 0120-4526493, E-mail : birasintesthouse1@gmail.com, Website : www.birasintesthouse.in



# BIRASINI TEST HOUSE

115

Govt. Approved / ISO IEC : 17025 : 2017 / ISO : 9001 : 2015  
ISO : 14001 : 2015 & OHSAS 45001 : 2018 Certified Laboratory  
(NABL Accredited Testing Laboratory)

BIRASINI TEST HOUSE



20105

## TEST REPORT

Issued To,  
M/S SIGN AGE INDIA PVT. LTD.  
B-49, Sector-83, Phase-II  
Extension Noida (U.P.)

Report No. : 50-26062023-55  
Date of Receiving : 26/06/2023  
Date of Starting : 26/06/2023  
Date of Completion : 07/07/2023  
Date of Reporting : 07/07/2023  
Submitted By : Customer  
Page 1 of 1

Sample Description : Waste Water  
Location : At the Bank of Yamuna, Agra  
Independent Drains : Khemchand Toffe Factor Drain

S.No.	Test Parameters	Units	Results	Test Method
1.	pH Value	-	7.36	IS: 3025 (P-11)-2022
2.	Biochemical Oxygen Demand (BOD) (3 days at 27°C)	mg/l	35	IS: 3025 (P-44)-1993
3.	Chemical Oxygen Demand (COD)	mg/l	104	IS: 3025 (P-58)-2006
4.	Total Suspended Solids (TSS)	mg/l	74	IS: 3025 (P-17)-1984
5.	Total Coliform	Per 100ml	Absent	IS: 15185-2016

\*\*\*END OF REPORT\*\*\*

\*The above test parameter by Client request.

  
Authorised Signatory

- Note : 1. The test results listed pertain to the sample tested and applicable parameters.  
2. Total liability of this lab is limited to Invoice amount  
3. Any discrepancy found in the test report may be communicated with in seven days from the date of issue to Test Report.  
4. Remainder of Sample tested may be collected within 15 days from the date of issue of test report After which it shall be disposed off.  
5. The test report should not be produced as an evidence for any legal purpose, Court, Advertising media without the prior permission of the director, BTH.



# BIRASINI TEST HOUSE

116

Govt. Approved / ISO IEC : 17025 : 2017 / ISO : 9001 : 2015  
ISO : 14001 : 2015 & OHSAS 45001 : 2018 Certified Laboratory  
(NABL Accredited Testing Laboratory)

BIRASINI TEST HOUSE



20106

## TEST REPORT

Issued To,  
M/S SIGN AGE INDIA PVT. LTD.  
B-49, Sector-83, Phase-II  
Extension Noida (U.P.)

Report No. : 50-26062023-56  
Date of Receiving : 26/06/2023  
Date of Starting : 26/06/2023  
Date of Completion : 07/07/2023  
Date of Reporting : 07/07/2023  
Submitted By : Customer

Page 1 of 1

Sample Description : Waste Water  
Location : At the Bank of Yamuna, Agra  
Independent Drains : Almary Factory Drain

S.No.	Test Parameters	Units	Results	Test Method
1.	pH Value	-	7.16	IS: 3025 (P-11)-2022
2.	Biochemical Oxygen Demand (BOD) (3 days at 27°C)	mg/l	33	IS: 3025 (P-44)-1993
3.	Chemical Oxygen Demand (COD)	mg/l	98	IS: 3025 (P-58)-2006
4.	Total Suspended Solids (TSS)	mg/l	60	IS: 3025 (P-17)-1984
5.	Total Coliform	Per 100ml	Absent	IS: 15185-2016

\*\*\*END OF REPORT\*\*\*

\*The above test parameter by Client request.



Authorised Signatory

- Note :
1. The test results listed pertain to the sample tested and applicable parameters.
  2. Total liability of this lab is limited to Invoice amount
  3. Any discrepancy found in the test report may be communicated with in seven days from the date of issue to Test Report.
  4. Remainder of Sample tested may be collected within 15 days from the date of issue of test report After which it shall be disposed off.
  5. The test report should not be produced as an evidence for any legal purpose, Court, Ad<sup>vs</sup> causing media without the prior permission of the director, BTH.



# BIRASINI TEST HOUSE

117

Govt. Approved / ISO IEC : 17025 : 2017 / ISO : 9001 : 2015  
ISO : 14001 : 2015 & OHSAS 45001 : 2018 Certified Laboratory  
(NABL Accredited Testing Laboratory)

BIRASINI TEST HOUSE



20107

## TEST REPORT

Issued To,  
M/S SIGN AGE INDIA PVT. LTD.  
B-49, Sector-83, Phase-II  
Extension Noida (U.P.)

Report No. : 50-26062023-57  
Date of Receiving : 26/06/2023  
Date of Starting : 26/06/2023  
Date of Completion : 07/07/2023  
Date of Reporting : 07/07/2023  
Submitted By : Customer  
Page 1 of 1

Sample Description : Waste Water  
Location : At the Bank of Yamuna, Agra  
Cluster 9 : Bhairon Nala (T)

S.No.	Test Parameters	Units	Results	Test Method
1.	pH Value	-	7.92	IS: 3025 (P-11)-2022
2.	Biochemical Oxygen Demand (BOD) (3 days at 27°C)	mg/l	53	IS: 3025 (P-44)-1993
3.	Chemical Oxygen Demand (COD)	mg/l	160	IS: 3025 (P-58)-2006
4.	Total Suspended Solids (TSS)	mg/l	76	IS: 3025 (P-17)-1984
5.	Total Coliform	Per 100ml	Absent	IS: 15185-2016

\*\*\*END OF REPORT\*\*\*

\*The above test parameter by Client request.



Authorised Signatory

- Note :
1. The test results listed pertain to the sample tested and applicable parameters.
  2. Total liability of this lab is limited to Invoice amount
  3. Any discrepancy found in the test report may be communicated with in seven days from the date of issue to Test Report.
  4. Remainder of Sample tested may be collected within 15 days from the date of issue of test report After which it shall be disposed off.
  5. The test report should not be produced as an evidence for any legal purpose, Court, Advertising media without the prior permission of the director, BTH.



# BIRASINI TEST HOUSE

118

Govt. Approved / ISO IEC : 17025 : 2017 / ISO : 9001 : 2015  
ISO : 14001 : 2015 & OHSAS 45001 : 2018 Certified Laboratory  
(NABL Accredited Testing Laboratory)

BIRASINI TEST HOUSE



20102

## TEST REPORT

Issued To,  
M/S SIGN AGE INDIA PVT. LTD.  
B-49, Sector-83, Phase-II  
Extension Noida (U.P.)

Report No. : 50-26062023-58  
Date of Receiving : 26/06/2023  
Date of Starting : 26/06/2023  
Date of Completion : 07/07/2023  
Date of Reporting : 07/07/2023  
Submitted By : Customer

Page 1 of 1

Sample Description : Waste Water  
Location : At the Bank of Yamuna, Agra  
Cluster 10 : Transport Nagar

S.No.	Test Parameters	Units	Results	Test Method
1.	pH Value	-	7.26	IS: 3025 (P-11)-2022
2.	Biochemical Oxygen Demand (BOD) (3 days at 27°C)	mg/l	32	IS: 3025 (P-44)-1993
3.	Chemical Oxygen Demand (COD)	mg/l	98	IS: 3025 (P-58)-2006
4.	Total Suspended Solids (TSS)	mg/l	55	IS: 3025 (P-17)-1984
5.	Total Coliform	Per 100ml	Absent	IS: 15185-2016

\*\*\*END OF REPORT\*\*\*

\*The above test parameter by Client request.

  
Authorised Signatory

- Note : 1. The test results listed pertain to the sample tested and applicable parameters.  
2. Total liability of this lab is limited to Invoice amount  
3. Any discrepancy found in the test report may be communicated with in seven days from the date of issue to Test Report.  
4. Remainder of Sample tested may be collected within 15 days from the date of issue of test report After which it shall be disposed off.  
5. The test report should not be produced as an evidence for any legal purpose, Court, Advertising media without the prior permission of the director, BTH.



# BIRASINI TEST HOUSE

119

Govt. Approved / ISO IEC : 17025 : 2017 / ISO : 9001 : 2015  
ISO : 14001 : 2015 & OHSAS 45001 : 2018 Certified Laboratory  
(NABL Accredited Testing Laboratory)

BIRASINI TEST HOUSE



20103

## TEST REPORT

Issued To,  
M/S SIGN AGE INDIA PVT. LTD.  
B-49, Sector-83, Phase-II  
Extension Noida (U.P.)

Report No. : 50-26062023-59  
Date of Receiving : 26/06/2023  
Date of Starting : 26/06/2023  
Date of Completion : 07/07/2023  
Date of Reporting : 07/07/2023  
Submitted By : Customer

Page 1 of 1

Sample Description : Waste Water  
Location : At the Bank of Yamuna, Agra  
Independent Drains : Sheksaria Drain

S.No.	Test Parameters	Units	Results	Test Method
1.	pH Value	-	7.52	IS: 3025 (P-11)-2022
2.	Biochemical Oxygen Demand (BOD) (3 days at 27°C)	mg/l	35	IS: 3025 (P-44)-1993
3.	Chemical Oxygen Demand (COD)	mg/l	108	IS: 3025 (P-58)-2006
4.	Total Suspended Solids (TSS)	mg/l	60	IS: 3025 (P-17)-1984
5.	Total Coliform	Per 100ml	Absent	IS: 15185-2016

\*\*\*END OF REPORT\*\*\*

\*The above test parameter by Client request.

Authorised Signatory

- Note :
1. The test results listed pertain to the sample tested and applicable parameters.
  2. Total liability of this lab is limited to Invoice amount
  3. Any discrepancy found in the test report may be communicated with in seven days from the date of issue to Test Report.
  4. Remainder of Sample tested may be collected within 15 days from the date of issue of test report After which it shall be disposed off.
  5. The test report should not be produced as an evidence for any legal purpose, Court, Advertising media without the prior permission of the director, BTH.

Laboratory Office: 4/31 B, Site-IV, Industrial Area, Sahibabad, Ghaziabad, U.P. - 201010  
Ph:- 0120-4526493, E-mail : birasintesthouse1@gmail.com, Website : www.birasintesthouse.in



# BIRASINI TEST HOUSE

120

Govt. Approved / ISO IEC : 17025 : 2017 / ISO : 9001 : 2015  
ISO : 14001 : 2015 & OHSAS 45001 : 2018 Certified Laboratory  
(NABL Accredited Testing Laboratory)

BIRASINI TEST HOUSE



20104

## TEST REPORT

Issued To,  
M/S SIGN AGE INDIA PVT. LTD.  
B-49, Sector-83, Phase-II  
Extension Noida (U.P.)

Report No. : 50-26062023-60  
Date of Receiving : 26/06/2023  
Date of Starting : 26/06/2023  
Date of Completion : 07/07/2023  
Date of Reporting : 07/07/2023  
Submitted By : Customer  
Page 1 of 1

Sample Description : Waste Water  
Location : At the Bank of Yamuna, Agra  
Independent Drains : Water Works (T)

S.No.	Test Parameters	Units	Results	Test Method
1.	pH Value	-	7.92	IS: 3025 (P-11)-2022
2.	Biochemical Oxygen Demand (BOD) (3 days at 27°C)	mg/l	52	IS: 3025 (P-44)-1993
3.	Chemical Oxygen Demand (COD)	mg/l	160	IS: 3025 (P-58)-2006
4.	Total Suspended Solids (TSS)	mg/l	70	IS: 3025 (P-17)-1984
5.	Total Coliform	Per 100ml	Absent	IS: 15185-2016

\*\*\*END OF REPORT\*\*\*

\*The above test parameter by Client request.

Authorised Signatory

- Note : 1. The test results listed pertain to the sample tested and applicable parameters.  
2. Total liability of this lab is limited to Invoice amount  
3. Any discrepancy found in the test report may be communicated with in seven days from the date of issue to Test Report.  
4. Remainder of Sample tested may be collected within 15 days from the date of issue of test report After which it shall be disposed off.  
5. The test report should not be produced as an evidence for any legal purpose, Court, Advertising media without the prior permission of the director, BTH.

Laboratory Office: 4/31 B, Site-IV, Industrial Area, Sahibabad, Ghaziabad, U.P. - 201010  
Ph:- 0120-4526493, E-mail : birasintesthouse1@gmail.com, Website : www.birasintesthouse.in



# BIRASINI TEST HOUSE

121

Govt. Approved / ISO IEC : 17025 : 2017 / ISO : 9001 : 2015  
ISO : 14001 : 2015 & OHSAS 45001 : 2018 Certified Laboratory  
(NABL Accredited Testing Laboratory)

BIRASINI TEST HOUSE



20099

## TEST REPORT

Issued To,  
M/S SIGN AGE INDIA PVT. LTD.  
B-49, Sector-83, Phase-II  
Extension Noida (U.P.)

Report No. : 50-26062023-61  
Date of Receiving : 26/06/2023  
Date of Starting : 26/06/2023  
Date of Completion : 07/07/2023  
Date of Reporting : 07/07/2023  
Submitted By : Customer  
Page 1 of 1

Sample Description : Waste Water  
Location : At the Bank of Yamuna, Agra  
Independent Drains : Taj West Gate (Merged with Khairati Tola) (T)

S.No.	Test Parameters	Units	Results	Test Method
1.	pH Value	-	7.10	IS: 3025 (P-11)-2022
2.	Biochemical Oxygen Demand (BOD) (3 days at 27°C)	mg/l	32	IS: 3025 (P-44)-1993
3.	Chemical Oxygen Demand (COD)	mg/l	102	IS: 3025 (P-58)-2006
4.	Total Suspended Solids (TSS)	mg/l	68	IS: 3025 (P-17)-1984
5.	Total Coliform	Per 100ml	Absent	IS: 15185-2016

\*\*\*END OF REPORT\*\*\*

\*The above test parameter by Client request.

Authorised Signatory

- Note : 1. The test results listed pertain to the sample tested and applicable parameters.  
2. Total liability of this lab is limited to Invoice amount  
3. Any discrepancy found in the test report may be communicated with in seven days from the date of issue to Test Report.  
4. Remainder of Sample tested may be collected within 15 days from the date of issue of test report After which it shall be disposed off.  
5. The test report should not be produced as an evidence for any legal purpose, Court, Advertising media without the prior permission of the director, BTH.

Laboratory Office: 4/31 B, Site-IV, Industrial Area, Sahibabad, Ghaziabad, U.P. - 201010  
Ph:- 0120-4526493, E-mail : birasinitesthouse1@gmail.com, Website : www.birasinitesthouse.in



# BIRASINI TEST HOUSE

122

Govt. Approved / ISO IEC : 17025 : 2017 / ISO : 9001 : 2015  
ISO : 14001 : 2015 & OHSAS 45001 : 2018 Certified Laboratory  
(NABL Accredited Testing Laboratory)

BIRASINI TEST HOUSE



20100

## TEST REPORT

Issued To,  
M/S SIGN AGE INDIA PVT. LTD.  
B-49, Sector-83, Phase-II  
Extension Noida (U.P.)

Report No. : 50-26062023-62  
Date of Receiving : 26/06/2023  
Date of Starting : 26/06/2023  
Date of Completion : 07/07/2023  
Date of Reporting : 07/07/2023  
Submitted By : Customer

Page 1 of 1

Sample Description : Waste Water  
Location : At the Bank of Yamuna, Agra  
Independent Drains : Mantola Drain

S.No.	Test Parameters	Units	Results	Test Method
1.	pH Value	-	7.86	IS: 3025 (P-11)-2022
2.	Biochemical Oxygen Demand (BOD) (3 days at 27°C)	mg/l	54	IS: 3025 (P-44)-1993
3.	Chemical Oxygen Demand (COD)	mg/l	160	IS: 3025 (P-58)-2006
4.	Total Suspended Solids (TSS)	mg/l	72	IS: 3025 (P-17)-1984
5.	Total Coliform	Per 100ml	Absent	IS: 15185-2016

\*\*\*END OF REPORT\*\*\*

\*The above test parameter by Client request.

  
Authorised Signatory

- Note : 1. The test results listed pertain to the sample tested and applicable parameters.  
2. Total liability of this lab is limited to Invoice amount  
3. Any discrepancy found in the test report may be communicated with in seven days from the date of issue to Test Report.  
4. Remainder of Sample tested may be collected within 15 days from the date of issue of test report After which it shall be disposed off.  
5. The test report should not be produced as an evidence for any legal purpose, Court, Advertising media without the prior permission of the director, BTH,

Laboratory Office: 4/31 B, Site-IV, Industrial Area, Sahibabad, Ghaziabad, U.P. - 201010  
Ph:- 0120-4526493, E-mail : birasinitesthouse1@gmail.com. Website : www.birasinitesthouse.com

**Subject: Compliance report of hearing held on 1.04.2023 of O.A. 840/2022 (Dr. Sanjay Kulshresthra vs Govt of UP & Ors.)**

**Point**

7. In the light of the said order and observations in the present case, the Chief Secretary, U.P., in coordination with other concerned authorities in the state, may ensure remedial action in the present case also for which a special meeting of concerned officers be convened preferably within one month to inter alia consider that all the existing 09 STPs are fully utilized and comply with standards and treated effluents are utilized for secondary purposes with defined sources/command area, untapped, partially tapped drains be intercepted and diverted to STPs, performance of in-situ projects is evaluated, fortnightly monitoring of existing treatment of waste water with reference to consent conditions takes place.

**Report**

At Agra Nagar Nigam, 7 nos. of STPs are maintained by UP Jal Nigam (Urban). Detail of these STPs is given below:-

S. No.	Name of STP	Technology	Capacity of STP (in MLD)	Treatment Utilization in July 2023 (in MLD)	Comply with standards	Maintaining Agency	Reuse of treated effluent
1	78 MLD STPDhandhpura	UASB	78.00	77.58	Yes	UPJN(U)	Treated effluent is reused for irrigation of agriculture with command area of about 840 acres.
2	24 MLD STPDhandhpura	UASB+EA	24.00	17.11	Yes	UPJN(U)	Treated effluent is reused for irrigation of agriculture with command area of about 100 acres.
3	10 MLD STPpeekhar	WSP	10.00	10.00	Yes	UPJN(U)	Treated effluent reuse proposal is taken under AMRUT 2.0.
4	2.25 MLD STP Nagla Burhi	WSP	2.25	2.25	Yes	UPJN(U)	Treated effluent is reused for irrigation of agriculture with command area of about 150 acres.
5	14 MLD STPlaganpur	UASB	14.00	14.00	Yes	UPJN(U)	Treated effluent is discharged into Rohia irrigation canal for Reuse.
6	12 MLD STPDeori Road	UASB	12.00	9.35	Yes	UPJN(U)	
7	40 MLD STPBidhpuri	UASB	40.00	27.16	Yes	UPJN(U)	
			180.25	157.46			

There were 90 nos. of identified drains at Agra. Their estimated discharge was 286 MLD in 2016. Out of these 90 drains, 21 nos. of drain are presently fully tapped. Detail of drains is given below:-

*Arundhati*

*R*

*AK*

Sl.	Status	Total No. of Drains	Drain Discharge (in MLD)
1	Fully Tapped Drains	21	60.37
2	Partially Tapped Drains	08	208.48
3	Untapped Drains	61	17.99
	<b>Total Drains in Agra City</b>	<b>90</b>	<b>286.84</b>

For tapping of 61 nos untapped and 8 nos partially tapped drains, following projects are sanctioned/ proposed: -

1. Agra Sewerage Scheme (Interception & Diversion and STP works) under Namami Gange Programme is sanctioned having project cost Rs 842.25 Cr in which 23 Nos. untapped and 3 nos. partially tapped drains are to be tapped along with construction of 3 nos. of STPs namely 100 MLD STP Dhadhupura, 31 MLD STP Jagampur and 35 MLD STP Peelkhar and 10 De-centralised STPs with total capacity of 11.60 MLD. Date of start of the project is 05.04.2023 and date of completion is 04.04.2025. After completion of this project, sewage treatment will be enhanced by 177.60 MLD and total treatment capacity at Agra city will be 406 MLD.
2. DPR of balanced drains of 38 nos untapped drains and 5 nos. of partially tapped drains is submitted to SMCG for approval.

  
(Swatantra Singh)  
Executive Engineer

Construction Division-II  
UP Jal Nigam (Urban), Agra

  
(Ramesh Chandra)

Superintending Engineer  
Construction Circle  
UP Jal Nigam (Urban), Agra

  
(D P Singh)

Chief Engineer (Agra Zone)  
UP Jal Nigam (Urban),  
Agra

Subject: Compliance report of hearing held on 11.04.2023 of O.A. 840/2022 (Dr. Sanjay Kulkshrestha Vs Govt. of UP & Ors.)

Point

Report

7. In the light of the said order and observation in the present case, the Chief Secretary, UP in coordination with other concerned authorities in the state, may ensure remedial action in the present case also for which a special meeting of concerned officers be convened preferably within one month to inter alia consider that all the existing (or STPs are fully utilized and comply with standards and treated effluents are utilized for secondary purposes with defined sources/command area, untapped, partially tapped drains be intercepted and diverted to STPs, performance of in-situ projects is evaluated, fortnightly monitoring of existing treatment of waste water with reference to consent conditions takes place.

At Agra Nagar Nigam, 02 nos. STPs are maintained by C&DS, UP Jal Nigam. Detail of these STPs is given below:

S. No.	Name of STP	Technology	Capacity of STP (in MLD)	Treated Utilization in July 2023 (in MLD)	Comply with standards	Maintaining Agency	Reuse of treated effluent
1	36 MLD STP Sadarvan Bichpuri	SBR	36	17	Yes	C&DS, UPJN	Treated effluent is reused for irrigation of agriculture.
2	4.5 MLD STP Kalindi Vihar	UASB	4.5	4.5	Yes	C&DS, UPJN	
			40.5	21.5			

सचिव प्रमुख  
जलकल विभाग, आगरा

Agra Municipal Corporation

Action taken report in compliance of direction given by Honorable NGT on 11.04.2023 in OA No. 840/2022 Mr. Sanjay Kulshreshthra vs Uttar Pradesh Government.

S.No.	Report	Present Status
7	In the light of the order and observations in the present case, the Chief Secretary, U.P., in coordination with other concerned authorities in the State, may ensure remedial action in the present case also for which a special meeting of concerned officers be convened preferably within one month to inter alia consider that all the existing 9 STPs are fully utilized and comply with standards and treated effluents are utilized for secondary purposes with defined sources/command area, untapped, partially tapped drains be intercepted and diverted to STPs, performance of in-situ projects is evaluated, fortnightly monitoring of existing treatment of waste water with reference to consent conditions takes place. An action taken report be find within four months by e-mail at judicial-ngt@gov.in preferably in the form of searchable PDF/OCR Support PDF and not in the form of Image PDF.	In Agra, 90 drains are flowing towards river Yamuna. Out of these drains, 29 drains are already tapped by Uttar Pradesh Jal Nigam. Bio-Remediation and Phyto-Remediation work on rest 61 drains and 06 other drains which are partially tapped, thus a total of 67 drains are being done continuously from October 2020. The reports after Bio/Phyto-Remediation from NABL approved laboratory is attached as annexure-"A".  For reuse of treated effluent from STP an underground reservoir of capacity 1000KL is constructed by Agra Municipal Corporation. The water collected here is being re-used for water sprinkling and road/footpath washing.

G.S.P.  
16/08/2023

R.E.  
14.08.23

पर्यावरण अभियन्ता  
नगर निगम, आगरा