



46

क्षेत्रीय कार्यालय-उ०प्र० प्रदूषण नियंत्रण बोर्ड, गाजियाबाद

Regional Office, U.P. Pollution Control Board, Ghaziabad
Website- www.uppcb.com, e-mail:roghaziabad@uppcb.in

संदर्भ संख्या : ११५५ /NGT-123/OA-68/2021/2024

दिनांक 13/05/2024

To,

The Registrar,
The National Green Tribunal,
Principal Bench,
New Delhi
E-mail- judicial-ngt@gov.in & ngt.filling@gmail.com

Sub: Reply/Response on behalf UPPCB in compliance to direction issued by Hon'ble NGT in EA no. 33/2021 in OA no. 68/2021 in the matter of Sushil Raghav vs Union of India & ors.

Respected Sir,

With reference to the above-mentioned subject in compliance of Hon'ble National Green Tribunal, order dated 12-03-2024 in EA no. 33/2021 in OA no. 68/2021 in the matter of Sushil Raghav vs Union of India & ors. Reply/Response is hereby submitted for kind perusal and necessary action please.

Enclosure: As above.

Yours Sincerely

(Vikas Mishra)
Regional Officer

Copy to:

1. Member Secretary, U.P. Pollution Control Board, Lucknow for information.
2. Chief Environmental Officer, Circle-1, U.P. Pollution Control Board, Lucknow for information.
3. Shri Pradeep Misra, Advocate, Hon'ble Supreme Court/NGT, New Delhi for perusal and necessary action please.
4. Law Officer-I, U.P. Pollution Control Board, Lucknow for information.

Regional Officer

क्षेत्रीय कार्यालय : आई०एन०एस०-२, सेक्टर-१६, वसुन्धरा, गाजियाबाद-२०१०१२ फोन-०१२०-४१६०१०८
मुख्यालय : TC-12V, विभूति खण्ड, गोमती नगर, लखनऊ २२६०१०

Reply/Response on behalf UPPCB in compliance to direction issued by Hon'ble NGT in EA no. 33/2021 in OA no. 68/2021 in the matter of Sushil Raghav vs Union of India & ors.

1- Introduction:-

Hon'ble NGT issued notice on 12.03.2024 in the matter of Sushil Raghav vs Union of India & ors in EA no. 33/2021 in OA no. 68/2021 and directed in para (2), which is given as under:-

"1. By this Execution Application, applicant is seeking the compliance of the order dated 19.03.2021 passed in OA No. 68/2021. The Tribunal on 12.01.2024 had issued notice to the respondent in this EA. Applicant has filed affidavit of service and submitted that all the respondents are served.

2. A request on behalf of Counsels appearing for Respondent Nos. 2,3,4 and 7 has been made for grant of four weeks' time to file the response/compliance report. It will be open to other respondents also to file their response/compliance report within the same period by e-mail at judicial-ngt@gov.in preferably in the form of searchable PDF/ OCR Support PDF and not in the form of Image PDF....."

2- Main matter of OA no. 68/2021: -

As per order passed by Hon'ble National Green Tribunal in said matter on dated 19.03.2021, main matter is as follows:

"1. This application seeks directions to take remedial action to prevent untreated sewage/effluent being discharged in the storm water drains in Karkarmodel, situated in Municipal Corporation Ward No. 43 at Sahibabad in Ghaziabad....."

3- Observations:-

1- In compliance of recommendations given by the Yamuna Monitoring Committee (YMC) appointed by Hon'ble Tribunal, monitoring of total 11 STPs situated in District Ghaziabad is being carried out on weekly basis by U.P. Pollution Control Board. Compliance status of each STP in month of April-2024 are as follows: -

S. No	Name of STP	Date	pH	Color	B.O.D mg/L	C.O.D mg/L	T.S.S mg/L	Total coliform MPN/100 ml	Fecal coliform MPN/100 ml
1	74 MLD SBR STP, Indirapuram	04.04.2024	6.82	Colorless	8.0	56.0	10.0	2800	790
		10.04.2024	6.64	Colorless	7.0	54.0	9.0	1600	540
		18.04.2024	6.76	Colorless	6.0	52.0	8.0	2800	790
		25.04.2024	6.90	Colorless	8.0	58.0	9.0	2500	450
2	56 MLD UASB STP, Indirapuram	04.04.2024	6.76	Colorless	12.0	84.0	20.0	2500	780
		10.04.2024	6.82	Colorless	15.0	90.0	22.0	1100	790
		18.04.2024	6.96	Colorless	14.0	88.0	20.0	1700	450
		25.04.2024	6.84	Colorless	16.0	92.0	24.0	3200	920
3	56 MLD SBR STP Vijay Nagar	04.04.2024	7.02	Colorless	7.0	50.0	9.0	1600	350
		11.04.2024	7.60	Colorless	6.0	48.0	8.0	1200	450
		19.04.2024	7.40	Colorless	7.0	52.0	9.0	1600	240
		25.04.2024	7.18	Colorless	9.0	56.0	10.0	2700	680
4	70 MLD UASB STP, Vijay Nagar	04.04.2024	7.20	Colorless	14.0	92.0	22.0	2200	450
		11.04.2024	6.98	Colorless	12.0	90.0	21.0	2400	780

				s					
		19.04.2024	7.23	Colorles s	13.0	94.0	23.0	3500	790
5	30 MLD Sadullabad	02.04.2024	7.36	Colorles s	7.0	56.0	10.0	1700	790
		10.04.2024	7.42	Colorles s	8.0	58.0	9.0	2400	680
		18.04.2024	7.18	Colorles s	7.0	54.0	8.0	2200	790
		23.04.2024	7.22	Colorles s	8.0	56.0	9.0	2200	450
6	56 MLD SBR STP Govindpura m	04.04.2024	7.42	Colorles s	9.0	60.0	10.0	1300	200
		10.04.2024	6.90	Colorles s	8.0	58.0	9.0	1600	540
		18.04.2024	7.04	Colorles s	6.0	54.0	8.0	1600	240
		23.04.2024	7.74	Colorles s	9.0	62.0	10.0	1400	200
7	56 MLD SBR STP Bapudham	04.04.2024	7.24	Colorles s	8.0	58.0	9.0	1600	240
		10.04.2024	6.86	Colorles s	7.0	54.0	8.0	1200	200
		18.04.2024	7.68	Colorles s	9.0	60.0	10.0	1500	400
		23.04.2024	7.02	Colorles s	7.0	56.0	8.0	2000	450
8	56 MLD SBR STP Morty	03.04.2024	7.36	Colorles s	14.0	80.0	24.0	1700	790
		11.04.2024	6.76	Colorles s	12.0	78.0	22.0	2100	930
		19.04.2024	7.36	Colorles s	10.0	74.0	20.0	1500	930
		25.04.2024	7.40	Colorles s	16.0	80.0	26.0	1700	780
9	05 MLD MBBR STP Tronica city, Loni	02.04.2024	7.18	Turbid	22.0	120.0	46.0	3200	680
		10.04.2024	6.70	Turbid	20.0	118.0	42.0	2200	790
		18.04.2024	7.20	Turbid	18.0	112.0	40.0	2100	780
		23.04.2024	7.09	Turbid	22.0	124.0	46.0	1600	540

10	20 MLD SBR STP Modinagar	04.04.2024	7.42	Turbid	24.0	120.0	80.0	1200	610
		10.04.2024	7.48	Turbid	20.0	118.0	24.0	1200	400
		18.04.2024	7.28	Turbid	18.0	116.0	22.0	2000	610
		23.04.2024	7.46	Turbid	15.0	100.0	18.0	1600	220
11	56 MLD STP SBR Indirapuram	04.04.2024	7.22	Colorless	6.0	48.0	8.0	1500	450
		10.04.2024	7.06	Colorless	8.0	50.0	9.0	1300	780
		18.04.2024	7.38	Colorless	14.0	88.0	20.0	2600	780
		25.04.2024	7.26	Colorless	7.0	52.0	9.0	2700	680

Remark: - In view of above report, all parameters in final outlet of STPs are found within prescribed norms.

2- Public sewerage line in Karkarmodel area Sahibabad is already laid down by U.P. Jal Nigam in year 2009 and all sewage/domestic effluent is being treated in common sewage treatment plant 56 MLD Indirapuram through pumping station situated near Ramleela ground, Village Karkar Model, Sahibabad, Ghaziabad. A report in this regard is also submitted by General Manager (Jal), Municipal Corporation, Ghaziabad vide letter dated 07.03.2024. Copy of same is annexed as **Annexure-I**.

The Above report is placed for kind consideration by the Hon'ble National Green Tribunal, New Delhi.

(Vikas Mishra)
Regional Officer,
U.P. Pollution Control Board
Ghaziabad.

कार्यालय महाप्रबन्धक(जल), गाजियाबाद नगर निगम

पत्रांक: 1193 /एस0टी0-जो0एम0/2023-24

दिनांक- 07/03/24

विषय:-

मा0 राष्ट्रीय हरित अधिकरण, नई दिल्ली में विचाराधीन Execution Application No-33/2021 In Original Application No-68/2021 Vs. Union of India & Ors में पारित आदेश दिनांक 12.01.2024 के अनुपालन के सम्बन्ध में।

7/3/24

अपर नगर आयुक्त/विधि प्रभारी
गाजियाबाद नगर निगम

महोदय,

कृपया उपरोक्त विषयक संयुक्त सचिव महोदय, उ0प्र0 शासन, नगर विकास अनुभाग-5, लखनऊ के कार्यालय पत्रांक-एन0जी0टी0-94/नौ-5-2024-21रिट/2023 दिनांक 29.02.2024 का अवलोकन करने का कष्ट करे। जिसके द्वारा मा0 राष्ट्रीय हरित अधिकरण, नई दिल्ली में विचाराधीन Execution Application No-33/2021 In Original Application No-68/2021 Vs. Union of India & Ors में पारित आदेश दिनांक 12.01.2024 के क्रम में अनुपालन आख्या उपलब्ध कराने के सम्बन्ध में है।

उक्त में उक्त के क्रम में सादर अवगत कराना है कि वांछित सूचना पत्र के साथ संलग्न कर आवश्यक कार्यवाही हेतु सादर प्रेषित है।

संलग्नक-उपरोक्तानुसार।

पत्रांक व दिनांक तदैव:-

प्रतिलिपि:-

2-

नगर आयुक्त महोदय को सादर सूचनार्थ प्रेषित।
पत्रावली एवं गार्ड फाईल।


महाप्रबन्धक(जल)
गाजियाबाद, नगर निगम


महाप्रबन्धक(जल)
ac

क्षेत्रीय कार्यालय उत्तर प्रदेश प्रदूषण नियंत्रण बोर्ड, गाज़ियाबाद।

Regional Office, U.P. Pollution Control Board, Ghaziabad.

दिनांक 12/10/2024

श्री. अशोक कुमार, अध्यक्ष, एम.एल.डी. संस्था, गाज़ियाबाद।

विषय: एम.एल.डी. टैंक वायुमय, चैनई एस0टी0पी0 के दीर्घकालीन रखरखाव हेतु वन रिट्रीव दन ऑर्डर/एन.एन.टी. संस्था के संयोजित चैनई एस0टी0पी0 के संचालित एस0टी0पी0 के निम्न परीक्षण के लिए अनुमति देना।

महोदय,

आपके कार्यालय से ईमेल द्वारा प्राप्त पत्र सं0-3054/कार्य-33/48 दिनांक-08/10/2024 का हार्ड में रिकॉर्ड पी0ए0 टैंक वायुमय, चैनई द्वारा संचालित 74 एम0एल0डी0 एस0टी0पी0, 74 एम0एल0डी0 एस0टी0पी0, इन्दिरापुरम, 70 एम0एल0डी0 एस0टी0पी0, चूनाडी 38 एम0एल0डी0 एस0टी0पी0, झूंडाईडा, 30 एम0एल0डी0 एस0टी0पी0 सदुल्लाहबाद लोनी एवं 3.0 एम0एल0डी0 एस0टी0पी0 का सप्ताहिक सैम्पल विश्लेषण की आख्याओं संलग्न कर

भारतीय


(विमल मिश्र)
क्षेत्रीय अधिकारी

क्षेत्रीय कार्यालय : आ ई.एन.एन. 2, रोड नं. 16, परसूरा, गाज़ियाबाद - 201012, फोन नं. 120-3160108

मुख्यालय: PC-12X, विमली खण्ड, गोमती नगर, लखनऊ - 226010

Website- www.uppcb.com, e-mail: roghaziabad@uppcb.in