

**BEFORE THE NATIONAL GREEN TRIBUNAL
PRINCIPAL BENCH, NEW DELHI**

(I.A. No. 750 of 2023)

IN

ORIGINAL APPLICATION NO. 06 of 2012

IN THE MATTER OF:

Nizamuddin West Association

.....Applicant

Versus

Union of India & Ors.

.....Respondents

INDEX

S.No.	Particulars	Page No.
1.	Status Report of Okhla STP on behalf of Delhi Jal Board in compliance of order dated 22.11.2023	1-2
2.	ANNEXURE-A Letter dated 20.12.2023 showcasing details of sewage being received at Okhla STP	3
3.	ANNEXURE-B Letter dated 18.12.2023 showcasing details/status of the Andrews Ganj SPS	4
4.	ANNEXURE-C Letter dated 18.12.2023 showcasing details of capacity of Okhla STP	5

Through

Richa Kapoor

Richa Kapoor
Advocate (D/725/1992)

Counsel for DJB

Ch. 407, lawyers Block
Delhi High Court-110003

Email: office@marklegal.co.in

Mob. 9810400407

New Delhi

Date: 21.12.2023

**BEFORE THE NATIONAL GREEN TRIBUNAL
PRINCIPAL BENCH, NEW DELHI**

I.A. No. 537 of 2023
IN
ORIGINAL APPLICATION NO. 06 of 2012

IN THE MATTER OF:

Nizamuddin West Association

.....Applicant

Versus

Union of India and ors

.....Respondents

STATUS REPORT OF OKHLA STP ON BEHALF OF DELHI JAL BOARD IN COMPLIANCE OF ORDER DATED 22.11.2023

Most respectfully showeth:-

1. That the present status report is being filed in compliance of order dated 22.11.2023 passed by this Hon'ble Tribunal wherein it had directed the Delhi Jal board to disclose the capacity of Okhla sewage treatment plant, the extent of sewage which is diverted to the Okhla sewage treatment plant from different sources and also if the capacity of the Okhla sewage treatment plant is sufficient to treat the sewage which is under process of being diverted from 11 points which were disclosed by Delhi Jal Board in Paragraph 11 of the status report dated 25.09.2023 filed in terms of earlier orders of this Hon'ble Tribunal.
2. That in compliance of the same order and in furtherance to the status report dated 25.09.2023, the Delhi Jal Board seeks to submit as under :-
 - i. That 142.36 MGD sewage is being received/diverted at Okhla STP from different sources as per the details annexed in **Annexure-A.**

- ii. The discharge in Chirag Delhi Drain coming from untrapped sources is approximately 6.00 MGD. After trapping of this discharge it will be received at Andrews Ganj Sewage Pumping Station with designed capacity of 40 MGD as per ANNEXURE-B and further will be pumped to Okhla Sewage Treatment Plant for treatment.
- iii. Total discharge which will be received at Okhla STP after trapping all 11 points will be $142.36+6=148.36$ MGD i.e 148 MGD (Approx.). After commissioning of the upgraded Okhla STP by 31.03.2024 it will be 170 MGD as per ANNEXURE-C. Hence it is submitted that capacity of Okhla STP will be sufficient to treat all the sewage coming from all 11 points.
3. That the present status of extent of sewage diverted to the Okhla sewage treatment plant from different sources alongwith the capacity of the Ohkla sewage treatment plant receiving sewage from 11 points is hereby submitted in compliance of the order dated 22.11.2023 passed in IA No. 537 of 2023 in Original Application No. 06 of 2012 for kind perusal and consideration of this Hon'ble Tribunal.

Submitted by :-


20-12-2023

NARESH KUMAR

EXECUTIVE ENGINEER (M)-50

DELHI JAL BOARD

Executive Engineer (M)-50
Delhi Jal Board, Govt. of Delhi
Engineers Bhawan, 2nd Floor
Andrewj Gang, New Delhi-110002

New Delhi

Date : 20-12-2023



DELHI JAL BOARD: GOVT. DISTRICT OF DELHI
OFFICE OF THE ADDITIONAL CHIEF ENGINEER (P)-3
EXECUTIVE ENGINEER (SDW)-II
OKHLA SEWAGE DISPOSAL WORKS, MATHURA ROAD
NEW DELHI- 110025.

e-mail:- delhijalboard2@gmail.com Ph. 011-20904819



3

No. DJB/EE (SDW) II/ 2023/2008 to 2011

Dated:- 20/12/2023

Subject: - **Status of Okhla Sewage Treatment Plant.**

In continuation to the letter No. DJB/ EE (SDW)-II/ 1994, dated 18.12.2023 issued from this office regarding disclosure of capacity of Okhla Sewage Treatment Plant.

Further as directed by the CE(SDW), the following is the detail of Sewage being received at the Okhla STP is as under: -

- | | |
|---|-----------------------------------|
| i) Kilokari SPS - 15.06 MGD, | ii) Ring Road SPS - 52.50 MGD |
| iii) Andrews Ganj SPS - 16.00 MGD, | iv) Pragati Vihar SPS - 14.56 MGD |
| v) Sarita Vihar SPS - 13.25 MGD, | vi) Tughlakabad SPS - 3.00 MGD |
| vii) Batla House SPS - 2.67 MGD, | viii) Jasola Vihar SPS - 1.24 MGD |
| ix) East of Kailash SPS - 1.00 MGD, | x) Sukhdev Vihar SPS - 0.40 MGD |
| xi) Modi Mill SPS 1 - 0.30 MGD, | xii) Modi Mill SPS 2 - 0.30 MGD |
| xiii) Sarita Vihar A block SPS- 1.58 MGD, | xiv) Okhla Vihar SPS - 2.50 MGD |
| xv) Kalkaji trunk sewer = 17.00 MGD approx. | |
| xvi) Harkesh Nagar 500 mm dia. Sewer = 1.00 MGD approx. | |

The above information is based on the report provided by Kilokari Control Room.

Total-142.36 MGD

-sd-

(ANIL KUMAR)
Executive Engineer (SDW) II

E.E. (M)-50

Copy to: -


- | | | |
|--------------------------|---|------------------------------|
| 1. CE (SDW) | : | for kind information please. |
| 2. Pr. CE (Dr.)Project-I | : | -do- |
| 3. ACE (P)-3 | : | -do- |
| 4. ACE (M)-10 | : | -do- |
| 5. AE (E&M)-I | : | |
| 6. Office Copy | : | |

Executive Engineer (SDW) II

6590
21/12/23



DELHI JAL BOARD, GOVT. OF N.C.T. OF DELHI
OFFICE OF THE EXECUTIVE ENGINEER (SDW)-XI
KILOKRI SPS, JAL VIHAR, LAJPAT NAGAR, DELHI-110024
Email: - eesdw11@gmail.com (M):-9650074666



No. DJB/EE(SDW)-XI/2023-24/1423 to 1426

Dated- 18-12-2023

SUBJECT : Status of Andrews Ganj Sewage Pumping Station.


This is in reference to your letter No. DJB/EE(M)-50/2023/2519-2523 dated: 15.12.2023 regarding above cited subject, the status of the Andrews Ganj SPS as directed by Hon'ble NGT vide its orders dated : 22.11.2023 to DJB is as under:-


1. Installed Capacity :-80MGD
2. Designed Capacity:-40MGD
3. Actual Pumping (Presently) Average :-27MGD Approx.

EE(M)-50

Copy to: -

1. CE(SDW) : For kind information please
2. ACE(P)3 :-----do.
3. ACE(M)-10 :-----do.
4. JE(E&M)
- ✓ 5. o/c


Executive Engineer (SDW)-XI


(Ex. Piyush Gupta)
Executive Engineer (SDW)-XI

 <p>Delhi Jal Board</p>	<p align="center">DELHI JAL BOARD: GOVT. OF NCT OF DELHI OFFICE OF THE ADDITIONAL CHIEF ENGINEER (P)-3 EXECUTIVE ENGINEER (SDW)-II OKHLA SEWAGE DISPOSAL WORKS, MATHURA ROAD NEW DELHI- 110025. e-mail:- delhijalboard2@gmail.com Ph. 011-20904819</p>	 <p>75 Azadi Ka Amrit Mahotsav</p>
--	--	---

No. DJB/EE (SDW) II/ 2023/1994 to 1997

Dated:- 18/12/2023

Subject: - Status of Okhla Sewage Treatment Plant.

In reference to letter No. DJB/ ACE (M)-10/ 2023/ issued from the office of ACE (M)-10 and subsequent letter No. DJB/ E E(M)-50/ 2023/ 2508 dated 14.12.2023 Issued from EE (M)-50, regarding discloser of capacity of Okhla Sewage Treatment Plant.

It is hereby informed that the present-capacity of the Okhla STP is 140 MGD which will further be enhanced to 170 MGD after commissioning of New 124 MGD WWTP at Okhla. The expected date of completion of new plant is 31 March 2024. Old plant of total capacity of 94 MGD (12 MGD, 37 MGD & 45 MGD) shall be demolished being very old after commissioning of new 124 MGD Plant.

The above may treated as reply pertain to EE (SDW) II Okhla.

In view of above you are requested to attend the hearing of Hon'ble NGT. As no other matter pertain to this division.

-sd-

(ANIL KUMAR)
Executive Engineer (SDW) II

E.E. (M)-50

Copy to: -

- | | | |
|--------------------------|---|------------------------------|
| 1. CE (SDW) | : | for kind information please. |
| 2. Pr. CE (Dr.)Project-I | : | -do- |
| 3. ACE (P)-3 | : | -do- |
| 4. ACE (M)-10 | : | -do- |
| 5. AE (E&M)-I | : | |
| 6. Office Copy | : | |

4/12/23
Executive Engineer (SDW) II

6589-1P

21/12/23