

BEFORE THE HON'BLE NATIONAL GREEN TRIBUNAL  
PRINCIPAL BENCH AT NEW DELHI

O.A. NO. 202 OF 2022

IN THE MATTER OF:

I.M. Goswami & Anr.

.....APPLICANTS

VERSUS

Govt. of NCT of Delhi & Ors.

.....RESPONDENTS

INDEX

S/NO.	PARTICULARS	PAGE NO.
1	ACTION TAKEN REPORT ON BEHALF OF THE MCD IN THE COMPLIANCE OF THE ORDER DATED 06.12.2022 PASSED BY THIS HON'BLE NATIONAL GREEN TRIBUNAL, PRINCIPAL BENCH.	
2	Copy of the inspection report dated 04.03.2023. <b>ANNEXURE-A.</b>	

Through

  
AEC (Electrical) / MCD (WZ)  
Office of The Executive Engineer (Electrical)  
Old Zonal Office Building, Vishal Enclave  
West Zone, MCD  
New Delhi 110027  
Email id ee.eleciiii@gmail.com

BEFORE THE HON'BLE NATIONAL GREEN TRIBUNAL

PRINCIPAL BENCH AT NEW DELHI

O.A. NO. 202 OF 2022

IN THE MATTER OF:

I.M. Goswami & Anr.

.....APPLICANTS

VERSUS

Govt. of NCT of Delhi & Ors.

.....RESPONDENTS


**ACTION TAKEN REPORT ON BEHALF OF THE MCD IN THE COMPLIANCE OF THE ORDER DATED 06.12.2022 PASSED BY THIS HON'BLE NATIONAL GREEN TRIBUNAL, PRINCIPAL BENCH.**

1. That the present original application has been filed by the applicants with the grievance regarding air and noise pollution also involving fire hazards caused by huge industrial diesel generator sets adjacent to the boundary walls of Cloud 9 Group of Maternity Hospitals, Punjabi Bagh, New Delhi and is operating the same 24X7.
2. That the present matter was listed before this Hon'ble NGT on 06.12.2022 wherein this Hon'ble Tribunal passed directions as follow:

*"7. In the facts and circumstances of the case, we also consider presence of Officers duly authorized by the Commissioner, Municipal Corporation, Delhi and the Deputy Commissioner/Magistrate (West), Delhi to be*

*essential for assisting this Tribunal in just and fair adjudication of the questions involved in the case and accordingly, such Officers shall remain present before this Tribunal physically with relevant records on the date fixed."*

3. That inspection has been carried out on 04.03.2023 by the office of The Executive Engineer (Electrical) West Zone MCD in compliance of the order dated 06.12.2022 passed by this Hon'ble Tribunal in the present matter. During inspection it was found that Diesel Generator Set was installed adjacent to the boundary wall of Cloud 9 Group of Maternity Hospitals, Punjabi Bagh, New Delhi. However, it was observed during inspection that Diesel Generator set was not in operation and was in shut down state. Noise level readings were taken and recorded with the help of Sound Level Meter. Copy of the inspection report dated 04.03.2023 is annexed herewith as **ANNEXURE-A**.

  
AB(E)/W2 (MCD)



MUNICIPAL CORPORATION OF DELHI  
OFFICE OF THE EXECUTIVE ENGINEER (E) WEST ZONE  
OLD ZONAL OFFICE BUILDING, VISHAL ENCLAVE  
NEW DELHI 110027



### REPORT

A Field inspection was conducted to measure noise levels at Cloud 9 Hospital Panjabi Bagh on dated 04/03/2023. The following officers from the office of The Executive Engineer (Electrical) were present during the inspection:-

S.No	Name	Designation
1	Sh. Vinay Kumar	Assistant Engineer
2	Sh. Vikas Mann	Junior Engineer

The readings of Noise levels were taken with the help of Sound Level Meter which are attached herewith. The observations are as follows:-

Date	04/03/2023
Time	12:05:19
Readings:	
S.No	(db)
LAeq	66.8
LAFmax	77.9
LAFmin	62.4
LAE	91.7
Remarks	DG Sets were in shut down state during the inspection

*[Signature]*  
04/03/23  
AE(WZ)/Electrical

*[Signature]*  
04/03/23  
JE(WZ)/Electrical

*[Signature]*  
AE(E)/WZ(MCD)

Cloud 9  
Hospital  
Punjab bagh



CASELLA  
CEL-620R1/IP v026-08  
Serial number 4806704  
Response Freefield  
Start  
4-Mar-2023 12:05:19  
Duration 0:05:10  
Pause duration 0:00:00  
Overload No Run 25

CALIBRATION

Before  
26-Jul-2022 17:09:29

RESULTS (dB)

L <sub>Aeq</sub>	66.8
L <sub>AFmax</sub>	77.9
L <sub>AFmin</sub>	62.4
L <sub>AE</sub>	91.7

Location

GPS -----

Operator Name

Signature

*[Handwritten Signature]*  
AEE/wz

Witness

*[Handwritten Signature]*  
SE/wz

*[Handwritten Signature]*  
AEE/wz (mco)