

**BEFORE THE HON'BLE NATIONAL GREEN TRIBUNAL,
PRINCIPAL BENCH, NEW DELHI**

Original Application No. 1002/2018

IN THE MATTER OF:

Abhisht Kusum Gupta

.....Applicant

Vs.

State of Uttar Pradesh & Others

.....Respondents

NDOH:-18.01.2024

INDEX

S. NO.	PARTICULARS	Page No.
1.	Status report on behalf of GNCTD in terms of order dated 03.08.2022.	1-4
2.	<u>Annexure-1</u> Copy of the tabular status of Analysis Report at Inlet and Outlet in respect of Kondli STPs for the month of November and December, 2023.	5
3.	<u>Annexure-2</u> Analysis Report in respect of Kondli STPs Phase I, II & III for the month of December, 2023.	6-7
4.	<u>Annexure-3</u> Analysis Report in respect of Kondli New STP Phase IV, for the month of December, 2023.	8-9
5.	<u>Annexure-4</u> Copy of the inspection report of STPs at Kondli Phase I, II, III & IV dated 03.01.2024.	10-21
6.	<u>Annexure-5</u> Copy of the directions dated 11.01.2024 issued by DPCC to DJB.	22-24
7.	<u>Annexure-6</u> Copy of the letter dated 14.12.2023 issued by DPCC to DJB.	25-26
8.	<u>Annexure-7</u> Copy of the reply submitted by DJB dated 18.12.2023.	27-38
9.	<u>Annexure-8</u> Minutes of the joint meeting dated 14.11.2022 and 24.02.2023 taken by Chairman, CPCB.	39-49

Filed by

Govt. of NCT Delhi.

**BEFORE THE HON'BLE NATIONAL GREEN TRIBUNAL,
PRINCIPAL BENCH, NEW DELHI**

Original Application No. 1002/2018

IN THE MATTER OF:

Abhisht Kusum Gupta

.....Applicant

Vs.

State of Uttar Pradesh & Others

.....Respondents

**STATUS REPORT ON BEHALF OF GOVERNMENT OF NCT OF
DELHI AND DELHI POLLUTION CONTROL COMMITTEE IN
COMPLIANCE TO THE ORDER DATED 08.11.2023.**

1. That this Hon'ble Tribunal took up the above referred matter on 08.11.2023 and pleased to observe that GNCTD and UP Government has not filed the report in in terms of the directions contained in Para 30 of the order of the Tribunal dated 03.08.2022.
2. That, with regard to above observation it is most respectfully submitted that, a joint status report on behalf of the GNCTD and DPCC was filed on 06.02.2023. On the website of this Hon'ble Tribunal this Report was shown as it was filed only by DPCC. This report contains the action of GNCTD and DPCC.
3. It is humbly submitted that directions contained in Para 30 of order dated 03.08.2022 on remedial action to be taken by concerned authorities and monitored at highest level, following compliances are submitted -
 - i. That DPCC conducted analysis in the month of November, 2023 & December, 2023 after taking samples from the Inlet and Outlet of STPs at Kondli Phase-I, Phase-II, Phase-III & Phase-IV. DPCC Laboratory analysed parameters of pH, TSS, BOD, COD, Ammonical Nitrogen, Dissolved Phosphate & Faecal coliform in the month of

November,2023 and pH, TSS, BOD, COD, Ammonical Nitrogen, Dissolved Phosphate in the month of December ,2023. The STPs of Kondli Phase-I, Phase-II & Phase-III are having common Inlet from main stream.

The Tabular status of Analysis Reports at Inlet and Outlet of STPs are at **Annexure- 1.**

The brief of the analysis reports are as follows:

- a) Kondli Phase – I , II and III STPs are meeting the prescribed standards. The Analysis Reports at Inlet and Outlet are collectively enclosed as **Annexure-2 (Colly.).** Since OLMS is not functional, consistency in meeting the standards cannot be confirmed.
 - b) Kondli Phase – IV STP is not meeting the prescribed standards w.r.t. TSS (30 mg/l against the prescribed standard of 10 mg/l), BOD (16 mg/l against the prescribed standard of 10 mg/l) and COD (88 mg/l against the prescribed standard of 50 mg/l). Analysis Reports at Inlet and Outlet are collectively enclosed as **Annexure-3 (Colly.).**
4. That inspection of the STPs at Kondli Phase I, II, III & IV was also carried out by a team of DPCC officials on 03.01.2024. Copy of the Inspection Report dated 03.01.2024 is at **Annexure – 4.**

Deficiencies observed by team of DPCC during inspection of STPs at Kondli on 03.01.2024 are briefed below :

- i. Kondli STP Phase-IV has total capacity of 45 MGD. However, half of the capacity i.e. (22.5 MGD) is being treated only and rest 22.5 MGD is being by-passed as the plant is under rehabilitation.
- ii. Only 01 out of 03 Odour Control Units (OCU) found operational at the time of inspection.
- iii. Rapid Gravity Filter (RGF) (for phase II & III) were found non-operational at the time of Inspection.
- iv. No OLMS found installed at Phase-II. OLMS was not found functional in any of the STPs and hence consistency in meeting the standards cannot be confirmed.
- v. Chlorination is not being carried out in Phase-II & III.
- vi. Sludge Handling Units of all 04 Phases has not been commissioned yet.

5. That, Directions u/s 33(A) of Water (Prevention and Control of Pollution) Act, 1974 has been issued by DPCC to Delhi Jal Board on 11.01.2024 for proper operation of STPs at Kondli to meet the Prescribed Standards including stoppage of by-passing of untreated sewage by DJB.
- Copy of the Directions dated 11.01.2024 issued by DPCC to DJB is at **Annexure-5.**
6. That DPCC vide letter dated 14.12.2023 requested Delhi Jal Board to forward the Tender Documents and Work Contract of the STPs including STPs at Kondli so that parameters used by Delhi Jal Board in procurement can be verified with the 08 parameters prescribed by DPCC.
- Copy of the letter dated 14.12.2023 of DPCC is at **Annexure – 6.**
7. That Tender Document and Work Contract in respect of all the STPs which are under rehabilitation/ proposed to be rehabilitated/ New STPs have not been provided by DJB including STPs at Kondli. Only partial information in respect of Kondli Phase-IV STP has been provided by DJB and information in respect of Kondli Phase-I, II & III STPs are awaited. The matter is being taken with DJB in this regard.
- Copy of the reply of Delhi Jal Board dated 18.12.2023 is at **Annexure – 7.**
8. With respect to direction of this Hon'ble NGT regarding utilisation of treated water, it is submitted that Delhi Jal Board informed in the meeting taken by Chief Secretary, Govt of NCT on 10.01.2024, that 20 MGD of treated water from STP is being utilised. CEO, DJB assured in the meeting that he will look into the matter and get detailed action plan prepared for utilisation of STP water at the earliest which is being pursued with DJB.
9. Further, it is also submitted that in compliance to the order of Hon'ble NGT dated 03.08.2022 Meetings of the Joint Committee headed by Chairman, CPCB were held on 14.11.2022 & 24.02.2023., wherein issues pertaining to Delhi, NTPC Khoda Makanpur Nagar Palika and Noida Authority were discussed. Copy of the Minutes of the meetings are attached as **Annexure – 8.**

10. That the present status report has been approved by the Chief Secretary, Govt. of NCT of Delhi and may kindly be taken on record in compliance with the directions contained in the order passed by this Hon'ble Tribunal dated 08.11.2023.



(Dr. K.S. Jayachandran)
Special Secretary (Environment)

4

Tabular Status of Analysis Reports at Inlet and Outlet of STPs carried out in the month of December, 2023

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	Faecal Coliform (MPN/100 ml)**	
1	Ph-I (10)	Inlet*	7.3	228	98	304	27.6	25.4	400	-
		Outlet	7.5	10	6	40	2.1	1.5	27	Meeting the prescribed standards
2	Ph-II (25)	Outlet	7.1	8	5	32	1.5	1.3	80	Meeting the prescribed standards.
3	Ph-III (10)	Outlet	7.5	8	4	16	1.4	1.4	90	Meeting the prescribed standards.
4	Ph-IV (45)	Inlet	7.3	204	175	224	18.9	23.5	500	Not Meeting the Standards w.r.t. TSS, BOD and COD
		Outlet	7.5	30	16	88	1.1	1.3	170	

* Ph-I, II & III have common Inlet Point.

** Analysis of Faecal Coliform was carried out by DPCC Laboratory in the month of November, 2023.


DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building
Kashmere Gate, Delhi 110006
(Visit us at <https://www.dpccocmms.nic.in>)



Lifestyle for
Environment

Dated 04/12/2023

Report Number: DPCC/W/STP/23-24/200 | 463

ANALYSIS REPORT OF STP

- Name of STP : Kondli
- Sampling location : Inlet and Outlet of STP
- Date of Inspection : 09.11.2023
- Samples collected by : DPCC Lab
- Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters										Remarks		
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	Feacel Coliform as FC (MPN/100ml)					
1	Ph-I (10)	Inlet	6.5-9.0	10	10	50	10	5	2	100					
		Outlet	7.4	220	96	256	4.4	27.5	25.6	4 x 10 ²					Meeting the standards.
		OLMS	7.6	8	5	32	2	2.5	1.9	-	-	80			OLMS was non-functional
2	Ph-II (25)	Outlet	7.8	10	5	32	1.2	1.8	1.1	-	-	-		Meeting the standards	
		OLMS	-	-	-	-	-	-	-	-	-	-			OLMS was non-functional
3	Ph-III (10)	Outlet	7.7	6	4	24	4.1	1.6	1.7	90				Meeting the standards.	
		OLMS	-	-	-	-	-	-	-	-	-				OLMS was non-functional
Total 45															

N. Mittal

I/C LABORATORY

Dr. Nandita Mohita
Scientist-D

ANNEXURE - 3 (Cally.)

8



DELHI POLLUTION CONTROL COMMITTEE
(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building
Kashmere Gate, Delhi 110006
(Visit us at <https://www.dpcccomms.nic.in>)



LIFE
Lifestyle for Environment

Dated 05/01/2024

Report Number: DPCC/W/STP/23-24/228 / 547

ANALYSIS REPORT OF STP FOR THE MONTH OF DECEMBER-2023

1. Name of STP : Kondli New
 2. Sampling location : Inlet and Outlet of STP
 3. Date of Inspection : 13.12.2023
 4. Samples collected by : DPCC Lab
 5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters							Remarks
			PH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	
1	Ph-IV (45)	Inlet	6.5-9.0	10	10	50	10	5	2	Not Meeting the Standards wrt TSS, BOD & COD. OLMS was non-functional
		Outlet	7.3	204	175	224	5.2	18.9	23.5	
		OLMS	7.5	30	16	88	2.4	1.1	1.3	
Total 45										

M. Nandita Pruthi
I/C LABORATORY

2



DELHI POLLUTION CONTROL COMMITTEE

(Government of N.C.T. of Delhi) 4th & 5th Floor, ISBT Building

Kashmere Gate, Delhi 110006

(Visit us at <https://www.dpccocmms.nic.in>)

Dated 04/12/23

Report Number: DPCCW/STP/23-24/201/464

ANALYSIS REPORT OF STP

1. Name of STP : Kondli New
2. Sampling location : Inlet and Outlet of STP
3. Date of Inspection : 09.11.2023
4. Samples collected by : DPCC Lab
5. Parameters analyzed and results :

Sr. No.	Installed Capacity (MGD)	STP Standard	Parameters								Remarks
			pH	TSS (mg/l)	BOD (mg/l)	COD (mg/l)	Oil & Grease (mg/l)	Ammonical Nitrogen (mg/l)	Dissolved Phosphate as P (mg/l)	Feecal Coliform as FC (MPN/100ml)	
1	Ph-IV (45)	Inlet	6.5-9.0	10	10	50	10	5	2	100	Not Meeting the Standards wrt TSS, BOD COD & Feecal Coliform
		Outlet	7.5	216	185	256	6.8	20.6	24.6	5x10 ²	
		OLMS	7.3	36	19	76	3.6	1.9	1.5	170	
Total 45			7.5	19.3	10.0	37.1	-	22.1	-	-	

N. Nandita
I/C LABORATORY
Dr. Nandita Nandita
Scientist 'D'

ANNEXURE - 4Inspection Report of STPs at Kondli

Inspection of STPs at Kondli was carried out by team of DPCC Officials on 03.01.2024. There are four phases of Kondli STP namely Ph-I (10 MGD), Ph-II (25 MGD), Ph-III (10 MGD) and Ph-IV (45 MGD). All the STPs at Kondli have common Inlet Point from where flow is divided into respective Phases. The Catchment Area of STPs at Kondli comprises of Preet Vihar, Jagriti Vihar, Dallupura, Kondli Ghadoli & Kalyanpuri.

Brief of the observations are as follows:

Kondli Ph-I

1. Liquid line of Plant was found operational during Inspection.
2. Flow Meter found installed at the Inlet & Outlet of STP.
3. Plant has 02 Coarse Bar Screens, 02 Fine Bar Screens and 02 Grit Chambers (Vortex type). All were found operational during the inspection.
4. Plant has 02 Primary Sedimentation Tanks (PST) and 02 Secondary Sedimentation Tanks (SST). All found operational.
5. There are 02 Aeration tanks (combination of anoxic, anaerobic & aerobic compartments) comprising of 03 Blowers with (880 x 2) diffusers. All found operational.
6. There is 01 Sludge Thickener (for sludge from PST) which was found operational during inspection. Dilution Air Flocculation (DAF) Unit is yet to be commissioned and presently complete sludge is being taken to Thickener Unit only.
7. There are 02 Chlorination tanks and chlorine dosing is being carried out.
8. Status of Sludge Units and Electricity Generation units are as follows:

Name of Unit	Operational Condition
Centrifuge	Commissioned and found operational
Sludge Thickener (for sludge from PST)	Operational
DAF (Dilution Air Flocculation) Thickener (for sludge from SST)	Civil construction & Mechanical work completed but not yet commissioned.
Sludge Digester Units	Operational (Gas is being released in atmosphere)
Gas Holding Unit	Civil construction work completed
Electricity Generation Units	Civil Construction work completed but not yet commissioned.

9. 04 unit of Rapid Gravity Filter (RGF) were found operational.
10. OLMS at the Outlet was found installed and it is in operational condition. As informed by Operator, OLMS is being calibrated on monthly basis and Calibration Reports provided by DJB are annexed at **Annexure-1**.

11

10

Kondli Ph-II & III

1. Both Plants were found operational during Inspection.
2. Flow meter is installed at the Inlet of Ph-II and Ph-III separately after Grit Chamber. However, a common Flow meter is installed at the Outlet of Ph-II and Ph-III after Chlorine Contact Tank.
3. Ph-II & Ph-III have common primary units. Plant has 05 Coarse Bar Screens, 05 Fine Bar Screens and 03 Grit Chambers (Vortex type). All were found operational during the inspection.
4. Ph-II has 02 Primary Sedimentation Tanks (PST) and 03 Secondary Sedimentation Tanks (SST).
5. Ph-III has 02 Primary Sedimentation Tanks (PST) and 03 Secondary Sedimentation Tanks (SST). All found in operational condition.
6. There are total 04 Aeration tanks 02 each for Ph-III & Ph-II (combination of anoxy, anaerobic & aerobic compartments) comprising of 03 Blowers with (880 x 2) diffusers & 06 Blowers with 4400 diffusers respectively. All found operational.
7. There are 02 Sludge Thickener (for both Phases) which were found operational during inspection. Dilution Air Flocculation (DAF) Unit is yet to be commissioned and presently complete sludge is being taken to Thickener Unit only. After thickener unit sludge is being diverted to Sludge Drying Beds. Excess waste water from Sludge reaches to sump percolating through Filter Media and being re-circulated to PST using temporary pipe arrangement.
8. The construction work of 04 Chlorination tanks is completed. However, not in operation as permission from Petroleum and Explosives Safety Organization (PESO) is not taken yet.
9. Status of Sludge Units and Electricity Generation units are as follows:

Name of Unit	Operational Condition
Centrifuge	Commissioned but not found operational
Sludge Thickener (for sludge from PST)	Operational
DAF (Dilution Air Flocculation) Thickener (for sludge from SST)	Civil construction work completed but not yet commissioned.
Sludge Digester Units	Civil work completed but on hold due to leakage.
Gas Holding Unit	Installation of 01 Gas Holder has been completed and 01 is under installation.
Electricity Generation Units	Civil Construction work completed but not yet commissioned.

10. Rapid Gravity Filter (RGF) (for both phases) found non-operational during Inspection. As informed by Plant Manager, RGF is non operational due to ongoing Electrical work.
11. OLMS found installed at the outlet of Ph-III after SST. However, no OLMS found installed for Ph-II.

(12)

(1)


Kondli Ph-IV

1. Plant was found operational during inspection.
2. Plant has total capacity of 45 MGD. However, half of the capacity i.e. (22.5 MGD) is being treated only and rest 22.5 MGD is being by-passed as the plant is under rehabilitation.
3. 01 out of 03 Odour Control Units (OCU) found operational at the time of inspection. As informed by Plant Manager, 01 OCU was not operational as the unit (Sludge Thickener and Primary Filtrate Sump) connected to particular OCU is under rehabilitation and 01 OCU was not operational due to Electrical malfunction.
4. Plant has 04 Coarse Bar Screens. All found operational.
5. Plant has 04 Fine Bar Screens. All found operational.
6. Out of 03 Grit Chambers, 02 were found operational and 01 is under rehabilitation.
7. Plant has 04 Primary Settling Tanks (PST). 03 PSTs has been rehabilitated and were found operational. 01 PST is under rehabilitation.
8. Plant has 04 Secondary Settling Tanks (SST). 03 SSTs has been rehabilitated and were found operational. 01 SST is under rehabilitation.
9. There are 04 Aeration tanks out of which only 02 are rehabilitated and in operation and rest 02 are under rehabilitation.
10. Sludge from PST and SST is directly being transferred to Sludge Drying Beds as Sludge Thickener has not been commissioned yet. 02 Additional Sludge Thickeners are under rehabilitation which were earlier used as DAF units in Old Plant.
11. Status of Sludge Units, Electricity Generation and Tertiary treatment units are as follows:

Name of Unit	Operational Condition
Bed Filter Press	Installed but not commissioned
Disc Filter	Under construction
UV Treatment Unit	Under construction
Sludge Digester	Total 04- 02 Rehabilitated & under Testing and 02 under Rehab.
Gas Holder	Total 02- 01 Rehabilitated & under Testing and 01 under Rehab.
Electricity Generation Units	Total 03- 01 ready to use but not in operation as supporting units are under construction/ Rehab and 02 Units are Rehab.

12. OLMS at the Outlet was found installed.


Ashish Uniyal
JEE, WMC-II


Abhishek Sharma
TE, WMC-II

AAXIS NANO
TECHNOLOGIES PVT. LTD.
Solutions For A Sustainable Environment

Annexure - 1
(Inspection Report)

0120 415 9238

www.aaxisnano.com

info@aaxisnano.com




AAXIS NANO
TECHNOLOGIES PVT. LTD.
Solutions For A Sustainable Environment


s can
Intelligent. Optical. Online.

CALIBRATION REPORT

Project Name:		DJB_EQMS	Date:	09-10-2023	
Station Name:		KONDLI PH-1 STP	Engineer:	RAGHVENDRA	
			Manager:	Dharmendra Singh	
S.No.	Parameters Name	Calibration Type	Online Result Precalibration	Lab Sample Calibration Point	Online Result Post Calibration
spectro::lyser (Calibration Method : multi point sample calibration w.r.t. laboratory analysis)					
1	COD (in mg/L)	Multi	55	40	40.1
2	BOD (in mg/L)	Multi	7.6	5	5.5
3	TSS (in mg/L)	Multi	10.42	8	8.2
ammo::lyser 1 (Calibration Method : sample calibration w.r.t. laboratory analysis/pH - buffers)					
4	TEMP	Global	29.45	31	31.4
5	AMMONIA	LINEAR	6.61	5	4.16
6	PH	LINEAR	7.59	7.5	7.52
Calibration by: ASHISH & FOZIA		Checked by :ASHIM DATTA			



14



AAXIS NANO
TECHNOLOGIES PVT. LTD.
Solutions For A Sustainable Environment

+91-7428541532

0120 415 9238

www.aaxisnano.com

info@aaxisnano.com




AAXIS NANO
TECHNOLOGIES PVT. LTD.
Solutions For A Sustainable Environment

s can
Intelligent. Optical. Online.

CALIBRATION REPORT

Project Name:		DJB_EQMS	Date:	09-10-2023	
Station Name:		KONDLI PH-3 STP	Engineer:	RAGHVENDRA	
			Manager:	Dharmendra Singh	
S.No.	Parameters Name	Calibration Type	Online Result Precalibration	Lab Sample Calibration Point	Online Result Post Calibration
spectro::lyser (Calibration Method : multi point sample calibration w.r.t. laboratory analysis)					
1	COD (in mg/L)	Multi	50.9	40	40.3
2	BOD (in mg/L)	Multi	9.7	6	5.6
3	TSS (in mg/L)	Multi	12.1	8	8.7
ammo::lyser 1 (Calibration Method : sample calibration w.r.t. laboratory analysis/pH - buffers)					
4	TEMP	Global	26.75	28	28.2
5	AMMONIA	LINEAR	8.38	4	4.11
6	PH	LINEAR	7.59	7.5	7.52
Calibration by: ASHISH & FOZIA		Checked by : ASHIM DATTA			

15



AAXIS NANO
TECHNOLOGIES PVT. LTD.
Solutions For A Sustainable Environment

+91-7428541532

0120 415 9238

www.aaxisnano.com

info@aaxisnano.com



134




AAXIS NANO
TECHNOLOGIES PVT. LTD.
Solutions For A Sustainable Environment

s = can
Intelligent. Optical. Online.

CALIBRATION REPORT

Project Name:	DJB_EQMS	Date:	09-10-2023		
Station Name	KONDLI PH-4 STP	Engineer:	RAGHVENDRA		
		Manager:	Dharmendra Singh		
S.No.	Parameters Name	Calibration Type	Online Result Precalibration	Lab Sample Calibration Point	Online Result Post Calibration
spectro::lyser (Calibration Method : multi point sample calibration w.r.t. laboratory analysis)					
1	COD (in mg/L)	Multi	54.6	46	46.1
2	BOD (in mg/L)	Multi	13.4	10	9.9
3	TSS (in mg/L)	Multi	25.8	21	19.5
ammo::lyser 1 (Calibration Method : sample calibration w.r.t. laboratory analysis/pH - buffers)					
4	TEMP	Global	26.9	30	30.4
5	AMMONIA	LINEAR	6.47	5	5.76
6	PH	LINEAR	7.6	7.5	7.52
Calibration by: ASHISH & FOZIA		Checked by : ASHIM DATTA			




AAXIS NANO
TECHNOLOGIES PVT. LTD.
Solutions For A Sustainable Environment

+91-7428541532

0120 415 9238

www.aaxisnano.com

info@aaxisnano.com




AAXIS NANO
TECHNOLOGIES PVT. LTD.
Solutions For A Sustainable Environment

s::can
Intelligent. Optical. Online.

CALIBRATION REPORT

Project Name:		DJB_EQMS	Date:	30-11-2023	
Station Name:		KONDLI PH-1 STP	Engineer:	RAGHVENDRA	
			Manager:	Dharmendra Singh	
S.No.	Parameters Name	Calibration Type	Online Result Precalibration	Lab Sample Calibration Point	Online Result Post Calibration
spectro::lyser (Calibration Method : multi point sample calibration w.r.t. laboratory analysis)					
1	COD (in mg/L)	Multi	38.2	30	28.53
2	BOD (in mg/L)	Multi	7.1	5	4.96
3	TSS (in mg/L)	Multi	11.56	8	7.76
ammo::lyser 1 (Calibration Method : sample calibration w.r.t. laboratory analysis/pH - buffers)					
4	TEMP	Global	20.45	23	23.5
5	AMMONIA	LINEAR	8.12	5	5.59
6	PH	LINEAR	7.6	7.5	7.52
Calibration by: ASHISH & FOZIA		Checked by : ASHIM DATTA			

17



AAXIS NANO
TECHNOLOGIES PVT. LTD.
Solutions For A Sustainable Environment

+91-7428541532



0120 415 9238

www.aaxisnano.com


info@aaxisnano.com



16

 AAXIS NANO TECHNOLOGIES PVT. LTD. Solutions For A Sustainable Environment		 s can Intelligent. Optical. Online.			
CALIBRATION REPORT					
Project Name:		DJB_EQMS	Date:	27-11-2023	
Station Name:		KONDLI PH-3 STP	Engineer:	RAGHVENDRA	
			Manager:	Dharmendra Singh	
S.No.	Parameters Name	Calibration Type	Online Result Precalibration	Lab Sample Calibration Point	Online Result Post Calibration
spectro::lyser (Calibration Method : multi point sample calibration w.r.t. laboratory analysis)					
1	COD (in mg/L)	Multi	47.8	33	32.8
2	BOD (in mg/L)	Multi	7.7	6	6.4
3	TSS (in mg/L)	Multi	11.2	8	7.6
ammo::lyser 1 (Calibration Method : sample calibration w.r.t. laboratory analysis/pH - buffers)					
4	TEMP	Global	22.9	21	21.6
5	AMMONIA	LINEAR	6.3	5	5.1
6	PH	LINEAR	7.44	7.5	7.51
Calibration by: ASHISH & FOZIA		Checked by : ASHIM DATTA			

(18)



AAXIS NANO
TECHNOLOGIES PVT. LTD.
Solutions For A Sustainable Environment

+91-7428541532

0120 415 9238


www.aaxisnano.com

info@aaxisnano.com



(18)

S.No.		Parameters Name	Calibration Type	Online Result Precalibration	Lab Sample Calibration Point	Online Result Post Calibration
spectro::lyser (Calibration Method : multi point sample calibration w.r.t. laboratory analysis)						
1		COD (in mg/L)	Multi	56.1	43	43.5
2		BOD (in mg/L)	Multi	13.7	11	11.6
3		TSS (in mg/L)	Multi	25.7	20	21.4
ammo::lyser 1 (Calibration Method : sample calibration w.r.t. laboratory analysis/pH - buffers)						
4		TEMP	Global	18.1	23	23.6
5		AMMONIA	LINEAR	8.88	7	7.06
6		PH	LINEAR	7.44	7.49	7.5
Calibration by: ASHISH & FOZIA			Checked by : ASHIM DATTA			



AAXIS NANO
TECHNOLOGIES PVT. LTD.
Solutions For A Sustainable Environment

s can
Intelligent. Optical. Online.

CALIBRATION REPORT

Project Name: DJB_EQMS Date: 27-11-2023

Station Name: KONDLI PH-4 STP Engineer: RAGHVENDRA

Manager: Dharmendra Singh

spectro::lyser (Calibration Method : multi point sample calibration w.r.t. laboratory analysis)

S.No.	Parameters Name	Calibration Type	Online Result Precalibration	Lab Sample Calibration Point	Online Result Post Calibration
1	COD (in mg/L)	Multi	56.1	43	43.5
2	BOD (in mg/L)	Multi	13.7	11	11.6
3	TSS (in mg/L)	Multi	25.7	20	21.4

ammo::lyser 1 (Calibration Method : sample calibration w.r.t. laboratory analysis/pH - buffers)


S.No.	Parameters Name	Calibration Type	Online Result Precalibration	Lab Sample Calibration Point	Online Result Post Calibration
4	TEMP	Global	18.1	23	23.6
5	AMMONIA	LINEAR	8.88	7	7.06
6	PH	LINEAR	7.44	7.49	7.5

Calibration by: ASHISH & FOZIA

Checked by : ASHIM DATTA



191



AAXIS NANO
TECHNOLOGIES PVT. LTD.
Solutions For A Sustainable Environment


180

+91-7428541532

0120 415 9238

www.aaxisnano.com

info@aaxisnano.com




AAXIS NANO
TECHNOLOGIES PVT. LTD.
Solutions For A Sustainable Environment

s can
Intelligent. Optical. Online.

CALIBRATION REPORT

Project Name:		DJB_EQMS	Date:	20-12-2023	
Station Name:		KONDLI PH-1 STP	Engineer:	RAGHVENDRA	
			Manager:	Dharmendra Singh	
S.No.	Parameters Name	Calibration Type	Online Result Precalibration	Lab Sample Calibration Point	Online Result Post Calibration
spectro::lyser (Calibration Method : multi point sample calibration w.r.t. laboratory analysis)					
1	COD (in mg/L)	Multi	34.36	30	28.92
2	BOD (in mg/L)	Multi	6.96	5	4.16
3	TSS (in mg/L)	Multi	8.34	7	6.42
ammo::lyser 1 (Calibration Method : sample calibration w.r.t. laboratory analysis/pH - buffers)					
4	TEMP	Global	18.92	20	20.7
5	AMMONIA	LINEAR	3.98	5	4.55
6	PH	LINEAR	7.37	7.45	7.44
Calibration by: ASHISH & FOZIA		Checked by : ASHIM DATTA			



AAXIS NANO
TECHNOLOGIES PVT. LTD.
Solutions For A Sustainable Environment

+91-7428541532

0120 415 9238

www.aaxisnano.com

info@aaxisnano.com



AAXIS NANO
TECHNOLOGIES PVT. LTD.
Solutions For A Sustainable Environment

s can
Intelligent. Optical. Online.

CALIBRATION REPORT

Project Name:		DJB_EQMS	Date:	20-12-2023	
Station Name:		KONDLI PH-3 STP	Engineer:	RAGHVENDRA	
			Manager:	Dharmendra Singh	
S.No.	Parameters Name	Calibration Type	Online Result Precalibration	Lab Sample Calibration Point	Online Result Post Calibration
spectro::lyser (Calibration Method : multi point sample calibration w.r.t. laboratory analysis)					
1	COD (in mg/L)	Multi	40.43	37	36.5
2	BOD (in mg/L)	Multi	12.9	6	6.95
3	TSS (in mg/L)	Multi	12.77	8	8.62
ammo::lyser 1 (Calibration Method : sample calibration w.r.t. laboratory analysis/pH - buffers)					
4	TEMP	Global	19	18	18.25
5	AMMONIA	LINEAR	6.11	4	4.44
6	PH	LINEAR	7.46	7.48	7.49
Calibration by: ASHISH & FOZIA		Checked by : ASHIM DATTA			

(21)

AAXIS NANO
TECHNOLOGIES PVT. LTD.
Solutions For A Sustainable Environment

+91-7428541532

0120 415 9238

www.aaxisnano.com

info@aaxisnano.com



AAXIS NANO
TECHNOLOGIES PVT. LTD.
Solutions For A Sustainable Environment

s can
Intelligent. Optical. Online.

CALIBRATION REPORT

Project Name:		DJB_EQMS	Date:	20-12-2023	
Station Name:		KONDLI PH-4 STP	Engineer:	RAGHVENDRA	
			Manager:	Dharmendra Singh	
S.No.	Parameters Name	Calibration Type	Online Result Precalibration	Lab Sample Calibration Point	Online Result Post Calibration
spectro::lyser (Calibration Method : multi point sample calibration w.r.t. laboratory analysis)					
1	COD (in mg/L)	Multi	52	45	45.9
2	BOD (in mg/L)	Multi	13.5	11	11.8
3	TSS (in mg/L)	Multi	25.4	22	22.9
ammo::lyser 1 (Calibration Method : sample calibration w.r.t. laboratory analysis/pH - buffers)					
4	TEMP	Global	18.9	21	20.8
5	AMMONIA	LINEAR	12.27	9	9.8
6	PH	LINEAR	7.35	7.5	7.52
Calibration by: ASHISH & FOZIA		Checked by : ASHIM DATTA			

ANNEXURE - 5

By Speed Post/ Email

	DELHI POLLUTION CONTROL COMMITTEE DEPARTMENT OF ENVIRONMENT, GOVT. OF NCT OF DELHI 5th FLOOR, ISBT BUILDING, KASHMERE GATE, DELHI-110006 visit us at : http://dpcc.delhigovt.nic.in
--	---

F. No. DPCC/(13)(9)(0073)/PLG-13/ 53-56

Dated: 11.01.2024

To,

The Member Drainage,
 Delhi Jal Board, Varunalaya Phase- II,
 Jhandewalan, Karol Bagh, Delhi-110005.

Subject: Directions u/s 33(A) of Water (Prevention and Control of Pollution) Act, 1974, as amended to date for proper operation of STPs at Kondli to meet the Prescribed Standards including stoppage of by-passing of untreated sewage by DJB.

Whereas, Central Pollution Control Board is the State Board for all the Union Territories to exercise powers and performs functions under the Water (Prevention and Control of Pollution) Act, 1974 and Air (Prevention and Control of Pollution) Act, 1981, as amended to date.

And whereas, Central Pollution Control Board has delegated all its powers and functions under the Air (Prevention and Control of Pollution) Act, 1981 and Water (Prevention and Control of Pollution) Act, 1974, as amended to date, in respect of Union Territory of Delhi to Delhi Pollution Control Committee (DPCC) vide Notification Dated 15.03.1991.

And whereas, as per Section 24 of the Water (Prevention and Control of Pollution) Act, 1974:

- (a) No person shall knowingly cause or permit any poisonous, noxious or polluting matter determined in accordance with such standards as may be laid down by the State Board to enter (whether directly or indirectly) into any [stream or well or sewer or on land]; or
- (b) No person shall knowingly cause or permit to enter into any stream any other matter which may tend, either directly or in combination with similar matters, to impede the proper flow of the water of the stream in a manner leading or likely to lead to a substantial aggravation of pollution due to other causes or of its consequences.

And whereas, Delhi Jal Board, having its Head Office at Varunalaya Phase-II, Jhandewalan, KarolBagh, Delhi-110005 is responsible for operation and maintenance of the Sewage Treatments Plants in Delhi including STPs at Kondli, Delhi.

And Whereas, the Hon'ble National Green Tribunal has passed various orders including orders dated 29.05.2023 in OA No 366/2023 in the matter of Rajesh Kumar Dokwal Vs. Govt. of NCT of Delhi passed the following order

"It appears that despite the above two orders passed in OA Nos. 882/2018 and 429/2019 (supra), no effective compliance has been done. In these circumstances, we direct DJB and DPCC to submit a factual and action taken Report in the matter, particularly, in the light of the orders already passed in OA Nos. 882/2018 and 429/2019 (supra). If no effective action has been taken, they shall also explain as to why effective compliance of the earlier orders has not been carried out till date."

And whereas, inspection of the 10 MGD STP Phase-I, 25 MGD STP Phase-II, 10 MGD STP Phase-III & 45 MGD STP Phase-IV at Kondli was carried out by the officials of DPCC on 04.07.2023 and Delhi Pollution Control Committee had issued Directions u/s 33(A) of Water (Prevention and Control of Pollution) Act, 1974 and u/s 31(A) of Air (Prevention and Control of Pollution) Act, 1981, on 27.07.2023 to Delhi Jal Board for proper operation of STPs at Kondli to meet the Prescribed Standards including stoppage of by-passing of untreated sewage by DJB and to explain non-effective compliance of Directions of Hon'ble National Green Tribunal in Orders dated 28.05.2019 passed in OA No. 882/2018 "Jagdish Singh Vs. Govt. of NCT of Delhi" and Order dated 12.11.2021 passed in OA No. 429/2019 "RWA Society Vs. Govt. of NCT of Delhi".

And Whereas, Delhi Jal Board vide letter dated 03.08.2023 submitted reply with respect to said Directions issued by DPCC on 27.07.2023 and the same has been considered.

And whereas, inspection of the 10 MGD STP Phase-I, 25 MGD STP Phase-II, 10 MGD STP Phase-III & 45 MGD STP Phase-IV at Kondli was carried out by the officials of DPCC on 03.01.2024. During the said inspection following deficiencies were observed:

1. Kondli STP Phase-IV has total capacity of 45 MGD. However, half of the capacity i.e. (22.5 MGD) is being treated only and rest 22.5 MGD is being by-passed as the plant is under rehabilitation.
2. Only 01 out of 03 Odour Control Units (OCU) found operational at the time of inspection.
3. Rapid Gravity Filter (RGF) (for phase II & III) were found non-operational at the time of Inspection.
4. No OLMS found installed at Phase-II.
5. Chlorination is not being carried out in Phase-II & III.
6. Sludge Handling Units of all 04 Phases has not been commissioned yet.

And whereas, as per the Analysis Reports dated 04.12.2023 (Samples collected on 09.11.2023) and as per the Analysis Reports dated 5.01.2024 (Samples collected on 13.12.2023) of DPCC laboratory, Kondli Phase - IV STP is not meeting the prescribed standards w.r.t. TSS (30 mg/l against the prescribed standard of 10 mg/l), BOD (16 mg/l against the prescribed standard of 10 mg/l) and COD (88 mg/l against the prescribed standard of 50 mg/l).

Now therefore, in view of the above and as decided by the Competent Authority in DPCC in exercise of powers conferred upon it u/s 33(A) of the Water (Prevention and Control of Pollution) Act, 1974, Member Drainage, Delhi Jal Board is hereby directed to take immediate steps for rectification of deficiencies/ violations observed and mentioned above and to meet the standards prescribed by Delhi Pollution Control Committee and to ensure that there will be no by-passing of the raw/ untreated sewage from the above mentioned 45 MGD STP at Kondli. DJB shall submit the compliance report within 15 days from the date of issue of this Letter.

24

22


In case of failure to submit compliance of the above directions within 15 days from the date of issue of this letter, necessary action will be initiated as per law, without any further reference in this regard.

This issues with the approval of the Chairman, Delhi Pollution Control Committee.



(Dr. K. S. Jayachandran)
Member Secretary, DPCC

Copy to:-

1. The Chief Executive Officer, Delhi Jal Board, Varunalaya Ph-II, Jhandewalan, Karol Bagh, Delhi-110005.
2. District Magistrate (East), L.M. Bund, Shastri Nagar, Delhi-31
3. PA to Chairman, DPCC


(Dr. K. S. Jayachandran)
Member Secretary, DPCC

ANNEXURE - 6

URGENT
By Email

DELHI POLLUTION CONTROL COMMITTEE
DEPARTMENT OF ENVIRONMENT, GOVT. OF NCT OF DELHI
5thFLOOR, ISBT BUILDING, KASHIMERE GATE, DELHI-110006
 visit us at : <http://dpcc.delhigovt.nic.in>

F. No. DPCC/WMC-II/OA 21 (Ashwani Yadav) / 2023 / 5747-5750

Dated: 14.12.2023

To,

Chief Executive Officer,
 Delhi Jal Board, Varunlalaya Phase-II, Jhandewalan,
 Karol Bagh, New Delhi-110005.

Sub: Clarification Regarding Non-Inclusion of All the Prescribed Parameters Including Total Nitrogen by DPCC for Upgradation of Sewage Treatment Plants (STPs) of Delhi Jal Board.

Reference: Letter dated 31.01.2020 (Copy enclosed), email dated 01.12.2023 of DPCC and letter dated 05.12.2023 of Delhi Jal Board regarding Compliance of Prescribed Standards by Sewage Treatment Plants of Delhi Jal Board.

Sir,

I am directed to mention that DPCC has prescribed following Standards for Sewage Treatment Plants of Delhi Jal Board as per the Directions of Central Pollution Control Board (CPCB) u/s 18 (1)(b) of the Water (Prevention and Control of Pollution) Act, 1974 vide letter dated 21.04.2015 and further clarified vide letter dated 27.04.2016 to specify stringent standards for STPs :

- | | | | |
|--|---|---------------------|--------------------|
| (i) pH - 6.5 - 9.0 | (ii) TSS < 10 mg/l | (iii) BOD < 10 mg/l | (iv) COD < 50 mg/l |
| (v) Ammonical Nitrogen < 5mg/l | (vi) Total Nitrogen (N-Total) < 10 mg/l | | |
| (vii) Phosphate (PO ₄ - P) < 2 mg/l | (viii) Fecal Coliform(FC) (MPN/100ml) < 230 | | |

Vide letter dated 05.12.2023, DJB has informed regarding Five Output Parameters (BOD, TSS, Phosphorus, Pathogen & Ammonia) for upgradation of STPs in Package I, II & III [Pappankalan Phase-I, Nilothi Phase-I, Najafgarh, Keshopur Phase-II, Keshopur Phase-III, Rohini Sec-25, Narela, Coronation Pillar Phase I & II and Coronation Pillar Phase-III] against the above mentioned 8 Parameters prescribed by DPCC..

Similarly, DJB has also informed regarding Seven Output Parameters (BOD, COD, TSS, Phosphorus, Pathogen, Ammonia/ Ammonical Nitrogen and Total Nitrogen) for upgradation of Kondli Ph-IV, Yamuna Vihar Ph-II and Rithala Ph-I against the above mentioned 8 Parameters prescribed by DPCC.

Table showing parameters prescribed by DPCC and Output Parameters for various STPs of DJB for Upgradation is enclosed.

In view of the above, it is requested to clarify as to why all the 8 Parameters including Total Nitrogen prescribed by DPCC have not been considered by DJB for upgradation of STPs including STPs in Package I, II & III, urgently by 15.12.2023. Also it is further requested to forward the tender documents and work contract of the aforesaid STPs to this office so that the parameters used by the DJB in the procurements concerned can be verified.

Yours Sincerely,

(Signature)
 (Dr. K. S. Jayachandran)
 Member Secretary, DPCC

Enclosures: As Above

Copy to:

1. Staff Officer to Chief Secretary, GNCTD, 5th Level, Delhi Secretariat, I.P. Estate, Delhi - 110002.
2. PS to Chairman, DPCC.
3. PS to Pr. Secy (Env.), Govt. of NCT of Delhi.

(Signature)
 (Dr. K. S. Jayachandran)
 Member Secretary, DPCC

Comparison between Parameters prescribed by DPCC, Hon'ble NGT & Output Parameters for various STPs of DJB for Upgradation

S o.	Parameters & Standards Prescribed by DPCC		Parameters & Standards Mentioned in NGT order Dated 30.04.2019 for Mega and Metropolitan Cities		Parameters & Standards for STPs in Package I, II & III (As per DJB)		Parameters & Standards for Kondli Phase-IV & Yamuna Vihar Phase-II & Rithala Phase - I		Parameters & Standards for Rithala Phase - I	
	Parameters	Standards	Parameters	Standards	Parameters	Standards	Parameters	Standards	Parameters	Standards
1.	pH	6.5-9.0	pH	5.5-9.0	BOD	10 mg/l	BOD	10 mg/l	BOD	10 mg/l
2.	BOD	10 mg/l	BOD	10 mg/l	TSS	10 mg/l	COD	50 mg/l	COD	50 mg/l
3.	COD	50 mg/l	COD	50 mg/l	Phosphorus	1 mg/l	TSS	10 mg/l	TSS	10 mg/l
4.	TSS	10 mg/l	TSS	20 mg/l	Pathogen	230 mg/l	Phosphorus	1 mg/l	Phosphorus	2 mg/l
5.	NH ₄ N	5 mg/l	-	-	Ammonia	5 mg/l	Pathogen	230 mg/l	Pathogen	100 mg/l
6.	N-Total	10 mg/l	N-Total	10 mg/l	* pH, Total Nitrogen & COD is not mentioned in the table.		Ammonia	5 mg/l	Ammonical Nitrogen	5 mg/l
7.	Fecal Coliform	230 MPN/ 100 ml	Fecal Coliform	230 MPN/ 100 ml	** Phosphorus is mentioned in place of PO ₄ - P, pathogen mentioned in place of Fecal coliform and Ammonia in place of Ammonical Nitrogen		Total Nitrogen	10 mg/l	Total Nitrogen	10 mg/l
8.	Phosphate (PO ₄ -P)	2 mg/l	Phosphorus as total (for discharge into ponds, lakes	1 mg/l	* pH is not mentioned in the table.		** Phosphorus is mentioned in place of PO ₄ -P ,pathogen mentioned in place of Fecal coliform and Ammonia in place of Ammonical Nitrogen		* pH is not mentioned in the table.	
					** Phosphorus is mentioned in place of PO ₄ -P ,pathogen mentioned in place of Fecal coliform and Ammonia in place of Ammonical Nitrogen		** Phosphorus is mentioned in place of PO ₄ -P and pathogen mentioned in place of Fecal coliform			

26

24

ANNEXURE - 7

DELHI JAL BOARD :GOVT. OF DELHI
OFFICE OF CHIEF ENGINEER(SDW)
6TH FLOOR, VARUNALAYA PH-II
JHANDEWALAN, ND-110005



F No/DJB/CE(SDW)/2023/565

DATE: 18.12.2023

To

Member(Secretary), DPCC
DPCC, 5th Floor, ISBT Building
Kashmere Gate, New Delhi-110006

Sub: Clarification Regarding Non-inclusion of all the prescribed parameters including total nitrogen by DPCC for upgradation of sewage treatment plants of Delhi Jal Board.

Sir,

This is in reference to E-mail dated 14.12.2023 on the subject cited above, in this connection it is certified that after upgradation of all the three packages, all 8 nos. of parameters prescribed by DPCC shall be maintain as follows:

S.N	KPI	Target
1	pH	6.5-9.0
2	BOD	≤10mg/l
3	COD	≤50mg/l
4	TSS	≤10mg/l
5	NH ₄ N	≤5mg/l
6	N-Total	≤10mg/l
7	Fecal coliform	230MPN
8	Phosphate (PO ₄ -P)	≤1mg/l

A

In support of above, photocopies of the Basic Engineering Package consisting of process, Design, Layout and hydraulic flow diagram duly vetted by Sh. A.K. Haritash, Professor, department of environmental engineering Delhi Technological University (formerly Delhi collage of Engineering) is attached herewith for reference as Annexure 'A'.

It is further certified that the parameters after upgradation of Kondli Ph-IV, Yamuna Vihar Ph-II shall be as under:

S.N	KPI	Target
1	pH	6.5-9.0
2	BOD	≤10mg/l
3	COD	≤50mg/l
4	TSS	≤10mg/l
5	NH ₄ N	≤5mg/l
6	N-Total	≤10mg/l
7	Fecal coliform	≤100MPN
8	Phosphate (PO ₄ -P)	≤1mg/l

It is further certified that the parameters after upgradation of Rithala Ph-I shall be as under:

S.N	KPI	Target
1	pH	6.5-9.0
2	BOD	≤10mg/l
3	COD	≤50mg/l
4	TSS	≤10mg/l

(29)

(29)

5	NH ₄ N	≤5mg/l
6	N-Total	≤10mg/l
7	Fecal coliform	≤100MPN
8	Phosphate (PO ₄ -P)	≤2mg/l

Further photocopies of the design basis and plant process description as per CA provision for Kondli Ph-IV, Yamuna Vihar Ph-II and Rithala Ph-I are attached herewith for reference please.

In view of the above, it is clarified that all 8 Nos. of parameter for treated effluent prescribed by DPCC shall be maintained after up-gradation of STP including STP contained in Package- I, II & III.

Thanking you.

With regards

Sd/-
(Bhupesh Kumar)
CE(SDW)

Copy for information to:

1. CEO, DJB
2. Member(Dr)


CE(SDW)

HINDUSTAN

20

20


CHAPTER - II TREATMENT DESIGN

2.1 PLANT DESIGN CRITERIA

It has been proposed to renovate and upgrade the existing 20MGD STP to 30 MGD with the addition/renovation of structures for increasing its removal efficiency with respect to BOD, COD, TSS, Faecal coliforms etc. as well for achieving nutrients removal i.e. phosphorus removal, nitrogen removal through nitrification, de-nitrification and process up-gradation followed by Tertiary Treatment with disc filtration then UV disinfection so as to achieve the treated waste water parameters prescribed by CPCB/DPCC.

Item/ Parameter/ Description	Units	
Treatment Process		IFAS
Existing STP Capacity	MGD	20
Design Average Flow (Upgraded flow)	MGD	30
Peak flow to STP	MGD	40
Influent Wastewater Characteristics		Asper adendum-5
pH	-	6.0 - 8.5
BOD	mg/L	250
COD	mg/L	550
TSS	mg/L	450
NH ₄ -Nitrogen	mg/L	35
TKN, mg/ L	Mg/L	45
TP as PO ₄ , mg/ L	mg/L	6
Total Coliform	MPN/100 mL	1.0 x 10 ⁶
Min. Sewage Temperature (T min)	°C	18
Max. Sewage Temperature (T max)	°C	35
Min. Ambient Temperature	°C	15
Max. Ambient Temperature	°C	45
Treated Effluent Quality Requirements (at outlet of disinfected Channel)		
pH - instantaneous range		6.5 - 9.0
BOD ₅ at 20°C	mg/L	≤10
COD	mg/L	≤50
TSS	mg/L	10
NH ₄ -N	mg/L	≤5
TKN	mg/L	10
PO ₄ -P (TP)	mg/L	≤1
Fecal Coliform	MPN/100mL	< 230

For SIPL Dwarka Water Systems Pvt. Ltd.


 Authorised Signatory
EUROTECK ENVIRONMENTAL
PVT. LTD.SIPL- DWARAKA WATER
SYSTEMS PRIVATE LIMITED

A. K. HARITASH

 Professor
 Department of Environmental Engineering
 Delhi Technological University


 DELHI JAL BOARD

PROJECT TITLE

REHABILITATION/ UP-GRADATION OF 20 MGD SEWAGE TREATMENT PLANT AT KESHOPUR PHASE II, DELHI.

2.1 PLANT DESIGN CRITERIA

It has been proposed to renovate and upgrade the existing 20 MGD STP with the addition/renovation of structures for its hydraulic load and removal efficiency with respect to BOD, COD, TSS, Faecal coliforms etc. as well for achieving nutrients removal i.e. phosphorus removal, nitrogen removal through nitrification, de-nitrification and process up-gradation followed by Tertiary Treatment with disc filtration then UV disinfection so as to achieve the treated waste water parameters prescribed by CPCB/DPCC.

Item/ Parameter/ Description	Units	
Treatment Process		IFAS
Existing STP Capacity	MGD	20
Design Average Flow (Upgraded flow)	MGD	20
Design Peak flow to STP	MGD	40
Influent Wastewater Characteristics		
pH.	-	6.0 - 8.5
BOD	mg/L	250 ✓
COD	mg/L	550 ✓
TSS	mg/L	450 ✓
NH4-Nitrogen	mg/L	30
TKN, mg/ L (assumed)	Mg/L	35
TP as PO4, mg/ L	mg/L	6
Total Coliform	MPN/100 mL	1.0 x 10 ⁶
Min. Sewage Temperature (T min)	°C	18
Max. Sewage Temperature (T max)	°C	35
Min. Ambient Temperature	°C	15
Max. Ambient Temperature	°C	45
Treated Effluent Quality Requirements (at outlet of disinfected Channel)		
pH - instantaneous range		6.5 - 9.0
BOD5 at 20°C	mg/L	≤10
COD	mg/L	≤50
TSS	mg/L	10
NH4-N	mg/L	≤5
TKN	mg/L	10
PO4-P (TP)	mg/L	≤1
Fecal Coliform	MPN/100mL	< 230


 S. V. DIXIT
 Executive Engineer (SDWA-VI)
 DELHI JAL BOARD
 WSTP Keshopur, New Delhi-18

PROJECT TITLE


REHABILITATION/UP-GRADATION OF 15 MGD TO 25 MGD SEWAGE TREATMENT PLANT AT ROHINI, DELHI.

1.3.2	Treated effluent Sewage Characteristics-secondary treatment		
	pH	=	6.5 to 9.0
	BOD5, mg/ L	=	10.00
	COD, mg/ L	=	50.00
	TSS, mg/ L	=	20.00
	Coliform , MPN/100ml	=	100000.00
	Total Nitrogen, mg/ L	=	10.00
	NH ₄ - Nitrogen, mg/ L	=	5.00
	TP as P,mg/ L (As PO ₄ -P)	=	1.00
1.3.3	Treated effluent Sewage Characteristics-Tertiary treatment		
	pH	=	6.5 to 9.0
	BOD5, mg/ L	=	10.00
	COD, mg/ L	=	50.00
	TSS, mg/ L	=	10.00
	Coliform , MPN/100ml	=	230.00
	Total Nitrogen, mg/ L	=	10.00
	NH ₄ - Nitrogen, mg/ L	=	5.00
	TP as P,mg/ L (As PO ₄ -P)	=	1.00
1.4.0	Flow Rates		
1.4.1	Peak Flow for design		
	m ³ / day		36200.00
	m ³ / Hr		5675.00

[Handwritten Signature]

A. K. HARITASH

Department of
Environmental Engineering
GGS Indraprastha University
New Delhi



Code 1 Recommended for approval for construction
Code 2 Recommended for approval with conditions
(for construction subject to incorporation of conditions)
Code 3 Recommended for approval with conditions
Code 4 Recommended for approval with conditions

34

33

Wastewater Quality (1988) Group Treatment Plant Results

Influent Sewage Characteristics	Value
pH	6-8.5
BOD, mg/l	250-300
COD, mg/l	425-600
TSS, mg/L	400-560
Faecal coliform, MPN/100ml	12x10 ⁶
Temperature, °C	26 (Design shall be suitable for all temperature)
NH ₄ - Nitrogen, mg/L	45
TP as PO ₄ , mg/L	8
Oil & Grease mg/l	35

The above data is based on wastewater quality analyzed by DJB. However, the contractor may conduct the sampling and tests of raw sewage by himself to ascertain the raw sewage quality for treatment process. The Employer (Dehi Jal Board) will not be responsible for the above and no relaxation will be given to the guarantee conditions of desired treated effluent quality. For design purposes, values higher of the two i.e. as given above or as per test got conducted by the contractor shall be considered.

1.6 Treated Effluent & Residual Guarantees

1.6.1 Treated Effluent Quality Requirement & Guarantee

The contractor shall design the process in such a way that the treated effluent qualities meet the following minimum standards or even better after secondary & tertiary treatment and disinfection

S No	Particulars	To be Guaranteed by Bidder
1	pH	6.5-8.0
2	TSS	≤ 10 mg/l
3	Total Nitrogen	≤ 10 mg/l
4	Ammonical Nitrogen (NH ₄ -N)	≤ 5 mg/l
5	BOD ₅	≤ 10 mg/l
6	COD	≤ 60 mg/l
7	PO ₄ -P (TP)	≤ 1 mg/l

000342

35

39

Upgradation of existing 45 MGD Sewage Treatment Plant, Kondli, Delhi

8	Fecal Coliform	< 100 MPN/100ml
---	----------------	-----------------

The contractor is to maintain guarantee parameters for treated effluent quality, as listed above, during defect liability period and O&M period.

Demonstration of the treated effluent quality parameters measurement incident, sampling, analyzing in laboratory and liquidated damages/penalty for non-conformance etc. have been mentioned in Volume-II, Part-9 Service Level Agreement.

1.5.2 Sludge Quality Standard

- Solids content in wet cake of at least 20 % (+/-) 2% w/w
- Ratio of TVSS/TSS shall be 48 % or less

The penalty for each residual noncompliance "incident" as indicated in Volume-II, Part-9 Service Level Agreement shall be adopted for residual quality guarantee.

1.7 Brief Scope of Work:


The brief scope of work comprises of the following major heads:

- 1) Interim Operation of the existing & partly rehabilitated WWTP during construction & rehabilitation period.
- 2) Construction, Rehabilitation and up-gradation of existing WWTP.
- 3) Integration of rehabilitated WWTP & Trial Run.
- 4) Operation of Plant during Defect Liability Period of two year.
- 5) Operation & Maintenance of the plant for a period of 10 years after successful completion of DLP.
- 6) Demolition of structures of existing WWTP, if any.

The Duration of the work execution shall be as follows:

Sl. No.	Description	Period
a)	Construction, rehabilitation & up-gradation period along with integration of rehabilitated plant	12 months
b)	Trial run	3 months
c)	Defect Liability Period (DLP)	24 months after successful completion of Trial run.
d)	O&M period	120 months (10 years) after successful completion of DLP

1) Interim Operation of the existing & partly rehabilitated WWTP during construction



Volume 22

[Handwritten signatures]

000343

PROJECT TITLE

REHABILITATION/ UP-GRADATION OF 10 MGD (45.5 MLD) SEWAGE TREATMENT,
PLANT PHASE II AT YAMUNA VIHAR DELHI.

Item/ Parameter/ Description	Units	15MGD YAMUNA VIHAR
pH - instantaneous range		6.5 - 9.0
BOD5 at 20°C	mg/L	≤10
COD	mg/L	≤50
TSS	mg/L	10
NH4-N	mg/L	≤5
Total N	mg/L	10
PO4-P (TP)	mg/L	≤1
Fecal Coliform - max monthly avg.	MPN/100mL	< 100
Treated Sludge Quality Requirements (Dewatered Sludge)		
Solids content in wet cake	w/w	at least 25 % (+/-) 2%
Ratio of TVSS/TSS shall be	%	48 % or less

Treated sludge disposal

The generation of sludge from the STP i.e digested sludge is de-watered in Belt Filter Press aided by the polyelectrolyte dosing and the wet cake is disposed off to the sludge dumping site identified by DJB.

Chemical requirements

Dewatering polyelectrolyte dosing tanks fitted with an agitator facilitates the Preparation of 0.20 % solution. DWPE dosing pumps are provided to dose the polyelectrolyte solution to centrifuges to improve the dewatering characteristics of the digested sludge. The dosing rate of the DWPE solution is varied by the manual stroke adjustment of the dosing pumps.

Tertiary Treatment

After the Biological Treatment the overflow of Secondary clarifier would be fed to the Disc Cloth Filter for filtration followed which the treated water would be dis-infected with UV System.

Dis-Infection

The area available for constructing Chlorine contact has lot of old trees and plantations hence cutting of large amount of tress would become inevitable. SO it has been proposed to dis-infect the tertiary treated water with UV System.

TECHNOLOGY PROVIDER

EUROTECK
EUROTECK
ENVIRONMENTAL PVT. LTD.

CONTRACTOR

SIPL
SUBHASH INFRAENGINEERS
PRIVATE LIMITED


Page 10 of 58

CONSULTANT

WAPCOS LIMITED

CLIENT

DELHI JAL BOARD





DESIGN BASIS & PLANT PROCESS DESCRIPTION

Rehabilitation & Up-gradation of Rithala Phase-I (182 MLD) Waste Water Treatment Plant (WWTP)

Bid Doc. No. BID-YAP-(III) (R2/2016-17)

Delhi Jal Board

Table 2. Incoming Wastewater Quality

Sl. No.	PARTICULARS	UNITS	RAW WASTEWATER			DESIGN VALUE
			AVG	MIN	MAX	
1	Air Temperature	C	25	5	48	Min & Max
2	Water	C	26.4	17.8	29.0	Min & Max
3	pH Value	-	7.20	7.054	7.38	7.0 to 7.40
4	Total Alkalinity	mg/l	350	279	415	400
5	Chlorides	mg/l	205	140	292	250
6	TSS	mg/l	275	205	330	400
7	VSS	mg/l	170	115	247	240
8	BOD	mg/l	175	100	212	225
9	COD	mg/l	426	300	515	450
10	Ammonia-N	mg/l	33	18	48	42
11	TKN	mg/l	46	29	55	50
12	Oil & Grease	mg/l	17.0	15.0	19.0	20
13	Total Phosphorus	mg/l	5	3.2	5.7	6.0

4.5 TREATED EFFLUENT QUALITY REQUIREMENTS

The treated effluent qualities shall meet the following minimum standards or even better after treatment and disinfection-

Table 3. Treated effluent quality requirement and Guarantee

Sl. No.	PARTICULARS	TO BE GUARANTEED
1	pH	6.5-9.0
2	TSS	≤ 10 mg/l
3	Total Nitrogen	≤ 10 mg/l
4	Ammoniacal Nitrogen (NH ₄ -N)	≤ 5 mg/l



0008000261

	DESIGN BASIS & PLANT PROCESS DESCRIPTION	
	Rehabilitation & Up-gradation of Rithala Phase-I (182 MLD) Waste Water Treatment Plant (WWTP)	
	Bid Doc. No. BID-YAP-(III) (R2/2016-17)	
	Delhi Jal Board	

SI. No.	PARTICULARS	TO BE GUARANTEED
5	BOD	≤ 10 mg/l
6	COD	≤ 50 mg/l
7	PO ₄ -P (TP)	≤ 2 mg/l
8	Faecal Coliform	< 100 MPN/100ml

4.6 SLUDGE QUALITY STANDARD

The sludge quality requirements to be met are listed below-

Sludge Quality requirements (Dewatered sludge)

PARAMETER	REQUIREMENT
Sludge Quality	Digested Stabilised Sludge
Minimum Sludge Consistency after Dewatering	25% (+/-) 2% w/w

The Dewatered Sludge should be truck-able and be suitable for disposal by open body truck.

4.7 UTILISATION OF BIOGAS FROM THE PROPOSED PLANT

Bio-gas generated from the proposed plant shall be taken for power generation by Biogas engine.

4.8 TREATED WATER DISPOSAL

The treated water shall be disposed-off to the existing Nangloi supplementary drain as per the specification in tender. Outfall structure shall be of RCC.





39

Annexure- 8

Speed Post/E-mail

F No- 14011/WQM-I/1002/2018/2022 6513-6518

Date: 28.11.2022

To

All concerned
(As per list)

Sub: Minutes of the meeting held in compliance to Hon'ble NGT directions in the matter of O.A. No. 1002/2018 titled Abhisht Kusum Gupta Vs. State of Uttar Pradesh & Ors.

Sir,

Enclosed please find herewith the minutes of the meeting held on 14th November, 2022 to review the status of compliance of directions given by Hon'ble NGT vide order dated 03.08.2022 in the matter of O.A. No. 1002/2018 titled Abhisht Kusum Gupta Vs. State of Uttar Pradesh & Ors.

This is for information and necessary action, please.

Yours faithfully,

[P K Mishra]

Divisional Head - WQM-I

Encl: As above

Copy to:

1. PA to CCB : For information of 'CCB' please
2. AO to MS : For information 'MS' please
3. DII-Law, CPCB : For information and record please

[P K Mishra]

o/c

N Singh
28/11/2022

List of officials

1. The Chief Executive Officer,
Delhi Jal Board (HQ)
Public Relations Office
Room No.306, 3rd Floor
Varunalaya Ph-II, Jhandewalan,
Karol Bagh, New Delhi-110005
2. The Chairman & Managing Director,
National Thermal Power Corporation
Limited (NTPC)
NTPC Bhawan, SCOPE Complex,
Institutional Area, Lodhi Road,
New Delhi - 110003
3. The CEO,
New Okhla Industrial Development
Authority (NOIDA)
Administrative Complex Sector 6,
Noida - 201301, Gautam Budh Nagar,
Uttar Pradesh
4. The Principal Secretary,
Urban Development Dept., Govt. of UP
601, Bapu Bhawan, Lucknow
5. The Member Secretary,
Delhi Pollution Control Committee,
6th Floor, C Wing, Delhi Secretariat,
I P Estate, Delhi - 110002
6. The Member Secretary,
Uttar Pradesh Pollution Control Board.
Building No. TC - 12V, Vibhuti Khand,
Gomti Nagar, Lucknow-226 010



Central Pollution Control Board
(Ministry of Environment, Forest & Climate Change, Govt. of India)
Parivesh Bhawan, East Arjun Nagar,
Delhi – 110032

Sub: Meeting held on 14th November, 2022 through Video Conference to review the status of compliance of directions given by Hon'ble NGT vide order dated 03.08.2022 in the matter of O.A. No. 1002/2018 titled Abhisht Kusum Gupta Vs. State of Uttar Pradesh & Ors.

Hon'ble NGT vide order dated 03.08.2022 in the matter of O.A. No. 1002/2018 titled Abhisht Kusum Gupta Vs. State of Uttar Pradesh & Ors directed CPCB to independently monitor the directions from para 29 (ii) to (viii). In this regard, a meeting was convened on 14th November, 2022 at 4:00 PM through Video Conference to review the status of compliance of directions given by Hon'ble NGT. List of participants attended the meeting is given in **Annexure-I**.

Sh. P.K Mishra, DH-WQM-I welcomed all the officials and stressed the need to ensure time bound action towards compliance of the Hon'ble NGT order dated 03.08.2022 in the matter of O.A. No. 1002/2018. He also pointed out that no response till date was received on CPCB letters dated 07.10.2022 & 21.10.2022 by any of the concerned authorities and then requested all the officials from the concerned agencies to apprise the as on date compliance status w.r.t the directions given by Hon'ble NGT.

Sh. Vishal Gandhi, Sc 'D' presented the directions of Hon'ble NGT given to various agencies like Delhi Jal Board, NTPC, NOIDA Authority, Urban Development Department, Govt. of Uttar Pradesh and concerned Pollution Control Board/Committee i.e DPCC & UPPCB.

The compliance status reported by the various agencies during the meeting are as below:

DJB: Sh.B.Saraswat, Additional Chief Engineer, DJB informed that no discharge from Delhi/NCT is entering Kondli Drain rather the waste is being discharged from Khoda area of Delhi. Upon which, Sh. Sanjay Parashar from NOIDA Authority later clarified that Kondli Drain is receiving 30-40 MLD discharge from Delhi. Sh. P.K Mishra, DH-WQM-I then intervened and suggested that in order to verify the reported variations and present source of discharge in Kondli Drain, a Joint inspection of Kondli Drain needs to be performed with the officials of DJB, Khoda Makanpur Nagar Palika and NOIDA Authority. Sh. Saraswat further informed that the four STPs are existing in Kondli and 02 STPs are under upgradation and rehabilitation to meet the designed parameters by the year 2023.

NOIDA Authority: Sh. Sanjay Parashar from NOIDA Authority informed that the work for interception of 30 drains or to take any other remedial action was awarded to CSIR-NEERI

on 21st July, 2022 and NEERI will submit a detailed survey report this month and a detailed project report (DPR) within 3 months.

NTPC: Sh. V.K Garg from NTPC, Dadri informed that they are working on the MoU between NTPC and NOIDA Authority for utilization of treated sewage and will revert back to NOIDA Authority within a week.

Khoda Makanpur Nagar Palika- Ms. Shalini, Executive Officer, Khoda informed that the tender for bioremediation of drains is already floated, work order will be issued within two weeks meanwhile they have also requested GDA & NOIDA Authority to connect the drains to their STPs due to the unavailability of space in Khoda for constructing STP.

Regarding status of deposit of interim compensation as per the order of the Tribunal, officials from NOIDA Authority and DJB informed that the EC amount of sum of Rs. 100 Crore Rs 50 Crore is not yet deposited in CPCB account. It was further informed that DJB has already filed an appeal before Hon'ble Supreme Court while NOIDA Authority is in the process of filing an appeal before Hon'ble Supreme Court for the same.

Upon discussion and deliberations held, following recommendations were made:

All the agencies to submit written compliance status w.r.t the applicable directions 29 (ii) to 29 (viii) by 21st November, 2022.

- i. CPCB to conduct Joint inspection of Kondli Drain with the officials of DJB, Khoda Makanpur Nagar Palika and NOIDA Authority.
- ii. DJB and NOIDA Authority shall submit the STP-wise information w.r.t a) Design capacity of each STP; b) Actual/ Capacity Utilization; c) Qualitative data (inlet/outlet) of STPs for the last 03 months and d) designed value of various parameters to confirm compliance of prescribed NGT norms.
- iii. DJB to submit action plan regarding 100% reuse of treated effluent of 90 MGD STP and to ensure its no discharge in Shahdara drain.
- iv. NOIDA Authority to provide list of reported thirty drains and other minor/major drains discharging into Noida drain containing information of approximate length, origin and ending point, peak discharge value and schematic diagram.
- v. NOIDA Authority to provide action plan for maximum utilization of treated sewage by the Group Housing Societies (GHS) and to ensure their discharge into sewer and not to the open drain.
- vi. Khoda Makanpur Nagar Palika to submit action plan to ensure treatment of sewage generated by Khoda-Makanpur.
- vii. NTPC to submit status of MoU between Noida for utilization for sewage.

The meeting ended with a vote of thanks to the Chair.

Annexure I**List of participants**

1. Sh. P.K.Mishra, DH, WQM-I Division, CPCB
2. Sh. Ajay Sharma, MS, UPPCB
3. Dr. K.S. Jayachandran, MS, DPCC
4. Sh. K.C.Meena, Chief Engineer, DJB
5. Sh. B. Saraswat, Additional Chief Engineer, DJB
6. Sh. Utsav Sharma, RO, Ghaziabad, UPPCB
7. Sh. Praveen Kumar, RO, Noida, UPPCB
8. Sh. V.K Garg, NTPC, Dadri
9. Sh. Sanjay Parashar, NOIDA Authority
10. Ms. Shalini, Executive Officer, Khoda Makanpur Nagar Palika
11. Sh. Rakesh Kumar, Senior Manager, NOIDA Authority
12. Sh. Vishal Gandhi, Sc. 'D', CPCB
13. Mrs. Suniti Parashar, Sc. 'C', CPCB
14. Ms. Deepa Kumari, SRF, CPCB

Speed Post/E-mail

F No- 14011/WQM-I/1002/2018 /2022 9270-9276

Date: 02.03.2023

To,
All concerned
(As per list)

Sub: Minutes of the Second Meeting held on 24th February, 2023 at 4:00 PM through Video Conference to review the status of compliance of directions given by Hon'ble NGT vide order dated 03.08.2022 in the matter of O.A. No. 1002/2018 titled Abhisht Kusum Gupta Vs. State of Uttar Pradesh & Ors

Sir,

Enclosed please find herewith the minutes of the second meeting held on 24th February, 2023 to review the status of compliance of directions given by Hon'ble NGT vide order dated 03.08.2022 in the matter of O.A. No. 1002/2018 titled Abhisht Kusum Gupta Vs. State of Uttar Pradesh & Ors.

This is for information and necessary action, please.

Yours faithfully,



[P K Mishra]

Divisional Head - WQM-I

Encl: As above

Copy to:

- | | | | |
|----|--------------|---|------------------------------------|
| 1. | PA to CCB | : | For information of 'CCB' please |
| 2. | AO to MS | : | For information 'MS' please |
| 3. | DH-Law, CPCB | : | For information and record please. |



[P K Mishra]

केन्द्रीय प्रदूषण नियंत्रण बोर्ड
निर्देश...
06/03/2023

List:

1. The Chief Executive Officer,
Delhi Jal Board (HQ)
Public Relations Office
Room No.306, 3rd Floor
Varunalaya Ph-II, Jhandewalan,
Karol Bagh, New Delhi-110005
2. The CEO,
New Okhla Industrial Development
Authority(NOIDA)
Administrative Complex Sector 6, Noida - 201301,
District. Gautam Budh Nagar, Uttar Pradesh
3. The Chairman & Managing Director,
NTPC
NTPC Bhawan, SCOPE Complex,
Institutional Area, Lodhi Road,
New Delhi - 110003
4. The Principal Secretary,
Urban Development Dept., Govt. of UP
601, Babu Bhawan, Lucknow
5. The Member Secretary,
Uttar Pradesh Pollution Control Board,
Building.No. TC-12V Vibhuti Khand,
Gomti Nagar Lucknow-226 010
6. The Member Secretary,
Delhi Pollution Control Committee,
Government of N.C.T. Delhi,
4th Floor, ISBT Building,
Kashmere Gate, Delhi-110006
7. The Executive Officer,
Nagar Palika Parishad- Khoda Makanpur
Gali No. 7, Prashant Garden, Block A, Khoda
Colony, Ghaziabad, Sector 62A, Noida,
Uttar Pradesh- 201309

Central Pollution Control Board
(Ministry of Environment, Forest & Climate Change, Govt. of India)
Parivesh Bhawan, East Arjun Nagar,
Delhi – 110032

Sub: Minutes of the Second Meeting held on 24th February, 2023 at 4:00 PM through Video Conference to review the status of compliance of directions given by Hon'ble NGT vide order dated 03.08.2022 in the matter of O.A. No. 1002/2018 titled Abhisht Kusum Gupta Vs. State of Uttar Pradesh & Ors.

Hon'ble NGT vide order dated 03.08.2022 in the matter of O.A. No. 1002/2018 titled Abhisht Kusum Gupta Vs. State of Uttar Pradesh & Ors directed CPCB to independently monitor the directions from para 29 (ii) to (viii). In this regard, second meeting was convened on 24th February, 2023 at 4:00 PM through Video Conference to review the status (as on date) of compliance of directions given by Hon'ble NGT. List of participants attended the meeting is given in **Annexure-I**.

Sh. P.K. Mishra, DH WQM I welcomed all the officials and after briefing the background of the matter he requested to representatives of various agencies to inform/discuss as on date status of needed & proposed remedial actions and stressed the need to ensure timely compliance of the Hon'ble NGT order dated 03.08.2022 in the matter of O.A. No. 1002/2018. He then requested Sh. Vishal Gandhi, Sc 'E' to make a presentation on the directions of Hon'ble NGT in the matter and the earlier reported subsequent action taken by the various agencies to obtain its updated status.

Sh. Vishal Gandhi, Sc 'E' presented the directions of Hon'ble NGT given to various agencies like Delhi Jal Board, NTPC, NOIDA Authority, Urban Development Department, Govt. of Uttar Pradesh alongwith the action taken by them and the compliance status as verified by CPCB.

The compliance status (as on date) reported by the various agencies during the meeting are as below:

DJB regarding compliance of direction Para 29 (iv) & (vii):

Sh. S.K Bhardwaj of DJB informed the as on date status of 4 Phases of Kondli STP. It was informed that Phase I STP is completely rehabilitated and is functional. In Phase II, liquid line is partially started but will be fully functional by 31st March and by 31st June it will be complying with the designed parameters. Sludge line for Phase I, II and III will be functional by 31st June, 2023. Rehabilitation of Phase III started in April, 2022 and by Mach, 2023 it will achieve the designed parameters while Phase IV is still under rehabilitation till November, 2023. Sh. D.K. Singh, SEE, Delhi Pollution Control Committee (DPCC) informed that the latest

compliance status of the four Phases of Kondli STP i.e for the month of January, 2023 is available on the website of DPCC.

Sh.S.K Bhardwaj also informed that out of 90 MGD treated wastewater only 20 MGD treated wastewater is being utilised in Sanjay Lake and Smriti Van and further utilization of 90 MGD treated wastewater is difficult, hence they are exploring for more options for reuse of this treated wastewater.

NTPC regarding compliance of direction 29 (v): Sh. V.K Garg from NTPC, Dadri informed that utilization of treated sewage cannot be possible due to techno-commercial reasons and the same will be communicated to CPCB & NOIDA Authority. Further they have filed an application in this regard in Hon'ble NGT including impleadment as party respondent.

Khoda Makanpur Nagar Palika regarding compliance of direction 29 (vi): Ms. Shalini, Executive Officer, Khoda informed that vide letter dated 31.02.2023, the DM, Ghaziabad has requested Principal Secretary, Urban Development Dept, Govt of Uttar Pradesh requesting for land for the constructing of STP due to the unavailability of space in Khoda. She too requested NOIDA Authority for the same and got no reply. Upon which, Sh. R.P. Singh from NOIDA Authority clarified and informed that they have already communicated to Khoda Makanpur Nagar Palika that there is no vacant land in Noida that can be provided to them for the construction of STP.

NOIDA Authority regarding compliance of direction 29 (iii): Sh. R.P. Singh of NOIDA Authority pointed that diversion of all the drains to the STP will be highly expensive and not cost effective. Hence, it is proposed to be treated through In-Situ treatment and Ex-situ treatment.

Sh. Mishra, DH-WQM-I pointed out that as per the direction of Hon'ble NGT, the thirty identified drains or any other such drain carrying sewage be **diverted to existing STPs**. Accordingly, he further requested NOIDA Authority to submit drain wise action plan/compliance status including name of drain, length (approx.), point of origin & ending, quantity of discharge and action plan regarding its diversion to the nearest STP with name of STP & remarks w.r.t accommodating additional hydraulic load.

NOIDA Authority regarding compliance of direction 29 (ii): Sh. R.P. Singh further informed that around 30% of treated wastewater is being used in green belts and it was also sold for construction purposes generating revenue of Rs. 28 lakhs.

UPPCB regarding compliance of direction 29 (ii): Upon the issue of Group Housing Societies (GHS), Sh. Praveen Kumar, Regional Officer- Noida, UPPCB informed that the

sewage of the GHS is discharged into the drains of NOIDA Authority and are finally being treated into the STPs of NOIDA Authority. In this context, Sh. Mishra, DH-WQM-I, asked UPPCB to submit list of GHS having builtup area >5000 sq.ft. alongwith their quantity discharge, disposal point, utilisation of treated sewage & consent status.

Also, further discussion was held regarding the direction 29 (i) of Hon'ble NGT regarding (1) All water bodies (lentic or lotic) and the Natural Storm water drains are not to be used for discharge of treated or untreated trade or sewage effluents. (2) No consent be given for discharging effluents not meeting BOD criteria of Class "B" (BOD: 3mg/L). (3) Drains built exclusively as conveyance system (open sewer) must terminate to STPs. Officials from all the agencies were of the view that if direction 29 (i) is implemented then almost all the existing STP/ETPs will become non-compliant to the existing norms and further their upgradation will be highly expensive which will not be feasible. Also the problem of reuse of the entire & large quantity of treated wastewater generated was raised. Discussion regarding difficulties of various agencies in implementation of direction 29(i), it was agreed that CPCB shall file application in this regard.

Upon discussion and deliberations held, following recommendations were made:

- i. DJB and DPCC to submit the compliance status of Kondli STP w.r.t Hon'ble NGT order dated 30.04.2019 in OA No. 1069/2018, Nitin Shankar Deshpande Vs. Union of India & Ors. for the last 03 months alongwith the status of disposal of treated effluent. Sludge management, reuse of treated effluent and status of OCEMS.
- ii. DJB to submit action plan regarding 100% reuse of treated effluent of 90 MGD STP and revised timeframe regarding the completion of Kondli STP.
- iii. UPPCB to submit a list of GHS with an area of >5000 sq.ft. alongwith their quantity of sewage generated, treated and its disposal, present utilisation status and consent status (specimen copy of C T O granted to the GHS shall also be provided)
- iv. NOIDA Authority to submit information w.r.t name of drain, quantity of discharge and action plan including diversion to the nearest STP alongwith the action plan for maximum utilization of treated sewage by the Group Housing Societies (GHS).
- v. DJB and NOIDA Authority to submit information regarding generation and utilisation of sludge and status of utilisation of treated wastewater.

The meeting ended with a vote of thanks to the Chair.

**



Annexure I**List of participants**

1. Sh. P.K.Mishra, DH, WQM-I Division, CPCB
2. Sh. Dinesh Jindal, UPPCB
3. Sh. Praveen Kumar, RO, Noida, UPPCB
4. Sh. D.K Singh, SEE, DPCC
5. Sh. B. Saraswat, Additional Chief Engineer, DJB
6. Sh. P.S. Pankaj
7. Sh. Pankaj Rajvanshi, SE, DJB
8. Sh.S.K Bhardwaj, DJB
9. Sh. Subhash Surenranath Kacker
10. Sh. Vijay Prakash, NTPC
11. Sh. Vivek Roy, CEO, UPPCB
12. Sh. Devendra Nigam, SEE, DPCC
13. Sh. V.K Garg, NTPC, Dadri
14. Sh. R P Singh, NOIDA Authority
15. Sh. Sanjay Parashar, NOIDA Authority
16. Ms. Shalini, Executive Officer, Khoda Makanpur Nagar Palika
17. Sh. Geet Arora
18. Sh. Laxman Kumar Nayak
19. Sh. Neeraj Kumar
20. Sh.P.K.Tyagi
21. Sh. Ritesh Vijay, NEERI
22. Sh. Vishal Gandhi, Sc. 'E', CPCB
23. Mrs. Suniti Parashar, Sc. 'C', CPCB
24. Ms. Deepa Kumari, SRF, CPCB